

Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505

Telephone: (804) 384-5111

December 13, 1979

Dr. D. F. Ross, Jr.
Director, Bulletins and Orders Task Force
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Subject: LOFT L3-1 Pre-test Prediction


Reference: Letter from J. H. Taylor to D. F. Ross, same subject,
November 20, 1979

Dear Dr. Ross:

The attached is B&W's pre-test prediction of LOFT test L3-1. The model used for this analysis is consistent with the model and outstanding concerns presented to Mr. Paul Norian during his visit to B&W's offices on November 20, 1979.

If you have questions concerning this submittal, please contact me or Henry Bailey (Ext. 2678) of my staff.

Very truly yours,


James H. Taylor
Manager, Licensing

JHT:dsf

Attach.

cc: R. B. Borsum (B&W)

1629 001

7 912200519

6002
S
1/1

B&W's BEST ESTIMATE PREDICTION OF THE LOFT L3-1
NUCLEAR SMALL BREAK TEST USING THE CRAFT2
COMPUTER CODE

December, 1979

Principal Investigators

C. G. Motloch

N. K. Savani

1629 002

Reviewed by:



R. C. Jones, Jr.

TABLE OF CONTENTS

	<u>PAGE</u>
1. Introduction	1-1
2. LOFT L3-1 System Summary	2-1
2.1 Initial Conditions	2-1
2.2 Initiating Sequence of Events	2-2
3. Computer Codes	3-1
3.1 CRAFT2, Version 9.3 with LOFT Pump Model	3-1
3.2 TAFY3, Version 20	3-2
4. CRAFT2 LOFT L3-1 Model	4-1
4.1 Nodal Arrangement	4-1
4.2 Bubble Rise Model	4-1
4.3 Discharge Model	4-1
4.4 Steam Generator	4-3
4.5 Pump Model	4-3
4.6 ECCS Model	4-3
4.7 Core Model	4-4
4.8 Primary Metal	4-4
5. Discussion of Results	5-1
5.1 System Pressure Response	5-1
5.2 Mixture Level in Reactor Vessel	5-1
5.3 ECCS Response	5-2
5.4 Leak Flow Path Response	5-2
6. References	6-1
7. Attachment	7-1

1629 003

LIST OF TABLES

<u>TABLE</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
1	Node Description	6-2
2	Heat Slab Description	6-3
3	Code Predicted Sequence of Events for LOFT Test L3-1	6-5

LIST OF FIGURES

<u>FIGURE</u>	<u>DESCRIPTION</u>	<u>PAGE</u>
4.1	LOFT Major Components	6-6
4.2	LOFT L3-1 Noding Diagram	6-7
5.1	Pressure, Upper Plenum (0 to 100 sec.)	6-8
5.2	Pressure, Upper Plenum ($C_D = 0.6$)	6-9
5.3	Pressure, Upper Plenum ($C_D = 0.9$)	6-10
5.4	Flow Rate, Accumulator ($C_D = 0.9$)	6-11
5.5	Flow Rate, HPIS ($C_D = 0.9$)	6-12
5.6	Mixture Level, Reactor Vessel ($C_D = 0.6$)	6-13
5.7	Mixture Level, Reactor Vessel ($C_D = 0.9$)	6-14
5.8	Mixture Level, Downcomer ($C_D = 0.9$)	6-15
5.9	Flow Rate, Break Flow, Path 32 ($C_D = 0.9$)	6-16

1629 004

1. INTRODUCTION

This report documents B&W's best estimate blind prediction for the Loss-of-Fluid-Test (LOFT) L3-1 small break Standard Problem with a nuclear core.¹ The LOFT facility² and L3-1 test were modeled using the CRAFT2, Version 9.3, computer code.³ The computer code and the model with Bernoulli-Moody Discharge Model with discharge coefficient (C_D) of 0.6 for all phases are identical to those as presented to Nuclear Regulatory Commission (NRC) prior to the test.⁴ However, a second case, which utilized a C_D of 0.9 for steam flow, was also run and is considered to be B&W's best estimate blind prediction. Within the predicted transient, the switch from C_D of 0.6 to C_D of 0.9 was made after the leak flow was observed to have stabilized to a pure steam discharge. Prior to that point in the transient, the C_D of 0.6 was utilized. The model change is consistent with the outstanding concerns identified in reference 4. The model, the results with each discharge coefficient, and a brief system description are presented herein.

1629 005

2. LOFT L3-1 SYSTEM SUMMARY

The LOFT L3-1 system and initial conditions are as presented in references 1 and 2. The primary side of the LOFT facility is comprised of a reactor vessel with a 5.5 feet, 50 MW(t) nuclear core, and a single intact loop containing a pressurizer, an inverted U-tube steam generator, and two primary coolant pumps in-parallel. In addition, a dead-ended broken loop hot leg contains a simulated pump and a simulated steam generator. Further, a 0.002214 ft² orifice upstream of a quick-opening blowdown valve (QOBV) in the broken loop cold leg is used to simulate the small break. The QOBV discharges to a pressure suppression tank. The total primary system volume is 272 ft³.

The emergency core cooling system (ECCS) consists of a high pressure injection system (HPIS), a low pressure injection system (LPIS), and an accumulator (i.e., core flood tank). All the ECCS are aligned to inject borated water into the intact loop cold leg piping downstream of the primary coolant pumps.

2.1. Initial Conditions

The initial condition for the L3-1 test are as follows:

Flowrate - 3.8×10^6 lbm/hr (10,000 gpm)
Pressure, upper plenum - 2177.96 psia
Pressure, secondary - 750 psia*
 ΔP , across pumps - 67.56 psid
 T_{ave} , primary - 560°F
Temperature, core inlet - 542.48°F
Temperature, core outlet - 577.71°F
Temperature, secondary - 510°F*
Power level - 50 MW(t)
Power history - 40 Effective Full Power Hours, minimum

1629 006

*These values were obtained per a telephone conversation between D. Jarrell of EG&G/LOFT and C. Motloch on 10/12/79.

2.2. Initiating Sequence of Events

The sequence of events leading up to the initiation of the test begins with scrambling the reactor. When the rod bottom lights are observed to be on, the following actions are taken concurrently:

1. The QOBV is opened, thus initiating the break. This valve has an opening time of from 10 to 50 milliseconds, but in this prediction it was assumed to open instantaneously.
2. The primary coolant pumps are tripped. Their coastdown is controlled by the flywheel action of the motor generator sets down to 750 rpm, after which they coastdown on their own inertia.
3. The steam generator main feedwater is shut off.
4. The steam flow control valve is placed into its automatic mode. The initial response in the automatic mode will be to begin shutting the steam valve at a rate of 5% of the full open position per second.

1629 007

3. COMPUTER CODES

3.1. CRAFT2, Version 9.3 With LOFT Pump Model

The CRAFT2³ computer program was developed to study the transient behavior of a Nuclear Steam Supply System undergoing a loss-of-coolant accident (LOCA).

The program solves the conservation equations for mass and energy, the continuity equation, and the equation of state for water. This program is based upon the CRAFT1 program and is similar to the FLASH programs and the RELAP3 program.

The CRAFT2 program permits the user to select the nodal representation that results in the best finite differencing of the fluid system to be analyzed.

The program then solves the conservation equations for each node and the momentum equation for each flow path between nodes. The Nuclear Steam Supply System is simulated in a node-flow path representation. Components with different thermal-hydraulic characteristics must be simulated as different nodes.

CRAFT2 contains flexible models of all major Nuclear Steam Supply System components. Various options as well as user input parameters enable the program to model the reactor core, reactor coolant pumps, steam generators, and connecting piping in any configuration and operating mode desired.

Version 9.3 of CRAFT2 was utilized because it contains a pump model which was developed specifically for modeling the LOFT pumps. Version 9.3 is essentially the same as the B&W ECCS Evaluation Model currently in use. User input for this prediction was selected to yield a best-estimate analysis.

1629 008

3.2. TAFY3⁵, Version 20

The code determines the fuel and cladding temperature distribution within a cylindrical fuel rod. The fuel-cladding gas conductivity, heat transfer coefficient, and the internal pressure are also determined.

TAFY3 uses a series of analytical and empirical-analytical steady-state calculational models to obtain solution to heat diffusion equations in one dimension (radial).

TAFY3 is currently a production code at Babcock & Wilcox.

TAFY3 was utilized to calculate the average fuel pellet temperature of the LOFT L3-1 nuclear core. This information was input into the CRAFT2 LOFT model.

1629 009

4. CRAFT2 LOFT L3-1 MODEL

4.1. Nodal Arrangement

The LOFT major components are shown in Figure 4.1. A noding diagram of the CRAFT2 LOFT L3-1 computer model is shown in Figure 4.2 and is described in Table 1. The model has 18 nodes and 36 flow paths. Except for across the pump, dual paths are used throughout the model to allow for counter-current flow. The secondary side of the steam generator is connected to the suppression tank (i.e., containment node) to simulate the steam flow to the LOFT air-cooled condenser. Consequently, to minimize unrealistic increases in suppression tank back pressure, the volume of that node was increased by a factor of one hundred.

4.2. Bubble Rise Model

The Wilson Bubble Rise Velocity model is used in all of the primary system nodes. A multiplier of 2.38 is used in the core node and 2.0 in the remainder of the vessel nodes. This approach is consistent with the B&W ECCS Evaluation Model. The secondary side of the SG has a steam separator, hence, a large bubble rise velocity is utilized to obtain complete phase separation.

4.3. Discharge Model (Bernoulli-Moody Discharge Model)

Leak flow area = 0.00214 ft^2

Leak flow paths = 32 & 33

Maximum quality to use Bernoulli = 0.0

Maximum quality for linear interpolation between Bernoulli
and Moody = 0.1%

1629 010

The Bernoulli-Moody Discharge Model was utilized for this analysis with the above values. Two cases were run with different discharge coefficients, i.e., $C_D = 0.6$ and $C_D = 0.9$.

In the first case, a C_D of 0.6 was maintained constant throughout all phases of the blowdown transient, i.e., the subcooled, the two-phase and the pure steam phase. This represents the "locked-in" model as presented to the NRC.⁴

In the second case, the switch from $C_D = 0.6$ to $C_D = 0.9$ occurs within the transient only after the leak flow was observed to have stabilized to pure steam. The C_D of 0.9 was then maintained constant throughout the remainder of the transient. However, as in the first case, during the subcooled and two-phase blowdown portion of the transient, a C_D of 0.6 was utilized. This second case represents B&W's best estimate prediction.

The decision to use a steam C_D of 0.9 for the best estimate case is based on two factors. B&W's evaluation of the transient blowdown test of the LOFT 0.6374-inch diameter flow nozzle, which was performed at the Transient Flow Calibration Facility at Wyle Laboratories,⁷ indicates that, within test accuracy, a C_D within the range of 0.4 to 1.0 would be appropriate. Also, based on studies done at B&W, it was concluded that a C_D of 0.9 for Moody Steam Flow correlates well with a Homogeneous Equilibrium Model (HEM). It is also expected that, in general, the HEM predicts steam phase blowdown reasonably well. The transient results for both cases are presented in Section 5. The Wyle nozzle-blowdown test information was not received early enough for B&W to properly assess it prior to the NRC's visit to Lynchburg on November 20, 1979. It should be noted that, as reported in reference 4, B&W was in the process of evaluating the discharge model at the time of the NRC's visit.

4.4. Steam Generator

The steam generator primary side is represented by two nodes and the secondary side with one node. The initial pressure drop across the steam generator primary side was calculated using the Low Resistance Orifice Curve², Figure 92, per telephone communication with D. Jarrell of EG&G/LOFT. The steam path from the secondary side of the steam generator, path 36, is open at the time of the reactor trip and starts closing at a rate of 5% of the full open position per second. An effective steady-state flow area was calculated based on the Moody correlation flow model. The effective flow area was changed, as a function of secondary side pressure, consistent with the given steam flow control valve response characteristics.

4.5. Pump Model

The CRAFT2 pump input was modified to model the specified LOFT pump characteristics. The two parallel pumps and associated piping were combined into a single equivalent pump node. Pump performance characteristics for each pump were assumed to be identical.

4.6. ECCS Model

The ECCS is comprised of one accumulator (core flood tank), one high pressure injection system, and one low pressure injection system. The injection point is the intact loop cold leg piping downstream of the primary coolant pumps. The ECCS actuation and performance characteristics are consistent with the specified initial conditions for this experiment.

1629 012

4.7. Core Model

The core is modeled as a single node with axial and radial peaking factors of 1.0. An initial average fuel pellet temperature of 1835^oF, based on an average linear heat rate of 6.993 kW/ft, was calculated using the TAFY3, Version 20, computer code⁵. The CRAFT2 point kinetics model was not utilized. Instead, the core heat generation was based on the given 40 Effective Full Power Hour LOFT decay heat curve⁶.

4.8. Primary Metal

The transfer of the stored energy in the metal adjacent to the water in the control volumes was modeled using the CRAFT2 Primary Metal Option. In reference 1, the primary system heat loss to ambient was estimated to be 248 ± 20 kW. During the saturated blowdown phase of the transient, this is equivalent to approximately 15% of the total LOFT system heat generation (i.e., decay heat plus primary metal heat flow). No credit for this heat loss to ambient was taken in the CRAFT2 model. The relative location of the heat slabs is depicted in Figure 1 and the heat slab description is given in Table 2.

1629 013

5. DISCUSSION OF RESULTS

As discussed in section 4.3 of this report, two sets of results are presented. One set represents the model "locked-in" by the NRC and has a discharge model with $C_D = 0.6$ for Moody steam flow. The second set of results utilizes a $C_D = 0.9$ for Moody steam flow. The transition to steam flow is predicted to occur approximately 375.0 seconds into the transient, and it was at this time in the transient that the value of C_D for Moody steam flow was altered. As requested in reference 1, plots are presented with a 0 to 100 seconds and a 0 to 1500 seconds time scale. Since the value of C_D was altered at 375.0 transient seconds, the 0 to 100 seconds plots are applicable to both cases mentioned above. The Code Predicted Sequence of Events for LOFT Test L3-1 are given in Table 3.

5.1. System Pressure Response

The pressure behavior in the upper plenum, Figures 5.1, 5.2, and 5.3, is typical of the pressure response for the reactor vessel, the intact and the broken loop piping. The pressure decays rapidly from an initial pressure of approximately 2178 psia to a saturation pressure of approximately 1200 psia in about 32 seconds after the break. The pressure then decays slowly during the saturated period of blowdown. As expected, and as shown in Figures 5.3 and 5.2, respectively, the rate of depressurization is higher for the discharge model with $C_D = 0.9$ as compared to a C_D of 0.6.

5.2. Mixture Level in Reactor Vessel

The mixture level in the reactor vessel is shown in Figures 5.6 and 5.7 for $C_D = 0.6$ and $C_D = 0.9$, respectively. As can be seen from Figure 5.7 (B&W best-estimate), the lowest mixture height is predicted to be ~3 ft above the core. Hence, the core is predicted not to uncover during the transient.

Consequently, the fuel is predicted to remain well cooled and the fuel temperature is predicted not to rise appreciably.

5.3. ECCS Response

The accumulator and the HPIS flow rates for the B&W best-estimate are shown in Figures 5.4 and 5.5, respectively. The HPIS initiation is predicted to occur 5.0 seconds after the break while the accumulator initiation, based on $C_D = 0.9$, is predicted to occur 850.0 seconds after the break. It is also predicted that, within the first 1500 seconds, the system will not depressurize sufficiently to actuate the LPIS injection.

The sudden cold water injection from the accumulator is predicted to cause local pressure suppression and flow oscillations. The accumulator cycles on and off as a function of the pressure in the intact loop cold leg, node 12. The downcomer liquid level is predicted to increase while the reactor vessel liquid level is predicted to decrease during the periods when the accumulator injection is on. This is shown in Figures 5.7 and 5.8, respectively.

5.4. Leak Flow Path Response

The transient leak flow out the broken loop cold leg orifice for the B&W best estimate case is shown in Figure 5.9. As expected, during the subcooled portion of the blowdown, the leak flow follows the system depressurization curve, Figure 5.3. At 225 seconds into the transient, the leak node becomes saturated and a two-phase mixture is expelled out the break. This continues until 390 seconds into the transient at which time the mixture level in the system has dropped sufficiently to allow a pure steam discharge out the orifice. At 375 seconds, the C_D was changed to 0.9 and remained constant for the remainder of the prediction. The steam discharge continues until the accumulators begin cycling on and off during which time a two-phase mixture is emitted from the break.

1629 015

REFERENCES

- ¹ Information for L3-1 Standard Problem, Kaufman, N.C., Kau-203-79, dated September 28, 1979.
- ² LOFT System and Test Description (5.5 ft Nuclear Core 1 LOCES), NUREG/CR-0274, TREE-1208, Reeder, D.L., dated July 1978.
- ³ CRAFT2, Fortran Program for Digital Simulation of a Multi-Node Reactor Plant During a Loss-of-Coolant, BAW-10092, Rev. 2, Babcock and Wilcox, April 1975.
- ⁴ Savani, N.K., "Preliminary CRAFT2 Model of LOFT L3-1 Experiment," November 20, 1979.
- ⁵ TAFY-Fuel Pin Temperature and Gas Pressure Analysis, BAW-10044, Babcock and Wilcox, April 1972.
- ⁶ Memo from G.D. McPherson (NRC) to J.H. Taylor (B&W), "LOFT Decay Heat for 40 Hour Operation," October 19, 1979.
- ⁷ "Small Break Nozzle Information for L3-1 Standard Problem," Kau-228-79, October 29, 1979.

1629 016

Table 1. Node Description

<u>Node No.</u>	<u>Description</u>
1	Downcomer annulus
2	Downcomer
3	Lower plenum
4	Core
5	Upper plenum & upper head
6	Pressurizer
7	Hot leg, intact loop
8	Steam generator, front half of primary side, intact loop
9	Steam generator, back half of primary side, intact loop
10	Steam generator outlet, cold leg piping, intact loop
11	Pump suction, intact loop
12	Pump discharge, intact loop
13	Hot leg plus half simulated SG, broken loop
14	Half simulated SG plus half pump, broken loop
15	Half pump plus piping, broken loop
16	Leak node
17	Suppression tank
18	Secondary side, intact loop

1629 017

Table 2. Heat Slab Description

<u>Slab No.</u>	<u>Associated node No.</u>	<u>Description</u>
1	1	Reactor vessel from top of downcomer annulus to top of distributor annulus plus two RV stubs
2	1	Reactor vessel filler from top of downcomer annulus to top of distributor annulus
3	1	Core barrel from top of downcomer annulus to top of distributor annulus
4	2	Reactor vessel from top to bottom of downcomer annulus
5	2	Reactor vessel filler from top to bottom of downcomer annulus
6	2	Core barrel from top to bottom of downcomer annulus
7	3	Reactor vessel below bottom of downcomer
8	3	Bottom portion of reactor vessel filler below bottom of downcomer annulus
9	3	Lower core support structure and lower core end boxes
10	4	Skirt and filler within active core height
11	5	Upper core support structure plus upper core end boxes
12	5	Skirt of core filler above active core to top of core barrel plus two RV stubs
13	7	Intact loop hot leg from RV stub to steam generator
14	8	Steam generator inlet plenum plus 1/2 of tube sheet plus 1/2 of plenum partition
15	8	1/2 of primary side of steam generator tubes
16	9	1/2 of primary side of steam generator tubes
17	9	Steam generator outlet plenum plus 1/2 of tube sheet plus 1/2 of plenum partition
18	18	Steam generator tubes, secondary side
19	18	Steam generator shroud, secondary side
20	18	Steam generator shell
21	18	Top of tube sheet exposed to secondary water
22	10	Steam generator outlet piping
23	11	Pump suction piping
24	12	Intact cold leg piping
25	6	Surge line
26	6	Pressurizer

1629 018

Table 2. (Cont'd)

<u>Slab No.</u>	<u>Associated node No.</u>	<u>Description</u>
27	13	Broken loop hot leg plus 1/2 steam generator simulator plus hot leg side of bypass system
28	14	1/2 pump simulator plus 1/2 steam generator simulator
29	15	1/2 simulated pump plus remainder of broken loop hot leg
30	16	Broken loop cold leg including cold leg side of bypass system

1629 019

Table 3. Code Predicted Sequence of Events for LOFT
Test L3-1

Event	Time, second
1. T ₀ (Experiment initiation)	0.0
2. HPIS initiation	5.0
3. Pumps reach 12.5 Hz	17.0
4. Pressurizer empty	~24.0
5. Maximum average clad temperature	28.0 (573°F)
6. Saturation pressure reached in outlet plenum	32.0
7. Auxiliary feedwater starts	60.0
8. Saturation pressure reached in pump inlet	74.0
9. Loop seal cleared	210.0
10. Break transition to steam flow	@ 225.0 sec, two- phase flow
	@ 390.0 sec, steam flow
11. Accumulator initiation	* 850.0 (1230.0)
12. LPIS initiation	** NA
13. Accumulator empty	NA
14. First indication of DNB	NA
15. First return to nucleate boiling	NA
16. Core uncover time	NA
17. Core completely recovered	*** See below

* The accumulator initiates at 850.0 seconds with C_D = 0.9, and at 1230.0 seconds with C_D = 0.6.

** The events that were predicted not to occur by the code are indicated by "NA."

*** Core remains covered through the transient; the minimum level in the RV was approximately 3.0' above core.

1629 020




Fig. 4.1, LOFT MAJOR COMPONENTS

POOR ORIGINAL

ANC-C-7002

6-6

1629 021

Figure 5.1 - Pressure, Upper Plenum (0 to 100 sec.)





Figure 5.2 - Pressure, Upper Plenum ($C_D = 0.6$)



_31S2EE


LOFT L3-1 STD PRBLM

NODE

5

1629 024

Figure 5.3 - Pressure, Upper Plenum ($C_D = 0.9$)




L31S374 LOFT L3-1 STD PRBLM

NODE

5

1629 025

Figure 5.4 - Flow Rate, Accumulator ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

FLOOD TANK

1

1629 026

Figure 5.5 - Flow Rate, HPIS ($C_D = 0.9$)



L31S374

LOFT L3-1 STD PRBLM


PATH

34

1629 027

Figure 5.6 - Mixture Level, Reactor Vessel ($C_D = 0.6$)


(NOTE: The top of the core is at 0.0 ft elevation)



L31S2EE LOFT L3-1 STD PRBLM
NODE 5 1629 028


Figure 5.7 - Mixture Level, Reactor Vessel ($C_D = 0.9$)

(NOTE: The top of the core is at 0.0 ft elevation)




L31S374 LOFT L3-1 STD PRBLM
NODE 5 1629 029

Figure 5.8 - Mixture Level, Downcomer ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM
NODE 1 1629 030

Figure 5.9 - Flow Rate, Break Flow, Path 32 ($C_D = 0.9$)



L31S374

LOFT L3-1 STD PRBLM

PATH

32

1629 031

7. ATTACHMENT

This section includes all the plots requested by NRC to evaluate the B&W's prediction. These plots are shown on Figures 2 through 166. The comparison parameters for the CRAFT2 analysis and LOFT experiment are described in Table 4. The input listing of CRAFT2 computer run is shown in Table 5.

1629 032

LIST OF FIGURES

<u>FIGURE</u>	<u>DESCRIPTION</u>
1	CRAFT2 Nodal Diagram for LOFT L3-1 Standard Problem
2	Pressure Pressurizer (0 to 100 sec.)
3	Pressure Pressurizer ($C_D = 0.6$)
4	Pressure Pressurizer ($C_D = 0.9$)
5	Pressure, Broken Loop Hot Leg Near Break (0 to 100 sec.)
6	Pressure, Broken Loop Hot Leg Near Break ($C_D = 0.6$)
7	Pressure, Broken Loop Hot Leg Near Break ($C_D = 0.9$)
8	Pressure, Broken Loop Cold Leg Near Break (0 to 100 sec.)
9	Pressure, Broken Loop Cold Leg Near Break ($C_D = 0.6$)
10	Pressure, Broken Loop Cold Leg Near Break ($C_D = 0.9$)
11	Pressure, Upper Plenum (0 to 100 sec.)
12	Pressure, Upper Plenum ($C_D = 0.6$)
13	Pressure, Upper Plenum ($C_D = 0.9$)
14	Pressure, Accumulator, Intact Loop (0 to 100 sec.)
15	Pressure, Accumulator, Intact Loop ($C_D = 0.6$)
16	Pressure, Accumulator, Intact Loop ($C_D = 0.9$)
17	Pressure, Steam Generator Secondary (0 to 100 sec.)
18	Pressure, Steam Generator Secondary ($C_D = 0.6$)
19	Pressure, Steam Generator Secondary ($C_D = 0.9$)
20	Density, Intact Loop Cold Leg (0 to 100 sec.)
21	Density, Intact Loop Cold Leg ($C_D = 0.6$)
22	Density, Intact Loop Cold Leg ($C_D = 0.9$)
23	Density, Intact Loop Hot Leg (0 to 100 sec.)
24	Density, Intact Loop Hot Leg ($C_D = 0.6$)
25	Density, Intact Loop Hot Leg ($C_D = 0.9$)

1629 033

LIST OF FIGURES (Cont'd)

<u>FIGURE</u>	<u>DESCRIPTION</u>
26	Density, Broken Loop Cold Leg (0 to 100 sec.)
27	Density, Broken Loop Cold Leg ($C_D = 0.6$)
28	Density, Broken Loop Cold Leg ($C_D = 0.9$)
29	Density, Broken Loop Hot Leg (0 to 100 sec.)
30	Density, Broken Loop Hot Leg ($C_D = 0.6$)
31	Density, Broken Loop Hot Leg ($C_D = 0.9$)
32	Density, Pump Suction (0 to 100 sec.)
33	Density, Pump Suction ($C_D = 0.6$)
34	Density, Pump Suction ($C_D = 0.9$)
35	Differential Pressure, Across Core (0 to 100 sec.)
36	Differential Pressure, Across Core ($C_D = 0.6$)
37	Differential Pressure, Across Core ($C_D = 0.9$)
38	Differential Pressure, Across Intact Loop Pump (0 to 100 sec.)
39	Differential Pressure, Across Intact Loop Pump ($C_D = 0.6$)
40	Differential Pressure, Across Intact Loop Pump ($C_D = 0.9$)
41	Differential Pressure, Pump Suction Leg (0 to 100 sec.)
42	Differential Pressure, Pump Suction Leg ($C_D = 0.6$)
43	Differential Pressure, Pump Suction Leg ($C_D = 0.9$)
44	Differential Pressure, Intact Hot Leg to Top of Vessel (0 to 100 sec.)
45	Differential Pressure, Intact Hot Leg to Top of Vessel ($C_D = 0.6$)
46	Differential Pressure, Intact Hot Leg to Top of Vessel ($C_D = 0.9$)
47	Fluid Temperature, Cold Leg, Upstream of Break (0 to 100 sec.)
48	Fluid Temperature, Cold Leg, Upstream of Break ($C_D = 0.6$)
49	Fluid Temperature, Cold Leg, Upstream of Break ($C_D = 0.9$)

1629 034

LIST OF FIGURES (Cont'd)

<u>FIGURE</u>	<u>DESCRIPTION</u>
50	Fluid Temperature, Upper Plenum (0 to 100 sec.)
51	Fluid Temperature, Upper Plenum ($C_D = 0.6$)
52	Fluid Temperature, Upper Plenum ($C_D = 0.9$)
53	Fluid Temperature, Pressurizer (0 to 100 sec.)
54	Fluid Temperature, Pressurizer ($C_D = 0.6$)
55	Fluid Temperature, Pressurizer ($C_D = 0.9$)
56	Fluid Temperature, Lower Plenum (0 to 100 sec.)
57	Fluid Temperature, Lower Plenum ($C_D = 0.6$)
58	Fluid Temperature, Lower Plenum ($C_D = 0.9$)
59	Flow Rate, Core Inlet, Path 1 (0 to 100 sec.)
60	Flow Rate, Core Inlet, Path 1 ($C_D = 0.6$)
61	Flow Rate, Core Inlet, Path 1 ($C_D = 0.9$)
62	Flow Rate, Core Inlet, Path 2 (0 to 100 sec.)
63	Flow Rate, Core Inlet, Path 2 ($C_D = 0.6$)
64	Flow Rate, Core Inlet, Path 2 ($C_D = 0.9$)
65	Flow Rate, Core Inlet, Path 3 (0 to 100 sec.)
66	Flow Rate, Core Inlet, Path 3 ($C_D = 0.6$)
67	Flow Rate, Core Inlet, Path 3 ($C_D = 0.9$)
68	Flow Rate, Core Outlet, Path 4 (0 to 100 sec.)
69	Flow Rate, Core Outlet, Path 4 ($C_D = 0.6$)
70	Flow Rate, Core Outlet, Path 4 ($C_D = 0.9$)
71	Flow Rate, Core Outlet, Path 5 (0 to 100 sec.)
72	Flow Rate, Core Outlet, Path 5 ($C_D = 0.6$)
73	Flow Rate, Core Outlet, Path 5 ($C_D = 0.9$)

1629 035

LIST OF FIGURES (Cont'd)

<u>FIGURE</u>	<u>DESCRIPTION</u>
74	Flow Rate, Break Flow, Path 32 (0 to 100 sec.)
75	Flow Rate, Break Flow, Path 32 ($C_D = 0.6$)
76	Flow Rate, Break Flow, Path 32 ($C_D = 0.9$)
77	Flow Rate, Break Flow, Path 33 (0 to 100 sec.)
78	Flow Rate, Break Flow, Path 33 ($C_D = 0.6$)
79	Flow Rate, Break Flow, Path 33 ($C_D = 0.9$)
80	Flow Rate, Cold Leg, Path 18 (0 to 100 sec.)
81	Flow Rate, Cold Leg, Path 18 ($C_D = 0.6$)
82	Flow Rate, Cold Leg, Path 18 ($C_D = 0.9$)
83	Flow Rate, Cold Leg, Path 19 (0 to 100 sec.)
84	Flow Rate, Cold Leg, Path 19 ($C_D = 0.6$)
85	Flow Rate, Cold Leg, Path 19 ($C_D = 0.9$)
86	Flow Rate, Hot Leg, Path 9 (0 to 100 sec.)
87	Flow Rate, Hot Leg, Path 9 ($C_D = 0.6$)
88	Flow Rate, Hot Leg, Path 9 ($C_D = 0.9$)
89	Flow Rate, Hot Leg, Path 10 (0 to 100 sec.)
90	Flow Rate, Hot Leg, Path 10 ($C_D = 0.6$)
91	Flow Rate, Hot Leg, Path 10 ($C_D = 0.9$)
92	Flow Rate, Accumulator (0 to 100 sec.)
93	Flow Rate, Accumulator ($C_D = 0.6$)
94	Flow Rate, Accumulator ($C_D = 0.9$)
95	Flow Rate, LPIS (0 to 100 sec.)
96	Flow Rate, LPIS ($C_D = 0.6$)
97	Flow Rate, LPIS ($C_D = 0.9$)

1629 036

LIST OF FIGURES (Cont'd)

<u>FIGURE</u>	<u>DESCRIPTION</u>
98	Flow Rate, HPIS (0 to 100 sec.)
99	Flow Rate, HPIS ($C_D = 0.6$)
100	Flow Rate, HPIS ($C_D = 0.9$)
101	Flow Rate, Pressurizer Surge Line (0 to 100 sec.)
102	Flow Rate, Pressurizer Surge Line ($C_D = 0.6$)
103	Flow Rate, Pressurizer Surge Line ($C_D = 0.9$)
104	Temperature, Average Fuel Rod, Core Path 1 (0 to 100 sec.)
105	Temperature, Average Fuel Rod, Core Path 1 ($C_D = 0.6$)
106	Temperature, Average Fuel Rod, Core Path 1 ($C_D = 0.9$)
107	Temperature, Average Fuel Rod, Core Path 2 (0 to 100 sec.)
108	Temperature, Average Fuel Rod, Core Path 2 ($C_D = 0.6$)
109	Temperature, Average Fuel Rod, Core Path 2 ($C_D = 0.9$)
110	Temperature, Average Clad, Core Path 1 (0 to 100 sec.)
111	Temperature, Average Clad, Core Path 1 ($C_D = 0.6$)
112	Temperature, Average Clad, Core Path 1 ($C_D = 0.9$)
113	Temperature, Average Clad, Core Path 2 (0 to 100 sec.)
114	Temperature, Average Clad, Core Path 2 ($C_D = 0.6$)
115	Temperature, Average Clad, Core Path 2 ($C_D = 0.9$)
116	Vessel Inventory, Node 1 (0 to 100 sec.)
117	Vessel Inventory, Node 2 (0 to 100 sec.)
118	Vessel Inventory, Node 3 (0 to 100 sec.)
119	Vessel Inventory, Node 4 (0 to 100 sec.)
120	Vessel Inventory, Node 5 (0 to 100 sec.)
121	Vessel Inventory, Node 1 ($C_D = 0.6$)
122	Vessel Inventory, Node 2 ($C_D = 0.6$)
123	Vessel Inventory, Node 3 ($C_D = 0.6$)

1629 057

LIST OF FIGURES (Cont'd)

<u>FIGURE</u>	<u>DESCRIPTION</u>
124	Vessel Inventory, Node 4 ($C_D = 0.6$)
125	Vessel Inventory, Node 5 ($C_D = 0.6$)
126	Vessel Inventory, Node 1 ($C_D = 0.9$)
127	Vessel Inventory, Node 2 ($C_D = 0.9$)
128	Vessel Inventory, Node 3 ($C_D = 0.9$)
129	Vessel Inventory, Node 4 ($C_D = 0.9$)
130	Vessel Inventory, Node 5 ($C_D = 0.9$)
131	Integrated Flow to Containment (0 to 100 sec.)
132	Integrated Flow to Containment ($C_D = 0.6$)
133	Integrated Flow to Containment ($C_D = 0.9$)
134	Integrated Energy to Containment (0 to 100 sec.)
135	Integrated Energy to Containment ($C_D = 0.6$)
136	Integrated Energy to Containment ($C_D = 0.9$)
137	Pipe Quality, Core Path 1 (0 to 100 sec.)
138	Pipe Quality, Core Path 1 ($C_D = 0.6$)
139	Pipe Quality, Core Path 1 ($C_D = 0.9$)
140	Pipe Quality, Core Path 2 (0 to 100 sec.)
141	Pipe Quality, Core Path 2 ($C_D = 0.6$)
142	Pipe Quality, Core Path 2 ($C_D = 0.9$)
143	Pipe Quality, Leak Path 32 (0 to 100 sec.)
144	Pipe Quality, Leak Path 32 ($C_D = 0.6$)
145	Pipe Quality, Leak Path 32 ($C_D = 0.9$)
146	Heat Transfer Coefficient, Core Path 1 (0 to 100 sec.)
147	Heat Transfer Coefficient, Core Path 1 ($C_D = 0.6$)
148	Heat Transfer Coefficient, Core Path 1 ($C_D = 0.9$)

1629 038

LIST OF FIGURES (Cont'd)

<u>FIGURE</u>	<u>DESCRIPTION</u>
149	Heat Transfer Coefficient, Core Path 2 (0 to 100 sec.)
150	Heat Transfer Coefficient, Core Path 2 ($C_D = 0.6$)
151	Heat Transfer Coefficient, Core Path 2 ($C_D = 0.9$)
152	Water Level, Vessel (0 to 100 sec.)
153	Water Level, Vessel ($C_D = 0.6$)
154	Water Level, Vessel ($C_D = 0.9$)
155	Water Level, Downcomer (0 to 100 sec.)
156	Water Level, Downcomer ($C_D = 0.6$)
157	Water Level, Downcomer ($C_D = 0.9$)
158	Water Level, Pressurizer (0 to 100 sec.)
159	Water Level, Pressurizer ($C_D = 0.6$)
160	Water Level, Pressurizer ($C_D = 0.9$)
161	Pump Speed (0 to 100 sec.)
162	Pump Speed ($C_D = 0.6$)
163	Pump Speed ($C_D = 0.9$)
164	Pump Head (0 to 100 sec.)
165	Pump Head ($C_D = 0.6$)
166	Pump Head ($C_D = 0.9$)

1629 039

Table 4. Parameters for Test Data Comparison

<u>Pressure</u>	<u>Instrument</u>	<u>CRAFT2</u>	<u>Figure No.</u>
Pressurizer (vapor space)	PE - PC - 4	Node 6	2-4
Broken loop hot leg, near break	PE - BL - 2	Node 13	5-7
Broken loop cold leg, near break	PE - BL - 1	Node 16	8-10
Upper plenum (upper end box)	PE - IUP - 1	Node 5	11-13
Accumulator, intact loop	PT - P120 - 43	Flood Tank	14-16
Steam generator secondary	PT - P4 - 10A	Node 18	17-19
<hr/>			
<u>Density</u>			
Intact loop cold leg	DE - PC - 1	Node 12	20-22
Intact loop hot leg	DE - PC - 2	Node 7	23-25
Broken loop cold leg	DE - BL - 1	Node 16	26-28
Broken loop hot leg	DE - BL - 2	Node 13	29-31
Pump suction	DE - PC - 3	Node 11	32-34
<hr/>			
<u>Differential pressure</u>			
Across core	No measurement	Node 3/Node 5	35-37
Across intact loop pump	PdE - PC - 1	Node 11/Node 12	38-40
Pump suction leg	No measurement	Node 10/Node 11	41-43
Intact hot leg to top of vessel	No measurement	Node 7/Node 5	44-46
<hr/>			
<u>Fluid Temperatures</u>			
Upstream of break, cold leg	TE - BL - 1	Node 16	47-49
Upper plenum	TE - IUP - 1	Node 5	50-52
Pressurizer (liquid)	TE - P139 - 20	Node 6	53-55
Lower plenum	TE - LLP - 1	Node 3	56-58

1629 040

Table 4. (Cont'd)

<u>Flow Rates</u>	<u>Instrument</u>	<u>CRAFT2</u>	<u>Figure No.</u>
Core inlet	No measurement	Paths 1, 2, & 3	59-67
Core outlet	No measurement	Paths 4 & 5	68-73
Break flow	TTE - BL - 1 ^a	Paths 32 & 33	74-79
Cold leg, intact loop	FE - PC - 1 ^b	Paths 18 & 19	80-85
Hot leg, intact loop	PNE - PC - 2 ^c	Paths 9 & 10	86-91
Accumulator, intact loop	FT - P120 - 36 - 1	Flood tank	92-94
LPIS	FT - P120 - 85	Path 35	95-97
HPIS	FT - P128 - 104	Path 34	98-100
Pressurizer surge line	Pde - PC - 8 ^b	Path 8	101-103
<u>Metal Temperatures</u>			
Average rod	No measurement	Core Paths 1 & 2	104-109
Hot rod	No measurement	Not given	
Clad average temperature	No measurement	Core Paths 1 & 2	110-115
Peak clad temperature	No measurement	Not given	
<u>Mass Inventories</u>			
Primary system liquid mass inventory	No measurement	Not given	
Vessel inventory (collapsed liquid volume)	No measurement	Nodes 1-5	116-130
Integrated mass leaving system through break junction	No measurement	Integrated flow to containment	131-133
Energy released to containment	No measurement	Integrated energy to containment	134-136
<u>Qualities, Heat Transfer Coefficients</u>			
Quality, core average	No measurement	Core Paths 1 & 2	137-142
Quality, leak path	No measurement	Leak Path 32	143-145
Heat transfer coefficients, core	No measurement	Core Paths 1 & 2	146-151

1629 041

Table 4. (Cont'd)

<u>Water Level</u>	<u>Instrument</u>	<u>CRAFT2</u>	<u>Figure No.</u>
Vessel	LE - 3F10	Node 5	152-154
Downcomer	LE - 1ST or 2ST	Node 1	155-157
Pressurizer	LE - P139 - 6, 7, 8	Node 6	158-160
<hr/>			
<u>Pump Performance</u>			
Pump speed	RPE - PC - 1 & 2	Pump speed	161-163
Pump head		Pump head	164-166

1629 042

Table 5. (Cont'd)

POOR ORIGINAL

101, 2.0
 1001, 20.0, 0.0, 0.0
 1004, 5.00, 5.00, 5.00

* PLOT INFORMATION

ID	X	MIN	MAX	SCALE	Y	MIN	MAX	LENGTH	X4	X5
----	---	-----	-----	-------	---	-----	-----	--------	----	----

* NODES

1501,	1105,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1502,	1106,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1503,	1107,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1504,	1112,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1505,	1113,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1506,	1116,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1507,	1118,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1508,	1201,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1509,	1202,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1510,	1203,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1511,	1204,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1512,	1205,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1513,	1206,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1514,	1208,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1515,	1209,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1516,	1210,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1517,	1218,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1518,	1308,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1519,	1309,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1520,	1408,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1521,	1407,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1522,	1603,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1523,	1604,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1524,	1605,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1525,	1606,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1526,	1608,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1527,	1609,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1528,	1616,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1529,	1618,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1530,	1801,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	3,	5
1531,	1802,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	11,	12
1532,	1803,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	10,	11
1533,	1804,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	7,	5

* FLOW PATHS

1534,	2101,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1535,	2102,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1536,	2103,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1537,	2104,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1538,	2105,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1539,	2109,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1540,	2110,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1541,	2117,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1542,	2118,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1543,	2119,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1544,	2124,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1545,	2125,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1546,	2132,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1547,	2133,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1548,	2134,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1549,	2135,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1550,	2401,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1551,	2402,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1552,	2409,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00
1553,	2411,	1,	0.0,	0.0,	10.0,	1,	0.0,	0.0,	10.0,	00,	00

Table 5. (Cont'd)

POOR ORIGINAL

1554.	2413.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1555.	2617.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1556.	2717.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
* CORE PATHS											
1557.	3101.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1558.	3102.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1559.	3201.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1560.	3202.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1561.	3301.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1562.	3302.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1563.	3501.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1564.	3502.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1565.	3601.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1566.	3602.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1567.	3801.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1568.	3802.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
* STEAM GENERATOR											
1569.	4101.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1570.	4301.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1571.	4401.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1572.	4501.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1573.	4701.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
* FLOOD TANKS											
1574.	5101.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1575.	5201.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1576.	5301.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1577.	5801.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
* MISC											
1578.	5401.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1579.	5501.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1580.	5601.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1581.	7104.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1582.	7107.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1583.	7111.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1584.	7112.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1585.	7113.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1586.	7116.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1587.	7201.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1588.	7202.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1589.	7203.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1590.	7204.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1591.	7205.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1592.	7206.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1593.	7208.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1594.	7209.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1595.	7210.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1596.	7211.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1597.	7218.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1598.	2108.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1599.	2432.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
1600.	1211.	1.	0.0.	0.0.	10.0.	1.	0.0.	0.0.	10.0.	00.	00
* PLOT SELECTION INFORMATION											
1601.	1105.	1604.	2132.	5601.	7204.	2717					
1701.	100										
* TIME INFORMATION											

Table 5. (Cont'd)

POOR ORIGINAL

2001, 0.0001, 10., 20., 0.0005, 100., 18., 0.001, 500., 8.

* CONTROL VOLUMES

3001,	2.422,	2.477,	20.661,	22.000,	20.611,	2199.77,	538.03,	0.0
3002,	1.451,	12.574,	8.087,	20.561,	8.037,	2193.88,	538.03,	0.0
3003,	6.113,	4.109,	9.694,	7.987,	5.635,	2197.07,	538.03,	0.0
3004,	1.988,	5.543,	15.278,	9.794,	9.744,	2199.42,	582.92,	0.0
3005,	3.254,	10.256,	22.000,	15.378,	15.328,	2178.56,	582.92,	0.0
3006,	6.040,	5.702,	26.298,	26.296,	26.249,	2168.30,	0.0,	3.71
3007,	11.650,	0.932,	22.000,	22.000,	21.534,	2170.70,	582.92,	0.0
3008,	2.442,	10.909,	32.393,	22.000,	21.534,	2159.25,	560.43,	0.0
3009,	2.430,	10.532,	22.498,	32.393,	21.911,	2148.25,	538.03,	0.0
3010,	0.842,	5.021,	13.257,	22.498,	17.791,	2135.46,	538.03,	0.0
3011,	2.327,	4.675,	22.000,	18.257,	17.791,	2134.31,	538.03,	0.0
3012,	16.191,	0.932,	22.0	22.0	21.534,	2199.66,	538.03,	0.0
3013,	1.987,	11.109,	32.041,	22.0	21.534,	2176.24,	538.03,	0.0
3014,	0.773,	15.088,	18.021,	32.041,	17.555,	2176.24,	538.03,	0.0
3015,	0.560,	4.860,	22.0	18.021,	17.563,	2179.60,	538.03,	0.0
3016,	4.120,	2.920,	22.0	22.0	21.534,	2199.33,	538.03,	0.0
3017,	21710.,	15.600,	22.0	11.49	8.490,	30.00,	0.0	4.17
3018,	14.630,	13.260,	44.01	34.23	25.62	750.00,	0.0	10.5

* PRIMARY METAL HEAT TRANSFER COEFFICIENTS

3510, 1.4, .00055

* PRIMARY METAL TIME STEPS

3511, 0.1, 15.0, .001, 1.+6

* PRIMARY METAL PROPERTIES

	VOL	H.T. AREA	THICK	CLAD T	BULK K	CLAD K	RHO CP	T-INC
3521,	1,	47.18,	0.51,	0.01042,	24.00,	10.99,	53.30,	0.0
3522,	1,	61.09,	0.842,	0.842,	10.99,	10.99,	62.90,	0.0
3523,	1,	21.40,	0.125,	0.125,	10.99,	10.99,	62.90,	0.0
3524,	2,	189.94,	0.399,	0.01042,	24.00,	10.99,	53.30,	0.0
3525,	2,	310.09,	0.842,	0.842,	10.99,	10.99,	62.90,	0.0
3526,	2,	103.63,	0.125,	0.125,	10.99,	10.99,	62.90,	0.0
3527,	3,	24.36,	0.325,	0.01042,	24.00,	10.99,	53.30,	0.0
3528,	3,	28.34,	0.842,	0.842,	10.99,	10.99,	62.90,	0.0
3529,	3,	64.00,	0.0449,	0.0449,	10.99,	10.99,	62.90,	0.0
3530,	4,	35.02,	0.254,	0.254,	10.99,	10.99,	62.90,	0.0
3531,	5,	973.0,	0.010,	0.010,	10.99,	10.99,	62.90,	0.0
3532,	5,	64.10,	0.254,	0.254,	10.99,	10.99,	62.90,	0.0
3533,	7,	50.09,	0.140,	0.140,	10.99,	10.99,	64.11,	0.0
3534,	8,	29.673,	0.267,	0.0208,	24.00,	10.8,	53.30,	0.0
3535,	8,	1449.8,	0.00204,	0.00204,	10.8,	10.8,	55.16,	0.0
3536,	9,	1449.8,	0.00204,	0.00204,	10.8,	10.8,	55.16,	0.0
3537,	9,	29.673,	0.267,	0.0208,	24.00,	10.8,	53.30,	0.0
3538,	18,	1610.0,	0.00204,	0.00204,	10.8,	10.8,	55.16,	0.0
3539,	18,	312.21,	0.0625,	0.0625,	24.00,	24.00,	53.30,	0.0
3540,	18,	268.03,	0.18,	0.18,	24.00,	24.00,	53.30,	0.0
3541,	18,	12.07,	0.479,	0.0208,	24.00,	10.8,	53.30,	0.0
3542,	10,	13.51,	0.135,	0.135,	10.99,	10.99,	64.11,	0.0
3543,	11,	34.66,	0.125,	0.125,	10.99,	10.99,	64.11,	0.0
3544,	12,	49.52,	0.129,	0.129,	10.99,	10.99,	64.11,	0.0
3545,	6,	11.01,	0.0293,	0.0293,	10.99,	10.99,	64.11,	0.0
3546,	6,	65.95,	0.2711,	0.0208,	24.00,	10.99,	53.30,	0.0
3547,	13,	127.82,	0.098,	0.098,	10.99,	10.99,	64.11,	0.0
3548,	14,	18.17,	0.093,	0.093,	10.99,	10.99,	64.11,	0.0
3549,	15,	13.67,	0.046,	0.046,	10.99,	10.99,	64.11,	0.0
3550,	16,	54.96,	0.092,	0.092,	10.99,	10.99,	64.11,	0.0

* CONTAINMENT NUMBER

Table 5. (Cont'd)

POOR ORIGINAL

3801.17,32,33

• WILSON MULTIPLIER TABLE

3890,	2.0,	0.0,	2.0,	1.+6
3891,	2.0,	0.0,	2.0,	1.+6
3892,	2.0,	0.0,	2.0,	1.+6
3893,	2.38,	0.0,	2.38,	1.+6
3894,	2.0,	0.0,	2.0,	1.+6

• BUBBLE RISE VELOCITY

3901,	1,-887.0,	2,-887.0,	3,-887.0,	4,-887.0,	5,-887.0,	6,-888.0
3902,	7,-888.0,	8,-888.0,	9,-888.0,	10,-888.0,	11,-888.0,	12,-888.0
3903,	13,-888.0,	14,-888.0,	15,-888.0,	16,-888.0,	17,-888.0,	18,1000.0

• HYDRAULIC DIAMETER FOR WILSON MODEL

3905,	1,0.292,	2,0.167,	3,0.035,	4,0.0402,	5,1.307,	6,2.783,	7,0.932
3906,	8,0.034,	9,0.034,	10,0.932,	11,0.9320,	12,0.932,	13,0.932,	14,0.058
3907,	15,0.338,	16,0.932,	17,1.938,	18,4.316			

• REGULAR FLOW PATHS

4001,	1,	3,	4,501.39,	6,884.0.828,	0.0	-1.44-4.0.0.100,	0.0,0.0.0402		
4002,	1,	3,	4,501.39,	6,884.0.828,	0.0	-1.44-4.0.0.100,	0.0,0.0.0402		
4003,	8,	3,	4,527.78,	7.062,1.340,	0.0	-1.30-2.0.0.1	0.0,0.173		
4004,	8,	4,	5,527.78,	7.062,1.340,	0.0	-1.02-4.0.0.1	0.0,0.1.306		
4005,	8,	4,	5,527.78,	7.062,1.340,	0.0	-1.32-4.0.0.1	0.0,0.1.306		
4006,	8,	5,	7,527.78,	29.10	0.361,	0.0	-6.86-4.0.0.466,	0.0,0.932	
4007,	8,	5,	7,527.78,	29.10	0.361,	0.0	-6.86-4.0.0.466,	0.0,0.932	
4008,	5,	6,	7,	0.0	1.394,	2.0.018,	7.6	-2.28-4.0.0.1	1.0-3.141.99
4009,	8,	7,	8,527.78,	37.540,	0.451,	0.0	7.625-4.0.0.1	0.0,0.0.0335	
4010,	8,	7,	8,527.78,	37.540,	0.451,	0.0	7.625-4.0.0.1	0.0,0.0.0335	
4011,	8,	8,	9,527.78,	8.521,	0.314,	0.0	0.0	0.0.0.479,	0.0,0.0335
4012,	8,	8,	9,527.78,	8.521,	0.314,	0.0	0.0	0.0.0.479,	0.0,0.0335
4013,	8,	9,10,527.78,	12.528,	0.746,	0.0	-7.63-4.0.0.1	0.0,0.0.0335		
4014,	8,	9,10,527.78,	12.528,	0.746,	0.0	-7.63-4.0.0.1	0.0,0.0.0335		
4015,	8,10,11,527.78,	13.922,	0.341,	0.0	0.0	0.0	0.0.0.466,	0.0,0.932	
4016,	8,10,11,527.78,	13.922,	0.341,	0.0	0.0	0.0	0.0.0.466,	0.0,0.932	
4017,	2,11,12,1055.6,	8.374,	1.075,	0.0	0.0	0.0	0.0.0.708,	0.0,0.932	
4018,	8,12,	1,527.78,	36.546,	0.366,	0.0	8.699-4.0.0.1	0.0.0.466,	0.0,0.932	
4019,	8,12,	1,527.78,	36.546,	0.366,	0.0	8.699-4.0.0.1	0.0.0.466,	0.0,0.932	
4020,	8,	1,	2,527.78,	10.241,	0.704,	0.0	1.295-4.0.0.1	0.0,0.0.292	
4021,	8,	1,	2,527.78,	10.241,	0.704,	0.0	1.295-4.0.0.1	0.0,0.0.292	
4022,	8,	2,	3,527.78,	11.055,	0.890,	0.0	1.772-4.0.0.1	0.0,0.0.167	
4023,	8,	2,	3,527.78,	11.055,	0.890,	0.0	1.772-4.0.0.1	0.0,0.0.167	
4024,	8,13,	5,	0.0	52.568,	0.180,	1.003,	6.856-4.0.0.1	0.0.466,	1.0-8.479
4025,	8,13,	5,	0.0	52.568,	0.180,	1.003,	6.856-4.0.0.1	0.0.466,	1.0-8.479
4026,	8,14,13,	0.0	106.75,	0.208,	12.56,	-5.92-4.0.0.1	0.0.602,	1.0-8.515	
4027,	8,14,13,	0.0	106.75,	0.208,	12.56,	-5.92-4.0.0.1	0.0.602,	1.0-8.515	
4028,	8,15,14,	0.0	112.37,	0.067,	4.56,	0.05290,	0.0.458,	1.0-8.292	
4029,	8,15,14,	0.0	112.37,	0.067,	4.56,	0.05290,	0.0.458,	1.0-8.292	
4030,	5,	1,1.16,	0.0	16.31,	0.396,	5.67,-8.70-4.0.0.1	0.0.466,	1.0-8.710	
4031,	8,	1,1.16,	0.0	16.31,	0.396,	5.67,-8.70-4.0.0.1	0.0.466,	1.0-8.710	

• LEAK FLOW PATHS

4232,	7,16,17,0.0,0.0010,	0.002714,	0.60,-1.0,0.053
4233,	7,17,16,0.0,0.0010,	0.002214,	0.60,-1.0,0.053

• FILL SYSTEM

4434,	6,1,12,0.1,0.43,09,0.0
4435,	6,2,12,0.1,0.43,09,0.0

Table 5. (Cont'd)

POOR ORIGINAL

4036, 10, 18, 17, 58.5, 100.0, .038487, 2.4359, 0.0, 0.0, 0.0, 1.1, -8.0, 22.1.0

* INTEGRATED FLOW PATH MASS

*
 4601, 1, 2, 3, 4, 5, 6, 7, 8, 9, 10, 11, 12, 13, 14, 15, 16, 17, 18, 19, 20
 4602, 21, 22, 23, 24, 26, 28, 30, 31, 32, 33
 4810, 36

* FLOW PATH ELEVATION MODIFICATIONS

	PATH	UP.ELEV	DN.ELEV
4901,	1,	9.584,	9.804
4902,	2,	9.644,	9.904
4903,	3,	9.684,	9.904
4904,	4,	15.168,	15.388
4905,	5,	15.268,	15.488
4906,	6,	22.232,	22.232
4907,	7,	21.768,	21.768
4908,	9,	22.232,	22.232
4909,	10,	21.768,	21.768
4910,	11,	31.964,	31.964
4911,	12,	31.006,	31.006
4912,	13,	22.873,	22.653
4913,	14,	22.973,	22.753
4914,	15,	18.490,	18.490
4915,	16,	18.025,	18.025
4916,	18,	22.232,	22.232
4917,	19,	21.768,	21.768
4918,	20,	20.671,	20.451
4919,	21,	20.771,	20.551
4920,	22,	8.097,	7.877
4921,	23,	8.197,	7.977
4922,	24,	22.232,	22.232
4923,	25,	21.768,	21.768
4924,	26,	32.341,	32.341
4925,	27,	31.740,	31.740
4926,	28,	18.106,	18.106
4927,	29,	17.936,	17.936
4928,	30,	22.232,	22.232
4929,	31,	21.768,	21.768
4930,	8,	26.298,	22.416

* STEAM FLOW CONTROL CONTROL VALVE

4951, 0.038487, 0.0, 0.0, 15.0, 0.0, 1.+6

* CORE PARAMETERS

*
 5001, 0.0402, 5.5, 7500., 3000.0, 10., 3, 2.15969+5, 394.96, 1., -9.8-5, 1., 1.,
 * 1., 1., 0.0, 0.0, 0.0
 5002, 0.0402, 5.5, 7500., 3000.0, 10., 3, 2.15969+5, 394.96, 1., -9.8-5, 1., 1.,
 * 1., 1., 0.0, 0.0, 0.0

* FUEL PIN GAP AND CLADDING PROPERTIES

*
 5101, 0.0152, 0.0, 0.0, 1835.0, 0.0003125, -1., -1., 0.00203, 0.0, 0.0, 0.0, 0.0,
 * 0.0, 0.0, 1.55.0
 5102, 0.0152, 0.0, 0.0, 1835.0, 0.0003125, -1., -1., 0.00203, 0.0, 0.0, 0.0, 0.0,
 * 0.0, 0.0, 2.55.0

* FUEL PIN FUEL DENSITY

5500, 636.92

* POISSON RATIO AND PIN PLENUM VOLUMES

Table 5. (Cont'd)

POOR ORIGINAL

5505,0.35,0.0,1.56-4,1.,0.2,0.0153,2
*
* UPPER AND LOWER PATHS FOR EACH CHANNEL
*
5510,1.1,1,2,2,2
*
* METAL-WATER REACTION CONSTANTS
*
5901,91.22,140.5,6.5,2.0,1.-5,1500.,45500.0,33.3,0.0
*
* DNB PARAMETERS
*
5921, 6.0+9, 1000.0, 1000.0, 2.75, 0.0
*
* SCRAM PARAMETERS
*
6001, 3.71, 0.0, 3000.0, 0.0, 0.0, 5, 6
*
* HEAT GENERATION VS TIME TABLE ... 40 HOUR OPERATION
*
6011, 1.0, 0.0, 0.059060, 1.0, 0.057404, 1.5
6012, 0.055963, 2.0, 0.051666, 4.0, 0.048779, 6.0
6013, 0.048640, 5.0, 0.044956, 10.0, 0.041893, 15.0
6014, 0.039756, 20.0, 0.034757, 40.0, 0.031988, 60.0
6015, 0.029900, 60.0, 0.023412, 100.0, 0.025868, 150.0
6016, 0.024201, 200.0, 0.020577, 400.0, 0.018552, 600.0
6017, 0.017087, 300.0, 0.015932, 1000.0, 0.013811, 1500.0
6018, 0.012315, 2000.0, 0.009993, 4000.0
*
* NORMALIZED HEAT TRANSFER COEFFICIENT VS TIME TABLE
*
7021,1.,0.0,1.,10000.0
7031,1.,0.0,1.,10000.0
*
* STEAM GENERATOR HEAT TRANSFER MODEL (OPTION 2)
*
7100,1,1
*
* STEAM GENERATOR
*
7101,9, 18, 15796.3, 31592.6, 40.13, 40.13, 58.5, 0.1
*
* STEAM GENERATOR LOGIC PARAMETERS
*
7201,1.+6,1.+6,60.0
*
* MAIN FEEDWATER COASTDOWN
*
7211, 0.0, 0.0, 0.0, 59.99, 1.11, 60.0, 1.11, 1500.0
*
* AUXILIARY FEEDWATER VS PRESSURE TABLE
*
7231,0.0,0.0,0.0,1.+6
*
* RELIEF VALVE ACTUATION PRESSURE VS TIME TABLE
*
7251,3000.0,0.0,3000.0,10000.0
*
* RELIEF VALVE CHARACTERISTICS
*
7271,0.0,0.0,0.0,10000.0
*
* SAFETY VALVE CHARACTERISTICS
*
7291,0.0,0.0,0.0,0.0
*
* PUMP CHARACTERISTICS

1629 049

Figure 2 - Pressure, Pressurizer (0 to 100 sec.)





Figure 3 - Pressure, Pressurizer ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM

NODE

6

1629 053

Figure 4 - Pressure, Pressurizer ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

6

1629 054

Figure 5 - Pressure, Broken Loop Hot Leg Near Break (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

13

1629 055

Figure 6 - Pressure, Broken Loop Hot Leg Near Break ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

13

1629 056

Figure 7 - Pressure, Broken Loop Hot Leg Near Break ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

NODE

13

1629 057

Figure 8 - Pressure, Broken Loop Cold Leg Near Break (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

16

1629 058

Figure 9 - Pressure, Broken Loop Cold Leg Near Break ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM

NODE

16

1629 059

Figure 10 - Pressure, Broken Loop Cold Leg Near Break ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

1629 0.0

NODE

16

Figure 11 - Pressure, Upper Plenum (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

NODE

5

1629 0.1

Figure 12 - Pressure, Upper Plenum ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

1629 002

NODE

5

Figure 13 - Pressure, Upper Plenum ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

5

1629 063

Figure 14 - Pressure, Accumulator, Intact Loop (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

FLOOD TANK

1

1629 064

Figure 15 - Pressure, Accumulator, Intact Loop ($C_D = 0.6$)




L31S2EE

LOFT L3-1 STD PRBLM
FLOOD TANK

1

1629 065

Figure 16 - Pressure, Accumulator, Intact Loop (0 to 0.9)




L31S374

LOFT L3-1 STD PRBLM
FLOOD TANK

1

1629 066

Figure 17 - Pressure, Steam Generator Secondary (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

18


1629 067

Figure 18 - Pressure, Steam Generator Secondary ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 18 1629 068

Figure 19 - Pressure, Steam Generator Secondary ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

1629 069

NODE

18

Figure 20 - Density, Intact Loop Cold Leg (0 to 100 sec.)



L31S2EE

LOFT L3-1 STD PRBLM

NODE

12

1629 070

Figure 21 - Density, Intact Loop Cold Leg ($C_D = 0.6$)





Figure 22 - Density, Intact Loop Cold Leg ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

NODE

12

1629 072

Figure 23 - Density, Intact Loop Hot Leg (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

NODE

7

1629 073

Figure 24 - Density, Intact Loop Hot Leg ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

7

1629 074

Figure 25 - Density, Intact Loop Hot Leg ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

NODE

7

1629 075

Figure 26 - Density, Broken Loop Cold Leg (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

16

1629 076

Figure 27 - Density, Broken Loop Cold Leg ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

16

1629 077

Figure 28 - Density, Broken Loop Cold Leg ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

NODE

16

1629 078

Figure 29 - Density, Broken Loop Hot Leg (0 to 100 sec.)



L31S2EE

LOFT L3-1

TIME (SEC)(X10¹)


STD PRBLM

NODE

13

1629 079

Figure 30 - Density, Broken Loop Hot Leg ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

13

1629 080

Figure 31 - Density, Broken Loop Hot Leg ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

13

1629 081

Figure 32 - Density, Pump Suction (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

NODE

11


1629 082

Figure 33 - Density, Pump Suction ($C_D = 0.6$)



L61S2EE LOFT L3-1 STD PRBLM
NODE 11 1629 083

Figure 34 - Density, Pump Suction ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

11

1629 084

Figure 35 - Differential Pressure, Across Core (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM

NODE 3- NODE

5

1629 085

Figure 36 - Differential Pressure, Across Core ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM
NODE 3- NODE

5

1629 086

Figure 37 - Differential Pressure, Across Core ($C_D = 0.9$)




L31S374 LOFT L3-1 STD PRBLM

NODE 3- NODE

5

1629 087

Figure 38 - Differential Pressure, Across Intact Loop Pump (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM

NODE 11- NODE 12

1629 088

Figure 39 - Differential Pressure, Across Intact Loop Pump ($C_D = 0.9$)




L31S2EE LOFT L3-1 STD PRBLM

NODE 11- NODE

12

1629 089

Figure 40 - Differential Pressure, Across Intact Loop Pump ($C_D = 0.9$)




L31S374 LOFT L3-1 STD PRBLM

NODE 11- NODE

12

1629 090

Figure 41 - Differential Pressure, Pump Suction Leg (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
NODE 10- NODE

11


1629 091

Figure 42 - Differential Pressure, Pump Suction Leg ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 10- NODE 11 1629 092

Figure 43 - Differential Pressure, Pump Suction Leg ($C_D = 0.9$)




L31S374 LOFT L3-1 STD PRBLM
NODE 10- NODE

11

1629 093

Figure 44 - Differential Pressure, Intact Hot Leg to Top of Vessel (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
NODE 7- NODE

5

1629 094

Figure 45 - Differential Pressure, Intact Hot Leg to Top of Vessel ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM
NODE 7- NODE

5

1629 095

Figure 46 -- Differential Pressure, Intact Hot Leg to Top of Vessel ($C_D = 0.9$)




L31S374 LOFT L3-1 STD PRBLM

NODE 7- NODE

5


1629 096

Figure 47 - Fluid Temperature, Cold Leg, Upstream of Break (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
NODE 16 1629 097

Figure 48 - Fluid Temperature, Cold Leg, Upstream of Break ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 16 1629 098

Figure 49 - Fluid Temperature, Cold Leg, Upstream of Break ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

NODE

16


1629 099

Figure 50 - Fluid Temperature, Upper Plenum (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
NODE 5 1629 100

Figure 51 - Fluid Temperature, Upper Plenum ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM 1629 101
NODE 5

Figure 52 - Fluid Temperature, Upper Plenum ($C_p = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

5

1629 102

Figure 53 - Fluid Temperature, Pressurizer (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

1629 103

NODE


6

Figure 54 - Fluid Temperature, Pressurizer ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 6 1629 104

Figure 55 - Fluid Temperature, Pressurizer ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

6

1629 105

Figure 56 - Fluid Temperature, Lower Plenum (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

3


1629 106

Figure 57 - Fluid Temperature, Lower Plenum ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 3 1629 107

Figure 58 - Fluid Temperature, Lower Plenum ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

3

1629 108

Figure 59 - Flow Rate, Core Inlet, Path 1 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

1


1629 109

Figure 60 - Flow Rate, Core Inlet, Path 1 ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM
PATH 1 1629 110

Figure 61 - Flow Rate, Core Inlet, Path 1 ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM
PATH 1 1629 111

Figure 62 - Flow Rate, Core Inlet, Path 2 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

2

1629 112

Figure 63 - Flow Rate, Core Inlet, Path 2 ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

1629 113

PATH

2

Figure 64 - Flow Rate, Core Inlet, Path 2 ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

2


1629 114

Figure 65 - Flow Rate, Core Inlet, Path 3 (0 to 100 sec.)



L31S2EE LOFT L3-1 STD PRBLM
PATH 3 1629 115


Figure 66 - Flow Rate, Core Inlet, Path 3 ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
PATH 3

1629 116

Figure 67 - Flow Rate, Core Inlet, Path 3 ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

3

1629 117

Figure 68 - Flow Rate, Core Outlet, Path 4 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

4


1629 118

Figure 69 - Flow Rate, Core Outlet, Path 4 ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM 1629 119
PATH 4

Figure 70 - Flow Rate, Core Outlet, Path 4 ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM 1629 120
PATH 4

Figure 71 - Flow Rate, Core Outlet, Path 5 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

5

1629 121

Figure 72 - Flow Rate, Core Outlet, Path 5 ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM
PATH

5

1629 122

Figure 73 - Flow Rate, Core Outlet, Path 5 ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

5

1629 123

Figure 74 - Flow Rate, Break Flow, Path 32 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

PATH

32


1629 124

Figure 75 - Flow Rate, Break Flow, Path 32 ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
PATH 32 1629 125

Figure 76 - Flow Rate, Break Flow, Path 32 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

PATH

32


1629 126

Figure 77 - Flow Rate, Break Flow, Path 33 (0 to 100 sec.)



L31S2EE LOFT L3-1 STD PRBLM
PATH 33 1629 127

Figure 78 - Flow Rate, Break Flow, Path 33 ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

33

1629 128

Figure 79 -- Flow Rate, Break Flow, Path 33 ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

33


1629 129

Figure 80 - Flow Rate, Cold Leg, Path 18 (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
PATH 18 1629 130

Figure 81 - Flow Rate, Cold Leg, Path 18 ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM
PATH 18 1629 131

Figure 82 - Flow Rate, Cold Leg, Path 18 ($C_D = 0.9$)




L31S374 LOFT L3-1 STD PRBLM 1629 132
PATH 18

Figure 83 - Flow Rate, Cold Leg, Path 19 (0 to 100 sec.)




L3152EE LOFT L3-1 STD PRBLM
PATH 19 1629 133

Figure 84 - Flow Rate, Cold Leg, Path 19 ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM
PATH 19 1629 134

Figure 85 - Flow Rate, Cold Leg, Path 19 ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM
PATH 19 1629 135

Figure 86 - Flow Rate, Hot Leg, Path 9 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

9

1629 136

Figure 87 - Flow Rate, Hot Leg, Path 9 ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

9

1629 137

Figure 88 - Flow Rate, Hot Leg, Path 9 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

PATH

9

1629 138

Figure 89 - Flow Rate, Hot Leg, Path 10 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

10


1629 139

Figure 90 - Flow Rate, Hot Leg, Path 10 ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
PATH 10 1629 140

Figure 91 - Flow Rate, Hot Leg, Path 10 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

PATH

10

1629 141

Figure 92 - Flow Rate, Accumulator (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

FLOOD TANK

1


1629 142

Figure 93 - Flow Rate, Accumulator ($C_D = 0.6$)



- L31S2EE LOFT L3-1 STD PRBLM
FLOOD TANK 1 1629 143

Figure 94 - Flow Rate, Accumulator ($C_D = 0.9$)




L31S374

LOFT L3-1 STD PRBLM
FLOOD TANK

1

1629 144

Figure 95 - Flow Rate, LPIS (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

35

1629 145

Figure 96 - Flow Rate, LPIS ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

35

1629 146

Figure 97 - Flow Rate, LPIS ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

35

1629 147

Figure 98 - Flow Rate, HPIS (0 to 100 sec.)



L31S2EE


LOFT L3-1 STU PRBLM

PATH

34


1629 148

Figure 99 - Flow Rate, HPIS ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
PATH 34 1629 149

Figure 100 - Flow Rate, HPIS ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

PATH

34

1629 150

Figure 101 - Flow Rate, Pressurizer Surge Line (0 to 100 sec.)



L31S2EE

LOFT L3-1

TIME (SEC)(X10¹)


STD PRBLM

PATH

8

1629 151

Figure 102 - Flow Rate, Pressurizer Surge Line ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

PATH

8

1629 152

Figure 103 - Flow Rate, Pressurizer Surge Line ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

8

1629 153

Figure 104 - Temperature, Average Fuel Rod, Core Path 1 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

1

1629 154

Figure 105 - Temperature, Average Fuel Rod, Core Path 1 ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

1

1629 155

Figure 106 - Temperature, Average Fuel Rod, Core Path 1 ($C_D = 0.9$)




L31S374

LOFT L3-1 STD PRBLM
CORE PATH

1

1629 156

Figure 107 - Temperature, Average Fuel Rod, Core Path 2 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

2

1629 157

Figure 108 - Temperature, Average Fuel Rod, Core Path 2 ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

2

1629 158

Figure 109 - Temperature, Average Fuel Rod, Core Path 2 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

CORE PATH

2

1629 159

Figure 110 - Temperature, Average Clad, Core Path 1 (0 to 100 sec.)




L31S2EE

LOFT L3-1 STD PRBLM
CORE PATH

1

1629 160

Figure 111 - Temperature, Average Clad, Core Path 1 ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

1

1629 161

Figure 112 - Temperature, Average Clad, Core Path 1 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

CORE PATH

1

1629 162

Figure 113 - Temperature, Average Clad, Core Path 2 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

2

1629 163

Figure 114 - Temperature, Average Clad, Core Path 2 ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

2

1629 164

Figure 115 - Temperature, Average Clad, Core Path 2 ($C_D = 0.9$)




L31S374

LOFT L3-1 STD PRBLM
CORE PATH

2

1629 165

Figure 116 - Vessel Inventory, Node 1 (0 to 100 sec.)



L31S2EE

LOFT L3-1

TIME (SEC)(X10¹)


STD PRBLM

1629 166

NODE

1

Figure 117 - Vessel Inventory, Node 2 (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

NODE

2

1629 167

Figure 118 - Vessel Inventory, Node 3 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

3

1629 168

Figure 119 - Vessel Inventory, Node 4 (0 to 100 sec.)



L31S2EE

LOFT L3-1

TIME (SEC X 10¹)


STO F M

NODE

4


1629 169

Figure 120 - Vessel Inventory, Node 5 (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM 1629 170
NODE 5

Figure 121 - Vessel Inventory, Node 1 ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 1 1629 171

Figure 122 - Vessel Inventory, Node 2 ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

NODE

2


1629 172

Figure 123 - Vessel Inventory, Node 3 ($C_D = 0.6$)




L31S2EE LOFT L3-1 STD PRBLM 3 1629 173
NODE

Figure 124 - Vessel Inventory, Node 4 ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 4 1629 174

Figure 125 - Vessel Inventory, Node 5 ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

NODE

5


1629 175

Figure 126 - Vessel Inventory, Node 1 (C_D 0.9)




L31S374 LOFT L3-1 STD PRBLM 1629 176
NODE 1

Figure 127 - Vessel Inventory, Node 2 ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM
NODE 2 1629 177

Figure 128 - Vessel Inventory, Node 3 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

3


1629 178

Figure 129 - Vessel Inventory, Node 4 ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM
NODE 4 1629 179

Figure 130 - Vessel Inventory, Node 5 ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

5


1629 180

Figure 131 - Integrated Flow to Containment (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM

Figure 132 - Integrated Flow to Containment ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM


Figure 133 - Integrated Flow to Containment ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM

1629 183


Figure 134 - Integrated Energy to Containment (0 to 100 sec.)



L31S2EE LOFT L3-1 STD PRBLM

1629 184


Figure 135 - Integrated Energy to Containment ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM

1629 185


Figure 136 - Integrated Energy to Containment ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM


1629 186

Figure 137 - Pipe Quality, Core Path 1 (0 to 100 sec.)



L31S2EE LOFT L3-1 STD PRBLM
PATH 1 1629 187

Figure 138 - Pipe Quality, Core Path 1 ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

PATH

1

1629 188

Figure 139 - Pipe Quality, Core Path 1 ($C_D = 0.9$)




L31S374

LOFT L3-1 STD PRBLM
PATH

1


1629 189

Figure 140 - Pipe Quality, Core Path 2 (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
PATH 2 1629 190

Figure 141 - Pipe Quality, Core Path 2 ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
PATH 2 1629 191

Figure 142 - Pipe Quality, Core Path 2 ($C_D = 0.9$)




L31S374

LOFT L3-1 STD PRBLM
PATH

2

1629 192

Figure 143 - Pipe Quality, Leak Path 32 (0 to 100 sec.)



L31S2EE

LOFT L3-1

TIME (SEC)(X10¹)


STD PRBLM

PATH

32

1629 193

Figure 144 - Pipe Quality, Leak Path 32 ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

1629 194

PATH

32

Figure 145 - Pipe Quality, Leak Path 32 ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

PATH

32

1629 195

Figure 146 - Heat Transfer Coefficient, Core Path 1 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

1

1629 196

Figure 147 - Heat Transfer Coefficient, Core Path 1 ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

1


1629 197

Figure 148 - Heat Transfer Coefficient, Core Path 1 ($C_D = 0.9$)



L31S374 LOFT L3-1 STD PRBLM 1629 198
CORE PATH 1

Figure 149 - Heat Transfer Coefficient, Core Path 2 (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

CORE PATH

2

1629 199

Figure 150 - Heat Transfer Coefficient, Core Path 2 ($C_D = 0.6$)



L31S2EE


LCFT L3-1 STD PRBLM

1629 200

CORE PATH

2

Figure 151 - Heat Transfer Coefficient, Core Path 2 ($C_D = 0.9$)




L31S374

LOFT L3-1 STD PRBLM
CORE PATH

2

1629 201

Figure 152 - Water Level, Vessel (0 to 100 sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

5


1629 202

Figure 153 - Water Level, Vessel ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 5 1629 203

Figure 154 - Water Level, Vessel ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

5


1629 204

Figure 155 - Water Level, Downcomer (0 to 100 sec.)




L31S2EE LOFT L3-1 STD PRBLM
NODE 1 1629 205

Figure 156 - Water Level, Downcomer ($C_D = 0.6$)



L31S2EE LOFT L3-1 STD PRBLM
NODE 1 1629 206

Figure 157 - Water Level, Downcomer ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

1629 207

NODE

1

Figure 158 - Water Level, Pressurizer ($C_D = 100$ sec.)



L31S2EE


LOFT L3-1 STD PRBLM

NODE

6

1629 208

Figure 159 - Water Level, Pressurizer ($C_D = 0.6$)



L31S2EE


LCFT L3-1 STD PRBLM

NODE

6

1629 209

Figure 160 - Water Level, Pressurizer ($C_D = 0.9$)



L31S374


LOFT L3-1 STD PRBLM

NODE

6

1629 210

Figure 161 - Pump Speed (0 to 100 sec.)




L31S2EE

LOFT L3-1 STD PRBLM

1629 211

PATH 17

Figure 162 - Pump Speed ($C_D = 0.6$)



L31S2EE


LOFT L3-1 STD PRBLM

PATH

17

1629 212

Figure 163 - Pump Speed ($C_D = 0.9$)



L31S374

LOFT L3-1


STD PRBLM

1629 213

PATH

17

Figure 164 - Pump Head (0 to 100 sec.)



L31S2EE

LOFT L3-1


STD PRBLM

1629 214

PATH

17

Figure 165 - Pump Head ($C_D = 0.6$)



L31S2EE

LOFT L3-1


STD PRBLM

1629 215

PATH

17

Figure 166 - Pump Head ($C_D = 0.9$)



L31S374

LOFT L3-1 STD PRBLM

PATH

17

1629 216