

**SARGENT & LUNDY
ENGINEERS**

FOUNDED BY FREDERICK SARGENT-1891
55 EAST MONROE STREET
CHICAGO, ILLINOIS 60603
TELEPHONE - 312-269-2000
CABLE ADDRESS - SARLUN-CHICAGO

J. E. McFARLAND
ASSOCIATE
312-269-8370

December 5, 1979
Project No. 0037-00

Sargent & Lundy's Response to
Report of NRC Inspection,
Report Number 99900507/79-04

Mr. Uldis Potapovs
Chief, Vendor Inspection Branch
U. S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, TX 76011

Dear Mr. Potapovs:

This letter is in response to the finding identified in your
Inspection Report, Number 99900507/79-04, received by Sargent &
Lundy November 19, 1979.

Sargent & Lundy's response to the finding is as follows:

Finding

Sargent & Lundy Topical Report number SL-TR-1A, Revision 5,
Section 02.05, requires "indoctrination and training of personnel
performing activities affecting quality as necessary to provide
assurance that appropriate proficiency in the application of the
QA Program and implementing quality assurance procedures is
achieved and maintained. This training is accomplished in accor-
dance with appropriate procedures and lesson plans approved by the
Head, QA Division"

Implementing procedure GQ-2.04, QA Training Section 3.0.A.2,
states in part:

"Personnel who . . . perform quality-related activities shall
receive training when one or more of the following criteria
apply:

1735 208

8001110 272

SARGENT & LUNDY
ENGINEERS
CHICAGO

Mr. Uldis Potapovs
U. S. Nuclear Regulatory Commission

December 5, 1979
Page 2

When an individual is promoted or transferred from one position, division, or department to another. When an individual is hired. When an individual was absent from a previously scheduled class."

Contrary to the above, a number of persons performing safety-related work have not received all required QA training although one or more of the above criteria apply. These personnel include project leaders, engineers, and designers in the structural, mechanical and electrical design and drafting divisions.


Response

As of December 5, 1979, all persons performing quality-related activities have either received all required QA training or have been scheduled to attend classes for this training.

In order to prevent recurrence of this finding, personnel that fail to complete their required QA training as scheduled will be removed from quality-related activities on nuclear projects until these requirements are complete.

If there are any questions regarding our response, please do not hesitate to contact me.

Yours very truly,



J. E. McFarland
Head, Quality Assurance Division

JEM:HST:ma
In duplicate
Copies:

R. W. Patterson
L. E. Ackmann
W. A. Chittenden
R. N. Bergstrom
W. G. Hegener
D. C. McClintock
J. M. McLaughlin
P. M. DeBlake

1735 209