

PUBLIC SERVICE COMPANY OF OKLAHOMA
A CENTRAL AND SOUTH WEST COMPANY



P.O. BOX 201 / TULSA, OKLAHOMA 74102 / (918) 583-3611

IRVING NUMBER
PROPOSED RULE **PR** Misc. Notice
Reg. Guide

August 13, 1979

Secretary of the Commission
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Docketing and Service Branch

Subject: Draft Regulatory Guide, Qualification Test for Cable Penetration
Fire Stops For Use In Nuclear Power Plants (Task RS 809-5)

Gentlemen:


We have reviewed the subject Draft Regulatory Guide and offer the following
comments for your consideration:

Position C.3 is unduly restrictive provided the added elements and the
modified fire stop are of the same type as the original.

Position C.8 is overly conservative in the requirement of 400°. Allow-
ance should be made for administrative controls which would keep very
low ignition combustibles away from fire stops.

Thank you for the opportunity to comment on this Draft Regulatory Guide.

Very truly yours,


V. L. Conrad, Manager
Licensing & Compliance



VLC/BWR:at

1756 127

Acknowledged by card. 8/21

800116005/

CENTRAL AND SOUTH WEST SYSTEM

Central Power and Light
Corpus Christi, Texas

Public Service Company of Oklahoma
Tulsa, Oklahoma

Southwestern Electric Power
Shreveport, Louisiana

West Texas Utilities
Abilene, Texas