

WRAP-PWR-EM SYSTEM DEVELOPMENT AND APPLICATIONS

by

F. Beranek

Savannah River Laboratory  
E. I. du Pont de Nemours & Co.  
Aiken, SC 29801

An invited paper to be presented to the  
Water Reactor Safety Meeting,  
Washington, DC,  
November 5-9, 1979.

---

This paper was prepared in connection with work under Contract No. AT(07-2)-1 with the U. S. Department of Energy. By acceptance of this paper, the publisher and/or recipient acknowledges the U. S. Government's right to retain a nonexclusive, royalty-free license in and to any copyright covering this paper, along with the right to reproduce and to authorize others to reproduce all or part of the copyrighted paper.

1603 300

## WRAP-PWR-EM SYSTEM DEVELOPMENT AND APPLICATIONS\*

by

F. Beranek

Savannah River Laboratory  
E. I. du Pont de Nemours & Co.  
Aiken, SC 29801

## SUMMARY

The WRAP-EM system is a complete computational system for analysis of loss-of-coolant accidents (LOCAs) in light-water power reactors. The system has been developed for use by the Nuclear Regulatory Commission in evaluating and interpreting reactor vendor model methods and results.

WRAP-EM has the capability of predicting fuel parameters during the normal operation of a reactor, performing thermal-hydraulic initialization of the reactor system, analysing the behavior of the reactor core during an accident (encompassing the blowdown, refill, and reflood stages), and executing a detailed transient thermal analysis of the hottest pin in the core during the accident. A minimum amount of user intervention is required throughout the analysis.

WRAP-PWR-EM is the integrated system of codes used for the analysis of pressurized water reactors (PWRs). GAPCON-THERMAL-2 is used to initialize fuel parameters as a function of reactor operating time. Both the blowdown and reflood phases of an accident are analyzed by RELAP4/MOD5. The refill calculation is based on a simple accumulator flow model (FLOW4) developed at NRC, and the hot-pin analysis is performed by FRAP-T4-LACE. The automated transfer of relevant data from one code to another is accomplished through interface routines developed at SRL (except RELAP4/MOD5-FLOOD to FRAP).

---

\* The information contained in this article was developed during the course of work under Contract No. AT(07-2)-1 with the U. S. Department of Energy.

Because different fuel models are used in the various codes, it is important to ascertain that the conditions predicted at a given time by two different codes are similar. In particular, at the time of accident initiation, the fuel parameters determined by RELAP and FRAP must be similar to, and more conservative than, the parameters predicted by GAPCON. The conservatism requirement is set for licensing concerns. Results achieved using Zion fuel indicate that fuel temperatures predicted by RELAP and FRAP are more conservative than the GAPCON predictions.

The refill portion of the transient is that time during which the lower plenum is being filled with water until the liquid level reaches the bottom of the core. Analysis of this period by RELAP requires very small calculational time-steps. An alternative technique has been developed based on a simple accumulator flow model. Within the refill period, the core is assumed to heat up adiabatically. The core thermal response is calculated by continuing the RELAP4 calculation with the hydraulics calculation bypassed. The lower plenum subcooling, which is required as input to the flood calculations, is calculated by a mixed-average, bulk-fluid, temperature calculation. Several assumptions relating to heat transfer during this period have been made to decrease the computational time. Results of sensitivity studies to determine conservative estimates of these parameters will be presented.

The system is presently being evaluated by analyzing various LOFT experiments and the Zion reactor. Results of these analyses will be discussed. Future plans include performing pre-test analyses on the LOFT L2 series experiments as well as reference and sensitivity studies regarding the Zion facility.

1603 302

## REFERENCES

1. M. M. Anderson. *WRAP - A Water Reactor Analysis Package*. Report DPST-NUREG-77-2, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1977).
2. M. V. Gregory. *User's Guide to Input for WRAP - A Water Reactor Analysis Package*. Report DPST-NUREG-77-2, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1977).
3. D. A. Sharp. *The BWR Steady-State Capability of the WRAP-EM System*. Report DPST-NUREG-78-1, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1979).
4. M. R. Buckner, et al. *The BWR Loss-of-Coolant-Accident Analysis Capability of the WRAP-EM System*. Report DPST-NUREG-78-2, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1979).
5. R. R. Beckmeyer, et al. *User's Guide for the BWR LOCA Analysis Capability of the WRAP-EM System*. Report DPST-NUREG-78-3, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1979).
6. D. A. Sharp. *The PWR Steady-State Capability of WRAP - A Water Reactor Analysis Package*. Report DPST-NUREG-77-3, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1977).
7. H. C. Honeck. *The JOSHUA System*. ERDA Report DP-1380, Savannah River Laboratory, E. I. du Pont de Nemours and Company, Aiken, SC (1975).

1603 303

WRAP-PWR-EM DEVELOPMENT AND APPLICATIONS

F. BERANEK  
SAVANNAH RIVER LABORATORY

1603 304


1603 305

OUTLINE

- I. System Description
- II. Fuel Model Consistency
- III. Refill
- IV. Analyses
  - LOFT
  - ZION
  - FLOOD Sensitivity
- V. Program

1603 305

# PWR ANALYSIS SCHEME



1603 106

GAPCON-FRAP CONSISTENCY AT HOTTEST AXIAL NODE

Burnup = 13000 MWD/MT

	<u>GT2<sup>1</sup></u>	<u>F4L<sup>2</sup></u>
Centerline Temperature (°F)	3159	3285
Fuel Surface Temperature (°F)	1540	1588
Gap Conductance (BTU/hr-ft <sup>2</sup> -°F)	374	356
Gap Pressure (psi)	1204	1238
Stored Energy (BTU/lb)	163	170

---

<sup>1</sup> GT2 ≡ GAPCON-THERMAL-2

<sup>2</sup> F4L ≡ FRAP-T4-LACE

1603 307



GAP CONDUCTANCE

FRAP (Open gap)

$$h = \frac{k}{\Delta X + g + 1.98R} + h_r$$


GAPCON (Open gap)

$$h = \frac{k}{\Delta X + g'} + h_r$$

- k           ≡ thermal conductivity of gas
- g and g'   ≡ temperature jump distances
- ΔX          ≡ gap width
- R           ≡ average roughness
- h<sub>r</sub>         ≡ radiation term
- h           ≡ gap conductance


1603 508

### GAPCON-FRAP Fuel Temperatures



1603 309

### GAPCON-FRAP Fuel Temperatures



1603 310

REFILL

- RELAP calculation prohibitive
- FLOW4 - Simple accumulator flow model
- Core thermal model - Adiabatic heatup
- Mixed average bulk fluid model

1603 311

GAPCON-FRAP CONSISTENCY AT HOTTEST AXIAL NODE  
WITH MODIFIED GAP CONDUCTANCE CORRELATION

Burnup = 13000 MWD/MT

	GT2 <sup>1</sup>	F4L <sup>2</sup>	F4LM <sup>3</sup>
Centerline Temperature (°F)	3159	3285	3234
Fuel Surface Temperature (°F)	1540	1588	1550
Gap Conductance (BTU/hr-ft <sup>2</sup> -°F)	374	356	372
Gap Pressure (psi)	1204	1238	1222
Stored Energy (BTU/lb)	163	170	166


---

<sup>1</sup> GT2 ≡ GAPCON-THERMAL-2

<sup>2</sup> F4L ≡ FRAP-T4-LACE


<sup>3</sup> F4LM ≡ FRAP-T4-LACE MODIFIED

### GAPCON-WRAP(RELAP) Fuel Temperature Comparison




1603 313

### Lower Plenum Pressure



1603 314


### Zion Core Flow



1603 315



# System Nodalization (Zion Plant)



1603 316

PROGRAM

- PWR System Checkout and Evaluation
- Verification Studies
  1. LOFT (L1-5 and L2-3)
  2. Semi-scale (S-06-03 and MOD3)
  3. Zion
- WRAP Analysis for NRC
  1. LOFT Pre-test Calculations
  2. Reference and Sensitivity Studies
  3. NRC Licensing Concerns

1603 317