

Application of
RAMONA-III and IRT Codes
to
BWR and PWR Analysis

D. J. Diamond and W. G. Shier

To be presented at Water Reactor Safety Research
Information Meeting, November 7, 1979

1603 318

RAMONA-III: A BWR TRANSIENT ANALYSIS CODE

D. J. Diamond and M. M. Levine

RAMONA-III is a new entry in BNL's library of codes for calculating operational transients and accidents in BWRs. The code was originally obtained from Scandpower A/S. It is intended for use in supplying technical assistance to the Division of Systems Safety. In February of this year work began under the sponsorship of the Division of Water Reactor Safety Research to make the code more accurate and generally useful for that purpose. The project is also charged with the task of generating plant model input data, performing sensitivity analysis, and validating the code.

The neutronics model is the "1-1/2 group," time dependent, diffusion equation in three dimensional geometry. A coarse mesh space discretization is used to solve for the fast flux and the thermal flux is obtained approximately from the fast flux. Albedo boundary conditions are used.

The coolant hydraulics is based on the continuity equations for vapor and liquid mass and for mixture momentum and energy. Thermodynamic equilibrium is not assumed. Subcooled boiling, slip, and steam generation and condensation are taken into account. The model allows for parallel channels in the core, leading to a riser region and then a steam dome. The first of two downcomer regions allows for feedwater flow and the second allows for an imposed pump head. The loop is completed with two lower plenum regions.

New components that have been developed at BNL are the steam separator, steamline, and jet pump with recirculation loop. The steamline includes a representation of the safety, relief, bypass, and turbine valves. The recirculation loop model includes the governing equations for the recirculation pump. The original fuel rod heat conduction model has been modified in order to account for heat capacity of the clad and non-uniform heat generation.

RAMONA has also been improved by adding the ability to calculate critical power ratio based on the GEXL boiling length-critical quality correlation and the concept of thermal margin. Parts of a BWR control and protection system have been added. These include feedwater and recirculation pump trips as well as scram trips. In addition the cross section parameterization has been changed so that the input is consistent with other codes in use at BNL.

Plant input models have been generated for the Peach Bottom-2 reactor. Calculations of turbine trip tests have been run using the original version and modified versions of the code. These calculations are being used to determine where further improvements in the code ought to be made.

1603 319

RAMONA-III: A BWR TRANSIENT ANALYSIS CODE

THERMAL-HYDRAULICS MODELLING

CONSERVATION EQUATIONS

MASS: VAPOR + LIQUID

ENERGY: MIXTURE

MOMENTUM: MIXTURE

SLIP: SOLBERG CORRELATION

PHASE CHANGE:

SUBCOOLED BOILING

CONDENSATION

SATURATION CONDITIONS

NO SUPERHEAT

FLUID PROPERTIES

MULTIPLE PARALLEL CORE HYDRAULIC CHANNELS

JENS-LOTTE & COLBURN HEAT TRANSFER CORRELATIONS

EXPLICIT INTEGRATION SCHEME


FUEL ROD HEAT CONDUCTION

UNIFORM HEAT SOURCE

PIECEWISE LINEAR TEMPERATURE DISTRIBUTION

NO CLAD HEAT CAPACITY

1603 320



ORIGINAL RAMONA-III MODEL

1603 321

NEUTRONICS MODELLING

DIFFUSION EQUATION

THREE DIMENSIONS - COURSE MESH

1-1/2 ENERGY GROUPS

FAST GROUP "EXACT"

THERMAL GROUP APPROXIMATE

ALBEDO BOUNDARY CONDITIONS

SIX DELAYED NEUTRON PRECURSOR GROUPS

DECAY HEAT

CROSS SECTION PARAMETERIZATION

MODERATOR & FUEL TEMPERATURE

VOID FRACTION

EXPOSURE & VOID HISTORY

CONTROL STATE, XE

1603 322

NEW COMPONENT MODELLING

STEAM SEPARATOR

$$(L/A)_{\text{EFF}} = F(X)$$

FRICTION FACTOR

CARRY-UNDER

JET PUMP/RECIRCULATION LOOP

SUCTION FLOW

MOMENTUM EXCHANGE IN THROAT

HEAD GAIN IN EXPANDING DIFFUSER

DRIVE PUMP

STEAMLINE

SINGLE PHASE COMPRESSIBLE VAPOR

SAFETY, RELIEF, BYPASS, & TURBINE VALVES


COMPARISON WITH GE RESULTS

FUEL ROD HEAT CONDUCTION MODEL

CLAD HEAT CAPACITY - EXPLICIT GAP

NON-UNIFORM HEAT GENERATION

1603 323



1603 324

MODIFIED RAMONA-III MODEL

NEW CALCULATIONAL FEATURES

CRITICAL POWER RATIO

GEXL CORRELATION

CROSS SECTION PARAMETERIZATION CONSISTENT WITH BNL CODES

GRAPHICS PACKAGE

CONTROL AND PROTECTION SYSTEM

SCRAM

HIGH POWER

HIGH SYSTEM PRESSURE

LOW/HIGH REACTOR VESSEL WATER LEVEL

TURBINE STOP VALVE CLOSURE *

MAIN STEAM ISOLATION VALVE CLOSURE *

TURBINE TRIP SIGNALS

LOW/HIGH VESSEL WATER LEVEL *

LOW TURBINE INLET PRESSURE *

RECIRCULATION PUMP TRIP

TURBINE INLET VALVE CLOSURE *

LOW VESSEL WATER LEVEL

TURBINE BYPASS OPENING

TURBINE INLET VALVE CLOSURE *

FEEDWATER SYSTEM TRIP

HIGH VESSEL WATER LEVEL

1603 325

* NOT YET IMPLEMENTED

PLANT MODELLING

PEACH BOTTOM-2 END-OF-CYCLE 2 TURBINE TRIP TESTS

BNL INPUT

ScP INPUT

1603 326

1603 326

FUTURE WORK

SMALL BREAK CAPABILITY

REACTIVITY EDITS

REDUCTION TO 2, 1 OR 0 DIMENSIONAL NEUTRONICS

ADDITIONAL PLANT PROTECTION AND CONTROL SYSTEM

BORON INJECTION

INCREASED RUNNING SPEED

IMPROVED CORRELATIONS

SENSITIVITY STUDIES

VALIDATION

IRT CODE MODIFICATION AND APPLICATION TO PWR ANALYSES

W. G. Shier and M. M. Levine

The IRT code is a fast running pressurized water reactor (PWR) systems code being modified by Brookhaven National Laboratory for the Nuclear Regulatory Commission. The code is applicable for the analysis of a number of PWR non-LOCA transients including steamline break, control rod withdrawal, loss of external load, loss of flow, loss of feedwater, and anticipated transients without scram (ATWS). In addition, the code is capable of analyzing any of these non-LOCA transients assuming concurrent steam generator tube rupture.

The IRT code solves the mass and energy equations and uses constant nodal volumes. The equation of state consists of the 1967 ASME steam tables. Since the momentum equation is not solved, main coolant flow rate is not calculated explicitly; pump volumetric flow rate is either held constant or determined from user specified values. The code models the primary system of a PWR with 17 control volumes plus a two-volume pressurizer. The primary system volumes are assumed to be homogeneous and at all the same pressure. The pressurizer is simulated with a non-equilibrium model that allows for various combinations of saturated, subcooled, and superheated conditions. Reactor coolant system pressure is determined based on the calculated pressurizer pressure and the pressure drop across the surge line.

Recent modifications to the IRT code have included the addition of a once-through steam generator model for the simulation of B&W reactors. The model represents the steam generator primary and secondary sides by twelve volumes each; the steam generator downcomer is represented by a homogeneous equilibrium model. Five modes of heat transfer are available to calculate the primary to secondary heat transfer. This model has been used to simulate the initial phase of the Three Mile Island event and the results agree reasonably well with the data.

Other modifications that have been implemented in the IRT code include the following:

- Reactor upper head region representation
- Metal heat capacity modelling
- Pressurizer level swell model
- Steam generator tube rupture model
- Decay heat for finite reactor operation
- Accumulator modelling

In addition to the analysis of the TMI event, the IRT code has also been used to analyze the effects of several plant modifications proposed by B&W to mitigate the effects of a TMI type event and to analyze an overfeed transient for a typical B&W plant design. For plant transient analysis of reactors with a U-tube steam generator design, IRT has recently been used to analyze steamline break (with concurrent tube rupture) transients, loss of flow transients and turbine trip transients. Future work includes the analysis of a number of operational transients (assuming concurrent tube rupture) for reactor designs with the once-through and U-tube steam generator designs.

IRT CODE MODIFICATION AND
APPLICATION TO PWR TRANSIENT ANALYSIS

1603 329

IRT CODE FEATURES

- PLANT TRANSIENT CODE FOR ANALYSIS OF PWRs
- ORIGINATED FROM COMBUSTION ENGINEERING
CESEC CODE
- APPLICABLE TO MANY NON-LOCA PLANT TRANSIENT
CALCULATIONS
- 17 FIXED PRIMARY SYSTEM NODES
- ONCE-THROUGH AND U-TUBE STEAM GENERATOR
· MODELLING


1603 330

IRT ASSUMPTIONS

- CONSERVES MASS AND ENERGY
- PUMP FLOW RATE USER SPECIFIED
(NO CONSERVATION OF MOMENTUM)
- HOMOGENEOUS EQUILIBRIUM MODEL FOR
PRIMARY SYSTEM
- NON-EQUILIBRIUM PRESSURIZER MODEL
- UNIFORM PRIMARY SYSTEM PRESSURE

1603 131

IRT PRIMARY SYSTEM NODALIZATION



1603 332

PRESSURIZER MODELLING ASSUMPTIONS

- COMPLETE PHASE SEPARATION
 - HOMOGENEOUS PHASES
 - STEAM: SATURATED OR SUPERHEATED
 - WATER: SATURATED OR SUBCOOLED

- MASS AND ENERGY TRANSPORT ACROSS INTERFACE
 - INSTANTANEOUS BUBBLE RISE OR DROPLET FALL
 - BULK BOILING OR BULK CONDENSATION
 - INTERFACE SURFACE EVAPORATION AND
CONDENSATION NEGLECTED

1603 333

PRESSURIZER MODES OF OPERATION

STEAM REGION

WATER REGION

SUPERHEATED

SUBCOOLED

SUPERHEATED

SATURATED

SATURATED

SUBCOOLED

SATURATED

SATURATED

SUPERHEATED

EMPTY

SATURATED

EMPTY

EMPTY

SUBCOOLED

EMPTY

SATURATED

1603 334

1603 334

ADDITIONAL IRT FEATURES

- METAL HEAT CAPACITY
- PLAN. PROTECTION SYSTEM
- SAFETY INJECTION SYSTEM
- ACCUMULATOR MODEL
- STEAM GENERATOR TUBE RUPTURE MODEL
- DNB CALCULATIONS
- TWO PHASE CORE HEAT TRANSFER
- DECAY HEAT FOR FINITE REACTOR OPERATION
- PRESSURIZER LEVEL SWELL MODEL

1603 335

IRT U-TUBE STEAM GENERATOR SECONDARY SIDE MODEL

- FOUR FIXED NODES
 - DOWNCOMER (SEPARATED LIQUID AND VAPOR)
 - TUBE REGION (VAPOR LIQUID MIXTURE)
 - RISER (VAPOR LIQUID MIXTURE)
 - STEAM DOME (ALL VAPOR)

- ALL REGIONS AT SATURATED CONDITIONS

- ADDITIONAL SYSTEMS MODELLED
 - STEAM DUMP
 - STEAM BYPASS
 - STEAM GENERATOR RELIEF VALVES

1603 336

IRT ONCE-THROUGH STEAM GENERATOR MODEL

MOD-1

TUBE REGION

12 FIXED NODES

CONSERVATION OF MASS AND ENERGY

HOMOGENEOUS EQUILIBRIUM MODEL

DOWNCOMER

SINGLE NODE

HOMOGENEOUS EQUILIBRIUM MODEL

AUXILIARY FEEDWATER

DISTRIBUTED OVER SUPERHEATED
NODES IN TUBE REGION

STEAM GENERATOR TUBE RUPTURE MODEL

UNIFORM SECONDARY SIDE PRESSURE

1603 337

MOD-2

TUBE REGION

FOUR REGIONS (TWO MOVING BOUNDARIES)

TWO FIXED BOUNDARIES AT LOCATION OF
TUBE RUPTURE AND ASPIRATOR FLOW

MOVING BOUNDARIES DIVIDE LIQUID AND
VAPOR REGIONS FROM TWO PHASE REGION

HOMOGENEOUS EQUILIBRIUM MODEL

SAME DOWNCOMER MODEL AS MOD-1

1603 339

TYPICAL TRANSIENTS FOR B&W DESIGN

- TMI LOSS OF FEEDWATER EVENT
- STEAM GENERATOR OVERFEED TRANSIENT
- EVALUATION OF PROPOSED B&W DESIGN CHANGES
- OPERATIONAL TRANSIENTS WITH CONCURRENT STEAM GENERATOR TUBE RUPTURE

1603 340

TYPICAL TRANSIENTS FOR U-TUBE
STEAM GENERATOR PLANT DESIGN

- STEAMLINER BREAK
- LOAD REJECTION
- CONTROL ROD WITHDRAWAL
- LOSS OF FLOW
- FEEDLINE BREAK
- ANTICIPATED TRANSIENTS WITHOUT SCRAM (ATWS)
- STEAM GENERATOR TUBE RUPTURE
- OPERATIONAL TRANSIENTS WITH CONCURRENT
STEAM GENERATOR TUBE RUPTURE

048 2001

1603 341

TYPICAL RESULTS

- ONCE-THROUGH STEAM GENERATOR MODEL
TMI LOSS OF FEEDWATER EVENT

- U-TUBE STEAM GENERATOR MODEL

STEAMLINE BREAK

FULL POWER ROD WITHDRAWAL

LOSS OF MAIN COOLANT FLOW


LOSS OF EXTERNAL LOAD

1603 342

1603 342

FIGURE 1: TMI LOSS OF FEEDWATER TRANSIENT

PRESSURIZER PRESSURE VS TIME



1603 343

07/16/79

FIGURE 2: TMI LOSS OF FEEDWATER TRANSIENT
PRESSURIZER LEVEL VS. TIME





FIGURE 3: TMI LOSS OF FEEDWATER TRANSIENT

Comparison of TMI-2 Data with IRT OTSG Calculation



POOR ORIGINAL.


APP 30081

1603 345

142 2001
POOR ORIGINAL


1603 346

TMI A-1
COOLANT TEMPERATURES VS TIME



07/16/79

PWR U-TUBE STEAM GENERATOR
STEAMLINE BREAK TRANSIENTS



COMPARISON OF IRT RESULTS WITH AVAILABLE FSAR RESULTS

	<u>IRT RESULTS</u>	<u>FSAR RESULTS</u>
FULL POWER ROD WITHDRAWAL TRANSIENT		
PEAK REACTOR POWER	109.3%	110. %
TIME OF PEAK REACTOR POWER	37 SECS	38 SECS
PEAK PRESSURIZER PRESSURE	1.6347×10^7 PASCALS	1.6207×10^7 PASCALS
TIME OF PEAK PRESSURIZER PRESSURE	43 SECS	42 SECS
LOSS OF MAIN COOLANT FLOW		
1. FOUR PUMP LOSS OF FLOW		
MINIMUM DNBR	1.55	1.55
TIME OF MINIMUM DNBR	10.1 SECS	10.5 SECS
2. ONE PUMP LOSS OF FLOW		
MINIMUM DNBR	1.52	1.45
TIME OF MINIMUM DNBR	4.9 SECS	5.8 SECS

COMPARISON OF IRT RESULTS WITH AVAILABLE FSAR RESULTS

	<u>IRT RESULTS</u>	<u>FSAR RESULTS</u>
LOSS OF EXTERNAL LOAD		
HIGH PRESSURE SCRAM SETPOINT	1.6694 x 10 ⁷ PASCALS	1.6694 x 10 ⁷ PASCALS
TIME OF SCRAM	8.7 SECS	7.0 SECS
PEAK REACTOR POWER	104.7%	106.0%
TIME OF PEAK POWER	8.8 SECS	8.0 SECS
PEAK PRESSURIZER PRESSURE	1.74458 x 10 ⁷ PASCALS	1.7232 x 10 ⁷ PASCALS
TIME OF PEAK PRESSURIZER PRESSURE	11.0 SECS	9.1 SECS
PEAK STEAM GENERATOR PRESSURE	.71582 x 10 ⁷ PASCALS	.71479 x 10 ⁷ PASCALS
TIME OF PEAK STEAM GENERATOR PRESSURE	15. SECS	12. SECS

1803 2081