

NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

IN THE MATTER OF:

SPECIAL MEETING

Place - Washington, D. C.

Date - Monday, 16 April 1979

Pages 1-334

Telephone:
(202) 347-3700

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capitol Street
Washington, D.C. 20001

NATIONWIDE COVERAGE - DAILY

67-007

7904230171

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

PUBLIC NOTICE BY THE
UNITED STATES NUCLEAR REGULATORY COMMISSION'S
ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

April 16, 1979

The contents of this stenographic transcript of the proceedings of the United States Nuclear Regulatory Commission's Advisory Committee on Reactor Safeguards (ACRS), as reported herein, is an uncorrected record of the discussions recorded at the meeting held on the above date.

No member of the ACRS Staff and no participant at this meeting accepts any responsibility for errors or inaccuracies of statement or data contained in this transcript.

1 UNITED STATES OF AMERICA
2 NUCLEAR REGULATORY COMMISSION
3 Advisory Committee on Reactor Safeguards
4
5

6 Special Meeting
7

8
9 Room 1046, 1717 H Street, N.W.,
10 Washington, D.C.

11 Monday, 16 April 1979

12 The Special Meeting was called to order at
13 8:30 a.m., Dr. Max W. Carbon presiding.

14 PRESENT:

15 Dr. Max W. Carbon, Chairman
16 Dr. Milton S. Plesset
17 Mr. Harold Etherington
18 Prof. William Kerr
19 Dr. Stephen Lawroski
20 Mr. William M. Mathis
21 Dr. David Okrent
22 Mr. Jeremiah J. Ray,
23 Dr. Paul G. Shewmon
24 Dr. Chester P. Siess

25 Also Present:

Raymond F. Fraley, Designated Federal Employee
James F. Jacobs

wb

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

C O N T E N T S

		3
	Presentation by NRC-Staff	3
	Dr. Mattson	3
	Mr. Varga	9
	Mr. Tedesco	50
	Executive Session:	
	Reports on current status of TMI-2	94
	Mr. Etherington	94
	Mr. Michaelson	107
	Dr. Catton	156
	Dr. Lawroski	168
	Mr. Ray	172

P R O C E E D I N G S

DR. CARBON: The meeting will now come to order.

This is a special meeting of the Advisory Committee on Reactor Safeguards to further consider the events surrounding the reactor accident at Three Mile Island Nuclear Station. The Committee will discuss this matter with the NRC Staff of the Nuclear Regulatory Commission.

This meeting is being conducted in accordance with the provisions of the Federal Advisory Committee Act and the Government in the Sunshine Act. Mr. Raymond Fraley is the designated Federal Employee for this portion of the meeting.

A transcript of portions of this meeting will be kept and it is requested that each speaker first identify himself and speak with sufficient clarity and volume so that he can be readily heard.

I now call on the Nuclear Regulatory Staff for our initial session, and call on Mr. Roger Mattson.

DR. OKRENT: Could I ask one question? Do you have any public participation? Have we any requests?

DR. CARBON: None.

DR. OKRENT: The reason I asked is Sunday in the Los Angeles Times there was an advertisement of the Union of Concerned Scientists which spoke concerning five nuclear reactors. All of these plants have nuclear reactors and equipment designed by the firm of Babcock and Wilcox, the firm that designed the

eb2

1 Three Mile Island Plant. "Will they then contain the same basic
2 design flaws and have the safety conditions that led to the
3 near tragedy at Three Mile Island," et cetera.

4 Then in California there was some kind of a hearing
5 of one of the legislative committees, and Mr. Pollard of the
6 Union of Concerned Scientists testified, and according to the
7 newspapers stated, for example, that "If I had been the operator,
8 I would have shut them off," end of quote, meaning the pumps
9 and so forth.

10 I thought, at least from my own point of view, I
11 would be interested in understanding in detail what is behind
12 these statements so that I would have a better picture, maybe
13 a chance to ask questions, as to why these opinions were held
14 so I could see whether there was some basis that we were not
15 aware of, and so forth.

16 Is there any way that we would be able to get a
17 technical discussion on this?

18 DR. CARBON: I should think we could ask them to
19 come and meet with us.

20 DR. OKRENT: I believe they're located in Washington.
21 I mean, among other things, I for one would like to understand
22 what they judge to be the risk for the existing situation, how
23 they quantify it, how this compares with other similar things
24 in other similar technologies, and so forth.

25 So for me at least it would be useful if I had a

eb3

1 chance to explore this with them.

2 DR. CARBON: I would think, if the other members are
3 agreeable, we'll simply ask them to come, perhaps at our May
4 meeting if this seems reasonable.

5 Let's move on then, and let me call on Mr. Mattson.

6 MR. MATTSON: Mr. Chairman, I would like to spend a
7 few minutes at the start to describe who is going to be speak-
8 ing to what portion of the problem here today.

9 For one thing, because we have a number of people
10 still at the site, some of the folks that you'll hear from
11 today are wearing somewhat different hats than they usually
12 wear when they're down here speaking to you, and for that
13 reason I think it would be good to go through the various roles
14 that are being played in a managerial sense, and then the scope
15 of the various presentations that you'll hear.

16 Steve Varga will speak to you first this morning
17 about what we call the immediate or on-going actions connected
18 with the bulletins to the other operating B&W plants. The scope
19 of his work, and the people who are reporting to him at this
20 juncture is rather narrow. And let me state that scope if I
21 can.

22 It's the immediate, on-going work involved with the
23 bulletins primarily intended to assure that the transients that
24 occurred at Three Mile Island and subsequent accident are not
25 repeated in that way in the near term with other operating B&W

4
1 plants.

2 Following right behind Steve Barga will be Bob
3 Tedesco who will be down a little bit later this morning. Bob
4 has a task force that he is heading with a number of Branch
5 Chiefs and senior technical staff reporting to him. His scope
6 is a bit broader. It covers short-term actions and long-term
7 actions, looking at feedwater transients in the B&W plants and
8 then somewhat broader to feedwater transients in pressurized
9 water reactors where the short-term goal is, one, to confirm
10 that the immediate actions taken through the bulletins are
11 indeed sufficient for the immediate near-term and if not, to
12 propose or recommend additional things that might be done in
13 the near term to continue to assure public health and safety
14 and then lay forth a plan for further actions over somewhat
15 longer term of the nature of re-analysis of operator actions,
16 licensing basis for transients and small loss-of-coolant acci-
17 dents, and possible design changes for B&W plants or pressurized
18 water reactors flowing from this experience.

19 I should caution that a lot of what you'll be hear-
20 ing today and a lot of questions that you'll be asking today
21 will fall in the area of on-going work. We may not have com-
22 plete answers to all your questions. People are working hard.
23 I think it is safe to say that the majority of the Staff are
24 turned to this problem at this point in time. We'll do our best
25 to answer your questions to the best of our current knowledge,

1 but it is clear to me that we won't be able to answer all of
2 them. But that's one of the reasons we're here, is to look for
3 constructive suggestions as to where we go from here.

4 As I understand it, those two presentations are the
5 extent of the Staff participation this morning, other than we
6 will stay and listen to the B&W things this afternoon, and the
7 Committee reports this morning.

8 Later this afternoon, starting, as my agenda reads,
9 at about 5:30, we'll go into several other areas.

10 First, Vic Benaroya will give us a summary of the
11 current status of the plant, updated through today.

12 Then Carl Berlinger will summarize the activities
13 on-going at the site, and in design shops at various places,
14 aimed at hardware modifications and contingency plans and what-
15 have-you, for moving the reactor into, as the media calls it,
16 the cold shutdown condition. That's a little bit different use
17 of the word than we're used to but let me say that that has to
18 do with the long-term cooling plans for the reactor as it exists
19 today.

20 We're prepared to speak to contingency plans in
21 general later on this afternoon and early evening at your con-
22 venience. Whether you want to talk about emergency procedures
23 that exist in the plant today for various contingencies or
24 contingencies on out into the future wasn't quite clear from
25 the agenda we had, so we're generally prepared to discuss those

1 things with you later.

2 With that introduction I guess I'm ready to turn it
3 over to Steve Barga, unless you have front-end questions this
4 morning about the status of the plant.

5 I returned last night about seven o'clock and maybe
6 I'm as fresh on that as anybody on the Staff side this morning.
7 If there are questions on the status now, rather than wait
8 until later this afternoon when we planned to get at it, maybe
9 we can have those questions.

10 Basically it's doing what it has been doing for the
11 last couple of weeks, and operations are stable and a lot of
12 work is going on to get the long-term cooling equipment in
13 place.

14 DR. CARBON: Let's leave that and go on to the
15 presentation.

16 MR. VARGA: Good morning. My name is Steve Varga,
17 with the Division of Project Management.

18 Normally, from my pleasant past relationships with
19 this Committee when I had another job at NRC, and from my
20 continuing respect for this Committee, I would say I'm happy to
21 be here. But I recognize the urgency of the particular in-
22 terest that you all have and, while my group is busy back there
23 working diligently I'm here to answer whatever questions you
24 may have after my presentation, recognizing that we're deep in
25 the midst of this particular review, and that all of the answers

67-016

1 are not currently available nor probably yet developed.

2 As Roger indicated, my particular task and the group
3 that I have reviewing the Bulletins 7905 and then that was
4 amended by or supplemented by 7905-A. I think it's important
5 to recognize the time frame and the intent of the bulletins
6 that were published at that time, April 1st, and then I believe
7 supplemented by April the 5th, based upon the information that
8 was available then and the perception of the prudent course of
9 action that appeared necessary in informing all the other B&W
10 plants.

11 As things progressed of course additional bulletins
12 are being prepared or have been prepared. I myself have not
13 seen them all, but they have been prepared and probably there
14 will be some discussion about those additional bulletins that
15 are being issued or have been issued that pertain to other
16 PWRs, and perhaps also to the BWRs. And I imagine that this
17 process and evaluation, as we get further and further into the
18 details in our own evaluation, will probably continue.

19 So I'm going to address particularly the response
20 to 05-A which essentially, although clarified, really replaced
21 05, and as Roger characterized it, is in the time frame of
22 immediate action or immediate response, as contrasted to short
23 term, and then the long-term activities underway.

24 As you recall in the Bulletin 05-A, there were about
25 12 or 13 items requiring response. In a sequential time frame,

67-017

ab7

140

1 Items 1, 2, 3, 4-A and 5 were required to be responded to by
2 the Licensees by April 11th. The remaining responses are due
3 today. We received the majority of those responses Thursday,
4 and the last one we got Friday morning, I believe. And we are
5 busy reviewing that and have been reviewing those responses
6 over the weekend.

7 So I will confine my remarks for the moment for
8 today to those responses that we have received as a result of
9 the due date of April 11th. In one or two instances there were
10 additional responses to some of the other items. Although we
11 have looked at those, we wanted to get a fairly rapid cut
12 across all the responses to those that were due on the 11th in
13 order to get as quickly as possible a perception of those res-
14 ponses.

15 We will continue as we get the responses today and
16 continue throughout the week in reviewing all of the responses
17 to 05-A.

18 Review priority. It's fairly simple. Those that
19 are operating are the ones we're reviewing. Those are at
20 Rancho Seco, Oconee 1, 2, and 3, and Crystal River. Davis-
21 Besse and ANO-1 as you know are down and we're getting some
22 up-to-date late information on what their plans are for re-
23 start.

24 We anticipate that we'll be able to finish the review
25 of these initial responses to five of the items late tomorrow.

1.180

Federal Reporters, Inc.

67-018

1 If the responses come in as we hope they will and we get copies
2 of them immediately, which I don't believe will be a problem,
3 we hope to finish our review of all the responses by Friday.

4 Let me give you a perception of, or at least the
5 structure of the review, what we're doing.

6 As is evident from reading the bulletin in its total
7 context, the thrust is to be sure the Licensees understood the
8 import of the event that happened at TMI 2, and throughout the
9 bulletin you will see words in there about procedures and under-
10 standing the particular events, and the Licensee's awareness
11 of the consequences of certain particular actions that have
12 occurred.

13 In our review we have identified and are identifying
14 some additional information that we believe may be required,
15 as well as we are also identifying or highlighting some clari-
16 fication that, as a result of the on-going evaluation, we have
17 identified in subsequent bulletins. So we're factoring that
18 into the review of this bulletin as appropriate in the responses
19 that we are reviewing and in our evaluation.

20 We are also reviewing the response of the Applicant
21 to Item 2 which was to review the transients that have occurred
22 at this facility, particularly those transients where the
23 performance deviated from expected performance. In one or two
24 instances we have identified transients, or events probably may
25 be a better word, that the Applicant, although he had notified

1 us in other documentation, did not emphasize or did not point
2 this out in his response. Whether this is an oversight or not,
3 we are looking into that. But there are only one or two
4 instances that we've identified so far.

5 Based upon our review to date, let me summarize
6 generally our perception of the over-all answers to those five
7 items.

8 Now let me just briefly go over those five items.

9 First it said-- And attached to the bulletin of
10 course were the preliminary notifications that went on through
11 I think to April 1st, issued by NRC, which, on a day-to-day
12 basis, outlined the particular activities that had occurred
13 that day, and gave a description of those events. All of those
14 preliminary notifications accompanied the bulletin.

15 In the bulletin as well there was, in this item
16 there was a delineation of certain highlighting of certain
17 particular actions that had occurred, and bringing those --
18 emphasizing those in the bulletin in order that the responses
19 also would be pointed or focused on those particular activities.
20 That's item one.

21 Item two then was to review other transients or
22 events in your facility with that item one scenario in mind,
23 the TMI 2 event scenarios. In addition, he was to report to us
24 whether any of these transients or events deviated from expected
25 performance.

1 The third of course was the actions for operating
2 procedures for coping with particular transients. And in this
3 particular item there was a highlight on the voiding that had
4 occurred in the TMI 2 incident, addressed to the prevention and
5 recognition of such voids.

6 Item four was a four-tiered item which had to do with
7 overriding engineered safety features.

8 The second part particularly emphasized the HPI
9 activities and concerns. The third part emphasized the reactor
10 coolant pump operational status. And the four part emphasized
11 the reliance only on level indication in the pressurizer. And
12 then, five, item five, emphasized or described or related it to
13 the closed valves. It requested verification of valve lineup,
14 review of all the procedures, all the Class E equipment, valve
15 equipment, emphasized the maintenance and training and sur-
16 veillance and testing procedures that are related to maintenance
17 -- to the operation of the plant wherein certain activities
18 associated with the maintenance of certain valves and the inter-
19 relationships and the operational activities that are going on
20 perhaps concurrently.

21 The other items along the bulletin, five through
22 twelve, emphasized further the specific parts of various se-
23 quences with particular emphasis on containment, particular
24 emphasis on the auxiliary feedwater trains, and items related
25 to the over-all scenario.

12
1 So let me give you a perception of the review we
2 have done to date of those five items, taking each particular
3 response as a whole.

4 We believe the Applicants have understood what we
5 were after. I believe their responses indicate an awareness
6 and understanding and the promptness of the review that was re-
7 quired. In several instances the responses indicated that
8 prior to the receipt of the bulletin they had already initiated
9 reviews of this particular transient.

10 Let me take a typical response and go through in
11 some general detail and summarize to you what our current per-
12 ception is of that particular response, recognizing that this
13 is still in the process of review and additional expertise being
14 used to evaluate some parts of it.

15 In the item one, most of the responses essentially
16 tracked the six statements or description of circumstances
17 that accompanied the bulletin regarding item one. As you recall,
18 those six statements of circumstances had to do with one, loss
19 of feedwater, then the circumstances around the relief valve,
20 then the erroneous level indication, then the discharge to the
21 containment, then the recirc pump problem and, finally, the --
22 no, five was the voiding in the core, and then the tripping
23 of the reactor coolant pumps.

24 So essentially the responses tracked those particu-
25 lar items and responded to those, recognizing in some instances

b13

1 that further response will be forthcoming when they answer
2 six, seven, eight, nine, and so forth.

3 But, however, in our review of the responses of this
4 one response, typical response, there was some question we had
5 about the depth of the level that these reviews -- of the
6 operating personnel and personnel and the management of the
7 utility itself who had participated.

8 So while we do find in general a satisfactory under-
9 standing of the sequence of events and the relationship to the
10 facility, we are, in order to assure that all the appropriate
11 levels have participated, we're going to require that all
12 licensed operators and plant managers and supervisors with
13 operational responsibilities participate in that review, and
14 that that be indicated in the plant records.

15 Concerning the electromagnetic relief valve in this
16 particular response, there was a discussion about the indication
17 that could be given as to the status of that valve by the
18 temperature indicator. We believe that that temperature monitor
19 may not be a valid indication of the relief valve status, parti-
20 cularly after some initial operation and that other parameters
21 such as the discharge relief tank temperature, pressure, or
22 level, in conjunction with that temperature monitor, could
23 assist in the status of the ERV.

24 Consequently, there were other instruction and pro-
25 cedures that we believe that could be given to the operators

1.300

67-023

b14

1 concerning the ERV which have been identified in these subse-
2 quent bulletins that have been provided in the last few days
3 to the other operating PWRs, and which we have picked up and
4 are going to require that they be addressed as well.

5 That has to do with identifying those plant indica-
6 tions such as valve discharge piping temperature, valve position
7 indication or valve discharge relief tank temperature, pressure,
8 or level indication which plant operators may utilize to deter-
9 mine that the pressurized power-operated relief valves are open.

316

10 And then also in our review of this particular res-
11 ponse there was no mention of the block or isolation valve on
12 that pressurizer, and the additional instructions or the addi-
13 tional directions and requirements given to the operators,
14 direct plant operators to manually close the power-operated relief
15 block valves when reactor coolant system pressure is reduced to
16 below the set points for normal automatic closure of the power-
17 operated relief valves and the valves remain stuck open.

18 In our review of the responses I believe only one
19 clear indication in the response indicated that the relief --
20 the block valve -- the isolation valve was there and what its
21 function could be used for, and the recognition that in this
22 event that that could be used. However, it was not emphasized
23 or highlighted in the other, so that's the reason for this
24 particular one.

A eral Reporters, Inc.

25

In the responses throughout where we have requested

67-024

5
1 operating procedures there are generalized statements about the
2 procedures, that these have been reviewed. In one or two in-
3 stances the specific procedures that were reviewed have been
4 listed and outlined.

5 We believe that in order to assure that there is no
6 inadvertent omission, we believe that we need certification
7 that all procedures have been reviewed, and then we would like
8 a listing of those procedures, particularly those procedures
9 that have been revised as a result of this review.

b
10 That also applies not only to operating instructions,
11 but also to operating procedures, maintenance procedures,
12 surveillance procedures, or operator training instructions.

13 In several places in the-- In fact, I think in all
14 of the responses there was a statement about additional aids
15 to the operator in the tracking of these events, aids provided
16 to him in the normal course of his operations, the pressure-
17 temperature saturation curves, for instance. Other aids are
18 mentioned.

19 We would like to have a definition of those aids,
20 a description of those aids, and where in the operating proce-
21 dures they occur or are mentioned or are alluded to or defined.

22 The concern-- Statement four of the first concern
23 had to do with the containment isolation of the pumping of
24 radioactive fluids out of the containment.

25 PROF. KERR: Excuse me. It isn't clear to me whether

67-025

16
1 you're describing something that you have as the result of the
2 response or something that, in the main, you do not have, these
3 things to which you refer, for example, the pressure saturation
4 curve.

5 Are you saying that these are things which even-
6 tually you expect to get from Licensees but you do not yet
7 have, or....

8 MR. VARGA: We do not have. The Licensees mentioned
9 that in response to -- particularly to voiding prevention or
10 recognition of voiding in the curve, the response indicates
11 that these pressure-temperature curves will be provided to the
12 operator for his input.

13 Of concern, beside the technical accuracy of those
14 particular curves, which we do not have and my group has not
15 reviewed and will probably be reviewed in the normal context
16 of the review that the I&E inspector makes of the particular
17 procedures, but what we're concerned about is that these aids
18 be properly identified and, rather than being perhaps in some
19 computer printout that may take some time to be defined, that
20 he has them readily available.

21 PROF. KERR: It strikes me that you're developing
22 rather detailed criteria for those things that you want to have
23 available. It seems to me that if that is the case that you
24 would save everybody time by letting the Licensee know what it
25 is you expect them to have available.

67-026

17
1 MR. VARGA: Well, certainly as the evaluation pro-
2 ceeds, as we get through the immediate actions and then the
3 short-term actions, as we develop additional information and
4 additional criteria from the work that we have on-going, we may
5 have some specific things that we direct the operators have
6 available.

7 The assumption is at the moment that pressure-tem-
8 perature curves are universally accurate if they are prepared
9 properly and that certainly is an indication of the status of
10 the reactor system fluid, and that these be provided to the
11 operator.

12 We did not direct. We just indicated the problems
13 with the voiding in the core, and it was the response of the
14 utilities that said this is one way in which the operator will
15 know the status.

16 Now there may be others.

17 I mentioned the problem with one in the bulletin
18 concerned the pumping of radioactive fluids out of the contain-
19 ment. In this particular review, the containment isolated both
20 on containment high pressure for psi, as well as on the low
21 pressure for the reactor coolant system pressure, so that either
22 one would have isolated the containment in this particular re-
23 view. That of course is not universal in the B&W facilities
24 that we are reviewing in the five. Only one other I believe
25 has that provision for isolation, either on containment pressure

1 or on safety injection or below reactor system pressure of
2 around 1600 psi, and we're looking at those responses.

3 In the bulletins and in the additional instructions
4 that we are preparing, particularly in response to that number
5 six which addresses containment isolation, we are going to be
6 looking carefully to see what other provisions are being made
7 for containment isolation.

8 The last item on item six -- not the last item but
9 statement four of item one --

10 PROF. KERR: Excuse me. Does "looking carefully"
11 mean that you havenot yet decided what should isolate contain-
12 ment but that after you've had a chance to give it some thought
13 you may develop criteria? I'm not sure what is the signifi-
14 cance of "looking carefully."

15 MR. VARGA: In the response to the bulletins and in
16 the bulletins themselves, particularly the ones that are -- that
17 followed 05, there is a statement in there about isolating the
18 pressure upon -- "review containment isolation, initiation
19 design procedures, and prepare and implement all changes neces-
20 sary to permit containment isolation, whether manual or auto-
21 matic, of all lines whose isolation does not degrade needed
22 safety features nor cooling capability upon automatic initia-
23 tion of safety injection."

24 So that's the instruction and the requirement that
25 we are implementing in the responses to the Applicants'

67-028

eb19

1 responses -- the Licensees' responses that we have to date.

2 So we are requiring that they review their contain-
3 ment isolation provisions and, upon automatic initiation,
4 implement the changes that are necessary to effect that.

5 DR. SHEWMON: Isolation containment sounds like a
6 good thing and comforting. I'm some concerned as to whether
7 or not-- It is well-defined, agreed-upon, and unambiguous,
8 just what should get isolated and what shouldn't get isolated
9 so we have all the safety functions we need but don't end up
10 doing things we shouldn't do?

11 MR. VARGA: Well, the thrust of the particular added
12 clarification of requirements that we are laying on recognizes,
13 for instance, reactor coolant pump seal, blower component, and
14 cooling water, which in some instances requires -- is isolated
15 upon containment isolation.

16 The instruction we are giving is to review and
17 implement those changes, that if you will degrade the safety
18 features or cooling capability by that particular isolation,
19 that you not do that.

20 Now, the particular specific lines and the specific
21 fluids that we're talking about we have not identified. We
22 are asking the Applicants to identify that, although in our
23 review, in our on-going review, that is certainly one of our
24 very critical points we're looking at.

eral Reporters, Inc.

25 DR. SHEWMON: And presumably that was all spelled out

67-029

1 and agreed to once in the FSAR?

2 MR. VARGA: Yes, indeed.

3 DR. SHEWMON: Okay.

4 MR. MATTSON: If I could interrupt just to make sure
5 that I understand the point and that we have communicated,
6 containment isolation provisions flowed from other considera-
7 tions besides the TMI accident. Now, given the TMI accident
8 and the sequence of events, have we learned something about
9 containment isolation initiation and what gets isolated that
10 ought to be changed in the near term at these other operating
11 B&W plants?

12 I think that's the focus of what Steve is looking at
13 in these bulletin responses.

14 DR. SHEWMON: And what gets isolated is independent
15 of what signal sets it off? Is that correct? Or what acci-
16 dent you think you want to protect yourself from?

17 MR. MATTSON: That's generally the situation today;
18 that's right.

19 DR. SHEWMON: And the operator can override some
20 of those individually if he feels it is to his best advantage,
21 or he can't? It seems to me that's a two-edged sword either
22 way.

23 MR. MATTSON: Well, he can't. He can't, of course.
24 It requires varying degrees of action, depending on which one
25 he's overriding, but that's part of what we're looking at:

67-030

Feb 21

1 Does he have time to override it if he needs to over-
2 ride it? Was it right to close all the same things, no matter
3 what the source of the containment isolation signal, and so on?

4 DR. SHEWMON: Thank you.

5 MR. VARGA: In the last statement of item one, which
6 had to do with the reactor coolant pump, in the review of this
7 particular response there were words indicating that procedures
8 will be reviewed so to preclude premature termination of the
9 reactor coolant pump. And that is not our intent for that
10 judgment to be made except under very specifically defined
11 circumstances.

12 So we are providing a clarification, which is a
13 point made in the subsequent bulletins that has to do with the
14 requirement that at least one reactor coolant pump per loop
15 shall remain operating as long as it's providing forced flow.

16 Finally, there was one item, an item we are request-
17 ing the Applicant to respond to which was not indicated specifi-
18 cally in the bulletin but it had to do with the operated modes
19 and procedures dealing with hydrogen that may be generated
20 during the transient, and that would remain either inside the
21 primary system or released to the containment.

22 Now we're asking them to review with the same in-
23 tent and the same focus and attention as the others. We're
24 asking them to review particularly the release of -- review his
25 procedures and modes of operation about dealing with hydrogen

22 1 either in the core or the containment.

2 DR. OKRENT: What do you have in mind for him to
3 review in that regard?

4 MR. VARGA: Well, first and foremost, at least in
5 my perception of the events that have transpired, is the loca-
6 tion, the access, the operability of the hydrogen recombiner,
7 it seems to me, would be a very important item to review,
8 review it in the circumstances of highly radioactive gas being
9 taken from the containment to the recombiner if it is outside
10 the containment or, if it is inside the containment, what the
11 procedures are for protection.

12 Another item would be the instrumentation to indi-
13 cate the evolution of hydrogen within the containment,
14 specifically redundancy, the location of the instrumentation,
15 items of that nature.

16 DR. OKRENT: Do you feel that the location and
17 availability of the recombiner is the major consideration with
18 regard to safety questions that would arise out of the genera-
19 tion of hydrogen?

20 MR. VARGA: Let me see if I understand your question.

21 DR. OKRENT: When I asked you about hydrogen, the
22 first thing you mentioned was the recombiner.

23 MR. VARGA: Right. That was the first thing, one
24 of the things, yes.

25 DR. OKRENT: And I'm asking whether, if you have a

67-032

23
1 real safety question connected with the generation of hydrogen,
2 whether you think it's the recombiner that's going to play a
3 vital role, or whether there are other questions that will be
4 important prior to it. In fact, if the recombiner is going to
5 be very important, other things will have arisen earlier.

6 MR. VARGA: Certainly. For instance, the general
7 question of hydrogen recombination, particularly in the primary
8 system, is the question of the venting and whether or not
9 procedures or means should be provided to vent the hydrogen
10 from the primary system.

11 Then, when it's vented to the containment you have
12 the problem of measuring what the level of hydrogen is and,
13 particularly, moving that hydrogen.

14 Now it's not clear to me, and I do not know, although
15 I'm sure there is someone here who may, how one measures the
16 hydrogen content in the primary system itself. Certainly from
17 the fluid sample you would be able to get the dissolved hydro-
18 gen. It's not clear to me how you would ascertain particularly
19 the amount of hydrogen in the system itself.

20 MR. MATTSON: May I interrupt? I'm not sure when
21 we got started on this track.

22 Dr. Okrent, could you rephrase what your basic
23 interest is in hydrogen, so we can get closer back to your ques-
24 tion?

25 DR. OKRENT: Sure. I'm reading something dated

67-003

eb24

1 April 13, 1979, from Mr. Moseley to a variety of people. And
2 item 12 says: "Review operating modes and procedures to deal
3 with significant amounts of hydrogen gas that may be generated
4 during a transient or other accident that would either remain
5 inside the primary system or be released to the containment."

6 I asked Mr. Varga, who brought up the subject of
7 hydrogen just a moment ago, what the Staff's interest was, what
8 they expected from the Applicant with regard to that question.
9 And the first thing he mentioned was the availability of the
10 recombiner, and frankly, that strikes me as not being the thing
11 I'd be most interested in if I were really concerned about the
12 generation of hydrogen, not that it is insignificant, but it
13 is not where my primary interest arises.

14 In fact,-- Well, so I'm trying to ascertain just
15 what the Staff has in mind.

16 Don't misunderstand me. I'm not saying you shouldn't
17 be interested in the hydrogen.

18 MR. ROSS: To give the specific reference to what
19 Dr. Okrent may be referring to, it's either I&E Bulletin 7906-A
20 or 06-B. I think they're both the same in this respect.

21 During the preparation of those bulletins we dis-
22 cussed a number of things along the line you're talking about
23 with respect to hydrogen gas. I don't think our list is parti-
24 cularly complete at this time, and we wanted the Licensee to
25 respond.

b25
1 But we did discuss, for example, on the recombiner,
2 the need to add shielding that wasn't otherwise provided. This
3 would be by way of an operating procedure, had this been con-
4 sidered. It had to be supplemented on an ad hoc basis at the
5 Island.

6 We also had a number of --

7 DR. SHEWMON: Shielding what?

8 MR. ROSS: The recombiner itself.

9 DR. SHEWMON: So you could get at it and do main-
10 tenance?

11 MR. ROSS: Yes. And in particular, another recom-
12 biner was plumbed in and there was concern at being able to
13 maintain the -- at other sampling valves and so on.

14 There was some speculation as to the response time
15 of the reactor building pressure transducers, to what extent
16 did they follow the spike that was observed around ten hours
17 and how would this correlate to a true response. In the first
18 few days of the event at TMI there was a question about strati-
19 fication and the extent to which the fan coolers would or would
20 not mix hydrogen, and were we getting stratification at the
21 top, and to what extent the sampling lines where you sampled
22 the reactor building hydrogen gas content represented a reason-
23 able sample of the reactor building.

24 As a corollary to that, during the TMI sequence
25 the waste gas decay tank was vented -- plural, tanks -- were

67-035

26
1 vented back to the containment, adding some hydrogen gas and
2 other isotopes that were in the waste gas decay tank. To what
3 extent had this contingency been factored into questions of
4 hydrogen?

5 This is an admittedly incomplete list and it's a
6 broad question, and it's asking for the Licensee to consider
7 these and other things and see if this has been properly taken
8 into account.

9 DR. OKRENT: I'm not quite sure I have more than the
10 same information I guess I had from reading the account of the
11 event. But what about the sampling of hydrogen itself? Are
12 there satisfactory means on all plants for getting early, prompt
13 measurements of the hydrogen concentration displayed in the control
14 room or available to the control room operator quickly?

647
15 MR. TEDESCO: As far as Regulatory Guide 1.7 and the
16 new rule 50.44 that deals with hydrogen control, the plant
17 would have to have the capability to monitor hydrogen levels
18 in the containment. These are done on a continuous basis or
19 from a sampling basis.

20 As far as full implementation of all plants, I don't
21 have the information at this point, but the capability exists
22 to sample the containment environment.

23 DR. SHEWMON: No matter what its activity is?

24 R. TEDESCO: That would be a requirement, yes.
25 Whatever that is, you have to have the capability to--

b27

1 DR. SHEWMON: No matter what the level of activity
2 is within the containment? That is, a person can do it re-
3 motely?

4 MR. TEDESCO: Well, the whole design basis is based
5 on the TID type of release, you know, so it should have that
6 capability.

7 DR. SHEWMON: The answer to my question is Yes?

8 MR. TEDESCO: Yes.

9 DR. SHEWMON: Thank you.

668

10 DR. OKRENT: And is it your impression that there
11 does or does not exist means of continuous monitoring?

12 MR. TEDESCO: On the newer plants it's more on the
13 basis of a continuous type capability. On the older plants
14 it would be on a sampling basis.

15 DR. OKRENT: How long does it take to get a sample?
16 How many samples are involved, do you know?

17 MR. TEDESCO: It would be on the order of a few
18 hours, based on the Three Mile Island experience.

19 DR. LAWROSKI: How many samples do you have to get?

20 MR. MATTSON: The samples were fairly consistent
21 with one another so the first was as good as the second, the
22 third, and the fourth one. And then when they got the hydrogen
23 recombiner installed it had a continuous monitor, so I think
24 the answer to your question, how many would you generally have
25 to take, is not many if there's fan coolers or some kind of

eb28

1 circulation going on inside the containment and you get a good
2 distribution of the hydrogen, and it's not a hard analytical
3 kind of chemistry process co-

4 DR. LAWROSKI: Well, the problem is to get a repre-
5 sentative sample for that two million or so cubic feet that's
6 in the containment, of total volume.

7 MR. MATTSON: Well, if the containment air is being
8 mixed it's not as much a problem as if the containment air
9 isn't being mixed.

10 DR. LAWROSKI: You said "if."

11 MR. MATTSON: Yes. Fan coolers and things like that
12 keep the containment air mixed.

13 DR. LAWROSKI: You have not seen any concentration
14 gradients in the points from wherever they take samples for
15 hydrogen content?

16 MR. MATTSON: We don't have hydrogen concentration
17 gradients that we can measure, but the temperature gradient
18 within the containment looks like there is pretty good mixing
19 from the fan coolers that have been running since early in the
20 accident, and it's what you would expect.

21 MR. RAY: As a corollary to Dr. Okrent's question
22 on the sampling of containment gases and so on, and reactor
23 gases to determine the degree of prevalence of and presence of
24 hydrogen, is there any way that you can evaluate the potential
25 release of oxygen to mix with it, and is it possible to inert

29 1 that in some fashion by injecting a chemical that would do so,
2 so that you won't get an explosive mixture if your hydrogen
3 is released?

4 DR. SHEWMON: And is there a way of getting the
5 comments of somebody who knows the recombination rate on
6 demand?

7 MR. MATTSON: Well, we learned about recombination
8 rates on demand in a period when things were moving quickly,
9 maybe not fast enough.

10 I think there are two questions here. One is the
11 recombination rate in the primary coolant system, and the other
12 is the potential for generation of oxygen inside the containment.

13 Now the broad question of hydrogen control, hydrogen
14 flammability, and hydrogen detonation inside the containment
15 has been a subject of review with this Committee and work with-
16 in the Staff going back to the late 1960s. That's why there
17 are recombiners there today, and the technical work that was
18 done over those many years led to a basic system of protection
19 that provides for mixing of the hydrogen within the containment,
20 and then controlled burning, i.e., recombination to keep you
21 from getting above flammable, and certainly keeps you below
22 detonation limits.

23 Oxygen generated in the sump by radiolysis in the
24 sump if there are fission products in the sump was not chosen
25 to be controlled in that method of containment protection.

eb30

1 The question of oxygen generation in the core
2 if there's hydrogen present in the primary coolant system I
3 think we have a pretty good understanding of today; that is,
4 if there's a hydrogen overpressure there's no net production
5 of oxygen by radiolysis in the absence of boiling.

6 DR. OKRENT: Well, I noticed that the question of
7 hydrogen has been sent out to the BWR owners and, I assume, to
8 all the PWR vendors, and I guess I'm not quite sure what it is
9 you're asking. You mentioned the recombiner a moment ago.

10 The design basis for that recombiner is a different
11 event than the one that transpired at Three Mile Island. I
12 don't think we should leave the impression, even indirectly,
13 that it was designed for the amount of hydrogen generated in
14 this event. It was for a much lesser release, a lesser rate and
15 a lesser amount.

16 MR. MATTSON: We understand that, and that's why the
17 question, for people to tell us what their capability is, plant
18 by plant today, for dealing with hydrogen.

19 DR. OKRENT: Well, --

20 DR. LAWROSKI: Well, Roger, just from the pressure
21 spike that occurred, one would get some reason to believe that
22 the mixing isn't so good as you implied at least.

23 MR. MATTSON: Well, there were no recombiners on at
24 that time and, as Dr. Okrent just said, the control of hydrogen
25 had a design basis that was somewhat different than the amount

eh 21 1 of oxidation that occurred in this core. There was more hydro-
2 gen there than was in the design basis.

3 That's one of the lessons learned, one of the things
4 that we're looking at.

5 DR. OKRENT: Let me put it another way:

6 If you're asking various reactor operators to con-
7 sider situations that might lead to about the same amount of
8 hydrogen as was generated at Three Mile Island 2, then there
9 would be other ramifications that go with such an event, and
10 this would be only one part of a broader picture.

11 So I'm still I guess trying to understand a little
12 bit better what this question means.

13 MR. MATTSON: Well, it doesn't mean that we've adopted
14 a new design basis for recombiners that is the Three Mile
15 Island accident. I think that that's a decision that you try
16 not to be in that situation. The intent must surely be to pre-
17 vent the occurrence of the Three Mile Island accident, and in
18 the process of working to do that, get a current up-to-date
19 summary of what the hydrogen capability is for all the plants
20 now in operation.

21 DR. OKRENT: No more on that now.

22 DR. CARBON: Go ahead, Mr. Varga.
23
24
25

agbl

1 MR. VARGA: Item Two of the response to the bulletin
2 requested the Licensee to review transients and events that
3 have occurred at his facility, particularly to report those that
4 where the performance deviated from the expected performance.

5 We have reviewed these and the discussion, in general,
6 in the responses and this response indicates and understanding
7 and an awareness of the various events that occurred in the
8 events and the transients that they're looking at.

9 And we have identified in this one particular typical
10 review that we have done, this one, there was a transient or an
11 event that had occurred that was reported to us some time in
12 January. That was not included in the response of the Licensee,
13 however, that event in itself is not too significantly different
14 than what he had already looked at, and we have not uncovered
15 ourselves any particular concern but are calling it to the
16 attention of the Licensee.

17 In these responses, as well as in all responses
18 that we are reviewing, I guess my personal perception is that
19 I'm taking certainly a different approach or a view from a
20 new direction about statements like "resulted in no safety
21 significance" or "this was terminated without adverse implica-
22 tions and that sort of thing.

23 We certainly are taking a very hard look at all
24 aspects of various events and occurrences that have occurred,
25 and it's being factored, of course, into the short-term program

67-112

agb2

1 that is following.

2 Item Three --

3 DR. CARBON: A question before you leave Number Two,
4 you say you feel they are aware of the question and so on.
5 But have they responded, indicating that there have been sig-
6 nificant deviations you didn't know about before?

7 MR. VARGA: Oh, no. All the significant deviations
8 that have been reported in the responses we have known about
9 before, except -- well, we have not completed our review, I
10 cannot say that straightforwardly, we have not completed our
11 review. In the review we have done to date, in general, across
12 the five and, in specific, across one, we have not identified
13 anything.

14 DR. CARBON: In the paragraph that says that there
15 have been significant deviations from expected performance
16 provide details and so on, you would ordinarily know about all
17 those, you really don't expect them to be telling you of any
18 new ones, do you?

19 MR. VARGA: I don't expect so, except that of
20 course it depends upon the equipment and the system involved,
21 and whether expected performance has to do something with the
22 protection of the health and safety of the public of that
23 particular event. I can't think of any, but there might be
24 performance of a non-safety grade equipment that deviated from
25 their expected performance that they may not have reported.

gb3

1 They have certain obligations to report to us
2 deviations from expected performance where that deviation has
3 the potential to affect the health and safety of the public
4 and indicates some deficiency in the design or the operation of
5 the plant.

6 There might be some circumstances outside that
7 that they may not have reported, and I'm not sure I have a feel
8 for the broad spectrum of that at this point.

9 I don't think any deviation that occurred in a
10 safety system that would affect the public health and safety
11 has not been reported, I don't believe that's the case. But
12 I cannot say that until we have reviewed all of the responses.

13 DR. CARBON: And you have reviewed only one so far?

14 MR. VARGA: We have reviewed all five in a, I would
15 say, in a read-through and a discussion. And we are reviewing
16 1. with our own resource investigation procedures. You know,
17 events transpire over a significant period of time and we're
18 reviewing our own records as well.

19 DR. CARBON: Thank you.

20 MR. VARGA: In Item Three of the bulletin, this had
21 to do with reviewing actions required by the operating procedures
22 for coping with transients and accidents with particular
23 attention to forming the voids in operator action to prevent,
24 an operator action to enhance core cooling.

25 And the responses were generally uniform. This

agb4 1 particular one indicated that they were reviewing the operating
2 procedures as well as the instructions to the operator and that,
3 in addition to providing additional aids to assist the operator
4 in the recognition of this situation, they were also embarking
5 upon a training program for the operators with the simulators
6 in order to -- and simulating to the extent, in my view, to
7 the extent possible, the sequence of events at TMI 2 and training
8 and instructing the operators.

9 In general, we find this an acceptable response.
10 The problem we have is the length of time the Licensee has
11 indicated for the completion of this review. He said that this
12 review and training will be completed in approximately 120 days.
13 We believe that that is much too long and believe that signifi-
14 cant reduction in that period of time should be made.

15 Item Four --

16 DR. SHEWMON: Pardon me, sir, is that really realistic
17 if you aren't sure what it is you're supposed to be retraining
18 them to do yet, or do we know indeed what it is we want them
19 to train them to do now?

20 MR. VARGA: Well, if I were the simulator, I could
21 certainly on my own put various events in as to the capability
22 of the simulator that I already know.

23 But more than just that -- and probably any knowledge-
24 able person in this particular activity can probably do it.

25 But we had a meeting with all the simulator owners

1 last week and went into detail as to the particular events and
2 the capabilities of the particular simulators in order to
3 ascertain what actions could be taken, what capabilities there
4 were, and I believe the results of that indicated that for
5 the B&W simulator at least it appeared that that had significant
6 capability to simulate that event, various aspects of the
7 event.

8 I, myself, do not know the complete capability --

9 DR. SHEWMON: So you think they should be able to
10 cope with the Three Mile Island event and have everybody
11 trained to cope with it better after less than 120 days?

12 MR. VARGA: Right.

13 DR. SHEWMON: My impression was that you thought they
14 should have thought up all other ramifications and contingencies,
15 have these defined and have everybody trained to cope with them
16 in less than 120 days.

17 MR. VARGA: No, I'm speaking specifically of the
18 TMI 2 incident that we did, and I'm sorry I didn't make that
19 clear. But certainly there may be follow-on as our review
20 continues and we may identify other training requirements.

21 DR. OKRENT: I would like to understand what it is
22 you think the B&W simulator can do. Do you believe it is able
23 to describe the fluid conditions inside the primary system on
24 a reasonably detailed basis for the event which transpires?

25 MR. VARGA: I cannot speak from personal knowledge,

67-046

agb6

1 and I suggest -- I'll answer you to the best of my ability,
2 but I would suggest probably asking B&W that at their particular
3 point might be appropriate as well.

4 But I believe that a simulator can simulate only,
5 of course, it's a platitude, what is put in. I believe when
6 you have changing regimes, I am highly suspect from now on of
7 any statement alluding to natural circulation.

8 The two phase flow regime, I believe there will be
9 always significant problems in simulating the actual phenomena
10 in a computer -- in a simulator. You could approach it. I
11 cannot address the question of how well does the B&W simulator
12 simulate the accident.

13 DR. OKRENT: Now this meeting you say you held with
14 the various simulator groups, is there detailed information
15 available on what they believe their simulators can and cannot
16 simulate?

17 MR. VARGA: I'm sure there will be information
18 available, I do not know how detailed. A member of my group
19 that is back in Bethesda now reviewing these was the person
20 from the Operating License Branch who was, I think -- had the
21 meeting and informed me about the detail as I have informed
22 you.

23 Now as additional information becomes available,
24 we can certainly make that available.

25 DR. OKRENT: Does the NRC Staff itself have, either at

agb7

1 Bethesda or via any of its contractors, an ability to simulate
2 each of the four water reactor vendor plants?

3 MR. VARGA: I will have to defer to someone else
4 on the Staff.

5 MR. MATTSON: I take your question to be in the sense
6 of the simulator or plant computer sense, not the computer
7 code analytical sense. Is that correct?

8 DR. OKRENT: Let me ask about the system behavior,
9 not in terms of all of the controls and alarms and so forth
10 that would be in a control room.

11 MR. MATTSON: Well it's my understanding late last
12 week they were beginning to see computer runs from our consult-
13 ants in Idaho, simulating or reconstructing, if you will, the
14 pressure, temperature, flow scenarios for this accident.

15 So evidently the answer is yes, we have the ability
16 to calculate what happened given the initiating events.

17 The Staff has no simulator under its direct control
18 which you could then input these plant parameters and follow
19 what the control panel or the simulator panel would do as a
20 consequence.

21 Now we have other contractual arrangements for
22 working with simulators to understand plant transients and what
23 have you. It's conceivable we could do that, we don't have
24 that capability today.

25 DR. CARBON: Go on, please.

1 MR. VARGA: Item Four of the bulletin requested
2 actions about operators not overriding automatic actuation of
3 engineered safety features and went on to talk about the HPI,
4 the restriction on HPI, termination of operation and (c) was
5 reactor coolant pump and then (d), the not relying on pressuri-
6 zer level alone.

7 The responses are due in and we are reviewing --
8 essentially deal with 4(a) about reviewing the actions directed
9 by the operating procedures and training instructions to insure
10 that operators do not override automatic actions of engineered
11 safety features.

12 We have, in general, the response to this item is
13 indicated -- well not in general but in two instances, as I
14 recall, the responses indicated some particular problem with
15 this unduly restrictive -- their interpretation of this action
16 as being unduly restrictive.

17 And in the one response we reviewed, we've had
18 subsequent communication from the Applicant -- from the Licensee
19 concerning that.

20 In the bulletins that have been issued to the other
21 PWRs, subsequent to O5-A, but to the other designs, there is
22 wording that clarifies the intent of that particular requirement
23 about overriding.

24 And let me just -- it's in the other bulletins and
25 we are going to provide that same clarification in our response

67-049

agb9

1 that we believe will be immediately transmitted back to the
2 Applicants as a result of our review that this clarification
3 is that review of the actions directed by the operating pro-
4 cedures and training instructions to insure that operators do
5 not override automatic actions of engineered safety features
6 unless continued operation of engineered safety features will
7 result in unsafe plant conditions, an example of continued
8 operation of HPI which threatened reactor vessel integrity,
9 then the HPI should be secured as noted in Number Two below.

10 Two below also then also then clarifies the 20
11 minutes and the subcooling requirement that -- either that the
12 HPI must remain in operation until either both low pressure
13 injection pumps are flowing for 20 minutes or longer at a rate
14 which would establish stable plant behavior or the HPI has been
15 in operation for 20 minutes and all hot and cold leg temperatures
16 are at least 50 degrees below the saturation temperature for the
17 existing pressure.

18 The important qualification there, or clarification is
19 the degree of subcooling beyond 50 degrees Fahrenheit and the
20 length of time HPI is in operation shall be limited by
21 pressure temperature considerations for the vessel integrity.

22 We will review then also the remaining responses to
23 4(b), (c), and (d) in response to you today.

24 Finally, Item Five, which was verify that emergency
25 feedwater valves are in the open position in accordance with

agbl0

1 Item Eight below and review all safety-related valve positions
2 and position requirements.

3 In general, the responses track about the same.
4 They indicate the emergency features or systems reviewed, in
5 some instances give the list of the procedures and also list
6 the maintenance and testing -- review of the maintenance and
7 testing procedures.

8 In the review of the one particular one we have gone
9 through in some detail, there was an omission concerning the
10 maintenance and testing -- review of the maintenance and
11 testing procedures, which we are requiring and have indicated
12 that that must be done. We believe that, in our discussion and
13 evaluation of this, we believe that this has been done but was
14 not indicated in the bulletin.

15 In the one we have reviewed in detail, there was an
16 implication in the response that the review of the valve lineups
17 and the procedures and the requirements for ascertaining that
18 they are all in place and correct.

19 The response appeared to be tailored to a short-term
20 response, indicating that this has been done. However, certain
21 valves could not be checked because the containment was closed.

22 So we're pointing out that certainly an immediate
23 response is required and a check is required, but important as
24 well are procedures and actions in place for the continuous
25 operation and long-term aspects to assure that that situation

agbl1 1 does not change.

2 Particularly we are highlighting where shift changes
3 occur, that maintenance procedures or surveillance procedures
4 occurring at a particular shift and ascertaining of certain valve
5 lineups or certain valves out of operation, that the Licensee
6 indicate specifically his shift transfer procedures to assure
7 that there is no oversight in this particular review, or this
8 particular action.

9 That summarizes briefly where we are and our per-
10 ception to date. As I mentioned earlier, we are deep in the
11 process of reviewing this, expediting to the extent possible
12 this review. If you have any questions, I'll be glad to see if
13 I can answer them.

14 DR. CARBON: Any questions, gentlemen?

15 MR. MICHAELSON: Carl Michaelson, ACRS consultant.

16 I believe you indicated that the reactor coolant pump
17 would be tripped only after there was evidence that you no
18 longer had flow. Would you expand upon that evidence?

19 MR. VARGA: Well let me make some remarks and perhaps
20 some additional clarification can come from the Staff.

21 There are times where the indications may show that
22 the reactor coolant pump for cavitational purposes, loss of
23 suction or some other reason, may be approaching the situation
24 where a temporary loss of suction had occurred and forced cooling
25 was no longer occurring. This could be indicated by a sudden

agbl2

1 change in the temperatures at a particular point.

2 It's conceivable to me that you would like to,
3 momentarily, perhaps, stop to trip the pump, re-establish perhaps
4 some head and essentially prime the pump, perhaps. That is
5 conceivable to me that you might want to be able to do that.

6 However, certainly we have not given detailed
7 definition of exactly when and when you cannot. As I said,
8 this is an immediate response sort of action. Additional
9 information or requirements may flow from our continuing
10 activities.

11 Would anyone like to add to that?

12 MR. MATTSON: I don't think we have any reason to
13 disagree with that answer.

14 Was there more you were looking for, Carl?

15 MR. MICHAELSON: Well, what I was really looking for
16 is, what does the operator do at the present time if he should
17 get into a similar situation, what kind of instruction have
18 you issued?

19 It appears from the wording of earlier instructions
20 that you run that pump, shall we say, to the bitter end. I
21 assume that's been clarified somewhat.

22 MR. ROSS: Let me read directly from Bulletin 06-A,
23 Page 45, the top six lines, which is paragraph C, 7C. This is
24 the bulletin that was sent to Westinghouse plants, and a
25 similar provision was sent to Combustion:

agbl3

1 "Operating procedures currently, or revised
2 to, specify that in the event of HPI with reactor
3 coolant pumps operating, at least one reactor cool-
4 ant pump shall remain operating for two loop plants,
5 at least two reactor coolant pumps shall remain
6 operating for three or four loop plants, as long as
7 the pump or pumps is providing forced flow."

8 Now, the discussion that we had -- and there will be
9 some of this in the minutes of the meeting that we had with
10 Westinghouse, and those minutes have been published and supplied
11 to the Committee as well as to the Public Document Room --
12 had to do with both the previous instructions given to the
13 plant operator to trip the pump in the event of a deviation such
14 as an action level on vibration of the pump. There are other
15 instructions on manual tripping having to do with, oh, perhaps,
16 excessive current as well as some automatic trips on loss of
17 coolant flow.

18 Some of the analog charts that we saw for the
19 Three Mile sequence showed variations in the measured reactor
20 coolant pump flow rates. The intent here was, as long as it
21 was perceived from the flow meters and other evidence that the
22 pump was pumping water, leave it on.

23 MR. MICHAELSON: I gather then that what you're
24 saying is leave it on irrespective of the vibrational levels
25 that are indicated and so forth, or the ammeters which might be

agbl4

1 swaying rather severely at that point in time.

2 MR. ROSS: Well I think what you said, the latter
3 statement, might be a contradiction in that the ammeter might
4 be an indicator that it is not pumping water, but from whatever
5 evidence available that it's pumping water, leave it on, yes, sir,
6 the vibration meter notwithstanding.

7 DR. CARBON: Ivan, did you have a question?

8 DR. CATTON: No.

9 DR. CARBON: Any other questions from the Committee?

10 (No response.)

11 Thank you, Steve.

12 It seems an appropriate time to take a 10-minute
13 break.

14 (Recess.)

15 DR. CARBON: Let's move on. I think it would be
16 appropriate at this time to discuss the bulletins which have
17 gone out to the other vendors, and I believe Mr. Ross is to
18 cover that topic.

19 MR. ROSS: Professor Carbon, a brief statement on
20 this: I want to point out for the benefit of the Committee that
21 bulletins have also been sent in the last few days. There was
22 a generalized bulletin which we refer to as the two-digit
23 06 that were action for Westinghouse and Combusion plants,
24 which was quickly followed by a specific 06-A for Westinghouse,
25 a specific bulletin 06-B for Combustion and then a day or so

2.290

15

1 later, the day before yesterday, we got a General Electric --
2 pardon me, a boiling water reactor specific 08.

3 We've talked about some of the differences already
4 this morning. The main thing we want to do at this time is
5 just to notify the Committee of the existence of these bulletins.
6 The replies are not due for a few more days, and our evaluation
7 will have to come after that.

8 So other than point these out, we really weren't
9 prepared to discuss them, but we can answer questions you might
10 have on the content of the questions.

11 DR. CARBON: Are there questions by the committee?

12 DR. LAWROSKI: I have one.

13 In connection with the containments, have your
14 bulletins included an admonition to make sure that there are no
15 unopened valves, because in this case we are fortunate that the
16 containment was apparently good and also that there were no
17 valves left open, so that once the containment was isolated it
18 kept the contents pretty well controlled.

19 MR. ROSS: I believe -- Let me use Bulletin 06-A for
20 reference, that may come up several places on these instructions.
21 Instruction Number Four has to do with containment isolation
22 initiation, so that you can, if necessary, isolate those features
23 not needed for ECCS or other safety features.

24 But there's also another portion of the same bulletin
25 having to do with maintenance and tests. Point Number Eight has

agbl6 1 to do with reviewing safety related valve positions and
2 Paragraph 10 is maintenance and test procedures when you're
3 taking features out of service and putting them back into
4 service.

5 So I think under one or more of those paragraphs
6 your question is covered.

7 DR. LAWROSKI: Thank you.

8 DR. CARBON: Let's move on, then.

9 Mr. Mattson?

10 MR. MATTSON: Bob Tedesco is going to tell you of the
11 short-term long-term activities that I described earlier.
12 Basically, Bob picks up where the immediate-term procedural
13 oriented bulletins leave off, recognizing that procedures are
14 effective over a period of time but with time their effective-
15 ness decays and therefore you look in the short-term or long-
16 term toward question of design modifications, operator training
17 and those kinds of things that Bob will be summarizing.

18 MR. TEDESCO: Good morning, my name is Bob Tedesco,
19 the Assistant Director for Reactor Safety in the Office of
20 Nuclear Reactor Regulation.

21 I'd like to share with you briefly this morning
22 the status of generic review that we are now going through with
23 regard to the feedwater transients in B&W reactors.

24 (Slide.)

25 Starting out with the purpose of our evaluation, it's

endlC
1D

2.360

Slide Set 1

A Jeral Reporters, Inc.

67-057

bl

1 in two parts, that this generic assessment will deal with
2 these transients in light of the Three Mile Island-2 event
3 (1) to establish the basis for continued safe operation of
4 these plants in the short term and (2) to determine the
5 review areas for long term re-assessment of the designs to
6 meet NRC regulations.

7 (Slide)

8 We've been started on this effort for about a
9 week now and are going ahead re-looking at various plants
10 that fall the category: the operating reactors at Three Mile
11 Island 1 and 2, Crystal River, Rancho Seco, Oconee, the three
12 units there, Arkansas-1 and Davis-Besse-1.

13 Now in addition to this effort on the generic
14 review of the B&W plants we'll also be looking at the other
15 PWRs of Westinghouse and Combustion, at least as an overlay,
16 to see where we are as far as the outcome of the B&W review and
17 what they might mean to the other plants.

18 We've made a survey based on the LERs of the
19 events related to the feedwater transients that may suggest a
20 precursor type of event to the Three Mile Island-2 incident.
21 Now the information that we have is based on the licensee's
22 responses in the LERs, but there may be other types of incidents
23 of feedwater origin where a plant has responded as designed
24 and, therefore, it would not be the subject of an LER.

25 But with regard to the incidents that we're talking

wb2

1 about, there appear to be five related events, two of which
2 we have found to be, in a way, similar precursors to the
3 Three Mile Island-2 event. Back in '75 Oconee-3 during its
4 initial program had an incident that actuated the power
5 operated relief valve. The valve subsequently stuck open,
6 and then the injection signal was hit, and he hit the injection
7 as designed.

8 Then a year later at Oconee-2 there was another
9 event with the feedwater where the power operated valve was
10 actuated and the system stabilized as designed after that.

11 Davis-Besse in September of '77, during its
12 initial startup program was somewhat similar to Oconee-3 in
13 that the valve was actuated, stuck open and you had injection.

14 Rancho Seco had a depressurization event during
15 1978 which caused an injection.

16 Oconee-1 had a similar event that caused both
17 the power operated relief valves to be actuated and the high
18 pressure system actuated.

19 At Three Mile Island-2 we had the sequence we're
20 talking about right now where we had the valve actuated and
21 it stuck open and you had injection.

22 So based on this preliminary comparative of the
23 LER information that we have there appear at this points two
24 events as precursors and were similar to the Three Mile,
25 Oconee and Davis-Besse. We're looking into these further to

wb3,

1 to try to find out generic implications of the events, what
2 had happened, and then to include them into our generic
3 evaluation.

(Slide)

4 I'd like to spend a brief time now on the Three
5 Mile Island-2, to kind of lay in the background of where we
6 are in our generic evaluation, identifying the major areas
7 that we are looking at.

8 Prof. KERR: Mr. Tedesco, in connection with your
9 early slide, can you tell us whether, in those cases in which
10 there were stuck-open relief valves, the operator was unaware
11 of the fact that they were stuck open?

12 MR. TEDESCO: Let me see if I have that.

13 (Pause)

14 Let me put that slide back.

15 (Slide)

16 With regard to Oconee-3, the indication was that
17 the operator did close the block valve at reactor trip. But
18 then he re-opened it because of the rise in pressurizer level.
19 So the action by the operator was to close the valve. So
20 there was an indication in that one that the valve had stuck
21 open.

22 PROF. KERR: Does your information indicate how he
23 knew it was open?

24 MR. TEDESCO: Well the information-- There is a
25 temperature readout at the valve that would indicate an increase

wb4: 1 in temperature with the valve open.

2 PROF. KERR: And was information of that type
3 available to the TMI operator?

4 MR. TEDESCO: That information is available.
5 There is a block valve downstream of the power operated
6 relief valve.

7 PROF. KERR: What about at Davis-Besse?

8 MR. TEDESCO: Davis-Besse was a--

9 PROF. KERR: Did the operator know then, in that
10 case?

11 MR. TEDESCO: Twenty minutes into the transient
12 the operator closed the power operated relief valve. But
13 also remember, on Davis-Besse we blew the rupture disc on the
14 pressurizer surge tanks. And so I'm not sure which was the
15 indication to him, whether it was the temperature or the fact
16 that--

17 PROF. KERR: But the evidence is that in both of
18 those cases the operator was aware that the valve was stuck
19 open?

20 MR. TEDESCO: Based on this information I would say
21 yes.

22 PROF. KERR: Thank you.

23 DR. SHEWMON: One would judge from this that it
24 seems to be the rule instead of the exception that the PORV
25 sticks open. Do we have any sort of reliability data on those

67-081

wb5

1 things? Or is this the only way we can test them?

2 MR. TEDESCO: As I get further into my generic
3 evaluation I'll be able to share further the equipment valve
4 function and how we're factoring that into the program.

5 DR. SHEWMON: Good.

6 MR. MICHAELSON: Would you care to comment now as
7 to whether or not these were identical power operated relief
8 valves, or were they of different manufacturers?

9 MR. TEDESCO: I can't answer that specifically
10 right now.

11 DR. CARBON: Bob, I'm confused on something.
12 I'm under the impression that at Three Mile Island-2 there was
13 no temperature indicator to show that the PORV was open.
14 What's--

15 MR. TEDESCO: Well so far as I know on the T&ID
16 there's an indication of it.

17 MR. MATTSON: Mr. Chairman, our understanding was
18 there was a temperature indicator on that valve.

19 DR. CARBON: A second question, then.

20 This temperature indicator presumably acts fairly
21 slowly. And I believe you indicated that maybe at Oconee-3
22 they closed the manual valve something like twenty minutes
23 after the--

24 MR. TEDESCO: Davis-Besse was twenty minutes.

25 DR. CARBON: Is that a typical time, that it takes

67-052

wb6

1 that long to recognize?

2.520

2 MR. TEDESCO: On the Oconee-3 incident the block
3 valve closed on reactor trip but reopened. That would have
4 been earlier than twenty minutes.

5 DR. SHEWMON: Max, it's a thermocouple hanging in
6 the fluid. It should respond in a matter of seconds, a minute
7 at worst.

8 DR. CARBON: Is it in the fluid? And how much
9 time lag, I wonder, does it have. I'm told it's a very slow
10 thermocouple.

11 MR. TEDESCO: You should be able to tell if this
12 valve is stuck open. You're going to start getting a depres-
13 surization indication in the control room, and you'll know--
14 If the valve should have reseated and you're still starting
15 to depressurize I think it's a very reasonable, logical indi-
16 cation that something has happened. You either have a small
17 break or the valve hasn't closed. The operator should then
18 go ahead and try to secure it with the block valve if no
19 kind of information signals are available to him in the control
20 room.

21 DR. CARBON: I don't question that. But I was
22 wondering if the lag of the thermocouple in telling the
23 operator anything--

24 MR. TEDESCO: It won't be a twenty-minute lag,
25 I'm sure, on the thermocouple.

wb7

1 DR. PLESSET: I was concerned about the valve
2 hanging open. When you've got loads on it due to flow out
3 through that valve which might have low quality then the loads
4 can be so that even though the valve wants to close it cannot.
5 I was just mentioning it to Darryl Eisenhut, and I'm glad to
6 know that they're worried about this, too, about this possi-
7 bility. But I think the loads may be higher than we're aware
8 of.

9 MR. TEDESCO: Dr. Plesset, one of the questions
10 we have is the adequacy of the valve to pass anything but
11 steam.

12 Remember, this is also part of the staff considera-
13 tion on ATWS. It's related to this.

14 DR. PLESSET: Yes. I think this is a rather
15 serious question.

16 MR. TEDESCO: Yes, it is.

17 DR. OKRENT: In some future listing of these
18 transients I think it might be helpful to have a fourth column
19 which indicated whether the operator had a basis for knowing
20 the status of the plant or whether there was ambiguous informa-
21 tion coming to the operator. That's separate from whether he
22 used all the information. --if I make the distinction.

23 MR. TEDESCO: I would hope that in our report
24 when I talk a little more about it, maybe I will identify the
25 appropriate area where this aspect will be discussed.

8
1 MR. MICHAELSON: Before you get off that I'd like
2 to ask one further question.

3 You apparently have indicating lights in the
4 control room concerning the position of the power operated
5 valve. What position did the lights indicate?

6 MR. TEDESCO: Let me see if I can add some light
7 to that.

8 Based on the information that we are putting
9 together now on Oconee-3 the control room light did not show
10 open status of the valves. At Davis-Besse I can't tell you: I
11 don't have the information with me right now.

12 MR. MICHAELSON: On Three Mile Island?

13 MR. TEDESCO: Roger, do you know?

14 MR. MATTSON: I'm sorry; I didn't hear the question.
15 Could you repeat the question? We have a valve line up back
16 here.

17 MR. MICHAELSON: The question was, What position
18 was indicated for the power operated relief valve on Three
19 Mile Island after the event started?

20 MR. VARGA: I have a list of the instrumentation
21 available, presently available, to sense opening or a leaking
22 PORV. On Three Mile Island-1 there's a thermocouple indication
23 but no alarm. On Three Mile Island-2 there was also a thermo-
24 couple indication but no alarm.

25 Crystal River has a thermocouple with an alarm.

wb9

1 Oconee-1, 2 and 3 have position indicators, thermocouple
2 location, quench tank level, pressure and temperature. I'm
3 not clear yet whether those are all alarmed. But indications
4 are available.

5 Rancho Seco has a thermocouple, not alarmed,
6 quench tank level, temperature and pressure. I don't know
7 whether those are alarmed.

8 On ANO-2 it has position indicators only, not
9 alarmed. Davis-Besse has position indicator and thermo-
10 couples.

11 MR. MICHAELSON: I guess I have to ask my ques-
12 tion again, then.

13 Is there a position indication at Three Mile
14 Island? They do not have one, or you don't know?

15 MR. VARGA: The review we have made, which is
16 subject to checking, indicates they do not.

17 (Slide)

18 MR. TEDESCO: Going back to my slide, it really
19 forms the basis for our generic review. We have feedwater
20 concentration at Three Mile Island. The sequence that fol-
21 lowed was that we challenged the plant design in certain
22 areas, namely, pressurizer level indicator, the one-through
23 steam generator, the feedwater control system, and the con-
24 figuration of reactor coolant system.

25 In addition to that, there were operator procedures

67-066

33

wb10

1 were available. Based on the information I'm looking at now,
2 it looks like it was the wrong operating procedure for that
3 particular situation, namely, in regard to what the operator
4 did with the high pressure injection system and what was also
5 done later with the reactor coolant pumps.

6 As far as equipment malfunction, we did have the
7 power operated relief valve stick open. And then the operator
8 failure falls in the category of the aux feedwater system
9 being blocked out.

10 Now collectively these sequences are being reviewed
11 in our generic program, and we are constituting what we call a
12 short term program to see what these are, to assess their
13 significance and impact on the other B&W plants.

14 So with that as background, we then went ahead
15 and said, All right, we're going to look the plant design
16 features, the operational aspects and the licensing basis
17 of where we are. And then, with the I&E bulletin as our
18 action point, to make this assessment for the short term
19 program.

20 The three categories we'll be talking about are
21 design, the operation, and the licensing that we'll be emphasiz-
22 ing in our review.

23 (Slide)

24 We recognize that the review is really very early
25 in this progression. We don't have all the answers yet. But

wbll

1 I would like to at least share some of the areas that we are
2 considering for our evaluation.

3 DR. OKRENT: Before you leave that last slide,
4 you mentioned something about the operational procedures were
5 not appropriate for that transient. And I assume that relates
6 to whether or not the RCP should stay on or off, and so forth.

7 MR. TEDESCO: Yes, sir, that's one of the ques-
8 tions, yes.

9 DR. OKRENT: And do you have any knowledge yet
10 as to whether the operator was very worried about overpressuriz-
11 ing the primary system? Was that a factor in his thinking?

12 MR. TEDESCO: Well, that would be on the high
13 pressure coolant injection system, when he went from an
14 ECCS mode of operation to the level control mode. And I would
15 share on that that it was a concern about overpressurizing in
16 this instance.

17 DR. OKRENT: Have interviews established that this
18 was the case?

19 MR. TEDESCO: This is speculation. We were at the
20 initial exploratory stage of asking what did he do and why
21 with respect to this question.

22 DR. MATTSON: Could I interrupt just a minute,
23 please?

24 The initial stages of the investigation of the
25 accident by the Office of Inspection and Enforcement were

wbl2

1 undertaken last week. And the kind of information that you're
2 looking for to remove the need for this sort of speculation
3 should be coming in relatively soon. But the staff here in
4 Bethesda doesn't have it yet.

5 DR. PLESSET: What kind of review of operator
6 training, operator background, will be made?

7 MR. TEDESCO: That falls in the category of our
8 licensing basis and the operational aspects. And the people
9 in the Operator Examining Branch are going through the whole
10 area. They are re-assessing operator training, operator
11 licensing requirements in light of the accident that happened
12 at Three Mile Island. That will be part of our report.

13 DR. PLESSET: It will be a searching re-examina-
14 tion?

15 MR. TEDESCO; All the areas -- design, licensing
16 basis, the operational -- they are all open now, all subject
17 to a complete re-assessment on our part.

18 (Slide)

19 Now in the area of plant design, here are some of
20 the matters that we're looking at.

21 We realize that during the incident the pressurizer
22 level started to indicate a rising pressure. The question is,
23 Why was that so when we knew we were voiding in the core?

24 So we went into three areas. We asked questions
25 of ourselves about the instrumentation itself, was it behaving

67-069

wb13

1 as designed?

2 No. 2, we asked ourselves the question about the
3 loop seals in the pressurizer surge line, could it have
4 affected the reading of the pressurizer level?

5 No. 3 was the effect of the thermodynamics on
6 the whole system.

7 We came up with the following preliminary tenta-
8 tive finding, that we believe the level indication was proper,
9 that the instrumentation was responding as designed, that it
10 showed a rising level in the pressurizer. And from the event
11 that we had at Three Mile Island, wherein you had a - quite -
12 small type of break in the pressurizer, the loop seal manometer
13 effect did not contribute to this indication.

14 No. 3, as far as the thermodynamics go, we made
15 some preliminary calculations at Idaho using Three Mile
16 Island-type of input scenario with the RELAP run, and the
17 preliminary results are showing that you would, for this type
18 of event, with a rising level in the pressurizer, with a
19 decreasing system pressure, would suggest strongly a
20 thermodynamic process during depressurization.

21 Westinghouse and Combustion, and even now B&W,
22 have all made similar analyses and are coming up with similar
23 types of findings.

24 So we believe the instrumentation was recording
25 right; we don't feel as strong at this point as to the

wbl4

1 contribution from the loop seals, and thermodynamics appear to
2 be predictable for it.

3 We're looking at the power operated relief valve,
4 its malfunction history, what type of valve it is, the manu-
5 facturer, and so on. That will be part of our generic review.

6 The primary coolant system configuration. We
7 do have for the B&W plants the once-through steam generator
8 causing the loop configuration into a candy cane type of con-
9 figuration. We're looking at that to see what possible kind
10 of design aspects exist with regard to the Three Mile Island-2
11 event. Also what effect it might have on entrained gases
12 and the natural circulation capability.

13 The once-through steam generator is unique to the
14 B&W plants, recognizing that it has a much smaller heat
15 capacity compared to Westinghouse and Combustion Engineering.
16 We have tried to assess its impact on the whole sequence.

17 The feedwater system malfunction: the principal
18 components, the history of it, will be included. And then also
19 the control and safety systems.

20 The B&W plants have an integrated control system
21 between the primary and secondary loops for control. We'll
22 be looking at that.

23 The safety systems, as far as their actuation goes,
24 what differences exist on B&W compared to the other pressurized
25 plants, and establishing the basis of whether or not we would

b15

1 have to do more on the basis of comparison.

2 DR. OKRENT: What do you really expect to look at
3 with regard to the control system for the B&W plants?

4 MR. TEDESCO: If you look at the control systems
5 with regard to the once-through steam generator, how these
6 things are coupled, realizing that with the smaller heat
7 capacity that you have and the smaller size of the heat
8 generator, the control system has to respond in a lot faster
9 way. It also involves the auxiliary feedwater system.

10 We found at Three Mile that the steam generator
11 went dry very early in the whole transient.

12 Now recognizing that for all these events, for a
13 small break, all pressurized water plants need auxiliary
14 feedwater systems.

15 And how does that tie into the control system?
16 The control system on these plants are generally not safety
17 grade. What effect does that have? That's just a kind of a
18 characterization of what we're looking at at this point.

19 DR. OKRENT: I guess I'm not quite sure what you
20 think you'll do with regard to your look at the control
21 system.

22 MR. TEDESCO: The role of the control system for all these
23 transients really hasn't been considered in great detail.
24 They've been considered to be normal plant operating features
25 where one has not had to rely upon their function.

wb16

1 Does the transient consider the anticipated event?

2 I think we have to re-think our whole process on that,
3 what role does the control system have. It may have to be
4 upgraded.

5 DR. OKRENT: Okay.

6 MR. TEDESCO: I just want to give you an idea of
7 the areas that we're looking at. Some of them may just not
8 be consequential, other ones may. We may have to add to it
9 and modify it as we go along.

10 DR. CARBON: A different question with respect to
11 Item 2 and your comment on natural circulation. Could you
12 summarize briefly what sort of calculation is done for each
13 of the different B&W plants to show that natural circulation
14 is feasible? And would you also comment on how much testing
15 is done at each of the plants to demonstrate natural circula-
16 tion capability?

17 MR. TEDESCO: Let me take the latter question.

18 Our preliminary review has shown that natural
19 circulation tests have been run at Oconee and at Davis-Besse.
20 They have been included.

21 DR. MATTSON: I might remind the Committee of the
22 discussion we had down here on RHR and the need to go to cold
23 shutdown on safety grade equipment. It must be two or three
24 months ago at this point. Where we talked about the state of
25 requirements for natural circulation testing and spoke to the

17

1 need to do additional natural circulation testing for that
2 safety grade decay, or RHR concern. I think we summarized
3 that for you at that point. That is, there are tests done
4 but they haven't been done on all plants.

5 Does that help?

6 DR. CARBON: It helps.

7 And specifically with regard to the plants under
8 discussion here, they have been run on Oconee and Davis-Besse?

9 MR. TEDESCO: That's my understanding, yes.

10 DR. CARBON: And not on the others?

11 MR. TEDESCO: I don't know about Three Mile. I
12 haven't checked.

13 DR. MATTSON: The B&W side of the room is nodding
14 that that information is accurate; those two plants have natural
15 circulation tests and the others do not.

16 MR. TEDESCO: Your first question about the analysis,
17 Ivanhoe is in the process of performing an evaluation of the
18 Three Mile Island situation for natural circulation. I don't
19 know the results. Maybe later on when Carl Berlinger comes
20 down he can share it with you. But I know we initially had an
21 evaluation of this matter.

22 DR. CARBON: Let me go back to a further question
23 to either you or Roger. Some of the B&W plants have the steam
24 generators quite high and some of them quite low. Are the
25 two tests that have been run, natural circulation tests, are

wbl8

1 they believed to cover both the situations, the high steam
2 generators and the low?

3 DR. MATTSON: Our answer is Yes, from over here.
4 We think it does. Let's see if B&W can confirm that so we
5 have the right information.

6 Yes, they indicate yes.

7 DR. TEDESCO: Ocone is representative of low
8 steam generator, Davis-Besse the high steam generator.

9 DR. PLESSET: Does the operator get adequate
10 preparation for going to natural circulation from full power
11 condition? And is it at all made aware of the importance
12 of the pressure in the reactor and its effect on natural circu-
13 lation?

14 DR. MATTSON: I think that's a little bit different
15 question. I don't believe these kinds of tests are conducted
16 starting from a full power, going through--

17 DR. PLESSET: I don't mean that. But I mean, is
18 the operator aware of the things he might have to go through
19 to get to natural circulation from full power?

20 DR. MATTSON: To my knowledge that is not a design
21 consideration in setting up these procedures. But it's subject
22 to check.

23 Does anybody over here have it?

24 MR. TEDESCO: We do know for loss of flow that
25 they have to track through. That would be loss of power or

wbl9

1 tripping of the pumps. So that is an effect that's analyzed.

2 DR. PLESSET: Well "analyzed," of course, is one
3 thing. It means that some sophisticated engineer -- let's
4 call him sophisticated -- has analyzed it. Does that mean
5 that the operator understands what he's going to have to go
6 through?

7 MR. TEDESCO: I really don't think at this point
8 I could give you a specific answer. As far as the detailed
9 operating procedure--

10 DR. MATTSON: We can get a specific answer pretty
11 quickly. Let us step out and make a call and we can get your
12 question answered on the record.

13 MR. MICHAELSON: I believe you indicated some
14 preliminary findings concerning the question of pressurizer
15 level. Would you clarify that these preliminary findings per-
16 tain both to the short term -- and by that I mean maybe the
17 first thirty minutes -- versus the long term, meaning the next
18 10, 15 hours?

19 MR. TEDESCO: Dr. Michaelson, I was speaking to
20 the initiation, the initial part of the transient.

21 MR. MICHAELSON: Well, do you have any comments
22 or preliminary observations concerning the longer term?

23 MR. TEDESCO: I guess as long as you are pres-
24 surized, voiding in the system, you would indicate a level.
25 Once you started with a simulated break up in the top side of

20
1 the pressurizer I think you're going to have -- you will
2 equalize somewhere in this time frame, and the level should
3 show a decrease. That would be in the long term.

4 PROF. KERR: Mr. Michaelson, let me in on what it
5 is you're driving at. What are the significant differences
6 between short and long term?

7 MR. MICHAELSON: Well, I was really searching
8 just for a clarification on a statement concerning the effect
9 of the loop seal on the pressurizer. I would fully agree
10 that the loop seal is immaterial in the short term, meaning
11 while the system is still essentially filled with water.
12 I would not necessarily agree with it being immaterial in the
13 long term.

14 PROF. KERR: Thank you.

15 DR. OKRENT: During the recent interchange of
16 questions and answers there was mention of loss of offsite
17 power as a possible way in which you could lose feedwater,
18 and so forth. And I was wondering whether in either your
19 analysis of what you're doing and, even more importantly, in
20 your questions and advice to those who have operating reactors,
21 whether you have included the examination of that transient
22 as something that the utilities should give attention to,
23 and whether you have thought in that regard.

24 MR. TEDESCO: In Bulletin 79-05, appended to it is
25 a summary write-up on the Davis-Besse incident where they

21

1 experienced a loss of offsite power, and the concerns about
2 loss of equipment affecting the core are described in that
3 attachment.

4 The next step of where we are today on the generic
5 review, when I get further into the licensing aspects I'll
6 be indicating that we do have to open up the whole approach
7 on the evaluation of feedwater transient. We have not made
8 specific evaluations yet with or without offsite power ques-
9 tions. But it will be part of our effort.

10 DR. MATTSON: Let me try to answer that the same
11 way but in little bit different words.

12 The bulletin's immediate on-going action is narrow-
13 ly looking at the event at Three Mile Island to avoid its
14 repetition. What Bob is saying is that the short term
15 study tht he's doing would include an assessment of other
16 possible initiators of this kind of event for study over the
17 long term, or for an identification of need to do something
18 if there's a need to do something in the short term.

19 We understand the importance of offsite power as
20 (a) an initiator of this kind of sequence, or (b) a contribu-
21 tor to the difficulty if you have some other initiator of
22 this kind of sequence. And both of those thoughts will have
23 to be factored into the broader question that Bob is
24 addressing.

End 1D
General Reporters, Inc.

25

67-078

bl

3.250

1 DR. OKRENT: But you haven't asked the utilities
2 to review their procedures with regard to that specific
3 initiating event; is that what I understand?

4 MR. TEDESCO: Let me get the bulletin out and
5 read right from it.

6 DR. OKRENT: It may be there. I was looking at
7 79-08.

8 MR. TEDESCO: Inclosure 2 is an evaluation of
9 feedwater transients in 79-05. And it says: A loss of off-
10 site power occurred at Davis-Besse -- and so on. And we're
11 transmitting this information. And the bulletin says: to
12 review the evaluation by the Staff of the postulated severe
13 transient related to B&W PWRs as described in Inclosure 2.

14 Do you have it?

15 DR. OKRENT: Well I was looking at 79-08 and I
16 didn't see so specific a reference to this.

17 I mean, we've been talking about whether the
18 primary system pumps should be turned or something. They'll
19 be turned off automatically in that case. And you have a
20 rather different transient and you are rather quickly under
21 other circumstances. And if all the effort and thinking is
22 aimed in one direction it might lead operators to be sort of
23 directed down one road, as they may in fact have been here
24 worried about overpressurization from lots of discussion about
25 overpressurization a year ago.

wb2

1 If I can ask just two other short questions:--

2 In your opinion is there a difference with regard
3 to the probability of a transient like a feedwater transient
4 or a control transient, or so forth, if the reactor is load
5 following or if it is running base loaded?

6 MR. TEDESCO: A base loaded plant is a stable plant.
7 You're just producing a certain fixed power level and just
8 balancing for short maneuvering type adjustments. I guess
9 in my opinion a plant that's a demand type of plant it probably
10 would affect the probability. That's just an opinion. I
11 don't have the hard data in front of me.

12 DR. OKRENT: I didn't notice anything in the dis-
13 cussion about operating plants, whether one wanted to consider
14 whether they should stay in the load following mode if they
15 were so, or not. And I was just trying to ascertain whether
16 you had given the matter consideration and arrived at a judgment
17 or not.

18 MR. TEDESCO: Not at this point.

19 DR. OKRENT: All right.

20 And just a question that relates really to the
21 previous discussion. I didn't seem to see anything that
22 related to trying to make more available temperature informa-
23 tion from the core in any of the bulletins. Did I miss it?

24 MR. MATTSON: No; it's not there. I think that's
25 part of the broader questions that we're looking at. The

wb3

1 whole question of instrumentation to follow the course of an
2 accident is one that we view has to be relooked at. The
3 question of qualification of equipment not normally called
4 safety grade equipment is of higher importance today than it
5 was two weeks ago. Certainly within those two categories
6 falls a question of the sort you just phrased, that is,
7 temperature instrumentation from the core. It's not in a
8 bulletin, but it is in our minds and it is in our scope of
9 inquiry; yes, sir.

10 While we're pausing a moment, if I could go back
11 to Dr. Plesset's question, and I think, Dr. Okrent, your line
12 of inquiry was somewhat related. The thrust of it was, a lot
13 of these things are analyzed by sophisticated engineers, I
14 believe they were described as, and safety analyses and
15 safety evaluations, but are there procedures. But certainly
16 for something like loss of offsite power, which is something
17 that happens and you lose reactor coolant pumps and you depend
18 upon aux feedwater, there are procedures for bringing that
19 plant into natural circulation and cooling with auxiliary
20 feedwater, and training of operators to do those kinds of
21 things is done, and operators are examined on their capability
22 to bring a plant into natural circulation following those
23 kinds of initiating events.

24 Now whether the question of-- Well, that's enough.
25 Does that get to your point?

4
1 DR. PLESSET: I think so.

2 But what I was in particular concerned about, would
3 the operator appreciate the significance of getting to satura-
4 tion pressure in the core, or even close to it, what that
5 might mean for the condition within the core. I think that's--
6 I don't know; it might seem subtle to some operators.

7 MR. MATTSON: I think he would appreciate it.
8 I think it's also safe to say he'd appreciate it better today
9 than he might have before. And that's part of the review
10 that's going on.

11 DR. PLESSET: Thank you.

12 DR. CARBON: Steve?

13 DR. LAWROSKI: In connection with the question
14 that Dr. Okrent just raised about following some of the
15 temperatures in the core, in the plants that have been in
16 operation somewhat longer and perhaps have been refueled,
17 are all of those thermocouples present in those plants?
18 As I understand, sometimes they're not included upon refueling.

19 MR. TEDESCO: Do you know if the thermocouples are
20 also in the older plants that have been refueled, Roger? Do
21 you know?

22 DR. MATTSON: I was led to believe that this
23 instrumentation was, the in-core thermocouples were pretty good
24 in this plant compared to some others.

25 I think maybe B&W could answer that better than us

wb5

1 at this point.

2 Recall that this instrumentation is not required
3 for safety purposes according to the way we normally do
4 business. This is plant monitoring information.

5 DR. LAWROSKI: Could I get an answer to my ques-
6 tion?

7 DR. MATTSON: I'd have to turn to B&W to see if
8 they have that information. I don't have it off the top of
9 my head.

10 MR. McMILLAN: I'm John McMillan from Babcock and
11 Wilcox. We do have in-core thermocouples in all of our operat-
12 ing units. In not all cases are they connected directly into
13 the computer where the operator would have an immediate read-
14 out. But there are thermocouples installed in each of the
15 operating units.

16 DR. LAWROSKI; Thank you.

17 DR. CARBON: Bob, in your review of loss of offsite
18 power, will you carry this further to include a case where
19 maybe the diesels don't start up?

20 MR. TEDESCO: You're talking about a total black-
21 out situation? At this point that's one of the generic
22 matters that we're looking at from the overall, you know,
23 Category A safety items. Not at this point is it a specific
24 requirement. The generic review on this particular event,--
25 Remember, it's a short-term approach we're taking from the

vb6
1 learning experience on Three Mile Island and what it means
2 right now. But the generic review on the longer term, we want
3 to acknowledge the loss of power incident as an initiator.
4 But at this point I do not see a total loss of power as being
5 involved specifically.

6 DR. MATTSON: It's important to remember also
7 that steam driven aux feed pumps do exist in all of these
8 plants, all the PWRs.

9 DR. CARBON: Steve.

10 DR. LAWROSKI: In how many of these are they not
11 connected to the computers?

12 MR. McMILLAN: There are fifty-two thermocouples
13 in all of the units. They connect to the plant computer on
14 the three Oconee units, Three Mile Island-2, Rancho Seco
15 and Davis-Besse. They do have them at Crystal River as a
16 computer input through a multiplexer, so that you can't read
17 them simultaneously. It's a little different configuration.

18 At Arkansas Nuclear-1 the in-core detectors can
19 be read from the in-core detector tank. But that's inside the
20 reactor building and not accessible to the operator.

21 DR. LAWROSKI: Thank you.

22 DR. CARBON: Roger, could I go back to your last
23 comment here.

24 Have you ever put probabilities together for
25 plants like these on loss of offsite power and the diesels

67-084

wb7

1 don't start, and this single pump -- which I understand
2 really aren't very reliable sorts of pumps. Just in general
3 the sequence here.

4 DR. MATTSON: As I recall, that's Task A under
5 General Issue A-44, which is one of the unresolved safety
6 issues. It is to do just exactly what you're asking for.

7 DR. CARBON: To try to put some probabilities
8 together?

9 DR. MATTSON: Yes. That is, to assess the
10 reliability of aux feedwater from just the view that you
11 propose.

12 Saul reminds me that the Reactor Safety Study
13 looked at that aspect. But, of course, that's only one
14 plant.

15 DR. CARBON: Yes. Do you have any idea what kind
16 of timing this particular generic item will receive?

17 DR. MATTSON: I'd suspect that that kind of infor-
18 mation in the normal course of events we'd see some time next
19 fall. Whether the Three Mile accident adds or subtracts from
20 the capability to meet such a goal is unclear to me at this
21 point. It's going to depend in large measure on the results
22 of Bob's work in which he is, in essence, going to say, These
23 are the important things to do now, and here are the things
24 that can be left to do a little later. And I don't know where
25 that one comes out for sure.

wb-8

1 DR. CARBON: Thank you.

2 DR. LAWROSKI: With respect to, I think it was
3 Dr. Okrent who asked about maintaining the offsite power,
4 some of the helicopters that were flying around this plant
5 were not all required in connection with monitoring this
6 plant, it's plumes, and so on. How long did it take to get
7 the others out of the way so that at least they wouldn't be
8 there to jeopardize that offsite power which might have been
9 needed?

10 DR. MATTSON: Dr. Lawroski, I can say that by the
11 time I arrived at the site on Sunday that I was told that the
12 plant had been placed in some sort of special status with
13 regard to assurance of offsite power from the grid if there
14 were difficulties with the grid. I was told that there were
15 five separate offsite power lines into the facility, so that
16 if one were lost it didn't mean you were necessarily in diffi-
17 culty.

18 I also saw helicopters flying there. I don't
19 believe there were any at that time that were not connected
20 with monitoring efforts either by the government or by the
21 licensee. By Monday they had moved the landing pad to a
22 better location relative to one offsite power line. And I
23 think that situation is under control.

24 DR. LAWROSKI: That was some time after, your ar-
25 rival was some time after.

b9

1 DR. MATTSON: Yes. I would suspect it's fair to
2 say it was under control by Saturday. I don't think it was
3 too far out of control ever.

4 DR. PLESSET: Can we move on, then?

5 (Slide)

6 MR. TEDESCO: This slide is the second part of our
7 review, which deals with operational matters.

8 The equipment malfunction history. We are looking
9 at the LERs to see if we cannot assess the malfunction history
10 as far as the power operated relief valves. We're looking at
11 the operator actions during this event. We're looking at the
12 probable response to feedwater transient. Plus the human
13 factor in the whole situation, how he follows procedures, why
14 he did certain things. We'll see if there are not generic
15 conclusions that one might be able to establish from the
16 operational experiences that we derive from the Three-Mile-2
17 accident.

18 (Slide)

19 The other part has to do with our NRC role on the
20 licensing basis that we follow in the evaluation of feedwater
21 type transients. We're looking at the vendors' message, their
22 models and capabilities, the general approach that one follows
23 in the evaluation of these types of transients.

24 We're reviewing the staff approach to transient
25 evaluation, namely, the general design criteria and the Standard

wb10

1 Review Plan that describe the review areas, the review cri-
2 teria and the findings that we make in our reviews.

3 We certainly now have to go back and re-look at
4 the whole process to see what's going on in the light of the
5 Three Mile Island-2 accident.

6 Along with this is involved a review of technical
7 specifications, What are we putting in as requirements on
8 these plants? Are some areas perhaps too refined? Are we
9 being too specific in certain areas? And in other areas are
10 we not being specific enough with regard to pressurizer,
11 pressurizer level, aux feedwater systems and the reactor trip
12 system. And then folding that into the operator procedures
13 to try to better understand what the operator follows; What
14 is he told to do in these type of transients, and how does
15 that fit into the Three Mile Island situation?

16 The last category will deal with the operator
17 training itself. What is the training that he gets to cope
18 with transients of the type we've just had, and others as
19 well?

20 So we're expanding our look into the whole area
21 on the licensing basis, what our regulations tell us to do,
22 what are the areas of weakness now which we could perhaps
23 beef up. That is part of our generic review.

24 So when we put the three parts together: one about
25 the design, one about the operational aspect, and the other

vbll 1 about the licensing basis, then in the short term we'll be
2 looking at the I&E bulletins, confirming the action taken
3 there, their adequacies: we may have to add to it in certain
4 areas depending on what we find out. And then launching into
5 a long term generic program that will look at all the aspects
6 that we're considering.

7 (Slide)

8 Right now where we are in regard to the three
9 areas: As far as design of the B&W plant, our preliminary
10 review indicates to us that we find no apparent major design
11 deficiencies on the B&W plants. This would not preclude
12 serious consideration of areas where improvement might be
13 accomplished to improve the safety capability of the plant.

14 As far as the operation goes, we certainly agree
15 that greater attention is needed on the plant safety equipment
16 with regard to its operability and availability, and greater
17 assurance has to be placed on this matter.

18 With the licensing aspect we certainly need more
19 emphasis on what we had earlier believed as a regular anti-
20 cipated event. We have to look harder at operational transients,
21 especially the feedwater type of event: what our tech spec
22 requirements are, the areas where they have to be augmented
23 or modified. And in conjunction with this whole review that
24 we are going through, we will be folding this into the I&E
25 bulletin action to confirm the actions that are being required.

67-089

wbl2

1 We are working toward an action date of something
2 like the end of this month to try to get our preliminary
3 report put together that will speak to the areas that we have
4 talked about right now.

5 That's the conclusion of my presentation.

6 DR. SHEWMON: If you ever got there, I missed just
7 what the testing procedure is on these relief valves on the
8 pressurizer.

9 MR. TEDESCO: Right now there would not be any
10 tech spec requirements for testing, periodic testing. That
11 question was folded into my tech spec review. We perhaps have
12 to rethink that requirement.

13 DR. SHEWMON: Have you ever got to whether a
14 meaningful test could be done without having pressure, a
15 significant amount of steam be released at the same time,
16 or without it being tested at 2200 pounds pressure in two-
17 phase flow?

18 MR. TEDESCO: I indicated earlier that a lot of
19 this concern that's being expressed with regard to ATWS,
20 it's the same type of question.

21 As far as the testability goes on the plants, the
22 safety valves and so on, they're all tested in accordance with
23 the ASME requirements, which means bench type tests for
24 actuation.

25 DR. SHEWMON: And they do that once, and that's good

wb13

1 forever?

2 MR. TEDESCO: I'm not sure what the frequency
3 is, whether it is only once, or after a certain modification
4 or maintenance procedure. I don't know specifically what
5 it is.

6 DR. SHEWMON: Who in the organization is responsible
7 for this?

8 MR. TEDESCO: This would be in Engineering under
9 Jim Dyke.

10 DR. SHEWMON: Thank you.

11 DR. CARBON: Chet?

12 DR. SIESS: Bob, will you be looking at the possibil-
13 ity of whether the use of evaluation model analyses, say for
14 small break LOCAs, can lead to inadequate or incorrect acci-
15 dent scenarios, and, thus, to inadequate guidance to the
16 operator?

17 MR. TEDESCO: At this point, yes. I can say we just
18 made some preliminary calculations at Idaho on this type of
19 test and it did reveal the thermodynamic behavior that was
20 experienced. So I have to say yes to your question.

21 PROF KERR. Are these models being used in the
22 conservative mode or a best estimate mode?

23 MR. TEDESCO: Right now, Dr. Kerr, the evaluation
24 that we are in the process of doing is based on the Three Mile
25 Island input parameters; in other words, what happened at

wbl4

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

that plant.

PROF. KERR: If one uses an evaluation model that conforms, for example, to Appendix K the emphasis is on conservatism rather than realism. Is the evaluation model being used that kind of model?

MR. TEDESCO: Up until March 27th the evaluation model was used on small breaks. It was not coupled to transient type events. We just have to re-look at the whole procedure, the process. I understand what you're saying about the conservative model passing out because of some of the subtlties that happened. It's a precaution that we will consider.

DR. PLESSET: It may not be entirely pertinent for what they were trying to do in their analysis, I believe, whether it was evaluation or best estimate. I think that in a best estimate mode they've gone beyond in trying to describe what happens, I think. Isn't that right?

MR. TEDESCO: Yes.

I have a curve, if you would like to see it.

DR. PLESSET: The only concern they would have would be what the decay heat would do, and probably there they would take the best value they would have.

DR. MATTSON: They took the parameters measured at Three Mile Island and input those to the code to see if they could reproduce the transient. And that, in effect, removes

wbl5

1 the conservatisms that are there for a loss of coolant accident
2 analysis that's done under the more traditional framework.

3 (Slide)

4 MR. TEDESCO: Here's a comparison of the Three
5 Mile Island event and the transient that's calculated by the
6 Idaho people. It's a preliminary thing. In the lower part
7 here--

8 DR. LAWROSKI: Could you use the pointer and stand
9 to the right, please?

10 MR. TEDESCO: All right.

11 Here we go. The solid curve is our RELAP run. As
12 indicated down here, the dashed line is the Three Mile
13 transient. There are phasing differences. This plot here is
14 the peak saturation during the process, and following along
15 until we reach somewhere about this range.

16 This spike appears about in the eight-minute point
17 at which the aux feedwater system went on, eight minutes into
18 the transient. The other curve I'll show you is related to
19 this, it's the pressurizer level. This pressurizer pressure
20 is falling during this period.

21 (Slide)

22 Here we put the level on with the same type of
23 nomenclature. You see the solid means the RELAP-4 run and
24 the dashed means it's the actual transient. And during this
25 period here we're showing a rising level, and the other curve

wbl6

1 shows the pressure going down.

2 Let me see if I can't put the two together.
3 It's a kind of a messy configuration, but let me see if I
4 can walk through it with you.

5 (Overlay)

6 This one here is pressure, showing it going down
7 during the transient, and then showing the level going up in
8 the pressurizer. And that's what the operator was responding
9 to. He thought he had plenty of water in the system and
10 that everything was well under control. He was following
11 procedures in the shift over to maintaining the level.

12 These are very preliminary runs. We haven't
13 gone through a thorough evaluation. They're running up to
14 about 12 and 20 minutes into the transient.

15 DR. SIESS: Is RELAP-4 an Appendix K approved
16 licensing evaluation model?

17 MR. TEDESCO: Yes, that's what we used.

18 DR. PLESSET: That's not quite the understanding,
19 Chet. It's not used for evaluation model analysis.

20 MR. TEDESCO: I think it is.

21 DR. PLESSET: But that's not what was used here?

22 MR. TEDESCO: No, not here. This is the RELAP-4
23 code that was used to mock up Three Mile Island.

24 DR. PLESSET: It looks as though it's doing fairly
25 well.

7
1 MR. TEDESCO: Trend-wise I think it looks pretty
2 good. There's a little shift on time sequences that we
3 haven't ironed out yet. But for a quick run to get some quick
4 sense of what happened, I think it's pretty good.

5 DR. CARBON: Dave?

6 DR. OKRENT: Bob, I think you made a comment that
7 as of now you don't see any basic design deficiency.

8 MR. TEDESCO: I used the word "major."

9 DR. OKRENT: Major design deficiencies.

10 MR. TEDESCO: Yes.

11 DR. OKRENT: In what context are you making that
12 statement? Is it in terms of the specific transient or
13 accident at Three Mile Island, or is it a general one where you
14 consider response to small breaks of all sizes, or a range of
15 transients, or what's the context of the comment?

16 MR. TEDESCO: The initial attention is on the
17 Three Mile Island event, on what experience we've derived from
18 that. Folding that into the design of the plant, do we see
19 anything basically wrong with it? And as far as we can tell
20 at this point, from a short term look we have found no major
21 design deficiencies.

22 DR. OKRENT: How do you plan to ascertain whether
23 there could be, or may be design deficiencies, if there are
24 any, for other kinds of transients, including small breaks
25 or intermittent breaks or whatever?

wbl8

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. TEDESCO: I have to rely on the outcome of our generic program for that. I tried to indicate our short term approach. It clearly focuses on Three Mile. And then we have to shift into the more generic aspects. The outcome of our report will be a set of findings and recommendations from whatever we learn, and not to be so narrow that we don't look at other aspects of it.

d 1E

lf ebl

1 DR. OKRENT: Has the Staff initiated a long-term
2 program concurrently with the short-term program, or does it
3 have to wait?

4 MR. TEDESCO: That's what we're trying to do now.
5 That's part of our effort.

6 MR. MATTSON: Part of the goal of the short-term
7 program is to define the long-term program.

8 MR. TEDESCO: We're only a part of the whole effort
9 on this thing. You know, if anything has taken priorities, if
10 it's one, two, three or A, B, C, it's one and A, believe me,
11 on the whole thing.

4.040

12 MR. MICHAELSON: Bob, I have just one question and
13 that is I'm having a little difficulty yet sorting out the
14 short-term events at Three Mile Island and the longer-term
15 events. You addressed here the computer calculations and ob-
16 servations and also drew a preliminary conclusion concerning
17 I guess the short-term situation.

18 Would you care to surmise or at least indicate what
19 you feel concerning the longer term, and also indicate perhaps
20 when you really think the damage occurred. Is it a short-term
21 effect or a long-term effect, and if it is a long-term effect,
22 then that's the one that appears to be the desirable one to
23 concentrate on.

24 DR. SHEWMON: By "damage" do you mean core damage?

25 MR. MICHAELSON: I mean when did all the activity

eb2

1 appear to be released? Core damage of course is the thing of
2 major concern here.

3 MR. TEDESCO: When I contrast long term and short
4 term I do not include such things as the containment isolation,
5 dealing with hydrogen, dealing with highly contaminated fluids,
6 and stuff like that.

7 I'm in short term looking at initiating events
8 and how it propagated in the system, up to the time we had the
9 core damage which was, you know, within the two-hour period
10 when the went off, and just seeing what the reactor responded
11 to.

12 As far as the long-term accident recovery, that's
13 another type of generic program that we'll be following.

14 MR. MATTSON: Maybe I can try.

15 Bob, I think two hours is about the time that Carl
16 is starting to get interested. It's between two hours and 15
17 hours that damage occurred, according to the information we
18 have today.

19 Bob is saying he's looking at the transient up to
20 that point that got you into the situation where damage did
21 occur, and that's the kind of thing that we want to concentrate
22 on in the sense of the short-term for deciding what are the
23 proper things to do from a procedure standpoint or a design
24 modification standpoint or an operator training standpoint to
25 not get in a situation where such damage would result.

3
1 Clearly there has to be a good look at the mechanisms
2 of damage, how the system was behaving once you got into the
3 box that could cause damage. A lot of that is going on right
4 now, trying to characterize what the core looks like for long-
5 term cooling purposes, trying to understand the mechanism of
6 damage, the extent of damage; that sort of thing.

7 I suspect that that may in fact be finished before
8 Bob has got his long-term program underway. We're not ignoring
9 it. But Bob is saying he's concentrating on the safety of
10 operating plants.

11 MR. MICHAELSON: Maybe I can make one more comment
12 in clarification then.

13 I would have to conclude from what you have said I
14 believe that you have strong reason to believe the problem
15 developed in the first 20 minutes and that that was kind of the
16 end of the analysis. Is that right?

17 MR. MATTSON: I think the sequence of operator actions
18 and equipment performance in the first 20 minutes is very
19 important and over the next two hours it is also important.
20 By the time you finish the first two to three hours, you're
21 in a position where the core is being damaged, extensively
22 damaged. And the goal here is to avoid getting beyond that first
23 two hours.

24 It's certainly important to understand what happened
25 after the two or three hours but with the idea being that you

b4

1 don't want to repeat that, then the focus right now, in our
2 judgment, has to be on how do you prevent the first two hours
3 from occurring.

4 MR. MICHAELSON: Are you intending to carry the
5 analysis out further than 20 minutes, say for the first two
6 hours?

7 MR. MATTSON: Oh, yes. I think eventually there
8 will have to be an analysis that extends not only the first
9 two or three hours but tries to reconstruct the physical situa-
10 tion within the reactor vessel over the whole accident, right
11 up until today.

12 Sol reminds me that a lot of that is not done with
13 computer calculations. Once you get steady-state and stationary,
14 stable, a lot of it is done by hand calculations. Computer
15 calculations of the sort that Bob has shown won't go that long.

16 DR. SHEWMON: I think we're all concerned that one
17 doesn't get too enamoured about how well one can get the com-
18 puter to fit the irrelevant part of the curve, the marginal
19 irrelevant.

20 MR. MATTSON: Yes, sir.

21 DR. CARBON: Are there other questions by the
22 Committee?

23 (No response.)

24 Does that then conclude the presentation?

25 MR. MATTSON: Yes, that's all we had planned this

1 morning. And the other things I mentioned we will be prepared
2 to discuss later this afternoon.

3 DR. CARBON: Let's then take a ten-minute break.

4 (Recess.)

5 DR. CARBON: Let's move on to the next part of the
6 agenda. I would like to call on Mr. Etherington to lead off
7 discussing the status of the Three Mile Island Station.

8 Harold, will you present your report?

9 MR. ETHERINGTON: Mr. Chairman, I spent two and a
10 half days with Dr. McCreless of the ACRS staff at the site,
11 from April 10th to 12th, observing the offsite activities
12 across the river from the plant, attending meetings, and talking
13 to personnel.

14 Other Committee members and Committee consultants
15 attended at various periods and I presume they have also made
16 their own observations.

17 My observation is the two organizations, the
18 Three Mile Island Recovery Organization and the Industry Ad-
19 visory Group, comprise an exceptional assemblage of high-level
20 talent. It would be difficult to get together an organization
21 better qualified to steer the recovery.

22 The chain of events has already been described by
23 Mr. Michaelson to the Committee at a previous meeting, and I
24 believe he proposes to update his conclusions.

25 We have also heard from the Staff and expect to hear

S.LL)

xzxzxz

eb6

1 further complete statements on the chain of events, and the
2 recovery procedures from others during this meeting.

3 With your permission, I would like to forego a
4 statement that would be fragmentary and prove repetitive, and
5 I would like to focus the attention of the Committee on two
6 basic, if obvious, requirements for natural circulation, one
7 of which appears -- and I emphasize "appears" -- from the re-
8 cord -- Let me restate that -- one of which appears from the
9 record -- and I emphasize "appears" -- not to have been met at
10 the Three Mile Island Plant, and this could well have been the
11 prime cause of the seriousness of the accident.

4.135

12 If I may go into that description, Mr. Chairman?

13 The heat sink in the steam generator must be at a
14 higher level than the core of the reactor. Obviously, if the
15 heat sink is at the same level as the core, we have a hot
16 leg which is balanced by a hot leg, a cold leg which is balanced
17 by a cold leg, and no driving force to promote circulation.

18 If the core is much below the heat sink or let me
19 say it the other way: If the heat sink is above the core, then
20 we have a balanced hot leg here, a balanced cold leg here, and
21 a cold leg here, which is also offset by a hot leg here, and
22 the driving force is the height of the one-inch square column
23 of cold water minus the weight of a one-inch-square column of
24 hot water.

eral Reporters, Inc.

25

Now clearly the first requirement is that the heat

b7

1 sink must be higher than the heat source. A conservative
2 interpretation would be that the heat sink should be as high
3 as possible in the steam generator.

4 Now, let us look at the actual conditions. During
5 steaming operation at full power, the level is 42 feet high
6 in a total cube length of 52-odd-feet. At full power
7 the level in the steam generator is about 42 feet.

8 At low power, down to 10 percent, the level is only
9 about 7 feet way down here.

10 Tom McCreless and I looked hard to find a statement
11 of what the condition would be during operation of the auxi-
12 liary feedwater system. We found the statement in either the
13 SAR for Three Mile Island or in one of the PSAR -- I forget
14 which it was we found it in. We looked in both. And the state-
15 ment was that when the auxiliary feedwater came on, the level
16 is to be maintained at an unspecified high level.

17 However, the record appears to show that following
18 dryout after the loss of feedwater, the level remained ex-
19 tremely low, about one foot, way down here, about 20 minutes
20 and at the time the recirculating pumps tripped, the level was
21 only about five feet, still way down here.

22 One obvious conclusion which one would be tempted
23 to make is that there could be no possibility of a natural
24 recirculation occurring at that time. Now I will qualify that
25 statement later.

b8

1 Obviously another conclusion-- The first conclu-
2 sion would be that the level control appeared not to function
3 as stated in the SAR.

4 After the pump was tripped, the water level rose
5 slowly in the steam generator and the secondary pressure dropped
6 to about 300 psig. This clearly suggested a continuation of
7 inflow of feedwater but with loss of heat sink inasmuch as the
8 temperature -- pressure in the steam generator didn't rise at
9 all. It was actually falling.

183

10 At the time the satisfactory level was reached, and
11 this was very late in the transient after the pumps had been
12 tripped, the second requirement, which I will mention now, could
13 not have been met, and therefore, natural circulation couldn't
14 have been promoted at that time.

15 The second requirement is that the pressure of the
16 reactor coolant must be high enough to prevent breaking of the
17 circuit by gas accumulation at the top of the loop. If we have
18 an accumulation of gas here, clearly it will be a problem in
19 establishing recirculation.

20 A conservative interpretation of this criterion
21 would be that there should be no release of gas.

22 I believe -- and I think if I'm not correct I would
23 like the physical chemists to correct me -- if we have a gas
24 bubble in the system and the free service of water, the pressure
25 here we'll say is P, and we'll give that a saturation

eb9

1 temperature, CP_{sat} , then the pressure here will have to be P_{sat} .
2 The saturation pressure corresponds to the temperature of the
3 water plus the partial pressure of the hydrogen in the bubble.

199

4 Now for a bubble to exist the pressure must be equal
5 to P_{sat} plus PH_2 , partial pressure of the hydrogen.

6 We can see what would happen. Let's suppose we in-
7 crease the pressure here and keep the temperature the same.
8 The saturation pressure of the steam would have to stay the
9 same. To balance this, the pressure of the hydrogen, the par-
10 tial pressure of the hydrogen will have to increase. For the
11 partial pressure of the hydrogen to increase, the hydrogen will
12 have to pass into the water in order to maintain the equili-
13 brium between the water and the gas phase, and that means the
14 bubble will shrink.

15 And ultimately when the total pressure exceeds these
16 two, there will be no longer any gas bubble.

17 Now I'm not a physical chemist, but I think that's
18 approximately right.

19 Steve, can you tell me what your opinion is?

20 DR. LAWROSKI: I think you're very modest.

21 MR. ETHERINGTON: This is now a presumption. By
22 the time the level rose in the steam generator to where you
23 could conceivably maintain natural circulation, there had been
24 so much damage to the core that there was a very large quantity
25 of hydrogen generated, and the loop that I erased at the top

eb10

1 of the steam generator is completely filled with gas, and there
2 is no possibility of recirculation.

3 Now please understand what I'm saying is not a state-
4 ment of what occurred. It is something which I think the
5 Committee might want to think about in its deliberations of
6 the over-all problem.

7 I should say something about the possibility that
8 there might have been some recirculation in spite of the very
9 low heat sink. There are two ways heat can get over.

10 The first is the spray. In the auxiliary feedwater
11 mode the spray is right at the top of the steam generator.
12 It's spraying on the tubes. I don't know to what extent it
13 penetrates the tube bank. I don't know how much water was
14 spraying, or how much heat could be removed; that is, what
15 temperature could be established in the cold leg.

16 The evidence, however, does seem to be that there
17 was no recirculation established. So whether this mode was
18 effective or not, I think we would have to leave it to B&W to
19 give us an analysis of the degree of penetration that they
20 could expect into the tube bundle.

21 The second possible mode of -- if I may call it a
22 degraded means of heat transfer to the steam generator. Shortly
23 after the pump trip the hot leg was at or above saturation.
24 We had hot water in the leg above the reactor vessel. There
25 would be bulk boiling, presumably, in steam, a crossover at

11 1 that point and steam could pass over, condensing in the water
2 in the cold legs and give you some mode of heat transfer which
3 might establish recirculation.

4 This doesn't look like a very strong mode of heat
5 transfer. Whether this would be an effective means of estab-
6 lishing natural circulation, I don't know, but the evidence
7 is of course that there was no natural circulation.

8 Now with these comments, it does appear important
9 that for all pressurized water reactors there should be a
10 precise instruction concerning the conditions necessary before
11 transferring from forced circulation to natural circulation,
12 and secondly there should be a clearly specified means of veri-
13 fying the natural circulation has in effect been instituted.

14 These apparently were lacking and I say again
15 "apparently" only as an inference.

16 I don't know how fast the steam generator can be
17 filled with the auxiliary pump. That also might be a factor.
18 If the reactor was operating with the water in the steam genera-
19 tor at a low level, then we would have to have a means of fill-
20 ing it fairly fast in order to establish the circulation.

21 Mr. Chairman, I think I will-- Well, let me see....
22 I think the Committee might want to have this in the back of
23 their minds as context material in considering the effects of
24 the early abnormalities. We could conclude that the early
25 abnormalities had no bearing at all on the subsequent events,

2 1 that in any case, as long as the transfer to natural circula-
2 tion was made, it was made with a low heat sink it could
3 not have been established, or we might conclude that the early
4 abnormalities did in effect contribute to what developed
5 later, possibly by gas generation.

6 I think that's all I have to say, Mr. Chairman.

7 DR. CARBON: Thank you, Harold.

8 Are there questions for Harold?

9 DR. PLESSET: I don't see quite how you can suppose,
10 if you had a fair amount of hydrogen in there, that it would
11 disappear. Certainly the vapor will disappear if the pressure
12 is above--

13 MR. ETHERINGTON: If you get the pressure high
14 enough so that the concentration of the hydrogen in the water
15 is greater than the partial pressure that you would have in
16 the steam space, then of course there would be no gas bubble.

17 DR. PLESSET: But the hydrogen is going to have to
18 dissolve.

19 MR. ETHERINGTON: It would have to dissolve.

20 DR. PLESSET: And it might be a very slow process.

21 MR. ETHERINGTON: Oh, yes. Excuse me, this is
22 strictly at equilibrium.

23 DR. PLESSET: Vapor condensation is rapid but the
24 hydrogen dissolution, that is--

25 MR. ETHERINGTON: You're absolutely right. I should

b13

1 have made it clear I'm talking about an equilibrium process
2 and the dynamics of it is something quite different.

3 DR. SHEWMON: To make sure I understand what you
4 said, on the first part you said not only do you need a solid
5 primary system for natural convection, you also need the water
6 level in the secondary side high enough--

7 MR. ETHERINGTON: -- to provide a heat sink which
8 it at a higher level in the core. You need a cold leg on one
9 side that more than balances the hot leg on the other side by
10 the greater density of the water.

11 DR. SHEWMON: A different one, though.

12 Do you have any evidence that says there was a signi-
13 ficant amount of hydrogen generated before, say, one and a half
14 hours, which was after both the pumps had been turned off?

15 MR. ETHERINGTON: No, I haven't. But the water level
16 in the steam generator remained low for a long time.

17 DR. SHEWMON: Long? You mean before and after the--

18 MR. ETHERINGTON: Before and after. It rose
19 gradually after the pumps were tripped, but it didn't reach a
20 really high level until hours, I believe, into the transient.

21 DR. CARBON: Fine. Let's go ahead then.

22 Carl, would you present--

23 MR. ETHERINGTON: Could I ask whether the Staff has
24 any rebuttal to what I said?

25 DR. CARBON: Surely.

1G agbl

1 The question was raised, do you have
2 any rebuttal to what Mr. Etherington has said?

3 MR. MATTSON: I think Harold understands the
4 situation quite well from the discussions he's had with the
5 people up there.

6 If I could try to summarize what I think the message
7 is, Mr. Etherington, then we can make sure we've understood
8 what you've said, because I think we agree with you.

9 I think you're saying that the success of putting
10 this machine on to natural circulation at the time the reactor
11 coolant pumps were tripped several hours into the accident
12 would have been a function of where the thermal center was in
13 the steam generator.

14 MR. ETHERINGTON: That's right.

15 MR. MATTSON: And the higher the better for that
16 thermal center.

17 MR. ETHERINGTON: Yes.

18 MR. MATTSON: But because the steam generators had
19 been through a transient where they boiled dry because of no
20 feedwater and then were refilled, that thermal center at the
21 time the pumps were tripped was low in the steam generator.
22 And had it been higher, natural circulation may in fact have
23 been achieved in time to prevent serious damage to the fuel.

24 MR. ETHERINGTON: That sounds right.

25 MR. MATTSON: That is more succinctly said today

b2

1 than I've heard it said before, but I have no reason to quarrel
2 with the technical facts that go into that kind of statement.

3 MR. ETHERINGTON: It doesn't seem to be very much
4 factored into the discussion of the chain of events, does it?
5 It hasn't really been discussed very much, this particular
6 phase of the accident.

7 MR. MATTSON: Well if I go back to Carl's point about
8 making sure that you look at the two to three hour portion of
9 the transient, I think the emphasis has been on early in the
10 transient, where the loss of feedwater and the stuck open relief
11 valve were very important controlling parameters. I have not
12 heard considerable discussion of what you're talking about.
13 I think there ought to be more.

14 DR. CARBON: Dave?

15 DR. OKRENT: Since this is not my field and I'm
16 trying to learn as I go along, I have to ask questions. And I
17 earlier asked questions about the loss of off-site power and
18 whether you were thinking about that, and what you were
19 suggesting operators be prepared to deal with.

20 What I can't tell is whether, in the event of loss
21 of off-site power, you might be in a position where your
22 steam generator level was low and where, when you hoped to go
23 into natural circulation, for example, you met one of the
24 conditions proposed by Mr. Etherington, a no-go condition,
25 in other words, too low a level in the steam generators.

b3

1 MR. MATTSON: I'm not sure I can answer a question
2 of whether we have confirmed that that's the case for the loss
3 of off-site power analysis. But certainly that would be an
4 important consideration in the loss of off-site power analysis
5 transient. Where you lost the reactor coolant pumps, you would
6 be on natural circulation in the primary system, you would have
7 a small transient in the secondary system where you went from
8 normal feedwater to aux. feedwater and the movement of the
9 sink or the thermal center, as we've been talking about it,
10 would be an important consideration in that analysis.

11 But these plants are analyzed for that event, and
12 shown to be capable of sustaining that event without fuel
13 damage.

14 The question I think you're phrasing is that event
15 as normally treated in the safety review is not compounded with
16 some of the failures that were observed early in the transient
17 at Three Mile Island and so how would some of those factors,
18 compounded with this normal transient, affect the course of that
19 transient.

20 DR. OKRENT: I guess I can't tell whether the short-
21 term program described by Tedesco earlier might benefit from a
22 little bit of broadening in what he's thinking about.

23 MR. MATTSON: Your question is, is this kind of effect
24 to be included in Tedesco's program? The answer is, it is.

25 DR. CARBON: Dr. Catton?

agb4

1 DR. CATTON: I'd like to make a couple of more
2 comments along the same line as Harold.

3 I don't think you could ever reliably establish
4 natural circulation with saturated fluid, I think the head is
5 just too high from the top of the steam generator down into
6 the core. Also, if you once bare the core and start to generate
7 hydrogen gas, I don't think your condenser is going to work.
8 Even if you have the surface available in the tubes of the
9 steam generator, I don't think you're going to get much
10 condensation. There will be blanketing by the hydrogen gas.

11 DR. SHEWMON: But the operator presumably could
12 have been able, or hoped he was able to go to natural circulation
13 when he turned the pumps off, which was before there was any
14 hydrogen generated.

15 DR. CATTON: But the fluid was saturated by that
16 time. He was boiling at that time. I think if the operator
17 knew that you can't get natural circulation with saturated
18 fluid, he might have done something else.

19 DR. SHEWMON: Saturating to you implies certain
20 areas which are super-super-saturated and thus it's boiling,
21 is that right?

22 DR. CATTON: Right.

23 DR. CARBON: Let's go on then, Carl.

2A agbl

4.440

1 MR. MICHAELSON: What I wanted to do this morning was
2 to go over the data that is now made available to us for the
3 event at Three Mile Island and discuss just a few of the curves
4 with you. The handout has 19 curves. I'm not going to discuss
5 all of them because of the limitations on time, but certainly
6 if you have a particular problem, I'll pull that particular
7 curve.

8 I'd like to keep this kind of informal now, so just
9 interrupt as we go.

10 (Slide.)

11 I'm afraid some of this will be repetitious from
12 what you might have discussed on other occasions, but I would
13 like to go through with you, just to be sure we're all together.

14 The first slide shows the --

15 PROFESSOR KERR: Excuse me. Would you comment on the
16 difference, if any, between these curves and the ones we saw
17 earlier, aside from distinctness of them?

18 MR. MICHAELSON: These are essentially the same
19 curves, the earlier ones were received by Thermofax or electronic
20 transmission, so some of the scales got stretched out, I
21 noticed. You can't overlay them too well.

22 These are pretty good curves, and they have a few
23 corrections already made on them. Keep in mind, of course, they
24 are still preliminary curves and may have other corrections
25 required. But this is the best we've got, and I think it is

agb2

1 appropriate that we work with these until we get something
2 better.

3 PROFESSOR KERR: Thank you.

4 MR. MICHAELSON: They have been redrawn and data
5 points have been plotted and you can tell now the difference
6 between strip chart data and computer data so they are much
7 more useful than that first set which were quite difficult to
8 read.

9 I didn't have time to cover these up so it's still
10 a little hard to follow these, but basically here's the pressure
11 transient that was observed. As the feedwater system was lost
12 and the turbine tripped, the pressure proceeded to rise on the
13 primary side until the relief valve opened, which was in the
14 vicinity of about 2250.

15 The reactor scrammed at about 10 seconds more or less,
16 and the pressure proceeded then to go at a very rapid drop,
17 which is to be expected. However, the drop is somewhat more than
18 is expected in that it appeared to go down continuously, and I
19 will show you later on the curves that have just kept on going
20 down, which was a little unexpected and perhaps indicative of
21 an in-progress loss of coolant accident.

22 While observing the level, you can see again the
23 level did a rapid turnaround. In fact, it turned around in
24 less than a minute which, for some people, was surprising in
25 view of the fact that the high pressure injection pumps were not

4.490

Jeral Reporters, Inc.

agb3

1 scheduled to come on until 1600 pounds was reached, which was
2 in the neighborhood of 2.5 minutes into the event. And you can
3 see from the curve here that there didn't seem to be any change
4 in shape when the pumps came on, which might be a little
5 surprising.

6 There is a fair indication -- and this is strictly
7 hearsay, I guess you would say -- there is a fair indication
8 that the first pump, of course, was running, the B pump was
9 running at time zero because it was used for normal charging.

10 The operator has instructions, apparently, at Three
11 Mile Island to manually start the A injection pump upon a
12 reactor trip in order to assure that you don't lose track of
13 where the level is in this transient, it helps to turn it around
14 much quicker. However, it isn't a safety requirement, since
15 that is only required at 2.5 minutes.

16 There's a possibility that he might have even turned
17 on the C pump, but we have no way to establish that at this
18 time.

19 But at any rate, there's nothing on this curve to
20 indicate pumps came on. There is an indication when the first
21 pump was tripped. You've got a nice little discontinuity.

22 This might have been the B pump, I don't know. If it
23 was, it was probably well throttled back because the B pump
24 was operating a level control off the pressurizer and wouldn't
25 have been delivering much flow at that point anyhow.

1 Interrupt me now if you have any questions. I'll
2 just go on, because there's quite a bit to cover.

3 (Slide.)

4 This is a plot of the temperature during the first
5 eight minutes. The temperature peaked at about 611 degrees on
6 the A loop on the primary side. It came down very quickly as
7 the cold leg temperatures rose and we see within one minute
8 we're establishing very small delta Ts through the core, which
9 is what's to be expected with all the reactor coolant pump
10 flow, and only reactor heat now to deal with.

11 It's also interesting to note that the temperatures
12 really didn't rise a whole lot for the first four to five
13 minutes. They started rising very rapidly when the first HPI
14 pump was tripped at about 4.5 minutes. Then they took off on a
15 pretty good slope here until about 8.5 minutes, at which time
16 the steam generator auxiliary feedwater was flowing and a new
17 heat sink was established.

18 Up to this point, the only heat sink that would be
19 apparent would be the open relief valve itself.

20 (Slide.)

21 This curve extends out into a little further time
22 to again show the pressure now coming down and reaching the
23 1600 pound setpoint somewhere in the neighborhood of 2.5 minutes.
24 And dropping on down to this point.

25 Now this is the point at which the system has

gb5

1 depressurized to the saturation conditions corresponding to the
2 T exit of the core. At that point, the system proceeded to
3 reheat because, as you recall from the previous drawing, this
4 is where the HPI pump was also tripped, and so the system
5 started to reheat and you're just seeing a saturation line here
6 which I will show you in a minute.

7 As soon as the steam generators became effective as
8 heat sinks, it turned the temperature right around and --
9 pardon me, it turned the pressure right around and it came
10 down again. The temperature was doing the same thing.

11 DR. CATTON: Was this following a saturation curve
12 during the last portion?

13 MR. MICHAELSON: I'll show you the curve in a moment.
14 It'll be easier to talk about it then.

15 (Slide.)

16 This is just a brief rundown of what happened to
17 temperature during the first 32 minutes. Again we see this
18 period of time when the temperature was rising rather rapidly
19 until the steam generator became effective and it turned it
20 around very nicely and you can see the hot leg temperature on
21 the A and the B loop.

22 Now the reason for differences here are probably
23 related to the steaming rates out of the two steam generators,
24 they were probably not steaming at the same rate for both
25 generators therefore one was running with a little larger

agb6

1 delta-T on it than the other.

2 DR. SHEWMON: Is there any evidence of when pressure
3 -- steam generator B opened up? There has been repeated talk
4 about leaks in that steam generator.

5 MR. MICHAELSON: I did not follow the leak situation,
6 but I think I have some curves that might give some idea.

7 DR. SHEWMON: Thank you.

8 (Slide.)

9 MR. MICHAELSON: This is the saturation curve you
10 were asking about. Here's the plot of saturation, pressure,
11 and here is the plot of the real system pressure. Of course,
12 it tracked very nicely until the steam generator became a heat
13 sink. At that point, there was a slight overpressure again
14 available on the system for up to about 15 to 16 minutes.

15 I would surmise that this overpressure was probably
16 available because there was quite a bit of heat remaining
17 in the pressurizer yet because of hot walls and, of course,
18 perhaps, the heaters were on. I do not know yet when the heaters
19 were lost to the event, but there was an overpressure, a very
20 slight one, during this period of time.

21 As you can see, it started losing at about 17
22 minutes.

23 DR. SHEWMON: Carl, is there any way that the operator
24 has of knowing where he is relative to saturation in something
25 like this, any practical way?

agb7

1 MR. MICHAELSON: The operator knows his pressure,
2 which is this curve, he knows his system T exit temperature,
3 which is measured up on the hot leg partway up, near the flow
4 elements, so he knows what the saturation pressure is according
5 to what temperature he reads and there's a set of these kind
6 of curves for each possible condition he could be in, I guess.

7 DR. SHEWMON: Well I guess my question is how does
8 he know it? He could go back and look at a chart on the wall
9 and figure it out if he has time and inclination, is that it?

10 MR. MICHAELSON: That would be it. If the chart
11 was readily available and it had been plotted up in a useful
12 form, he can pull the steam tables out and derive one. It's
13 not a difficult operation.

14 DR. SHEWMON: For an operator.

15 MR. MICHAELSON: Yes.

16 DR. SHEWMON: With three things going on.

17 MR. MICHAELSON: I don't think he would do this,
18 very likely, but he could.

19 Now we should keep in mind that this is not a real
20 fast transient, although it isn't exactly slow in terms of all
21 the kinds of things the operator is required to do.

22 DR. OKRENT: This is the sort of thing you could
23 easily teach a computer to do, I would think.

24 MR. MICHAELSON: You could easily read into a
25 computer the conditions and it will keep plotting the saturation

agb8

1 curves for you on a cathode ray tube or something, it would be
2 real handy.

3 (Slide.)

4 This is the auxiliary feedwater discharge pressure.
5 This is primarily simple evidence to show when the auxiliary
6 feedwater was likely to have started. The auxiliary feedwater
7 started up automatically, both the electrical and the steam-
8 driven.

9 Now there is a bit of conjecture yet as to whether
10 the electric-driven are automatic. But I have it on reasonably
11 good authority that they are automatic, but I'm not positive.
12 The steam-driven is automatic.

13 But at any rate, within 30 seconds or so they were
14 all up and running. And then they just sat along here at a
15 certain discharge pressure which is set by the pump characteris-
16 tic and the amount of minimum flow that might have been falling
17 back to some tank, enough flow to keep the pumps from boiling.

18 And they will set at a constant pressure until you
19 start to open up the valves, at which time the pressure will
20 drop commensurate with the increase in flow.

21 So you can say here, I guess, at eight minutes he
22 started to do something to increase flow on both the steam-
23 and electric-driven, and at about 10 minutes he did some more.

24 This is not real clear to me as to whether that
25 was an operator action or some kind of an automatic action, but

agb9

1 clearly something more was done to increase flow at around
2 10 minutes. And then it was backed off again at around 11
3 minutes, and I assume from then on they just got the flow he
4 thought he needed to put his steam generator wherever he wished
5 to keep it.

6 DR. OKRENT: Do you know if the valves that were
7 opened were opened from the control room or from another
8 point?

9 MR. MICHAELSON: I did not talk with the operator
10 who was in the control room at that point, so anything I could
11 say would be purely hearsay.

12 So would you rephrase the question and I'll give you
13 the hearsay.

14 DR. OKRENT: At eight minutes the valves that were
15 closed and preventing auxiliary feedwater flow were opened.
16 From where were they opened? Was it a manual or a remote
17 procedure?

18 MR. MICHAELSON: It's my understanding only from
19 hearsay that they were opened from the control room by simply
20 pushing a button and putting it back in operation. But that's
21 not an established fact yet.

22 DR. OKRENT: Is there anyone here who can give me a
23 different impression of that? In other words, were those
24 valves opened from the control room at eight minutes?

25 MR. MATTSON: I'm operating on the same hearsay that

agbl0¹ Carl is, that's my understanding.

2 DR. OKRENT: Does B&W know anything different?

3 MR. MC MILLAN: I don't know anything factual that
4 would be different from that.

5 DR. OKRENT: Thank you.

6 (Slide.)

7 MR. MICHAELSON: This is the curve that's showing
8 what's happening in the once-through steam generator during
9 the first 32 minutes.

10 And it's kind of interesting also because you can
11 see that, of course, as is characterized by once-through steam
12 generator -- and I'm sure B&W can give us more information
13 on this -- when you essentially isolate the generator, which
14 you do when you trip the turbine, the level of fluid in the
15 system which is really originally running at kind of a froth,
16 it will collapse and settle down very quickly to some relatively
17 small level.

18 Here apparently it was something of the order of
19 10 to 15 inches in the steam generator which seemed very low,
20 but it may have to do with where inches are measured from.

21 And I'm trying to get the data now on what the instrument was
22 really reading. Zero on that instrument does not necessarily
23 perhaps mean the steam generator is empty. I don't know yet.

24 But at any rate, it settles down to a very low level.

25 And according to this plot, the actual level was not changed

b11

1 for 20 minutes.

2 Now this is only the level at the bottom, it has
3 nothing to do with the spraying of the tubes. This is only a
4 reflection of the accumulation of water at the bottom.

5 And it remained relatively fixed for 20 minutes,
6 at which time it started coming up and you can see from other
7 curves that the operator was starting to raise this minimum
8 level.

9 However, the real action that occurred was somewhere --
10 after a couple of minutes, the steam generator could no longer
11 hold pressure. The reason most likely is it was running out of
12 water and the automatic circuitry which attempts to control
13 pressure could no longer hold it up, so the pressure came on
14 down without control.

15 And it proceeded to come down to around 800 pounds
16 or less. And I'm sure when the operator noticed this condition
17 developing, he recognized the need for getting water back in
18 the generator, which he did at the eight-minute point. And
19 this is another very nice check on the other charts to show
20 that yes, indeed, at about eight minutes certainly something
21 rather dramatic happened.

22 DR. SHEWMON: This is secondary pressure?

23 MR. MICHAELSON: This is the secondary side of the
24 once-through steam generator, the steam side.

25 DR. SHEWMON: Okay. Why is it when he turned the

67-124

agbl2

1 pumps on -- and the bottom line here is indicating the level
2 on the primary or the secondary side.

3 MR. MICHAELSON: This is the secondary side water
4 level on the bottom.

5 DR. SHEWMON: Now Harold earlier was talking about
6 where you wanted your level to get, I guess it is technically
7 called the thermal center, up in a nice high place. Is this
8 bottom line here a reasonable indication of what is called the
9 thermal center?

10 MR. MICHAELSON: I would not think so. I'll show
11 you a picture here, maybe it will help clear up your question.

12 (Slide.)

13 This is a once-through steam generator, and the level
14 we're talking about is this water at the bottom, as opposed to
15 the water which is spraying in near the top of the steam
16 generator.

17 I would expect -- and I'm not qualified to discuss
18 these generators in detail, but I would expect the thermal
19 center is being controlled by the spray of the auxiliary feed-
20 water on the tube bank being up in here at some point. It
21 wouldn't convect too well if this were the only cool section,
22 it wouldn't even work. It's not too likely, at least, to work,
23 but that's what we're talking about -- is the situation we're
24 in.

.eral Reporters, Inc.

25 This water level is probably immaterial, I believe.

67-125

b13

1 I think it's the spraying of the tubes that is really the
2 effective part, although this could also be an effective cooler
3 so long as you have reactor coolant pumps running, which we
4 did in this case.

5 DR. OKRENT: Could the delay of the increase in water
6 level be due to evaporation of all of the water being sprayed
7 in because of an initially warm primary system?

8 MR. MICHAELSON: I'm not sure I track your question.

9 DR. OKRENT: In other words, what you see there is
10 at eight minutes water started coming in but none was reaching
11 the bottom. And I'm asking, could it all evaporate before
12 reaching the bottom or what?

13 MR. MICHAELSON: I believe that would be a likely
14 conclusion, yes. I'm assuming that this steady level here
15 might be indicative of the fact that whatever was being sprayed
16 early in the game, for instance, was -- well, pardon me, early
17 in the game is over here (indicating).

18 This early in the game, the beginning first two or
19 three minutes could only have been controlled by water re-
20 maining in the bottom of the steam generator, because there was
21 no auxiliary feedwater flow for that period of time.

22 DR. OKRENT: Let me put it this way. If you had had
23 full flow from the auxiliary feedwater system at eight minutes,
24 would you expect to start accumulating water at the bottom at
25 eight minutes?

gbl4

1 MR. MICHAELSON: Yes, I would have expected it unless
2 it were being heavily evaporated to the extent of, perhaps, all
3 of it being evaporated. Yes, I would expect the water level to
4 start to rise because now you're spraying.

5 This was the condition at the beginning, there was no
6 spray here. There is some water here that could have been
7 effective as cooling, perhaps, but you will also note in the
8 drawing it didn't seem to change in elevation.

9 So I said Well, gee, I guess we didn't boil this
10 dry either. Maybe it didn't even communicate somehow with the
11 heat source, because this should have, I would have thought
12 would have dried out because you are in forced circulation.

13 But that sort of thing is among many loose ends which
14 need to be tidied up.

15 (Slide.)

16 DR. SHEWMON: The steam that is -- the turbines
17 shut off and tripped, this goes directly into the condensor
18 and that's our heat sink ultimately?

19 MR. MICHAELSON: The steam that might have been
20 generated here goes to the --

21 DR. SHEWMON: No, on the right.

22 MR. MICHAELSON: This steam is going through the
23 bypass valves to the condensor, yes. The bypass valves open
24 up the control pressure and he appears to be on pressure control
25 here which is about the right range where he might want to

agbl5

1 operate.

2 You remember the B generator was doing some earlier
3 strange things and he controlled it lower down. I cannot at
4 this time explain why these two were always consistently
5 different. It had to do perhaps with operating mode but it
6 may have had to do with a whole lot of other things.

7 (Slide.)

8 This is the information relative to when the reactor
9 coolant pumps were tripped. This shows the, presumably the
10 mass flow in the reactor coolant loops, both the A loop and the
11 B loop.

12 The B loop was secured at about 75 seconds -- I'm
13 sorry, 75 minutes. It was secured because there was apparent
14 problems with it.

15 Again, this is only subjective but the indications
16 I have were that the ammeters started to oscillate, and they
17 were receiving alarms on vibration. The ammeter oscillation is
18 a real good indicator if the pump has decided to go into surge.
19 And the vibration, of course, is a good confirmation of it as
20 well.

21 As I understand it -- again from hearsay -- it was
22 that the B loop got in trouble first in terms of vibration and
23 surge, possible surge. The A loop then proceeded to operate
24 until about 100 minutes, after which it started doing the same
25 thing that the B loop had done earlier, and so the operator cut

agbl6

1 it off at 100 minutes.

2 MR. MATTSON: Carl, could I interrupt just a second?

3 Does the behavior you were noting in the B steam
4 generator on the previous slide coincide with the time of the
5 trip of the B loop pump, or are those totally different in time?

6 MR. MICHAELSON: Well, we'll have to find out.

7 (Slide.)

8 There's a lot of good information in these things,
9 if we'd just have time enough to sit and think about it.

10 MR. MATTSON: I can't read it from here, but it
11 looks like it's earlier in time.

12 MR. MICHAELSON: I'm not sure now your question,
13 at what point in time are you concerned with?

14 MR. MATTSON: Well you were pointing out that the
15 B steam generator is apparently doing something different than
16 the A steam generator and it's unclear whether that was operator
17 control or some normal behavior of the system. But that looks
18 like, if I can read it, like about 20 minutes. Is that the
19 scale now?

20 MR. MICHAELSON: Well out here, this is 20 minutes
21 out here.

22 MR. MATTSON: But you said that continued over a
23 fair length of time.

24 MR. MICHAELSON: That's right. And I didn't attach
25 too much importance to it because -- when looking at a bunch

agbl7

1 of curves that are in the handout, but I just didn't want to
2 talk about -- he apparently just decided to keep different
3 levels in the generator and so forth, so perhaps there's a lot of
4 illogical explanations, maybe not. I think it's a good area
5 to look at for whatever information you can glean from it.

6 MR. MATTSON: Well lower level in that steam generator
7 would coincide with quicker reaching of conditions in the
8 B loop, saturation or what have you that caused the pump to
9 cavitate or oscillate and hence led to the securing of the
10 B loop before the A loop.

11 MR. MICHAELSON: Yes, but the B loop was running at
12 a lower temperature than the A loop, which you will recall
13 was --

14 MR. MATTSON: That's contradictory.

15 MR. MICHAELSON: Yes.

16 (Slide.)

17 There may be other real good explanations but this
18 situation was here you ran along on the B loop, it's somewhat
19 cooler.

20 DR. SHEWMON: Let me stay with that. The last one
21 doesn't have to go back on, but as I look at these various
22 curves the thing is that the reactor continued to be bled --
23 of the primary system continued to bleed. And ultimately, we
24 then ended up with inability to pump water or things which
25 made the pumps cavitate -- or at least they couldn't pump

b18

1 enough water, I guess that's what the last figure showed,
2 isn't that right?

3 MR. MICHAELSON: What I was going to do was, I'm
4 going through what I consider the facts first, and then I was
5 going to spend just a little bit of time on possible guesses
6 as to what is happening and how they might relate to the facts,
7 just so I don't -- you know, I don't want to make that part
8 sound factual because it's not, it's just an idea.

9 DR. LAWROSKI: Do you know if before the accident
10 there was this difference in the behavior of the two steam
11 generators?

12 MR. MICHAELSON: I don't know, I just haven't had
13 time to sit down and look at it carefully. I don't know.
14 I just don't know how much importance to put on it. It may be
15 very important, but right now I'm not -- my guess is that it's
16 not the thing we're looking for, but it may turn out later that
17 one would want to look carefully. I'm sure that all of this
18 will get worked over very hard. These are just first looks at
19 it without a whole lot of time yet to do it in detail.

20 (Slide.)

21 This is a curve of what happened to the reactor
22 coolant system pressure versus time. You can see the initial
23 depressurization curve coming on down and it dropped to a
24 relatively low level at about 2.3 hours into the event, and
25 you'll recall that that was a little while after the reactor

gb19

1 coolant pumps had been tripped, which was right along in here.
2 And the pressure just kept on coming down.

3 At this point, as I understand it from the chronology
4 of events, the relief valve was closed. And of course, as one
5 might expect then a very rapid, a relatively rapid repressuriza-
6 tion occurred. This isn't really all that fast when you look
7 at the time scale. It was fairly slow as this part of the event
8 goes.

9 But it went back to full pressure. And after this
10 there is a large number of operations that were performed
11 for which I have little or no information yet and I would be
12 purely guessing as to what all this is about until we get some
13 information on when pumps are turned on and off, when relief
14 valves were opened or closed or when the steam generator
15 situations were changed or whatever.

16 But clearly it went through quite a number of opera-
17 tions all the way out to somewhere around 15 hours more or less,
18 at which time, as I understand it, they finally went to the
19 full flooding and turned the transient around.

20 I am soliciting information out here to 20 hours
21 because I could not conclude that the event terminated yet on
22 this chart from looking at the numbers.

23 MR. MATTSON: Carl, a question, have you tried to
24 correlate the indicators from the self-powered neutron detectors
25 in-core with the first ramp in pressure there? I think you say

agb20

1 that that corresponds to when the valve was isolated.

2 My chronology says that's about 2.3 hours. The
3 self-powered neutron detector strip chart shows that they
4 indicate erratic behavior beginning at about 2.5 hours.

5 MR. MICHAELSON: I thought it was earlier than that.

6 MR. MATTSON: My technical people tell me that what
7 they're probably seeing is voiding in the core, gamma indication
8 rather than neutron indication.

9 And that's a little difficult to understand with that
10 pressure ramp going on at the same time, unless we haven't
11 fully understood the timing yet which might put it out with the
12 pressure decrease after that initial peak.

13 You haven't looked at that and compared it with
14 this chart?

15 MR. MICHAELSON: The data, as I understand, is
16 available. I haven't seen it yet. Maybe Mr. Catton would want
17 to comment on it because he was looking at some of this and was
18 telling me a little about it last night.

19 DR. CATTON: Are you referring to Kaufman's exercise?

20 MR. MATTSON: I was thinking of the strip chart
21 recorders from the self-powered neutron detectors.

22 DR. CATTON: I think he looked at those and he
23 felt between 126 minutes and 176 minutes, the core was essentially
24 dry.

25 MR. MATTSON: But the self-powered neutron detectors

agb21

1 give the, I think, probably the best indication of when it
2 voided and you ought to be able to key the time of those in-
3 ductions to the time of these pressure indications.

4 DR. CATTON: I think that's what he was doing,
5 between 126 minutes and 176 minutes, he felt the core was dry
6 and that that's when all the damage occurred.

7 PROFESSOR KERR: You're interpreting that increase
8 in pressure as to mean that the core was not seeing voids. It
9 seems to me that depends a lot on how much water was in the
10 total primary system. One could have had an increase in pressure
11 like this just because of heatup, without very much change in
12 voiding, I think.

13 MR. MATTSON: That's why I bring it up. The increase
14 in voiding could be read to say that you're collapsing voids
15 when, in fact, really what was going on was increasing voids
16 causing the increase in pressure.

17 DR. CATTON: I think you're right.

18 MR. MICHAELSON: I was going to do that part of the
19 subjective material at the end, and maybe we can comment on it
20 some more at that time.

21 DR. SHEWMON: Before you leave that, will you read
22 the fine print down there "around two hours" to me again or
23 tell me what happened? The pumps came back on --

24 MR. MICHAELSON: That's what was filling the steam
25 generator to try to start natural circulation. I don't --

22

1 that's on the graph.

2 DR. SHEWMON: The primary pumps came on again, then,
3 after two hours, is that correct?

4 MR. MICHAELSON: No, they never came on again. It
5 was somewhere around 16 hours.

6 DR. SHEWMON: What is the other --

7 MR. MICHAELSON: This was closure of the block
8 valves.

9 DR. SHEWMON: Okay.

10 MR. MICHAELSON: Which would then bottl the system
11 back up and permit it to repressurize. During the repressuriza-
12 tion process now you might ask, of course, what's happening to
13 levels and what's happening to void formation and you'll see
14 some other interesting things in a couple of charts here which
15 give you more food for thought.

16 (Slide.)

17 This is the history of what the operator was seeing
18 on his level indicator as a function of time throughout the
19 event. And, again, it's pretty interesting.

20 The period of particular concern, which seems to be
21 now related to other data that we're giving, is the period
22 from two to three hours, where it is possible that that's where
23 most of the damage was done but we really don't know yet for
24 sure. But there are some pretty good indications that interesting
25 things are happening during this period of time.

agb23

1 Now on his level indicator he was holding what is
2 ordinarily a very comfortable level, since the normal operating
3 level is somewhere down in the 220 range. So he had plenty of
4 water in the pressurizer if he wished to believe it.

5 He did know though he was having a decreasing
6 pressure. He was also seeing a decreasing level with time but
7 not a disturbing one, this is a very slow disappearance of
8 water from the pressurizer, and since there is so much level
9 I guess he wouldn't get real excited over it.

10 Now, when we get to the last part of the discussion,
11 I'll point out what I think might be happening in here. But
12 for now, I think we can say that as far as his apparent level
13 indication, it went back to off-scale or very near off-scale.
14 Off-scale, as I understand it, being about 400 inches.

15 You can see he is allowing it to wiggle back on scale
16 occasionally, I suspect just to derive comfort that it's
17 working and things were looking all right.

18 Again, I don't have any good history really beyond
19 this 2.3 hour point where things -- in terms of operator actions
20 and equipment operations. I just don't know when they turned
21 things on and off, so there's an awful lot of guessing until
22 you get better data as to what caused the shapes that you see.

23 DR. SHEWMON: Is there a log for this or are there
24 continuing strip charts?

25 MR. MICHAELSON: There are logs for this. There is

agb24

1 some amount of computer data printout. There are some strip
2 charts. A lot of what you see, of course, are off strip
3 charts, but some of it is off the data logger.

4 I think the information will become available as to
5 the certain values on these parameters, although some of them
6 are only printed by the computer when the computer is asked to
7 follow them and, of course, nobody ran downstairs to ask it
8 necessarily to follow all of these. So we'll have to do with
9 what we have got, but it is still pretty good information.
10 There's quite a bit to work with.

11 The real key though is when did he turn things on and
12 off and some of that is logged, some of it is not.

13 (Slide.)

14 2A
15 2B

16 As you can see, then, the last pump was tripped about
17 1-2/3 hours into the event. And before that, the temperature
18 rise through the core and so forth was very nominal. The
19 situation appeared to be well stabilized.

20 Then he had to trip his last reactor coolant pump.
21 The first pump trip occurred a little over an hour into the
22 event and it didn't seem to create a big problem, just a few
23 little wiggles.

24 The last trip, though, seemed to precipitate some-
25 thing very strange. He proceeded to begin to see very high
temperatures measured up near the flow meter in the vertical
hot leg, which is where these loop temperatures are instrumented,

General Reporters, Inc.

67-137

gb25

1 as I understand it.

C6

2
3 And these very high temperatures, when you look at
4 the pressure existing in the system at the time, are indicative
5 of superheating of the steam and not the saturation temperature.

6 So he was clearly into some kind of a heatup
7 situation which is not altogether understandable in view of the
8 fact that there was water in the pressurizer throughout this
9 entire event.

10 These proceeded to go off-scale and stay off-scale
11 for several hours, until they finally started -- one of them
12 started coming on-scale off out here and during the latter
13 part of the event.

14 Again now what the model is for this, I guess we'll
15 just have to think about and guess at. There are some good
16 possibilities, but I am sure there are many good possibilities
17 and I will discuss at least one in a moment.

18 You should notice here also that the cold leg
19 temperatures proceeded to drop to very low values. Now this
20 cold leg temperature is right underneath the bottom of the
21 reactor coolant pump, and these low temperatures then are
22 indicative of the fact that the fluid is no longer circulating
23 through the system because you are seeing enormous delta-Ts
24 between hot leg temperatures and cold leg temperatures and
25 you don't need anything like that to remove the heat in the
steam generator.

agb26

1 So the situation is indicative of some kind of a
2 loss of circulation situation.

3 MR. STRATTON: Were these temperatures immediately
4 available to the operator?

5 MR. MICHAELSON: I really can't say. I would think
6 that they were available, but I can't -- maybe somebody knows
7 whether these were reading out in the control room at least.

8 MR. MATTSON: Certainly all of these are on the
9 computer and some of these are on the control panel. T-hot and
10 T-cold are on the control panel, pressure is on the control
11 panel, level is on the control panel. I suspect most of what
12 you have up there is on the control panel. Certainly it's all
13 on the computer.

14 MR. MICHAELSON: I think they have on the computer
15 a few more points than they have on the panel, but I had
16 assumed that they read these out in the control room but I
17 never really asked.

18 So that's it.

19 Now there are several more in the handouts, but I
20 won't go into them unless somebody is really interested.

21 MR. ETHERINGTON: Would you show Figure 17, Carl?

22 MR. MICHAELSON: Okay.

23 (Slide.)

24 MR. ETHERINGTON: That figure shows the extremely
25 low level in the steam generator at the time of the coolant pump

agb27 1 trips.

2 MR. MICHAELSON: Yes, right.

3 MR. ETHERINGTON: On the extreme left. And then you
4 can see as soon as the trip occurred, they started to fill.

5 MR. MICHAELSON: I asked the operator about this,
6 and he said there's nothing unusual about operating at those
7 low levels as long as everything seems to be all right.

8 But at this point he was starting all the desperation
9 moves, I would imagine, and one of them was to Let's get more
10 water in the steam generator and see if that helps some. And
11 then later on he appeared to do the same thing with the B
12 generator, except he set it up to control at a lower level.
13 These are percent of range, I believe.

14 MR. ETHERINGTON: Right.

15 MR. MICHAELSON: And I believe, as I recall, 50
16 percent range was -- I've forgotten now -- 200 or 300 inches
17 in the steam generator, a very high level.

18 MR. MATTSON: Carl, I can't read your graph again.
19 Is the B steam generator the one whose level comes up second
20 or the one whose level comes up first?

21 MR. MICHAELSON: It goes up second. He waited 'till
22 2.5 hours to bring the level up. The A generator, which was
23 where he had his operating reactor coolant pump just shortly
24 before, was brought up apparently about the same time the
25 reactor coolant pump tripped.

agb28

1 MR. ETHERINGTON: It remains a question of whether
2 he brought it up or whether it just climbed when he lost the
3 recirculation.

4 MR. MICHAELSON: These are on level control, though.
5 I don't believe he has to change to setpoints to bring the
6 level on up. He can set these where he wishes to control
7 level in terms of percent of operating range. I assumed he
8 turned his level controller up to set a new range here,
9 50 percent. And then he fiddled with it a little bit and finally
10 over here he decided to go full range.

11 MR. ETHERINGTON: That was long after the trip.

12 MR. MICHAELSON: That's right, yes.

13 Initially on trip, about coincident with the trip,
14 he decided or perhaps it's automatic, I don't know. The fact is
15 it's possible that it's automatic, I'm not sure because I think
16 it has to do with some characteristics of this generator that
17 makes it desirable to start filling it if you lose the pump
18 on that loop.

19 At any rate, the level popped on up.

20 Are there any others you would like to see?

21 MR. STRATTON: How does he control the level, Carl,
22 is it by means of -- does he change the pumping action?

23 MR. MICHAELSON: The level of the steam generator?

24 MR. STRATTON: Yes.

25 MR. MICHAELSON. It was my impression in talking with

agb29 1 the operator that it's sort of like a dial indicator, you dial
2 the level you wish, the percent of control. But that's, only
3 an impression I got.

4 PROFESSOR KERR: It's probably valve controlled,
5 isn't it?

6 MR. MICHAELSON: I think there's some automatic
7 control of this as well relating to some number of pumps that
8 might still be operating. I think he told me and I just don't
9 recall, but I believe he was saying that if you tripped certain
10 combinations of pumps then he would want to bring this level
11 up to certain values and that may be what we see.

12 DR. OKRENT: But is it your impression that before
13 an hour and two-thirds or whatever it is, the point at which
14 the level started rising for a steam generator, that the flow
15 into the secondary was the maximum possible or that it was
16 throttled?

17 MR. MICHAELSON: I'm assuming that the auxiliary
18 feedwater control was throttling to whatever you needed.

19 Now keep in mind, looking at all the temperature
20 charts, there's no reason to believe that there's any problem
21 with heat removal. You remember the previous one I showed you,
22 the temperature, there was only a few degrees through the core
23 between the hot and the cold legs and there was no -- I, at
24 least, could find no reason to believe there was any trouble
25 at one hour, you know, from looking at numbers on charts.

agb30

1 MR. ETHERINGTON: Carl, the pool of water at the
2 bottom of the steam generator does seem to be sufficient for
3 removing small quantities of heat. At 10 percent power, the
4 SAR gives the level as three feet, and that is the normal
5 supply, so apparently they're getting enough heat transfer at
6 10 percent of power with seven feet of water at the bottom of
7 the steam generator. And in this case we're talking about
8 1-1/2 percent of power, so it shouldn't take much.

9 MR. MICHAELSON: That pool of water down there should
10 be an effective means of heat removal so long as the reactor
11 coolant pumps are operating. Once they stopped operating,
12 of course, then it was lost. However, the spray power at the
13 top was still working, but now we have to go into the sub-
14 jective part about what all this might mean.

15 DR. CATTON: Shouldn't they have been a little bit
16 suspicious when the saturation pressure was greater than the
17 actual pressure, and that occurred at 17 minutes? In fact,
18 from 17 minutes out to about three hours.

19 MR. MICHAELSON: The saturation pressure based on
20 what temperature now?

21 DR. CATTON: Your curve.

22 MR. MICHAELSON: Which curve are you looking at?

23 DR. CATTON: Number 12.

24 DR. OKRENT: In the primary.

25 DR. CATTON: Yes. That tells me you've had boiling

agb31

1 from about 17 minutes on.

2 (Slide.)

3 MR. MICHAELSON: Is this the figure you're looking
4 at?

5 DR. CATTON: Your Figure 12.

6 MR. MICHAELSON: It is eradicated on here, I can't
7 read it.

8 DR. CATTON: You must have a different one.

9 MR. MICHAELSON: That figure didn't have a number
10 on it.

11 PROFESSOR KERR: The superposition of the actual
12 pressure of the --

13 MR. MICHAELSON: Oh, you want the saturation curve,
14 all right.

15 (Slide.)

16 And now your question?

17 DR. CATTON: It seems to me that at 17 minutes you
18 should have known you had a problem.

19 MR. MICHAELSON: Yes, I would agree. But he wasn't
20 tracking any -- he wasn't tracking something that was printing
21 this out for him necessarily. The information was available
22 as it is now. He knew his temperature and he knew his pressure
23 and he maybe had a steam table.

24 DR. CATTON: You made the comment there was nothing
25 you could see that would lead you to believe there was a problem.

agb32

1 I can see this and it leads me to believe there's a problem at
2 17 minutes.

3 DR. SHEWMON: But he couldn't see that.

4 DR. CATTON: The operator couldn't, no.

5 MR. MICHAELSON: If he looked at what he normally
6 would monitor, namely, the level of the pressurizer and cold
7 leg temperatures and hot leg temperatures, he didn't seem to
8 be all that bad. -- and pressure. Unless he went back to think
9 about where he was on this curve here and he was, I believe,
10 riding a saturation situation probably all this time.

11 MR. MATTSON: For what it's worth, the drain tank
12 ruptured at about 16 minutes, so there may have been a lot of
13 things on his mind at that time.

14 DR. CATTON: I'm sure there were.

15 MR. MICHAELSON: I believe you're referring to this
16 figure here.

17 (Slide.)

18 MR. MATTSON: Right.

19 MR. MICHAELSON: Early in the game, we believe
20 this is the relief valve opening to try to relieve the
21 pressure, but the pressure continued to build up. I'm not
22 quite sure whether this is a change in system pressure that
23 caused the dump tank pressure to drop for a while or not, but
24 at any rate something happened at about 12 minutes and the
25 pressure took off and very shortly thereafter ruptured the

agb33

1 diaphragm. This must have gotten him -- gotten his attention,
2 although I don't, know how, in alarms or readsout or whatever,
3 maybe none of this information is brought readily to his
4 attention, I just don't know.

5 (Slide.)

6 At this point, I would just like to go through a
7 little discussion now of the subjective part of the business.

8 What I'm trying to do is to guess at, from the
9 data we see, what the possible model of this situation might
10 be. To do that, I first looked at time zero, which was the
11 condition wherein there was no auxiliary feedwater in the spray
12 on the tubes. The reactor coolant pumps were running, fluid
13 was circulating properly. There was a level in the pressurizer.
14 There was considerable flashing in the pressurizer because
15 we are assuming that the relief valve was stuck open.

16 So this was the early first few minutes situation
17 in which there is say proper heat removal out here -- well,
18 excuse me, there is no proper heat removal out here except as
19 might be a contribution of the water in the bottom of the
20 generator, and I'm not sure whether it was really doing any
21 cooling or not.

22 But for the first several minutes safety injection
23 was available, and it was adding cold water to the otherwise
24 warmer water. And this situation was riding along for a while.

25 (Slide.)

b34

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

The next thing that one sees, then, is the addition of auxiliary feedwater to start an effective cooling job which I tried to sketch up here.

The water is now pouring out of the auxiliary feedwater sparger and presumably properly cooling the fluid in the tube, so it is not immaterial what is happening, I think, to the level in the bottom. That's on the assumption, of course, that this spray up here is more than adequate for decay heat removal.

Now the level in the pressurizer is coming on up. It's still flashing up here, it's still losing the water out through the pressurizer. And I believe on this plant, the block valve is prior to the heat relief valve, but there seems to be some question about that. I think this is the correct one, according to the SAR, at least (indicating).

So he was still rocking along fine here. But the pressure was coming down very quickly, as you recall, to saturation. And when he reached the saturation pressure, his pressurizer was no longer really controlling the events in the system.

Wherever there might be a higher elevation and associated with a higher temperature, it is possible that he starts to get void formation in such location, perhaps. At the top of the steam generator there was a void forming, although there probably it was getting swept out for a while, at least.

agb35

1 The reactor vessel is a real good candidate because
2 it sees T-exit of the core but it is at a somewhat lower ele-
3 vation so if T-exit of the core is a degree or so higher than
4 the rest of the system, of course, it can form a very nice void
5 there and support all the other columns.

6 So this seemed to be the next situation. Again,
7 still quite adequate core cooling, and probably this situation
8 existed for maybe 20 minutes or so into the event.

9 (Slide.)

10 The problem, though, that he didn't perhaps appre-
11 ciate was he was losing mass from the system perhaps faster
12 than he was making it up to the system because he wasn't really
13 monitoring his inventory but, rather, watching level, so he
14 could get in trouble if he was losing water faster than he was
15 making up and he was watching the inventory and he held a very
16 fine level in the pressurizer, which he could do, there was
17 plenty of pressure to support this column of water. But in the
18 meantime, he was losing a net amount of mass from the system,
19 so the void in the reactor had to grow larger and larger.

20 At this point, the pumps were beginning to work
21 harder and harder, trying to somehow find sufficient suction
22 head down here to force the fluid around the system and at least
23 splash it over the top of the steam generator connection.

24 Now I think this is what happened out at 100 minutes
25 into the event. It was working very hard to try to find

agb36

1 sufficient suction head.

2 Now, I don't know how these pumps behave in a
3 situation like this, I don't know how far you can draw this
4 elevation down before this pump would simply cease to pump.
5 I'm surmising here for the moment that it was able to draw
6 a fairly low elevation in the steam generator and still somehow
7 shove the water over the top.

8 If you assume that that is the case, you can still
9 draw -- you can still adequately cool the core, because the
10 heat rates are getting quite low so you could even trip a pair
11 of pumps and be all right, because the other pair of pumps
12 were still working.

13 Now it's when you trip the last pair of pumps that
14 things begin to happen. And one of the reasons is that, at
15 that point, when the pumps are tripped, that this negative --
16 this low elevation in the steam generator is no longer the
17 case. This whole leg acts as a monometer and the water from
18 the higher points of the system want to come down here and
19 settle out and fill the lower part of the steam generator, so
20 that pulls a lot of water out of the system pretty quickly and
21 stores it in the steam generator.

22 He did the same trick, I believe, when he tripped
23 the first set of pumps and stored some of the water in the
24 other steam generator. And by the time he tripped these, he
25 had stored even more water.

agb37

1 Now it depends upon what the elevation is here.
2 There's more than enough capacity between the pump elevation
3 in the bottom tube sheet to store all the water in the upper
4 part of the system according to a little quick and dirty
5 calculation.

6 So now it's a question of where was really the
7 elevation in here? I think he pulled a fair amount of the
8 water out of the system, and that is the reason then he started
9 seeing things happen pretty quickly thereafter.

10 DR. PLESSET: Carl, could I ask you a question
11 about this? You've kind of described a small LOCA.

12 MR. MICHAELSON: That's right.

13 DR. PLESSET: And a small LOCA, I guess, is about
14 like 200ths of a square foot.

15 MR. MICHAELSON: That's about right.

16 DR. PLESSET: And you mentioned that he was very
17 possibly not realizing that he was losing coolant faster than
18 he was able to make it up.

19 MR. MICHAELSON: Faster than he wanted to make it
20 up, yes.

21 DR. PLESSET: Yes.

22 Now has this kind of thing been adequately analyzed?
23 I think you have studied this.

24 MR. MICHAELSON: Yes. That doesn't make it adequately
25 analyzed by any means. But I did look at the possibilities of

agb38

1 this happening, yes, and it does appear that you could get into
2 such a situation with very small breaks.

3 DR. PLESSET: But it seems to me that this should
4 have been more strongly emphasized to the designers of this
5 type of plant, or any kind of plant.

6 MR. MICHAELSON: Well the situation is not identified
7 by the normal ECCS type analysis that was performed. The ECCS
8 analysis shows for this type of plant that something around
9 0.05 square foot is the largest -- the smallest break at which
10 you still may uncover a small portion of the core. As you go
11 to smaller breaks, the core coverage is equal to or better
12 than that critical break size which, as I understand it, is
13 about 0.05 or thereabouts.

14 MR. MATTSON: But wouldn't those analyses have
15 inventory being made up by the high pressure coolant injection
16 system while you're reducing the inventory from the small
17 break, isn't that the reason the core stays covered?

18 MR. MICHAELSON: Yeah. The key question of those
19 analyses, of course, is whether appropriate credit has been
20 given for the effects of repressurization that occur during
21 the period of time when you do the analysis, keeping in mind
22 that for an ECCS analysis you do not assume the pumps are
23 running, you have to start with natural circulation to begin
24 with and you have to go through some little gyrations trying
25 to communicate with the heat sink.

agb39

1 And all those factors need to be in the analysis to
2 be sure that you have appropriately tracked the pressure history,
3 because the injection rate is a function of the pressure
4 history. The higher the pressure the lower the rate.

5 MR. MATTSON: It's not just the pumps, either.
6 It's the overriding of the ECCS because of a perception that
7 the level is okay, rather than letting the ECCS do its makeup
8 function all by itself, independent of what the level says it's
9 doing.

10 MR. MICHAELSON: Right. It is important, of course,
11 to make sure that one performs the software analysis that
12 verifies that if you don't intercept the safety injection and
13 if you lose off-site power and so forth, that this thing will
14 ride through properly.

15 It is important to do that analysis and presumably
16 the analysis showed that you do ride through properly. And you
17 only might get in trouble if you come and intervene, for
18 instance, and adjust the safety injection rate to a value other
19 than used in the analysis.

20 MR. MATTSON: Well one of the early things this
21 kind of thinking says to us is that there needs to be a
22 coupling between the normal transient analysis and the normal
23 loss of coolant accident analysis which brings to bear the
24 two kinds of thinking.

25 Some of this thinking had gone into the transient

agb40 1 analysis, a lot of it has gone into the LOCA analysis, and the
2 coupling between the two seems to be the interesting thing to
3 study at this juncture.

4 MR. MICHAELSON: Yes, I think that's right.

5 And what makes this unusual, of course, is that it's
6 all going on so slowly that you can do it, you know, on the
7 back of an envelope, you don't need a large computer to study
8 what's happening, but you do need to appreciate what's happening
9 to be sure that you have proper communication to your heat
10 sink, keeping in mind that a hole this size cannot take out the
11 heat as fast as it's being generated for some period of time.

12 DR. PLESSET: I don't think this was explored
13 sufficiently, Carl, this situation you've described as a small
14 break LOCA.

15 MR. MICHAELSON: Well, I've looked at a few of these
16 small break LOCA analyses that are turned out by the NSS
17 suppliers. I did not find this sort of thing as a part of the
18 analysis. Perhaps it was done by the people and discounted
19 on some basis, I don't know.

20 PROFESSOR KERR: Carl, when you say "this sort of
21 thing," what do you include?

22 MR. MICHAELSON: You simply have to be sure that
23 in the very slow moving events, that you know where the water
24 is and where the levels are and whether or not you communicate
25 with the heat sink, since the hole in itself is not adequate

agb41

1 to take out the heat for a rather prolonged period of time.

2 PROFESSOR KERR: But if you have a pool water makeup
3 flow that is more rapid than the water outlet, or at least
4 equal to the water outlet, at least you aren't going to have
5 void formation, are you?

6 MR. MICHAELSON: Yes, you'll still have void
7 formation, if the break is large enough to drop the pressure
8 down to the saturation conditions for the system, yes.

9 PROFESSOR KERR: No, but that can't happen unless
10 the water outflow is greater than the water inflow, can it?

11 MR. MICHAELSON: Yes, it can happen. For instance --
12 a hole in the pressurizer will do it. It drops the pressure
13 very rapidly .

14 The pressure dropped all the time.

15 PROFESSOR KERR: But that pressure drop we saw
16 initially was occurring before the -- or at least apparently
17 before the HPCI system came on.

18 MR. MICHAELSON: Would you repeat that? I didn't
19 hear it.

20 PROFESSOR KERR: It's my impression from your
21 earlier statement that that initial rapid pressure drop was
22 occurring before the high pressure injection system came on.
23 From your comments that may not be altogether clear and there
24 may have been a pump running or something but at least before
25 the full flow came on is where you got the big pressure drop,

General Reporters, Inc.

agb42

1 isn't it?

2 MR. MICHAELSON: Yes, and that's to be expected.
3 It's to be expected, to some extent, and was shown in the
4 earlier analyses today on the basis of the transient alone,
5 without necessarily a hole even.

6 If you look at the FSAR analysis for Three Mile
7 Island, you will see -- you'll find such a curve in there for
8 loss of feedwater with one auxiliary feedwater pump.

9 PROFESSOR KERR: In this particular incident, isn't
10 the indication that one did not get into a flashing situation
11 until after the HPCI pumps were turned on?

12 MR. MICHAELSON: The flashing started about the
13 time the first pump was shut off, yes.

14 PROFESSOR KERR: Right.

15 DR. SHEWMON: Carl, a different way to phrase that
16 question, could one say there would have been no flashing if
17 the operator had controlled on system pressure, or controlled
18 his HPCI flow on system pressure instead of by water level in
19 the pressurizer?

20 MR. MICHAELSON: No, I think it was just a
21 coincidence, but I'm guessing a little bit here. I believe
22 it was a coincidence that he happened to reach the saturation
23 point at the exact same time he decided to trip his pump.

24 DR. SHEWMON: That was not my question.

25 He could have kept his pumps on and kept the pressure

agb43

1 above 1400 psi or something, could he not have?

2 MR. MICHAELSON: Yes, if he had kept his pumps on
3 and if the pumps were making up fluid in the system faster
4 than it was being lost from the system, then he would proceed
5 to refill -- he would proceed to pump the system back up,
6 essentially, with the high pressure pumps.

7 DR. SHEWMON: If you keep the pressure up, then you
8 could do what you said, Bill, but if you don't, then --

9 MR. MATTSON: But that makes it the traditional
10 small break LOCA analysis. You've got the pumps on and they're
11 larger than the break sufficient to keep the pressure up and
12 keep the core covered, even without the pumps.

13 MR. MICHAELSON: I have to disagree with you. If
14 you look at the small break analysis, you'll find that the
15 level drops with these kind of breaks all the way down to the
16 top of the core, at least that's true for the B&W plants.

17 MR. MATTSON: That's all I was saying, that it
18 keeps the core covered.

19 MR. MICHAELSON: It keeps the core covered, but it
20 doesn't keep overpressure on, they aren't able to keep up with
21 the break so there is no overpressure. They're following the
22 saturation pressure on down. There's no overpressure on it.
23 But they are keeping the core covered, which is really all that's
24 necessary.

25 This event is of no serious consequence if you keep

agb44 1 the core covered. It's the uncovering, and that's the last
2 picture.

3 (Slide.)

4 Again this is subjective, but here's a possible
5 situation late in the game.

6 Auxiliary feedwater is still working fine. After
7 tripping the last pumps, then there is some equalization of
8 level and loss of inventory by storage in the steam generator.
9 Safety injection is still coming in. Condensation, to some
10 extent, is still perhaps occurring out here, in which there's
11 a small return of water.

12 Again, though, for a while yet he was still worrying
13 about control on inventory, as indicated by level in the steam
14 generator -- pardon me, in the pressurizer.

15 At about this point in time, of course, then he
16 closed the block valve and now you have to go into some other
17 things which -- we did see some amount of changing in the level.

18 And one of the things that one has to keep in mind
19 here is that, although you could readily support a water column
20 of this sort with only steam pressure over here, provided that
21 it has got a degree or so higher saturation temperature, if
22 you do lose inventory from here, you can't make it back up
23 again unless you somehow raise the level back in here at some
24 time during your story and get some water back in there.

25 You can lose it but you can't get it back without

agb45

1 flooding, at least as I see it, without flooding the entrance
2 or alternatively doing a whole lot of condensing over there,
3 and that doesn't seem likely.

4 But after that point of closing here, then one
5 needs to go back now and I think you might have a backward
6 way of telling how the water might have been going up and down
7 in the core, depending on what they were trying.

8 Now, a puzzling thing to keep in mind is the tempera-
9 ture, that off-range temperature for about 10 hours was
10 measured up here on the hot leg. If their reflooding efforts
11 from time to time ever reached that temperature indicator, I'm
12 sure you would have seen it. We saw nothing on it for 10
13 hours to indicate that it was being quenched.

14 So perhaps the whole game was being played in here.
15 And on occasion, I suspect the occasion was at first two to
16 three hours, it was when the uncovering occurred in the very
17 higher temperatures at least -- occurred in the top of the
18 core.

19 DR. SHEWMON: The cold leg indication is taken
20 where?

21 MR. MICHAELSON: My understanding -- I'm getting
22 the drawings but I haven't gotten them yet -- it's not very
23 far from the bottom of the suction of the pump. It's supposed
24 to be right along in there.

67-158

2c ebl

1 Now we saw on occasion, these temperatures rising
2 and I believe that occurs when you bring the water level on up
3 and you start backing the hot water into the pump, and I should
4 see these temperatures going up again for a while, and then
5 coming back down, and there is nothing to stir it around. And
6 there was quite a bit of that sort of thing going on here, too,
7 on the cold leg side.

6.400

8 So my own initial opinion is that there was a pre-
9 liminary core uncovering which is further evidenced by some
10 of the monitoring work they did, perhaps of the order of --
11 something of the order of less than an hour. And after that
12 time there may have been occasions when the water was going up
13 and down, but it appeared that the water never got up very high
14 into the hot leg until some time way later. And I'm trying to
15 get the strip charts on out to 20 hours to find out when they
16 did appear to quench these thermocouples.

17 So that would be one possible model of what happened.
18 There are other possibilities, but one thing to keep in mind is
19 we must decide whether the level indicator is really working
20 up there or not. If it is, then you've got to explain somehow
21 water being up there and working its way around.

22 PROF. KERR: When you say preliminary damage may
23 have occurred in less than one hour, this implies that it may
24 have occurred before the first pump was turned off.

General Reporters, Inc.

25 MR. MICHAELSON: If I said less than one hour, I

67-159

~~CONFIDENTIAL~~

1 didn't mean it. I think the damage occurred somewhere after the
2 last pumps were shut off.

3 PROF. KERR: Thank you.

4 MR. MICHAELSON: At one and two-thirds hours, or
5 later.

6 DR. CARBON: Dave?

7 DR. OKRENT: A little earlier Roger Mattson indi-
8 cated that he thought there could be value in looking at situa-
9 tions which involved a coupling of small breaks and transients,
10 and I agree. I think we should also keep in mind a second
11 question which has been raised by Mr. Michaelson about whether
12 there is a class of small breaks for which you have a problem
13 maintaining core inventory and adequate cooling of the fuel for
14 some significant period of time, aside from other complications.

15 So I just don't want you to lose sight of that ques-
16 tion. It may or may not turn out to have significant applica-
17 tion.

18 DR. SHEWMON: Could somebody convert the size of
19 leak we think we had into square feet, which seems to be the
20 argot of the ECCS people?

21 DR. PLESSET: .025 I think.

22 DR. SHEWMON: And the numbers I've heard bandied
23 around here are that .05 is usually the lowest analyzed because
24 that's what the pumps will keep up with if they're operating,
25 or something like that?

eb3

1 MR. MICHAELSON: The pumps won't keep up if the
2 break-- For this type plant, I don't know what the break point
3 is; generally of the order of one-half to one inch pipe break
4 is about the largest hole that the pumps can keep up with,
5 assuming only one pump of course operating.

6 DR. SHEWMON: And that's less than .01?

7 MR. MICHAELSON: Oh, yes.

8 Now I'm sure B&W has the numbers on what the small
9 break is. Breaks larger than that are defined as LOCAs then
10 because the pumps cannot keep -- the normal makeup system cannot
11 keep up with it.

12 DR. SHEWMON: I'm talking about the HPCI.

13 MR. MICHAELSON: Well, the normal makeup system for
14 a plant of this type is the charging pump which is also the
15 high pressure injection pump. There are three such pumps in
16 this plant. One is running normally for charging. One is--
17 And the other two are on standby for high pressure injection.
18 So the normal charging is the operation of one pump.

19 If you exceed that ability-- If you have a hole
20 which exceeds the ability of that one pump, then it becomes a
21 LOCA, as I understand it.

22 DR. SHEWMON: .025 is the generally agreed-on size
23 of the leak?

24 MR. MICHAELSON: No. I got the drawings on the valve
25 and it is somewhat smaller I believe than .025. It is a two and

eb4

1 a half inch relief valve, but the port opening, as I recall,
2 appears to be more like about one and a half inch, and it would
3 be the port opening of the valve that you would look at.

4 DR. SHEWMON: And we're talking about the valve which
5 is either open or shut. If it is stuck open it didn't come
6 back halfway and hang up someplace?

7 MR. MICHAELSON: Well, you'd have to guess. I'm
8 assuming that it was stuck wide open. Anything in between just
9 varies the hole -- the break size.

10 DR. PLESSET: Did you communicate your concern with
11 these small breaks to the vendor?

12 MR. MICHAELSON: Yes. We had some discussions and
13 correspondence from time to time, yes.

14 DR. PLESSET: Were they responsive? That's a term
15 we like to use occasionally.

16 MR. MICHAELSON: Well, these are kinds of events
17 which have not necessarily been looked at carefully by the
18 Regulatory Commission as well, the reason being because they
19 seemed to be of such a size that they are already covered by
20 the present ECCS analysis, keeping in mind that the analysis
21 shows that as you go to smaller breaks, the core is always
22 covered.

23 So it's a little more difficult then to get people
24 interested in very small breaks when they look at the calcula-
25 tions and it says Well, the core is covered, and there's nothing

1 to worry about.

2 DR. CARBON: Let's move ahead with Dr. Catton's
3 report.

4 DR. CATTON: Actually what I would like to do is
5 make a few comments about where it's at now, and I'd like to
6 start by having read the newspapers before I got there, I
7 thought I was going to see a disaster. The combination of the
8 industrial associate group, GP, and NRC really comprised, as
9 far as I could tell, an exceptional pool of talent. I was really
10 amazed by the way things were going.

11 I'll start with cooldown.

12 A couple of days ago they decided they were going
13 to bring it from 280 degrees down to 230 degrees by just chang-
14 ing the steaming rate. It turns out all they've been able to
15 reach is 250, and at the present time the heat transfer is
16 limited on the secondary side. I personally really see no
17 problem with this. I'm not sure why they felt they had to get
18 to 230 before they could go to natural circulation anyway.

19 Another thing, I really think that if the operator
20 knew that going to natural circulation with a saturated system
21 meant that he would have very little cooling he would have done
22 something differently.

23 The present or the next series of events that are
24 going to occur is the first thing, the B steam generator is
25 out because of leakage problems. I don't think they are serious.

eb6

1 I just think that with the highly contaminated water they feel
2 they'll get into a problem so what they're going to do is to
3 use the turbine oil coolers and a little bit of replumbing and
4 that system will be taken to solid water.

5 At that time they will switch off the A steam genera-
6 tor onto the B steam generator which is now solid water. They
7 are then going to take the A loop and modify the routing into
8 the condenser so that the condenser will act better as a liquid-
9 liquid heat exchanger.

10 They then will bring the A loop solid water so they
11 have both the A loop and the B loop solid water through the
12 steam generators sitting at 1,000 psi.

13 They'll go to natural circulation, then they're going
14 to drop it, the pressure in the primary system, down to some-
15 where between 20 and 50 psi.

16 The question about gas content has been checked. The
17 results that came back from Idaho show that at the low pressure
18 they could have a hydrogen bubble of 350 cubic feet and at those
19 low pressures that's not very much.

20 The final step in this aspect is they will build
21 another cooling system that will be designed to 650 psi. This
22 will replace the two steam generators, the reason being is that if
23 they get into a problem and they have to come back up and
24 pressure, they'll have a secondary side that can withstand it.

General Reporters, Inc.

25 DR. SHEWMON: I'm lost here someplace. You talked

eb7

1 about 1,000 psi. That's your secondary system pressure.

2 DR. CATTON: No, the primary system is now at 1,000
3 psi.

4 DR. SHEWMON: Yeah, but you talked about-- And I've
5 heard 20 or 30, which I thought was where they wanted to take
6 the primary.

7 DR. CATTON: Yes.

8 DR. SHEWMON: Now we come back to 650 and that 650
9 applies to what?

10 DR. CATTON: To the secondary. You see, the inter-
11 mediate part of it in the near term, the secondary will be a
12 low pressure system, and so you have high pressure in your pri-
13 mary and low pressure in your secondary, and that's not a good
14 situation to stay in. So they're bringing the 650 psi for the
15 secondary system. The primary will be at 50, hopefully, but
16 if something happens to get out of line they can bring the
17 pressure back up and still have the high pressure on the second-
18 ary side.

19 DR. SIESS: You said there was a leak in the B steam
20 generator.

21 DR. CATTON: I believe so, yes.

22 DR. SIESS: How do they know?

23 DR. CATTON: I think they were picking up very high
24 levels in the secondary side.

25 MR. MATTSON: Could I add a couple of points that

eb8

1 might clarify two or three things here?

2 First on that one, there was evidently leakage on
3 the B steam generator early in the accident before it was
4 isolated. Indications are now from radioactivity measurements
5 in the secondary that the leakage has not continued. One ex-
6 planation for that might be that it leaked because it dried
7 out and then as it cooled off, being isolated and getting down
8 to these cooler temperatures, it doesn't leak as bad at colder
9 temperatures as it did at higher temperatures.

10 That's encouraging because it means when they go
11 to the water solid B steam generator the amount of fission
600 12 products carried to equipment they'll be pumping with will be
13 smaller.

14 Two other brief comments.

15 The Idaho analysis showed an amount of gas currently
16 existing in the primary coolant that would expand to something
17 like 300 cubic feet at 20 to 50 psi. It didn't show that it
18 was all hydrogen, however; it showed that it was mostly nitro-
19 gen, a little oxygen and a little hydrogen. It's just what you
20 would expect in a normal degassed system of this type during
21 normal operations.

22 Now we're confirming that first analysis. One was
23 done at Idaho and there was a second pressurized sample taken
24 of the primary coolant. I believe it's being analyzed at D&W
25 right now. There are several more planned, and they will go to

Serial Reporters, Inc.

1 different laboratories also, so that we get a check of the
2 veracity of the measurement. Early indications are quite good.

3 One final point.

4 The modification of the B steam generator to take
5 it solid that was just described is one of two alternatives
6 actually being pursued right now. The other alternative would
7 be to do the short-term and long-term B steam generator modi-
8 fication all at once.

9 They've been analyzing the PERT charts for the con-
10 struction process and it looks like you can actually achieve
11 both of them on the same time scale. If that's true then you
12 can go to the pressurized B secondary side in the first step
13 rather than having to wait for a second step.

14 I think those kinds of decisions are being made at
15 the site today. In the meantime, construction is going ahead
16 with piping and piping drawings and things like that. It's not
17 on the critical path. You'll hear more of this this afternoon
18 from Carl Berlinger.

19 DR. OKRENT: You indicated that that amount of gas
20 didn't seem to be a problem. In what sense?

21 DR. CATTON: There's 1500 cubic feet I believe in
22 the upper dome of the vessel.

23 DR. OKRENT: Do you know that that's where it will
24 go and not into the candy cane?

25 DR. CATTON: Not for sure.

ab10

1 DR. OKRENT: If it is in the candy cane is it a
2 problem?

3 DR. CATTON: I think it could be, yes. That many
4 cubic feet might be able to vapor lock--

5 MR. MATTSON: It's going to be on the basis of these
6 analyses that the pressure is chosen for the primary system
7 in natural circulation. There is nothing that says it has to
8 be 20 pounds or 50 pounds or 100 pounds. I think it's pre-
9 ferred to be lower but if the gas could expand and give you
10 difficulty and you can calculate that, then that's how you
11 choose your eventual pressure.

666

12 What is clear is that the system has been degassed
13 to a pressure of 300 psi, which means that anything that would
14 expand at 300 psi already has, and it has been brought into
15 solution out of the control rod drive housings or where-have-
16 you, high in the system. And that was the purpose of the de-
17 gassing operation for a period of some days last week.

674

c7

18 DR. SHEWMON: What evidence do you have that you're
19 beginning to get outgassing? I mean there are two sorts of
20 questions.

21 One, let's say you do fill the candy cane. Is it
22 just a matter of increasing the pressure to get yourself back
23 solid again?

24 And B, what evidence do you have before all of a
25 sudden you've got a large delta-T someplace and you're getting

eb11

1 into trouble?

2 MR. MATTSON: Those kinds of troubles are being
3 worked pretty hard. Essentially what you're asking are what
4 are the indicators of successful achievement of natural circu-
5 lation and maintenance of natural circulation.

6 You've got temperature indicators. You've got
7 pressure indicators. You've got core thermometry. Those kinds
8 of--

9 DR. SHEWMON: I'm asking about the unsuccessful
10 attempts.

11 MR. MATTSON: I'm sorry, I'm saying it in the same
12 sense. What would you be looking at to tell you first and
13 quickest that the natural circulation wasn't working?

14 MR. ETHERINGTON: Are the flow meters off-scale?

15 MR. MATTSON: Now, or in natural circulation?

16 MR. ETHERINGTON: In natural circulation.

17 MR. MATTSON: I would think they would be. Much too
18 low a signal is what Steve Hanauer is saying for the low flow
19 rates of natural circulation.

20 MR. ETHERINGTON: There'd be no difficulty in putting
21 in a monometer or something that would register it, would there?

22 MR. MATTSON: I won't say there's no difficulty in
23 installing post-accident monitoring equipment through sample
24 lines outside the containment. It is difficult. That is the
25 kind of thing people are looking at now, and designing and

eb12

1 putting in place.

2 For this natural circulation process to work you must
3 of course keep the primary system full and pressurized. There
4 is a system being designed and constructed for solid primary
5 pressure control from outside of containment. That will be
6 constructed and installed in the same time frame as the modifi-
7 cations to the steam generator.

8 MR. ETHERINGTON: Well, of course "difficulty" is
9 relative. Do I understand that people are looking to the
10 possibility of using the flow meters for an indication of flow?

11 MR. MATTSON: I think they decided that they won't
12 work.

13 MR. ETHERINGTON: No, I meant with-- Oh, not even
14 with the more sensitive....

15 MR. MATTSON: I see your point. The transmitters
16 are inside the reactor.

17 MR. MC MILLAN: And there's no way to get access to
18 those.

19 MR. ETHERINGTON: I see.

20 DR. CARBON: Go ahead, Dr. Catton.

21 DR. CATTON: I might just mention some of the con-
22 tingencies that have been mentioned in case natural convection
23 doesn't work, and I guess there are three or more.

24 The first was just to turn back on the reactor coolant
25 pumps.

eb13

1 And the second was to use feedwater in and bleed it
2 out of the pressurizer system.

3 The final one that I've heard is the reflux boiler.
4 I frankly don't think the reflux boiler will work with all those
5 gases; the non-condensables are just going to shut it off.

6 Also, Westinghouse is in the process of building a
7 residual heat removal system that's going to sit outside the
8 building on skids and sit in a Quonset Hut that's all properly
9 controlled. They're also, as I understand it, checking out the
10 existing residual heat removal system and doing things like
11 trying to figure out how to remote the lubrication so that if
12 it gets kind of messy in there they won't have to go in.

13 I understand they are also doing something with all
14 the drains and so forth so that if there is any leakage it can
15 be pumped and put back into the system.

16 That would give them three systems, each one of which
17 I believe could take care of the heat load.

18 They are also designing a permanent system that
19 would go in a building outside that itself would have to be
20 drained.

21 So that means there would be five methods, five dif-
22 ferent drains, each of which could do it itself.

23 MR. MATTSON: I'd add one more to that.

24 It is always possible for a short period of time at
25 least, on the order of days, to feed and bleed. You use low

b14

1 pressure to prime high pressure.

2 DR. CATTON: I mentioned feed and bleed.

3 MR. MATTSON: I didn't hear it. I'm sorry.

4 DR. CATTON: I mentioned the reactor coolant pump,
5 feed and bleed, and the reflux boiler, which I don't believe --

6 MR. MATTSON: Okay.

7 DR. CATTON: -- and then the Westinghouse systems
8 of which there will be eventually five.

050

9 The time scale in all of this stuff is really
10 amazing. Of course the days keep slipping, but it's always that
11 in five days away it's going to be running.

12 I'd just like to finish by mentioning-- When I
13 talked to the Westinghouse people Saturday afternoon, they
14 indicated next Friday which is pretty soon, I think.

15 I'd like to just mention the status of the core. It
16 does feed back onto the natural circulation in that you have to
17 circulate the fluid through the core in whatever state it's in.
18 Koffman from LOFT did a very nice analysis I think. What he
19 came up with seems to agree with everybody else's. I guess
20 there's been an analysis done by B&W, one by the Staff them-
21 selves, and then Koffman's, and then there was another group
22 with the Industrial Associates.

23 And basically what they-- The conclusion they come
24 to is that 30 to 45 percent of the zirconium is gone, it
25 oxidized, and that the central portion of the core which is

b15

1 about one-half radius and maybe a half down into the core is
2 pretty beat up and is probably in particles of a size that
3 they're unsure of. I've heard arguments all the way from dust
4 to each pellet being six pieces laying on a grid spacer. I'm
5 not sure where it's at.

6 Some of the work done by Ed Zebroski, I think from
7 EPRI-- He tried to make some calculations that would tell him
8 what temperatures are reached. And based on the xenon release,
9 he felt that the temperatures that were reached in the fuel
10 were like from 1600 to 1800 degrees Centigrade, or 2600 Fahren-
11 heit to 30000 Fahrenheit.

12 The interesting thing is that Koffman's analysis
13 was based on in-core instrumentation. I don't know exactly what
14 he did but he was able to interpret it as if it were a densi-
15 tometer, and from this he concludes that between 126 minutes
16 and 176 minutes, the core was dry, or pretty dry. And it was
17 in the middle of this period when they saw the big radiation
18 spike in the effluent coming out of the relief system.

19 And so it was his conclusion that most of the damage
20 was done during that period, and in the subsequent period there
21 was actually some boiling in the core so it really wasn't really
22 fully dried out.

23 MR. MATTSON: I would like just to add to that
24 description of the core that there is a spectrum of opinion
25 on what its exact configuration is. We've been pulling together

b16

1 here in Bethesda work done by the Industrial Advisory Group in
2 Middletown, the work done in several national laboratories,
3 and the work done here in Bethesda, trying to draw down that
4 spectrum of opinion and make it consistent with all the facts
5 as they are becoming available.

6 I think the description that has been given here is
7 probably toward the more extreme end of the possibilities. The
8 lesser end of the spectrum certainly doesn't have dust.

9 This is important from the standpoint of projecting
10 what the indicators of successful natural circulation should
11 be, and we expect to have that information pulled together this
12 week some time, and of course would want to provide it to the
13 Committee for your review and consideration.

14 DR. CATTON: As I understand it, the measurements
15 show that the resistance to the flow in the core has increased
16 by a factor of nine. And I believe the B&W study with regard
17 to whether circulation would work assumed a factor of 60, and
18 they came to the conclusion that natural circulation would be
19 okay.

20 So it seems to me that if it is only nine, that
21 there's plenty of margin. I do believe you may get local
22 boiling in the debris beds but I don't think that's any signi-
23 ficant problem. You'll just condense.

24 One other thing. In talking to some of the people,
25 nobody seemed to know how long-- There was some question as to

517
1 what you should do first. Maybe the Staff can clear this up.

2 If you decide you have to go on one of those RHR
3 systems, and Westinghouse's system is sitting out on the skid
4 and you've got the one inside that probably works, which one
5 do you choose first?

6 MR. MATTSON: The ones inside.

7 DR. CATTON: Well, that's not the opinion that I got
8 from some other people that were at the site. They felt that
9 the one inside, you had no way of knowing how long it was going
10 to run and further, that the grit in the water would burn out
11 all the mechanical bearings and you may only run for eight
12 hours.

13 MR. MATTSON: I think that's a severe speculation.
14 I don't know who you're talking to, but that's being looked at
15 very hard. Clearly the choice is the one inside.

16 DR. CARBON: Let me interrupt here. I would like to
17 try and stay on schedule, or close to it if possible.

18 Can we go to Steve? Do you have a report that you
19 would like to make?

20 DR. LAWROSKI: I think relative to what the agenda
21 says I don't have any, because I visited much earlier than
22 Harold or Michaelson or Catton.

23 I would like to ask, however, a question with res-
24 spect to the most recent -- the more recently taken primary
25 sample.

b18

1 Is there evidence of much suspended zirconium oxide
2 that would suggest problems of blockage?

3 MR. MATTSON: It is my understanding that there is
4 not evidence of zirconium oxide.

5 DR. LAWROSKI: I had heard there is not much uranium,
6 if any, but I didn't know with respect to the zirconium oxide
7 which is a lighter material and would be more easily suspended.

8 DR. SHEWMON: Is there any evidence of suspended
9 uranium oxide?

10 DR. LAWROSKI: That's a lot denser material, Paul.

11 DR. SHEWMON: I know.

12 MR. MATTSON: The answer is yes, there is some indi-
13 cation of uranium, small, small amounts and -- correct me if
14 I'm wrong -- lesser amounts than have been found with other
15 local damage situations in the past. The signs from the pri-
16 mary coolant sample of what kind of particulates are involved
17 and what the extent of uranium involvement and zirconium in-
18 volvement were are encouraging signs in the sense of material
19 outside of the core.

20 DR. LAWROSKI: And how about with respect to fission
21 products which, at the pH's we have here, would be more soluble,
22 as an indication of what might have happened in the core beyond
23 the severe high temperatures but short of any melting?

24 MR. MATTSON: I'm not sure I understand your ques-
25 tion.

eb19

1 DR. LAWROSKI: In the most recent sample of the pri-
2 mary, are there fission products detected which would be easier
3 to identify and quantify than uranium, because all the concen-
4 trations will be low pH's involved here, strontium, for
5 example?

6 MR. MATTSON: They're looking at--

7 DR. PLESSET: Fission products diffuse very slowly.
8 That's I think what Dr. Lawroski was concerned about, in part.

9 MR. MATTSON: If the question is are we going radio-
10 chemical analysis, looking for all these fission products, the
11 answer is Yes.

12 If you haven't seen the piece of paper that summarizes
13 them and from which people are drawing conclusions about the
14 extent of fuel involvement in the temperature transient, then
15 we'll get them to you. They are available.

16 But the correlate well, the first sample to the
17 second sample, lab to lab, a fairly good radiochemical charac-
18 terization of the core involvement.

19 DR. LAWROSKI: I haven't seen them.

20 MR. MATTSON: We'll get them to you.

21 DR. LAWROSKI: I know they had problems getting
22 additional primary samples out within the time they had hoped
23 to get them out.

24 MR. MATTSON: That problem has been solved and
25 samples are flowing rather routinely at this point; not many,

eb20

1 because it's a hot area, but as many as we need when we need
2 them.

3 DR. LAWROSKI: When I was there, which was Saturday
4 and Sunday -- Friday and Saturday, I should say, there was
5 concern about having enough volume for the liquid waste parti-
6 cularly. Has that problem been alleviated?

7 MR. MATTSON: Yes, two ways. One was to stop some
8 leakage in the auxiliary building of non-contaminated fluids
9 that were being used in secondary cooling systems outside of
10 containment. They shut those systems down for a brief period
11 of time, repacked the valves, repacked pump seals, and so that
12 non-contaminated leakage, which of course picks up some of the
13 contaminated fluid which came into the auxiliary building
14 early in the accident and spreads it around, that problem has
15 been put under control now.

16 In addition to that, there is work going on to add
17 liquid waste storage capacity in the plant, a significant addi-
18 tion of tankage, a tank farm in the spent fuel storage pool for
19 Unit 2. Those tanks were being installed yesterday and should
20 be piped up and ready to go in another few days.

21 DR. LAWROSKI: Because they were somewhat handi-
22 capped as to what they could do at that time with the additional
23 quantities of effluent.

24 MR. MATTSON: That was a management difficulty, a
25 liquid waste management difficulty a week or so ago, and it

21

1 seems to be under control at this point.

2 MR. ETHERINGTON: There was an indication of silver,
3 presumably from control rods in the water. Any indication of
4 how much?

5 MR. MATSON: I'm not sure that's correct. There
6 may have been a misimpression from the first primary coolant
7 sample done at Bettis. What was said was they looked for silver
8 from the control rods and the detection capability of the equip-
9 ment and with this kind of sample would mean that they couldn't
10 see anything less than three control rods involved in the
11 coolant; that is, if there were less than three they couldn't
12 detect it.

13 They didn't detect any so they said there certainly
14 weren't more than three, is what I understand the results of
15 that sample to be.

16 That's not the same thing as saying there is silver
17 in the coolant, and I don't think anybody has detected silver
18 in the coolant yet.

19 DR. CARBON: Shall we move ahead then to Jerry,
20 your report?

21 MR. RAY: A couple of very brief comments due to the
22 shortage of time. The gentlemen before me have covered quite
23 thoroughly the situation out there, but I do have to repeat
24 in all justice the observations of Harold and Ivan in tribute
25 to the organization that was set up here and the participants

xz...xzx

eral Reporters, Inc.

b22

1 in it that were participants, as you know, from all the reactor
2 vendors, several of the utilities, and of course all compo-
3 nents of the NRC organization, and GPU also. And their con-
4 centration appropriately was on the control and cooldown of
5 the plant, and maintaining it in a safe condition.

6 And do think that their work was outstanding and we
7 all owe them a tribute.

8 I was interested in the continuity of service of the
9 electrical facilities and I was very much impressed that so many
10 of the thermocouples were still in service. I think as of
11 Wednesday when I left there were 49 or 52 thermocouples still
12 in service, which was quite an accomplishment recognizing the
13 extreme environment to which they had been exposed. And simi-
14 larly for the rest of the facilities.

15 Dave Okrent raised the question of offsite pow-
16 and while I was there, Roger, I had the impression, as you
17 stated, that there was an understanding with the PJM inter-
18 connection management and operations that this site would get
19 preferential service.

20 And I might comment that you couldn't be in a better
21 position insofar as PJM's 230 Kv network is concerned for good,
22 reliable offsite supply. It's a very well-integrated, very
23 closely-coupled system, and you have lines coming into the
24 Susquehannah Valley from north, south, east and west, so it's
25 ideal from that standpoint. And the Susquehannah Valley is

eb23

1 very well sprinkled with generation capacity so that you're not
2 going to -- you're not likely to be isolated.

3 And having a multiple series of channels of trans-
4 mission into the site, it's in very good shape from that view-
5 point.

6 The real --

7 MR. MATTSON: Could I interrupt just a second, please?

8 The problem with offsite power we ought to also men-
9 tion, that auxiliary power supplies have been brought to the
10 site and are being hooked up, so this question of reliance on
11 onsite power is rapidly coming to a conclusion. I'd expect
12 within this week that most of the backup power supplies are
13 being hooked up, and that that kind of problem will cease to be
14 one.

15 MR. RAY: I understand they're going to have their
16 own drive. They are either diesels or small diesels or gas
17 turbines and that sort of thing. It will be divorced ultimately
18 from reliance on offsite.

19 MR. MATTSON: That's right.

20 MR. RAY: The decentralization of those supplies is
21 good, too, because then you're less vulnerable to an on-site
22 incident that would take out a transformer.

23 Steve mentioned concern about the helicopter traffic
24 pattern. Carl Michaelson and I discussed that while we were
25 there and I didn't see it, but he said he saw one helicopter

24
1 flying over the island.

2 My observations were that the traffic in and out of
3 the paths was from the east and northeast and really what they
4 were doing was staying clear of the 500 Kv substation and they
5 were staying clear of the island and they were going off at
6 an angle and going north to get away from the site. And it
7 looked like someone had gotten to the pilots and they under-
8 stood where their channels were to get in and out.

9 DR. LAWROSKI: That was the situation later.

10 MR. RAY: Yes. That was Wednesday, yes.

11 So that from that viewpoint it seemed to be well-
12 organized.

13 I did get a chance to discuss with several of the
14 NRC people this question, in view of the operating incidents
15 that precipitated this and developed during the incident,
16 their impressions of the capabilities of the operators of MetEd.
17 And incidentally I was told that at least two NRC personnel,
18 and sometimes three or four will be in the control room at all
19 times, three shifts a day.

20 The preliminary impressions that had been formed as
21 of then by the NRC people who were in close touch with these
22 operators was that there was no really basic lack of competence.
23 Of course the incidents that developed here, being an exception
24 to the situation, but it seemed-- The impression was that they

e-25

1 knew what they were doing. They were well familiar with their
2 plant and were able to perform.

3 There may be changed in that respect in the mean-
4 while but I don't know. That was as of Wednesday.

5 Also the NRC people indicated that there had
6 been immediate attention to the need for fire protection and
7 that steps had been taken by the operating personnel to insure
8 that all the alarms and all the hoses were in position, and
9 that there was a 24-hour fire watch with personnel on duty
10 around the clock, all of which indicated to me that they had
11 addressed themselves to the really urgent situation, and with
12 good responsiveness.

13 I was very much interested in B&W's presentation on
14 Wednesday afternoon as to their studies of what had happened
15 in the core with respect to fuel damage, and also their concern
16 about the transition to natural circulation. They obviously
17 had analyzed it quite thoroughly, and I would hope that you're
18 going to tell that story this afternoon in your presentation.

19 They had gone to the point of establishing benchmarks
20 to guide operation in the course of the transition and while
21 on natural circulation, so it seemed to me that it was quite
22 thoroughly addressed.

23 One last point was that they had considered, in view
24 of the disarrayed condition of the fuel elements, the question
25 of criticality, and I gathered from the story that they gave us

eb26

1 that with the proper boron content -- and they've indicated
2 the quantitative measure of that as of then -- you were in good,
3 safe condition for all possible fuel configurations including
4 a total core slump.

5 And I hope, Mr. McMillan, you're going to tell us
6 that story this afternoon.

7 That's all.

8 MR. MATTSON: I might just add some further elabora-
9 tion of that.

10 In engineering analyses sometimes you take things
11 to the limit to make sure you can't be in a situation that gets
12 you in trouble. And one limit, a hypothetical limit, is to
13 assume that the rods are gone, as you've described. There is
14 no evidence to indicate that they are, or that they are not --
15 are in any way different than where they started.

16 Even if they were all gone and even if you took
17 theoretical packing densities and things like that, borated to
18 the extent you are borated now you would not have criticality.
19 That has ceased to be a concern.

20 DR. CARBON: Dr. McCreless?

21 DR. MC CRELESS: I just wanted to bring this to the
22 Committee's attention, the report you have on the site visit,
23 which then devotes some written detail, everything I think
24 you've heard today, but the current status of the plant, the
25 recovery organization, and recovery plan, and the answer to

eb27

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

several questions that various Committee members have asked before that we were able to get the answers for while we were there.

DR. CARBON: Any last questions from the Committee?

(No response.)

Let's recess for an hour for lunch.

(Whereupon, at 1:40 p.m. the meeting was recessed to reconvene at 2:40 p.m. the same day.)

End WRBloom
Ioffman fls.

AFTERNOON SESSION

(2:40 p.m.)

1
2
3 DR. CARBON: Let me bring up an extraneous topic
4 before we get into the afternoon session. We're having some
5 difficulty scheduling a common time for the Commissioners
6 tomorrow afternoon. Their schedule doesn't fit ours and
7 vice versa.

8 I'd like to check and ask what time are people
9 leaving tomorrow afternoon? Specifically, who needs to leave
10 by 4:00 o'clock?

11 (A show of hands.)

12 DR. CARBON: One, two, three, plus Dr. Kerr will
13 leave this evening. So that after 4:00 tomorrow, we would have
14 two, three, four, five, six of us.

15 DR. OKRENT: How do you define "after 4:00"? I have
16 a 5:40 plane from Dulles, and can you tell me?

17 DR. CARBON: I'm not sure.

18 MR. FRALEY: They have proposed a meeting from 3:30
19 to 4:40 instead of 2:30 to 3:30. I'd like to know how many
20 can be here at that meeting?

21 (A show of hands.)

22 DR. CARBON: The three of us, I guess. Okay.
23 Let's go ahead, then, to the afternoon session. I'll
24 call on Mr. MacMillan.

25 MR. MAC MILLAN: Thank you, Mr. Chairman. As I look

1 around the table, I've seen many of you in the last two weeks
2 at Three Mile Island as you've been visiting the site there.
3 I'm pleased to hear the reports that you've brought back and
4 reported this morning.

5 I'm going to read a prepared statement. I believe
6 you all have copies of that statement. I understand that
7 there may be some logistical problems in the sequence in which
8 the figures are attached to that statement, and so I will be
9 showing slides, overhead slides, as the appropriate time in the
10 statement comes up, and you may have to be working backwards
11 through your figures rather than forwards.

12 My name is John MacMillan. I'm Vice President of
13 the Nuclear Power Generation Division of the Babcock & Wilcox
14 Company. The Division is responsible for marketing, engineering,
15 project management and related services of the nuclear steam
16 systems supplied to the utility industry by Babcock & Wilcox.

17 Today I will discuss the incident at Three Mile
18 Island 2, with special emphasis on B&W's activities which we
19 have currently underway or shortly will have underway as a
20 result of that incident.

21 I have with me today a number of support personnel,
22 many of whom are familiar to the Committee, to assist in
23 answering questions. These people are arrayed around the
24 table there on the other side of the room.

25 From the time that B&W was first notified of the

1 TMI-2 incident, B&W's number one priority has been to provide
2 support and assistance to bring the plant to a cold shutdown
3 condition. Closely paralleling that have been efforts to
4 assure continued safe operation of the other B&W operating
5 plants. As the situation at Three Mile Island continues to
6 improve, we will be strengthening our efforts related to the
7 other plants.

8 On the basis of what is now known about the factors
9 affecting the incident, we believe that appropriate measures
10 have been taken by the utilities, B&W and the NRC to ensure
11 the continued safe operation of those plants.

12 My remarks today will be prefaced by: One, an overview
13 of the B&W nuclear steam system, with emphasis on those plant
14 features of relevance to the incident; two, a summary of the
15 specific actions taken by B&W to support and assist the
16 licensee in connection with the TMI-2 incident; and three, our
17 preliminary views on the six factors identified by the NRC in
18 its I.E. Bulletin 79-05A as significantly affecting the course
19 of that incident.

20 In that context, I will then proceed to address:
21 First, the immediate actions taken by B&W, the utilities and the
22 NRC to ensure continued safe operation of the other B&W reactors;
23 second, our planned near-term and long-term actions to provide
24 further assurance of continued safe operation.

25

For the purpose of our discussion today, I will

1 provide a brief overview of typical B&W design features.

2 (Slide.)

3 You'll see this attached figure to the prepared
4 testimony. Shown here is a reactor vessel and the reactor core
5 is located in that vessel. There are two steam generators,
6 one shown here and one here, each served by two reactor coolant
7 pumps. The flow comes from out of the bottom reactor steam
8 generator into the reactor vessel, through the reactor core,
9 out of the reactor vessel and back into the steam generator.

10 On the A loop of the Three Mile Island unit is
11 located a pressurizer. And this is a schematic. This does
12 not show the elevation of the components.

13 In the top of the steam generator, there's an electro-
14 magnetic relief valve, which we'll talk a great deal about
15 during the discussion, an isolation valve on the pressurizer
16 side of that power-operated relief valve. There are also two
17 code safety valves located in the top of the pressurizer.

18 All of these valves discharge into a drain tank which
19 condenses the steam and keeps that steam out of the reactor
20 building.

21 There are a number of other features shown here. The
22 normal line to the letdown coolers comes off the bottom of the
23 steam generators here. High-pressure injection comes back into
24 each of the four reactor coolant loops on the cold side, on the
25 pump discharge side of that loop. And the makeup control

1 valve normally supplies makeup through that same path.

2 There are two core flood tanks, which are pressurized
3 with nitrogen and which tie into the reactor vessel through
4 check valves as shown here.

5 (Slide.)

6 Looking at an elevation of the nuclear steam system,
7 you will recognize this as quite similar to the diagrams that
8 Carl Michaelson had all colored up for you this morning. This
9 is the reactor vessel in the center, the reactor core in the
10 middle of that reactor vessel, one steam generator shown here.
11 High-temperature water comes out of the reactor, goes up through
12 the top of the steam generator, flows down through the tubes on
13 the inside of the steam generator, discharges through two lines
14 coming out of the bottom of the steam generator, which feed
15 the circulating pumps, back into the reactor vessel.

16 The position of the pressurizer is shown here, the
17 surge line tying into the hot leg, the high-temperature leg
18 of the A loop, and the surge line feeding into the pressurizer.
19 The pressurizer electrical heater is located at the bottom of
20 the pressurizer. The relief valve is located on the top of
21 the pressurizer.

22 DR. CARBON: And these are to scale as far as
23 elevation?

24 MR. MAC MILLAN: Yes, these show the relative
25 elevation of the components.

1 Let's look, then, at the secondary system.

2 (Slide.)

3 This secondary system is schematic, and I say a
4 simplified schematic of the Three Mile Island 2 system. The
5 steam generators you see on the right-hand side of the chart,
6 each, of course, tied in with the reactor coolant system.
7 Steam comes out of the steam generators, flows over to the
8 turbine in normal service, and the turbine into the condenser.
9 Suction is taken on the condenser by the condensate pumps.
10 The condensate polishing equipment, located upstream of those
11 pumps, feeds the condensate booster pumps through a series of
12 heaters to the feedwater pumps, through high-pressure heaters
13 and back into the steam generators, through the main feedwater
14 nozzles of the steam generator.

15 For emergency service, there is a series of feedwater
16 pumps, two half-size electric motor pumps and one whole-sized,
17 steam-driven pump. These pumps can either take suction from
18 the main feedwater header here, you see, or from the condensate
19 storage tanks.

20 I would hasten to say, these check valves are shown
21 diagrammatically as installed backwards. They allow free
22 suction from the suction of the feed pumps, from these feed
23 pumps through the control valves which modulate the feedwater
24 flow from the auxiliary pumps through block valves --these are
25 the block valves that were closed in the early phases of the

1 incident -- and then into the steam generators at the
2 auxiliary header, which is located at or near the top of the
3 secondary side of those steam generators, as you saw this
4 morning in Carl Michaelson's diagram.

5 I didn't mention that when the turbine is out of
6 service there is a turbine bypass valve which allows steam to
7 be taken directly from the main steam lines through bypass
8 control valves and dumping into the condenser, and in fact,
9 that's the mode in which the A generator is presently operating
10 at Three Mile Island 2.

11 As designed, this arrangement will satisfactorily
12 accommodate a loss of feedwater transient. This is confirmed
13 by our safety analyses and experiences with a number of loss
14 of feedwater transients which have occurred at this plant and
15 other B&W-operated units.

16 With that background, then, let me turn to a summary
17 of the actions that we've taken in support of the incident at
18 Three Mile Island 2.

19 Early in the morning of March 28th, B&W management
20 in Lynchburg was notified of the incident. Immediately there-
21 after, we convened a meeting of experts to identify specific
22 information and manpower needs for providing support to the
23 licensee.

24 As a result of that meeting, five people were
25 dispatched to the site, and by early afternoon a communications

1 center was established in Lynchburg, which was staffed by our
2 senior management and technical people.

3 By the second day, Thursday, we had established on
4 organization to provide round-the-clock support within that
5 organization. Specific responsibility was assigned for evalu-
6 ating data obtained from the site and developing a postulated
7 sequence of events for conducting simulations of the events
8 on the B&W control room simulator and for developing and
9 recommending contingency procedures for performing comparisons
10 of the physical plant data, for conducting specific analyses,
11 as requested by the licensee or the NRC, and for reviewing
12 reports of other loss of feedwater transients.

13 As the course of the incident progressed and the
14 need for support increased, we dispatched additional people
15 and equipment to the site. I personally went to the site to
16 head the B&W on-site team. At the peak of the B&W effort on
17 the incident, we deployed 47 people to the site and 218 people
18 in Lynchburg were assigned to the communications center and
19 related support activities.

20 Out of this initial effort grew an organizational
21 framework which gave us the capability to shift our emphasis
22 to efforts to assure continued safe operation of the other B&W
23 operating reactors.

24 (Slide.)

25 Let me turn now to a discussion of the significant

1 factors in the incident. For the purpose of today's discussion,
2 we accept the sequence and the list of six significant factors
3 identified by the NRC in its I.E. Bulletin 79.05A. Thus I
4 will not retreat ground already covered, but instead, will
5 summarize our views on the significance of those factors and
6 their sequence.

7 First, after the loss of feedwater transient was
8 underway, the absence of auxiliary feedwater to provide
9 secondary side cooling for a period of in excess of eight
10 minutes resulted in delay of residual heat removal and tempera-
11 ture increase in the reactor coolant system. The presence of
12 auxiliary feedwater, as designed, would have stabilized reactor
13 coolant temperature earlier in the transient and eliminated a
14 complicating distraction to the operator.

15 Second, as a result of the system pressure increase,
16 the pilot-operated pressurizer relief valve opened as designed,
17 but did not reseal properly, thus allowing reactor coolant
18 system pressure to continue decreasing. In our view, the
19 significance of this factor is not only the failure of the
20 valve to reseal, but more importantly, the time which elapsed
21 between the failure to reseal and the recognition that this
22 had occurred.

23 Third, the high-pressure injection system, which had
24 been automatically actuated, as designed, on low reactor
25 coolant system pressure, was prematurely terminated, even

1 though there were indications of an opening in the reactor
2 coolant system pressure boundary, such as increasing quench
3 tank pressure and decreasing reactor coolant system pressure.

4 Fourth, the containment did not isolate at the time
5 the emergency core cooling system was actuated. This is in
6 accordance with the licensed design. This led, through a
7 series of circumstances, to radioactive water in the reactor
8 building sump, and the lack of containment isolation allowed
9 this fluid to be pumped to the auxiliary building, from which
10 subsequent radiation releases occurred.

11 DR. CARBON: Question. Could I go back to Item 3.

12 MR. MAC MILLAN: Yes, sir.

13 DR. CARBON: I've asked several times in the last
14 two weeks whether there is or is not an indicator in the
15 control room that the PORV is open or closed. Is there or is
16 there not?

17 MR. MAC MILLAN: Let me answer that very specifically:
18 There are indicators in the control room which indicate whether
19 or not the solenoid on that power-operated relief valve has
20 been energized or de-energized. And in the event that it is
21 energized, it indicates the valve is open; and when it's
22 de-energized, you would assume the valve was closed.

23 However, that does not measure the position of the
24 seat on the pressure-operated relief valve. So the operator
25 is not seeing an indication of whether the valve is open or

1 shut; he is merely seeing whether the solenoid which operates
2 the pilot on that valve has been energized or de-energized.
3 So he could get an indication that the solenoid is de-energized,
4 presume that the valve was closed when in fact the valve was
5 open.

6 Now, there are other indications which would lead
7 him to an indication of open valve. We talked thi. morning
8 about thermocoupling the tailpipe. That's in the line that
9 comes from the discharge of the power-operated relief valve
10 to the quench tank. That tells him whether he's got hot fluid
11 in that tailpipe.

12 I think you raised a question this morning about the
13 response. It was a very fast-responding thermocouple.

14 DR. CARBON: How about in a small leak, if the valve
15 closed 95 percent or something and you still had steam going
16 out. Would the thermocouple show it?

17 MR. MAC MILLAN: The thermocouple has a couple of
18 purposes. One is to show that the valve is open, if you go and
19 look at the thermocouple. A second one is also to tell whether
20 the valve is simmering, and when it simmers you get a higher
21 temperature on that thermocouple than you do in the other, the
22 tailpipe of the other valves. But it's not at the temperature
23 of the steam in the pressurizer.

24 If the valve is wide open, then the temperature you
25 see in that thermocouple is essentially the pressurizer steam

1 temperature.

2 Now, in addition to that, there are indicators on
3 the quench tank for both pressure and level. These are
4 audible and visible light alarms in the control room. So
5 there is that backup indication as well that the valves may
6 be open.

7 DR. PLESSET: Has consideration been given in the
8 design of that pressurizer valve to its withstanding exit flow,
9 particularly if it's not of high quality? Do we know that it
10 would still close if the solenoid were de-energized?

11 MR. MAC MILLAN: The valve is designed primarily for
12 steam service. We've had evidence that it will operate with a
13 mixture of steam and vapor.

14 DR. PLESSET: But have they analyzed it to see what
15 kind of loads that low-quality flow might give which would act
16 so as to make it less likely that the valve would close?

17 MR. MAC MILLAN: I can't answer that question. I
18 don't know. But we'll get you an answer for that.

19 DR. PLESSET: Thank you.

20 MR. MAC MILLAN: Yes?

21 DR. SHEWMON: Is there anything in the record -- I
22 don't know whether this is from you or the staff -- as to
23 whether or not the operator had in the operating room an
24 indication that the solenoid had been de-energized?

25 MR. MAC MILLAN: No, I just don't know. I don't know

1 what the operator had available to him at the time of the
2 incident, and I couldn't confirm that.

3 DR. SHEWMON: Thank you.

4 MR. MAC MILLAN: Fifth, high-pressure injection was
5 evidently manually operated, based on high pressurizer level
6 indication.

7 We have conducted reviews of data from Three Mile
8 Island and performed analyses that lead us to conclude that the
9 indicated pressurizer level was not significantly in error.
10 Plus or minus one foot, we believe that the pressurizer was
11 essentially full during a long period of this transient. But
12 a portion of the reactor coolant system was void. Consequently,
13 termination of high-pressure injection flow should not have
14 been based on the single parameter of pressurizer level.

15 Sixth, all four reactor coolant pumps were secured.
16 Although securing one coolant pump in each loop in response to
17 indications of low coolant flow may be advisable, securing all
18 pumps under the circumstances then present caused an uncovering
19 of the core.

20 PROF. KERR: Excuse me. Under the fifth item, I
21 presume "operating" refers to, at least initially, the pumps
22 being turned off?

23 MR. MAC MILLAN: Yes. Let me understand, Bill, what
24 your point is there.

25 PROF. KERR: You say high-pressure injection was

e-1

1 manually operated?

2 MR. MAC MILLAN: Was manually initially turned on.

3 PROF. KERR: Thank you.

4 MR. MAC MILLAN: The high-pressure injection pumps
5 went on at 1600 pounds, as designed, and the evidence was that
6 they were secured, one or more were secured shortly there-
7 after.

8 DR. CARBON: One more question on that thermocouple.
9 Does it read out on some instrument?

10 MR. MAC MILLAN: I know it reads out on the computer.
11 I don't know whether it reads out on an instrument. But we'll
12 find that out.

13 Would you make a note of that?

14 DR. CARBON: And if it's in the computer, an associ-
15 ated question would be: Does the operator routinely see it or
16 does he have to look for it?

17 MR. MAC MILLAN: He would have to call for that
18 information from the computer.

19 MR. CASE: John, do you know if HPI was turned on and
20 if so, when, again?

21 MR. MAC MILLAN: Ed, I ought to say right here that
22 one of the missing pieces of evidence in this incident is a
23 time-phased understanding of what actions were taken in the
24 control room, including the timing of securing HPI and
25 re-initiating HPI and whether or not it was being throttled,

1 and if so, to what extent.

2 I think the comment was made here earlier that we
3 ought to try to go through and try to reconstruct an analysis
4 of the events as they actually took place at Three Mile
5 Island 2 in order to understand the transient better. I would
6 say one of the important missing pieces of information in
7 conducting that analysis is the amount of high-pressure injec-
8 tion or makeup flow that was being pumped into the reactor
9 coolant system as a function of time. That's a very vital
10 piece of information in order to make that analysis.

11 I'd like now to turn to actions implemented for our
12 operating reactors. Our analysis of the foregoing factors has
13 led us to conclude that the B&W systems can be operated safely
14 for a spectrum of equipment failures, including those experi-
15 enced at Three Mile Island 2.

16 However, the severity of the Three Mile Island 2
17 incident warrants timely actions to encourage proper operator
18 performance in these events. Our recommended actions can and
19 should be implemented in chronological stems to ensure and
20 enhance continued safe operation. Thus, my discussion consists
21 of addressing: A, the actions already taken; B, the near-term
22 actions to be taken; and, C, longer-term actions appropriate
23 to meet the above objectives.

24 Before proceeding to a discussion of the specific
25 actions, I would like to establish a context for those

1 discussions with our initial view of the lessons learned from
2 the incident.

3 (Slide.)

4 Our analysis of the six factors identified by the
5 NRC has yielded a set of three basic principles which we
6 believe warrant emphasis in considering any future actions.

7 First, renewed emphasis must be placed in the near term
8 on administrative controls to assure that plant systems impor-
9 tant to safety are available. In the longer term, considera-
10 tion should be given to whether plant systems to augment those
11 administrative controls should be developed and implemented.

12 Second, renewed emphasis must be placed on maintaining
13 the individual operator's focus upon the fundamental physical
14 processes which assure core cooling and on determining that
15 our systems complement or increase the likelihood of maintaining
16 that focus in any event in the near term. This means placing
17 emphasis in operator training programs and instructions on the
18 fact that the most stable and forgiving condition in a pres-
19 surized water reactor is one in which the reactor coolant is
20 subcooled and core cooling is maintained.

21 As a corollary, a saturated loop must signal in the
22 mind of the operator: One, extreme caution before securing
23 any means of maintaining primary system inventory; two, a
24 warning that a system opening exists; and three, a prohibition
25 against any action which might diminish core cooling.

1 Third, any actions or modifications implemented must
2 be considered in the broader context of total plant safety.
3 Hasty and ill-conceived actions which might be partially
4 responsive to the TMI-2 events could, in certain cases,
5 produce adverse impacts in other safety systems which were not
6 involved at TMI-2.

7 Now, with that introduction, I will proceed to
8 discuss the actions already taken and those anticipated for
9 the near and longer term. Let's look at those that we've
10 already taken.

11 B&W contacted representatives of its other operating
12 plants by telephone between March 29th, the day after the
13 incident was initiated, and March 31st, to provide them with
14 the information regarding TMI-2 and to recommend that they
15 have station personnel check the configuration of their
16 auxiliary feedwater systems and make such inspections and tests
17 as necessary to confirm that the systems would initiate flow
18 of auxiliary feedwater upon actuation.

19 By April 1st, Sunday, B&W had further data regarding
20 TMI-2 which we believed would be helpful to other B&W operating
21 plants in understanding the causes and the course of events of
22 that incident. I personally contacted each of the utilities,
23 the management of each of the utilities, and invited them to
24 send representatives to a meeting in Lynchburg scheduled for
25 Tuesday, April 3rd.

1 Soon thereafter, I guess almost concurrently, NRC
2 issued its Bulletin 79-05. The meeting was held in Lynchburg
3 on April 3rd and 4th, with each of the utilities having
4 representatives present.

5 At that meeting, B&W presented the data we had on
6 the incident and discussed with the representatives similarities
7 and differences in their equipment and procedures from those
8 of TMI-2.

9 I might say that much of the information that
10 Carl Michaelson presented to you this morning on the curves
11 and graphs formed the basis for that presentation to those
12 utilities.

13 Additional information was provided and specific
14 questions by customer representatives were answered.
15 Bulletin 79-05 was discussed and B&W provided assistance in
16 responding to Bulletin 79-05, both during this meeting and
17 subsequent thereto.

18 The first B&W advisory was forwarded by telecopy to
19 these utilities on April 2nd. It recommended as a precautionary
20 step that the operators perform a thorough review of the
21 auxiliary feedwater system, associated support and control
22 systems, and normal maintenance and emergency procedures to
23 identify potential problems that might lead to failure of the
24 auxiliary feedwater system when it is required. It also
25 recommended that the design of the auxiliary feedwater system

1 and the operating, maintenance and emergency procedures
2 associated with this system be reviewed with all operators,
3 maintenance and supervisory personnel, with special emphasis
4 on the importance to plant safety.

5 The second advisory was forwarded by telecopy to
6 operating plant customers on April 4th, 1979. It recommended
7 that if the high-pressure injection system has been actuated
8 because of a low pressure condition, it should remain in
9 operation until specific plant conditions exist. The conditions
10 stated are that the operation of the high-pressure injection
11 continue for at least 20 minutes and as long thereafter as
12 necessary to obtain temperatures in the loop which are at
13 least 50 degrees Fahrenheit below saturation temperature, or
14 that operation of the high-pressure injection continue until
15 both low-pressure injection pumps are flowing at a rate of
16 at least 1,000 gallons per minute each in a stable condition,
17 and have been so flowing for at least 20 minutes.

18 The advisory also called for continued operation of
19 at least one reactor coolant pump per loop if the high-pressure
20 injection system has been actuated and the reactor coolant
21 pumps are in operation at the time of the actuation.

22 On April 6th, another meeting between B&W and the
23 owners was held specifically to discuss information available
24 and B&W recommendations regarding the responses the utilities
25 were preparing to I.E. Bulletin 79-05 and -05A. We provided

1 further assistance in regard to Item 1, involving understanding
2 of the sequence of events, and Item 3, involving operating
3 procedures for coping with transients with a potential for
4 introducing voids in the reactor coolant system.

5 We understand that the actions implemented and the
6 audits conducted in response to NRC Bulletin 79-05 and -05A
7 have been positive. This, coupled with the NRC staff's review
8 of utility responses to these bulletins and its ongoing review
9 of the incident, provide high confidence that the significant
10 factors in the TMI-2 incident have been properly addressed.
11 Thus, we believe that the actions taken to date by B&W, the
12 utilities and the NRC provide adequate assurance of continued
13 safe operation, while considering additional near and longer-
14 term actions.

15 Let's now look at those actions which we categorize
16 as near-term. Although we believe that the steps taken by the
17 utilities, the NRC and B&W assure safe operation of the nuclear
18 units, we recognize that additional measures must be taken so
19 that operators are better able to manage transients.

20 I would like to summarize the actions B&W currently
21 has underway or will be commencing soon to further enhance the
22 safety of B&W units.

23 First, B&W is preparing a supplementary advisory
24 requesting that all operating and supervisory personnel review
25 the indications of an opening in the reactor coolant system

1 boundary resulting from an open relief valve. The supplementary
2 instructions will be issued this week to all our customers with
3 operating reactors.

4 Second, during the April 6th meeting with represen-
5 tatives of our other B&W operating plants, B&W suggested a
6 special training program for operators, to be conducted on our
7 simulator, so that they would be more familiar with the TMI-2
8 sequence of events. On Monday, April 9th, B&W began conducting
9 training for operating and management personnel on the events
10 involved in the TMI-2 incident.

11 (Slide.)

12 The training consists of the following: A discussion
13 of the TMI-2 transient from the information available to B&W.

14 Secondly, a demonstration of the incident on the B&W
15 simulator. We have modified our simulator so that we can
16 fully simulate the events that took place, including our best
17 knowledge of what actions were taken by the operators during
18 the course of this event.

19 MR. MICHAELSON: Would you clarify whether that
20 simulation is the long-term or the first, say, 20 minutes?

21 MR. MAC MILLAN: It's long-term.

22 PROF. KERR: Excuse me. I did not hear
23 Mr. Michaelson's question and I would like to.

24 MR. MICHAELSON: The question was simply a clarifica-
25 tion as to how far out in time the simulation went.

1 MR. MAC MILLAN: The simulation deals primarily with
2 the early events in the incident. I think there was a question
3 earlier -- perhaps Dr. Okrent asked the question -- about just
4 how well we could simulate the various features of the reactor
5 system and the reactor core. We believe we have a valid
6 simulation of all of these features involved in the thermal
7 hydraulics of the reactor system and the reactor core up to
8 the point where there might be the introduction of
9 non-condensable gases or some type of major cladding inter-
10 action. But the basic thermal and hydraulic characteristics of
11 the system and the core, we believe we have.

12 A training session on the simulator, having students
13 recover the plant from a depressurization event which involves
14 the formation of steam voids in the reactor coolant system
15 outside the pressurizer. This is characteristic as to what
16 was shown at Three Mile Island. It could also simulate other
17 events which could get the nuclear system into a similar kind
18 of steam void condition in the reactor coolant system.

19 Six operators are included in each training session.
20 The training session lasts one day. At the present time, 33
21 operators have been through the course, and 99 more have defi-
22 nite schedules established, including operators from all the
23 operating B&W plants.

24 We believe this course will significantly contribute
25 to the ability of operators to respond properly to transients

1 in general and the loss of feedwater transient in particular.
2 We also believe it will serve to emphasize the procedures to
3 be followed in identifying a small reactor coolant system leak
4 and particularly an open pressurizer relief valve.

5 The third near-term action item: Based on informa-
6 tion currently available to B&W, the equipment in both the
7 primary and secondary plant, with the exception of the pilot-
8 operated pressurizer relief valve, performed as designed.
9 However, considering the unanticipated events at TMI-2, design
10 improvements should be considered in order to assist plant
11 operators in controlling nuclear power plants during transients.
12 Some potential design improvements are currently being studied.

13 DR. CARBON: Question.

14 DR. PLESSET: Mr. MacMillan, could you send to us
15 some description of this simulator program and how the training
16 is carried out?

17 MR. MAC MILLAN: Yes, sir.

18 DR. PLESSET: That would be much appreciated, I
19 think.

20 MR. MAC MILLAN: I would even offer, if you would
21 like, for some of your Committee members to come to Lynchburg
22 and try it yourself. I'll leave that as an open invitation.

23 DR. CARBON: What level of operators have you been
24 having? Senior operators? Supervisors?

25 MR. MAC MILLAN: Yes, all of the above.

1 MR. MATHIS: One other question: How does the
2 simulator present the formation of voids so the operator can
3 recognize it?

4 MR. MAC MILLAN: He has to determine that from the
5 in-plant instrumentation that's installed and displayed on the
6 control panel. He has system pressure, he has pressurizer
7 level, he has the hot and cold-leg temperatures, all of these
8 on one segment of the control panel right adjacent to one
9 another. By looking at the pressure and the temperature, he
10 can determine whether he is in a subcooled or saturated
11 condition. And in the event he is showing saturated conditions
12 and he has to assume that there are voids in the system at
13 some place, that should trigger him to be concerned about
14 whether or not he's getting a valid pressurizer level indica-
15 tion.

16 Yes?

17 DR. SHEWMON: How does he know whether or not he's
18 saturated?

19 MR. MAC MILLAN: That's a good question, and the only
20 way that he knows right now is to either look at a chart that
21 has been drawn for him -- some utilities have put the pressure
22 versus temperature on their computer, so he can call that up and
23 look and see what it is. Other utilities put a little chart,
24 just pasting it right on the control panel.

25 It would not be difficult to make that kind of a

1 display available to the operator right adjacent to the gauges
2 he has.

3 DR. SHEWMON: Before the Three Mile Island incident,
4 did your computer have the ability to simulate the significant
5 part of the primary system going into a steam system, and thus
6 what would happen by way of pressure pulses when he starts
7 trying to refuel that again?

8 MR. MAC MILLAN: We had built into the simulator
9 fault conditions, including the loss of off-site power and
10 obviously the loss of feedwater flow. And we had built into
11 the simulator various breaks in the reactor coolant system,
12 which would be equivalent to having a valve left open. And
13 then he had to respond to those in his training.

14 Now, I guess I would have to say -- I would have to
15 qualify that at this point by saying, I'm not sure that we had
16 the simulation perfected to the point of getting into a posi-
17 tion where he had substantial voiding in the system and then
18 trying to work his way out of it.

19 DR. SHEWMON: Do you now?

20 MR. MAC MILLAN: That's what we are trying to do in
21 the course of this training program.

22 DR. LAWROSKI: Has there been any feedback yet on the 33?

23 MR. MAC MILLAN: Dr. Lawroski, I have not been in
24 Lynchburg very much lately and I don't have any feedback. I
25 don't know whether any of the others have it or not. We can

1 get some feedback for you, if you'd like.

2 Again, turning to the item of design or equipment
3 improvement, in the near-term we expect to recommend design
4 improvements which do not affect other plant systems or require
5 extensive analysis to improve operator performance during
6 transients similar to TMI-2. In this category are such things
7 as more positive indication of pilot-operated relief valve
8 position, an interlock that would isolate certain containment
9 penetrations, including the containment sump, upon emergency
10 core cooling system actuation, and instrumentation which will
11 indicate to the operator whether the reactor coolant is
12 approaching the saturated condition without his having to
13 consult steam tables or curves. And this gets to the point,
14 the question you raised just a minute ago.

15 We anticipate that recommendations of this type will
16 be made within about six weeks. Implementation would be possi-
17 ble during almost any outage.

18 We are also reviewing the implication of these design
19 improvements for other B&W 145, 177 and 205 fuel assembly
20 plants now being designed and constructed.

e-2

21
22
23
24
25

General Motors, Inc.

67-211

1 MR. MICHAELSON: I notice the absence now of level
2 indication in the reactor vessel as a parameter of possible
3 interest.

4 MR. MAC MILLAN: I'm getting there.

5 MR. MICHAELSON: Okay.

6 DR. LAWROSKI: You're in a big hurry, Carl.

7 MR. MAC MILLAN: The fourth item of near-term action.
8 I have appointed a special task force to advise me within three
9 months concerning other implications for plant design as a
10 result of the TMI-2 incident.

11 The charter of this task force is shown on the next
12 overhead.

13 (Slide.)

14 I have asked them to review the technical aspects
15 of the occurrence, to develop recommendations on equipment
16 improvements, operator interface or intelligence made available
17 to the operator, recovery requirements, and what would we do to
18 make the recovery and support a recovery -- more effective --
19 and what incident support modifications we might be looking at
20 in the event that a similar occurrence might transpire in the
21 future; then, finally, assess the impact of the occurrence and
22 potential resulting changes in the regulations -- on our divi-
23 sion, technical activities.

24 This task force is comprised of a diverse group of
25 technical personnel, both within our nuclear power division and

1 from other divisions of the company, including our research and
2 development division.

3 Let me turn now to what we classify as longer-term
4 actions. Beyond the immediate- and near-term actions, the
5 longer-term actions will be undertaken. The ACRS has recommend-
6 ed a major reanalysis effort on transients and pressurized
7 water reactors that involve initially, or at some time during
8 their course, a small break in the primary system, and expressed
9 its belief that the TMI-2 incident has -- and these analyses
10 will demonstrate that additional information regarding the
11 status of the system will be needed in order for the plant
12 operator to follow the course of an accident and thus be able
13 to respond in an appropriate manner.

14 Although we agree that the TMI-2 incident has shown
15 a need to consider on both a near-term and long-term basis the
16 feasibility and the desirability of potential design modifica-
17 tions to improve the information available to operators, we do
18 no believe that major reanalysis is necessary for these near-
19 and longer-term design decisions.

20 At this juncture we intend to undertake of those
21 anticipated transients which result in the opening up of the
22 pilot-operated relief valve to confirm that an open-up, pilot-
23 operated relief valve, in conjunction with this antiicipated
24 transients is covered by, or enveloped by existing, small break
25 analysis.

1 It these reviews -- our own and the NRC's Staff's
2 ongoing reviews of the TMI-2 incident -- and our planned
3 efforts to assess proposed near- and longer-term modifications
4 should indicated a need for additional analyses, obviously, we
5 will promptly undertake to perform that.

6 With respect to further criteria for design
7 modifications, beyond that being immediately addressed, we will
8 be examining such other criteria, but with the caveat that each
9 must be carefully evaluated with respect to any impact on other
10 design requirements within this area.

11 We will consider the merits of reactor vessel fluid
12 level indication instrumentation and reactor trip on loss of
13 feedwater flow.

14 More extensive consideration will be given to
15 containment isolation upon actuation of the emergency core
16 cooling system to review particularly which systems should be
17 isolated and which should be maintained as necessary to enhance
18 plant safety.

19 An additional direction for consideration of further
20 criteria involves recovery from and mitigation of the transients.
21 Obviously, prevention is now, as before, the foremost goal of
22 design, but consideration will be given to such items as
23 isolated and shielded long-term decay cooling, reactor vessel
24 venting, more formalized structure, and procedures for
25 communication between the site and outside support, and the

1 handling of hydrogen generation.

2 In conclusion, it is B&W's view that the B&W-designed
3 plants can be safely operated. The severity of the TMI-2
4 incident warrants reemphasis of, first, near-term upgrading of
5 administrative controls, and longer-term consideration of
6 system modifications to provide additional assurance that the
7 safety systems will be available on demand.

8 Secondly, near-term operator training and instructions
9 and longer-term consideration of system modifications to
10 provide additional assurance that the operator will recognize
11 the importance of maintaining sub-cooled, loop conditions and
12 core-cooling capability for a broad spectrum of transient
13 conditions.

14 In response to the TMI-2 incident, B&W has, first,
15 expended major priority efforts to support and assist the
16 licensee in bringing TMI-2 to a long-term, shutdown condition.

17 Secondly, taken immediate action to review the
18 incident with operators of other B&W plants, issue instructions
19 and advisories to these operators, and to provide support and
20 assistance to the operators of B&W plants, all with a view to
21 assuring that incidents similar to TMI-2 will not recur.

22 Third, undertake efforts to continue its review of
23 the incident and revise and update instructions and advisories
24 as necessary, and to implement an operator-training program,
25 with specific reference to the TMI-2 incident.

1 Fourth, B&W implemented efforts to evaluate potential
2 near term design modifications which do not otherwise impact
3 other elements of plant safety, with a view toward providing
4 further assurance against recurrence of incidents similar to
5 TMI-2.

6 Fifth, we've developed plans for consideration of
7 longer term improvements in the capability of B&W plants, to
8 prevent, mitigate and recover from incidents similar to TMI-2.
9 While the TMI-2 incident was serious, we believe there are
10 constructive lessons to be learned and that timely, responsive
11 actions have been taken to assure the safe operation of B&W
12 reactors.

13 We believe that the additional actions which I have
14 outlined today will further enhance that safe operation.

15 In closing, let me emphasize that we will remain open
16 to any suggestions that the Committee might have at this time
17 and as the results of our near and long term actions become
18 available. In the meantime we will endeavor to keep the
19 committee and the NRC advised at each significant juncture in
20 our efforts.

21 That concludes my prepared statement. I'd be glad
22 to answer any questions that you might have.

23 DR. CARBON: Dr. Catton, in most of your presentation
24 it wasn't obvious to me that you're doing any human engineering
25 with respect to your control room. Too much information can be

pmcc 2

1 as bad as too little. Have you looked into how best to
2 display the information so that the operator of the reactor
3 can respond properly?

4 MR. MAC MILLAN: In the comments that I made relative
5 to the issue of modifications that might encourage the
6 operator to take the correct actions I was really driving at
7 exactly that point. How can you display information to the
8 operator so that he can quickly assess what the situation is
9 and take the appropriate action. I would call that human
10 engineering, the operator-machine interface. I believe that's
11 an area where we can do substantial work to enhance, encourage
12 him to make the right kind of decisions.

13 What has to be recognized is a very hectic environ-
14 ment in the event of one of these major transients.

15 DR. CARBON: Dave?

16 DR. OKRENT: I have several questions. Could you
17 tell me why the core thermocouples are connected to the
18 computer in such a way that, when you go above a relatively
19 low temperature, you get a question mark, instead of continuing
20 to read the actual temperature?

21 MR. MAC MILLAN: I think I can answer that. The
22 core thermocouples are put in the computer and are used
23 primarily for getting some confirmation of core power
24 distribution during normal operation, to assist in the fuel
25 management and to confirm the in core detector indications

1 relative to power distribution.

2 They are put into the computer so that, I believe,
3 they peg it somewhere around 800 degrees, which, of course, in
4 the normal operation of the unit is a substantial margin above
5 the temperatures we'd expect to read on those thermocouples.
6 The thermocouples were not installed in the plant originally
7 as a means of following significance transients of this sort.

8 DR. OKRENT: Yes. But is there anything that
9 prevented these thermocouples from reading to a higher range?

10 MR. MAC MILLAN: Strictly a case of the limitations
11 that were put on the computer in its interface with the
12 thermocouples. In fact, during the sequence of the transients
13 some of those thermocouple readings were checked that were
14 indicating that they were being pegged at 800, were checked in
15 fact to find what higher temperatures were indicated.

16 DR. OKRENT: Again, if I understand correctly, it
17 didn't even say high. It said question mark.

18 MR. MAC MILLAN: That's correct. When it gets up
19 in that range, it just prints out a question mark.

20 DR. OKRENT: Yes. Now, it seems awkward, to say the
21 least, that in the two events that have led to significant
22 damage to the core in a power reactor, namely Three Mile Island
23 -2, and many years ago Fermi-1, there was thermocouple infor-
24 mation available. The thermocouples were installed, and in this
25 case in fact the information as to temperatures was unavailable

c 4 1 to the operator.

2 In the other case it was not in a place where he
3 would see it, and it wasn't built into any alarm system, and
4 it seems to me at least that for the future I might have heard
5 an interest expressed in getting this additional piece of
6 information built into the system in a way where it could be
7 useful for safety purposes. Well --

8 MR. MAC MILLAN: I respect your comment.

9 DR. OKRENT: I'll leave that for the moment.

10 Could you tell me something else?

11 PROFESSOR KERR: Mr. Okrent, I want to hear your
12 comments, if you could use your mike.

13 DR. OKRENT: I'm wearing it, but it may be set down
14 low. If I understand what I've been reading and have read
15 about the behavior of the control system that relates core
16 power and feed water flow and demand and so forth, and I'm
17 quickly going to get over my head, since my area of knowledge
18 is not reactor control. I'm trying to understand how B&W
19 decides what constitutes an acceptable control system from
20 the point of view of how many times it challenges the operator
21 or the safety system to do something to get the reactor shut
22 down safely.

23 Is the question clear?

24 MR. MAC MILLAN: I'm not sure I understand what
25 you're driving at.

c 5 1 DR. OKRENT: Well, let me put it this way. If you
2 had a control system that every day required a reactor
3 protection system to work to keep the reactor safe, I think
4 you would feel that you were challenging it too frequently.
5 Or if every day the control system required the operator to do
6 something not routine in order to either get the reactor shut
7 down safely or to restore it to some acceptable steady state
8 condition, I think we would both agree that this was too
9 frequent.

10 Now, as I look at the number of events that have
11 transpired in the last few years, there have been several
12 situations where the operator was pressed one way or another
13 to restore the reactor, where in some cases the control system
14 received faulty information because of some malfunction, a
15 short circuit or whatever, or the operator got misinformation
16 or both.

17 And I'm trying to understand whether this in any
18 way relates to the particular mode of control used, whether it,
19 in your opinion, a reasonable number of challenges, a reasonable
20 number of anomalous situations, whether all reactors should be
21 expected to have this kind of behavior or just how do you
22 evaluate the safety implications of the control system
23 employed on the B&W reactor.

24 MR. MAC MILLAN: If I understand what you're saying,
25 do we have a criterion that says, if your control system has a

Page 6 1 fault more than three times a month, that's unacceptable, the
2 answer to that question, we don't have such a criterion. Our
3 integrated control system reliability is an area where we're
4 working to improve its reliability. I'm sure you'll under-
5 stand that that was not a factor in the sequence of events
6 which we are discussing today relative to Three Mile Island-2.

7 DR. OKRENT: I understand it very well; however, in
8 looking through the history, I can see other transients that
9 might have transpired into a complex or more complex event
10 than they were, situations where, at least for a period of
11 time, full information concerning the status of the reactor
12 was not available to the operator, and situations where the
13 operator needed to do things far from what he ordinarily does
14 to return it to a state of normalcy.

15 And again I'm trying to understand whether in some
16 way the control system has been or should be reviewed as a
17 contributor to, let's say, the initiation of possible acci-
18 dents. I guess that's a way of putting it.

19 MR. MAC MILLAN: Let me answer that, if I could,
20 with a couple of comments. First of all, let me say that we
21 are not satisfied with the reliability of the integrated
22 control system and are working to improve that reliability.

23 Secondly, the safety of the equipment, the safety
24 of the operation is not controlled by the ICS. It's controlled
25 by the reactor protector system and the engineering safeguards

mcc 7

1 features actuation system. I agree with your concern that we
2 do not want to have an integrated control system that is
3 challenging your operator on a daily basis to see if he's on
4 his toes, to handle abnormal events.

5 And the thrust of our reliability program would be
6 to reduce the number of those instances.

7 DR. OKRENT: Let me ask a related question. There
8 is some history of what you might call feedwater transients,
9 one way or another, that transpired prior to Three Mile Island.
10 None of them, to my knowledge, was associated with, for
11 example, isolation of the auxiliary feedwater system or other
12 things here, but there sometimes might have been other things
13 associated with them.

14 Do you review the frequency of such events and judge
15 whether there is some pattern that needs consideration, or is
16 that outside the scope of the B&W area of responsibility? Is
17 it the architect engineers who are supposed to worry about
18 this or just what? Where does this fall?

19 MR. MAC MILLAN: Let me address the issue of loss of
20 feedwater experience. We've had a number of those transients
21 on the B&W systems. I don't know the exact number, but it's
22 in the range of 60 instances of loss of feedwater.

23 I guess I ought to set the record straight. In
24 direct answer to your question, the design of the feedwater
25 system primarily is not a B&W responsibility; however, we do

General Reporters, Inc.

c 8 1 place certain requirements in terms of the quantities of
2 feedwater, the temperature of the feedwater, the quality of
3 the feedwater, which must be satisfied in order to assure the
4 appropriate operation of the B&W equipment.

5 Most of the loss of feedwater transients that have
6 occurred have been initiated through factors which are involved
7 in the design of the feedwater system. Some designs are much
8 more susceptible to loss of feedwater than other designs, and
9 it's closely related to the number of safety features and
10 interlocks and protection devices that are built into the
11 feedwater system.

12 And the features of the feedwater system that deter-
13 mine, seem to determine the frequency of these events, where we
14 see an abnormal number of those events, it's been our
15 practice to work with the utility or his architect engineer,
16 depending upon any particular customer, to try to understand
17 what it is that's causing these transients, and are there
18 things that can be done to reduce their frequency?

19 I have to say to you in most cases the corrective
20 measures associated with that are involved usually in changes
21 in the feedwater system rather than changes in the equipment
22 which B&W supplies.

enc. 3

1 DR. OKRENT: If I can ask a few more questions. You
2 indicated that you thought you didn't have a need for major
3 reanalysis. I think those were your words.

4 By the way, I don't think they're in the ACRS letter.
5 Maybe they shouldn't have been.

6 MR. MAC MILLAN: Maybe I inferred that from the
7 third paragraph of that letter, Dave.

8 DR. OKRENT: But I'm a little bit curious. I have
9 to assume you didn't analyze any transients like Three Mile
10 Island transients before it occurred. It's an unusual sequence
11 of events.

12 Had you analyzed any at B&W and documented them, at
13 least internally, which led to overheating of the fuel?

14 MR. MAC MILLAN: All of the accident analyses we've
15 done, including the spectrum of small break analyses, including
16 loss of feedwater transients and loss of off-site power, we
17 have documented, and in each of those instances we have
18 demonstrated that, given the continued operation of the emer-
19 gency injection system, the high-pressure injection systems,
20 water is maintained in the core and the core condition is
21 maintained in a safe configuration, and you do not see the kind
22 of temperature transients that we have seen here at Three Mile
23 island 2.

24 The answer to your earlier question is, we have not
25 previously analyzed the sequence of events that transpired at

1 Three Mile Island 2, nor do I think we could have predicted
2 ahead of time the sequence of operations that transpired
3 there at the time the incident occurred.

4 DR. OKRENT: No. My question was: Have you
5 analyzed any that led to overheating of the core?

6 MR. MAC MILLAN: On the design-basis accident,
7 the core is overheated.

8 DR. OKRENT: Ah, but only in a modest way.

9 I mean, to something that resembles this degree
10 of degradation-- I'm just curious -- as part of your
11 simulation studies.

12 MR. MAC MILLAN: The most severe transient in terms
13 of core temperature that we have analyzed is the design-
14 basis accident.

15 DR. OKRENT: Do you think with your current
16 simulator you could have put in these conditions as actually
17 occurred, and let's assume we'll be able to find out with
18 sufficient detail, into your simulator and predicted formation
19 of hydrogen gas bubbles and where it would be?

20 I'm just trying to understand the power of your
21 current methods.

22 MR. MAC MILLAN: Our present simulator -- nor do
23 any of our analytical methods in our computer account for the
24 formation of noncompressible gas or hydrogen, or try to say
25 where that would be in the system.

1 DR. OKRENT: Do you think you could have described
2 the matter, including the formation of voids in some detail
3 that's boiling in the core and so forth with your current
4 simulator?

5 MR. MAC MILLAN: Yes, sir.

6 DR. OKRENT: Now as you know, there are some
7 questions about whether for very small breaks there is the
8 possibility, if you don't have the primary system pumps,
9 that there may be a mismatch of heat input from a shutdown
10 core and heat output from the small break, and so forth.

11 Have you done calculations covering the full
12 spectrum of that specific accident at various break locations
13 throughout the primary system in the pressurizer, in the pipe,
14 the cold leg, hot leg, and so forth?

15 MR. MAC MILLAN: We have looked at and have
16 documented an evaluation of a series of break sizes down to
17 and including a .05 square foot break, and we have looked at
18 that sized break at various locations around the reactor
19 coolant system in order to determine which may be the most
20 severe condition that we have to be prepared to address.

21 And in each of those cases, as I indicated earlier,
22 we have determined that we maintain water in the core and
23 would not expect to see significant fuel cladding temperatures
24 under those circumstances.

25 DR. OKRENT: I can't tell, though, whether going

1 down to .05 is a way of answering the question I posed,
2 because my break starts at 0 and goes up. And it may be the
3 interesting sizes are below .05. Have you looked?

4 MR. MAC MILLAN: We have looked at smaller break
5 sizes, yes, and concluded that they are not as severe as the
6 ones around the .05 square foot size.

7 DR. OKRENT: So you've looked exhaustively, then,
8 for sizes below .05. Is that what I should assume?

9 MR. MAC MILLAN: I'm very hesitant on that word
10 "exhaustive."

11 DR. OKRENT: There should be no surprises below
12 .05?

13 MR. MAC MILLAN: We don't believe there are, from
14 the work that we have done.

15 DR. OKRENT: Just one other question.

16 There are other kinds of instrumentation that one
17 might think of that could have been useful here, had we had
18 it. Some of it would fall within the scope of the NSSS
19 supplier, I would think, or at least some of it might fall
20 in the area that the balance-of-plant man would supply.

21 I wonder if you have developed any opinions about
22 whether and what other kinds should receive serious
23 consideration?

24 MR. MAC MILLAN: I think I ought to answer that
25 this way: We're in the early phases of analyzing this event.

1 As I indicated in my testimony, the primary thrust of our
2 efforts has been directed toward the support of the activities
3 of Three Mile Island 2, and any of those immediate actions
4 which we deem to be appropriate in terms of supporting the
5 continuing operation of our other nuclear plants.

6 Obviously a lot of people are doing a lot of thinking
7 about what other sources of information might we have? What
8 kinds of design modifications might we make based on the
9 lessons to be learned at Three Mile?

10 I believe that's something we need to do in a very
11 orderly and a very, I'd say, cautious way, as we look at the
12 events therein, as we try to get more information about what
13 took place in that incident.

14 I do not have at this point any suggestions or
15 recommendations about other kinds of instrumentation that we
16 ought to have as a consequence of a detailed analysis of TMI 2.
17 I think that will come in due course.

18 I'd be interested in suggestions, if you have some
19 ideas.

20 DR. CARBON: Dr. Kerr?

21 PROF. KERR: John, I think earlier you indicated
22 a rather extensive look at systems, not an exhaustive
23 reanalysis, and I am sure you're concentrating on this kind of
24 transient, as I think one has to.

25 All of us, I think, are conscious of this as an

1 example of the fact that we may have overlooked some other
2 things, as well.

3 Is there any systematic way -- do you have any
4 plans to try to look perhaps a bit further than this kind of
5 transient for -- I don't know how to describe looking for
6 things that one hasn't thought of -- but do you have any
7 plans to do anything that would be a systematic approach to
8 perhaps a finer sieve than we have used?

9 MR. MAC MILLAN: You do pose a very difficult
10 question: How do you look for things you don't know about?

11 DR. PLESSET: Let me throw one your way. May I?

12 MR. MAC MILLAN: Yes, sir.

13 DR. PLESSET: I'll give you a "for instance."

14 Supposing you have delayed scram. Have you looked
15 at that?

16 MR. MAC MILLAN: We do look at the effect of
17 various delay times before scrambling and the impact.

18 DR. PLESSET: I was just trying to help Bill.

19 PROF. KERR: As a matter of fact, on this
20 transient, they did have delayed scram.

21 DR. PLESSET: I was thinking of a more significant
22 delay than the one they had.

23 MR. MAC MILLAN: Our system is designed so that we
24 do not normally -- it's not part of the safety system to scram
25 a reactor when either the turbine trips or there's a loss of

1 feedwater.

2 In this particular incident, as designed, the
3 reactor tripped on high reactor coolant system pressure, and
4 that took place, if my memory serves me right, somewhere
5 around 12 seconds after the initiating incident.

6 The question could be asked -- and I think I
7 mentioned in my testimony -- that one of the things we are
8 looking at is whether or not it would be more appropriate for
9 us to build the system in such a way that the reactor scrambled
10 on the loss of feedwater flow.

11 What I said in my testimony also was: I didn't
12 think we ought to rush in any hasty or ill-conceived solutions
13 because we need to look at what the implication of that
14 would be relative to all the other operating phases that the
15 reactor may be subjected to.

16 I believe, Bill, the other thing I said in my
17 testimony that gets at something of the point that you are
18 making is that we have -- we are going to look at all of the
19 transients that we are aware of that cause the power-operated
20 relief valve to open. And there are a number of them. And
21 then evaluate, if the valve sticks open in the course of that
22 transient, what is the impact on the system? What happens in
23 the system? What actions are automatically initiated by the
24 safety systems? What kind of actions would be expected by
25 the operator? And what would be the extent of the effect of

1 those transients?

2 Now that's a very specific area of looking at, on a
3 systematic basis, those things which could cause that valve to
4 open, and what happens if it sticks open? And what happens if
5 that open valve goes undetected by the operator in the
6 subsequent time?

7 PROF. KERR: You mentioned "feedwater" earlier, and
8 I don't want to belabor it, but it has been my impression that
9 feedwater control systems in some cases may be somewhat
10 primitive, especially in the way in which they react to
11 feedwater flows at low power levels or low loads.

12 Is any additional analysis of the system -- I
13 recognize that this is probably never, or at least not
14 normally your direct responsibility, and you said that you
15 supply specifications -- but specifications are not very
16 useful if they can't be adhered to.

17 Is it your experience that specifications you
18 provide are generally met? Or is that somebody else's
19 responsibility?

20 MR. MAC MILLAN: We have the responsibility, Bill,
21 to check the design to assure that the secondary system, the
22 feedwater system as designed accomplishes the requirements
23 that we have established.

24 But I have to say to you again, those requirements
25 relate primarily to how much feedwater flow you're going to

1 get at what kind of temperature and what kind of quality,
2 and don't necessarily address how many heaters are in the
3 train, what kind of interlocks do you put on the feed pumps
4 so that if you lose some inlet pressures --

5 PROF. KERR: I'm not thinking so much of inter-
6 locks as I am whether you specify steady-state, or quasi-
7 steady-state, which it seems to me must frequently be the
8 case, and don't really have much of a specification on the
9 transient operating performance.

10 That doesn't seem reasonable to me. But from
11 looking at the experience with these systems, one could almost
12 get the impression that not much attention is given to the
13 transient performance, especially at low loads, because that's
14 where the difficulty seems to occur.

15 MR. MAC MILLAN: We do have some limits that we
16 put on the system relative to how rapidly it can change
17 temperature, because that has some impact on the temperatures,
18 the transients in the steam generator itself.

19 We also have requirements on -- in which we would
20 accept a change in steam flow as a function of time, and that
21 affects the rate of feeding of the feedwater. So there are
22 some transient requirements that are required, but I sense
23 that what you're driving at is: At low flows, you sometimes
24 get some oscillations in the feedwater flow.

25 PROF. KERR: I can remember an instance in which

1 we were looking at water hammer, in contrast to this
2 particular transient. And on this plant, it seems to me, it
3 was discovered that at low flows the design of the valve was
4 such that one, in effect, got a very high gain in the loop
5 gain of the control system, and it simply was unstable,
6 apparently.

7 Those things don't show up in a quasi-steady state
8 analysis, but they're very important to the transient
9 performance of the system.

10 MR. MAC MILLAN: I guess my response would be that
11 where we see a high incidence of loss of feedwater, and this
12 was the case on Oconee 1, we sat down with the designers and
13 said, "Now what can we do to decrease the frequency of these
14 incidents? What were the causes? How can we eliminate those
15 causes and have a more assured continuity of feedwater flow?"

16 Again, that's not our design responsibility, but
17 we feel, when we see that kind of repetitive performance,
18 we need to get together with the designer and try to work our
19 way through it.

20 PROF. KERR: On another subject, both the NRC and
21 you have urged operators to look at their administrative
22 procedures for making certain that either of the safety systems
23 are available when needed, yet unquestionably there must have
24 been other objections to review this same sort of thing, and
25 we found the situation in which the auxiliary feedwater was

1 available.

2 One could try to move in a direction of additional
3 interlocks on the operator startup unless these were
4 available, but then one would have to have interlocks on the
5 interlocks, I suppose.

6 Do you plan to give any thought to whether one can
7 obtain appropriate operation if these auxiliary feedwater
8 systems are manual? Maybe we're going in the wrong direction.

9 I'm not asking you to design the system today. I
10 would urge that at least that possibility not be neglected.

11 MR. MAC MILLAN: That's an interesting thought.
12 I'll have to say that's one we hadn't thought of. Clearly
13 we'd thought of other ways to make sure those shut-off valves
14 are opened at the time that they need to be open, but going
15 into manual --

16 PROF. KERR: It may be irrelevant or impossible,
17 but at least if somebody had to do something and had time to
18 do it -- well, it strikes me as an alternate approach which
19 it seems to me ought to at least be looked at before it's
20 completely discarded.

21 MR. MAC MILLAN: We'll make a note of that.

22 PROF. KERR: I have no more questions.

23 DR. CARBON: Paul?

24 DR. SHEWMON: Yes, a couple of comments.

25 Do you have any idea of why the primary feedwater

1 failed in this case? There was some talk about demineralizers,
2 or something else coming out of the rumor mill. I'm not sure.

3 MR. MAC MILLAN: I heard the same rumors you did.
4 I don't really know what happened as the initiating event in
5 the loss of feedwater.

6 DR. SHEWMON: Okay.

7 In the handout that Tedesco had this morning, he had
8 a list of six feedwater transients. The PORV was activated in
9 five of them. It stuck open in three of those five.

10 MR. MAC MILLAN: Yes, sir.

11 DR. SHEWMON: That's not a batting record that
12 anybody outside of the Major Leagues would be very pleased
13 with. And I wonder if you could say -- I assume, since that's
14 on the top of the pressurizer, that it's something you people
15 specify, if you don't build it.

16 Could you tell me something about how these are
17 tested, and whether we can see any improvements down the road?
18 It's nice to tell the operator, to train him to tell him that
19 it always sticks open, but that doesn't quite seem like the
20 way to whip it.

21 MR. MAC MILLAN: Let me respond to several of --
22 where I think your question is at.

23 I think the implication was that three out of five
24 we had the valves stick. That isn't really the right
25 statistic. We've had somewhere -- and I don't have an exact

1 number, but it's in the range of 150 events in the history of
2 the B&W units which have caused the power-operated relief valve
3 to open. Out of that 150, in 3 instances the valve has stuck
4 open, for one reason or another. That is not far from the
5 kind of statistics that have been generated in the evaluation
6 of reactor safety, about a .02 probability. It seems to be
7 right on target.

8 Now there was some question this morning about
9 whether all of these valves were the same valves, or whether
10 they were different suppliers.

11 The valve at Oconee and the valve at Three Mile
12 Island 2 are Dresser valves and are essentially equivalent,
13 identical valves. The valve at Davis-Besse is a Crosby valve
14 of a different design.

15 These valves are used extensively not only in the
16 nuclear business, but in the fossil steam business, for
17 pressure relief, pressure control.

end #4

4051 / 1
PMAN t5
pmcc 1

1 The testing of these valves involves a hydro test.
2 The normal manufacturing involves a hydro test. And then a
3 subsequent cycling test of the valve, where the valve is
4 relieved, the pressure comes down. It's allowed to sit for
5 five minutes, blown again.

6 DR. SHEWMON: What's going through the valve?

7 MR. MAC MILLAN: Steam.

8 DR. SHEWMON: At 2200 psi.

9 MR. MAC MILLAN: The steam at the design relief
10 pressure, and this is cycled three times to check the relief
11 pressure and the receding pressure and to assure that in a
12 receded position that the valve -- the seal is not simmering.

13 DR. SHEWMON: That happens when?

14 MR. MAC MILLAN: At the time the valve is manu-
15 factured.

16 DR. SHEWMON: Did that ever happen again in the course
17 of the semi-annual review or the decennial review? Is there
18 any in service inspection on these?

19 MR. MAC MILLAN: I don't know the answer to that
20 question. Do you know what the annual inspection requirements
21 are?

22 MR. TAYLOR: Jim Taylor of B&W. After each of the
23 two instances that Mr. MacMillan referred to in the cases where
24 valves stuck open, in the first case it was at Oconee. That,
25 I believe, was in 1975. An investigation was made of the causes

pmcc 2

1 of the problem. It was determined to be corrosion and
2 improper clearances in the valve. These valves were reworked.
3 Field changes were put out to all the plants that had these
4 valves installed, and they were tested.

5 In the case of the Davis-Bessie transient, which was
6 a Crosby valve of a different design, it happens to be the only
7 B&W plant that has the Crosby valve. The rest of them are
8 Dresser valves. It was an electrical problem quite different
9 than the one that occurred at Oconee. And that electrical
10 problem involved a relay having been left out of the circuit,
11 which was not a part of the equipment that we had supplied, and
12 that valve was corrected and tested after that also.

13 So in each of the cases where a difficulty with a
14 sticking valve had occurred, an investigation of the cause was
15 made. The valve was retested, and all the other subsequent
16 valves were also reworked. We have recently developed a
17 thorough periodic test procedure which has been sent out to the
18 field on each of the plants, which involves a very extensive
19 test, both each time the plant goes into the cold shutdown
20 condition and during each heatup. So that the cold tests are
21 run involving a solenoid voltage position indication.

22 The input of dummy signals into the valve operating
23 circuits and a host of other tests are made during the cold
24 condition. And then the valve is lifted during the pre-
25 critical heatup phase. And so there has been a suggestion

eral Reporters, Inc.

1 passed on to each of the plants to make these periodic tests,
2 where the Dresser valves are involved.

3 DR. SHEWMON: And that pre-critical heatup is after
4 you've got your system at pressure?

5 MR. TAYLOR: Yes, Dr. Shewmon, it is. That's when
6 you can blow steam through the valve into the quench tank,
7 and they will not only check the operation of the valve at
8 that time but also check the response of the thermocouple on
9 the pipe and the pressure in the surge tank. Those are just
10 very recent test procedures.

11 DR. SHEWMON: And these are things the operators
12 would do as part of their startup. They would know what that
13 downtail, or whatever your word is, for the indicating thermo-
14 couple looks like when the steam is going through.

15 MR. TAYLOR: Yes, sir.

16 DR. CARBON: Harold?

17 MR. ETHERINGTON: Mr. MacMillan, you recommend on a
18 contingent basis using the high pressure injection to
19 continue for at least 20 minutes. In this particular incident
20 at Three Mile Island they would probably have gone solid in
21 about nine to ten minutes. Would that concern you?

22 MR. MAC MILLAN: It would not concern me to the
23 extent that that is the expected result of high pressure,
24 continuing high pressure injection, and we'd expect to relieve
25 the pressure through the open relief valve in that particular

page 4 1 way.

2 MR. ETHERINGTON: Would the relief valve take the
3 water hammer, if any?

4 MR. MAC MILLAN: We believe so, yes.

5 MR. ETHERINGTON: I have one more question. You're
6 planning, I expect, at some time to address in detail the
7 conditions required before going to natural circulation.

8 MR. MAC MILLAN: I hadn't planned to talk about that
9 this afternoon.

10 MR. ETHERINGTON: I didn't mean that.

11 MR. MAC MILLAN: I'm sorry.

12 MR. ETHERINGTON: You know, I consider it a pretty
13 important item, and you don't address it here. But it's
14 something you have under consideration to instruct the
15 operators of B&W plants?

16 MR. MAC MILLAN: Let me answer that in a couple of
17 parts. You remind me that I wanted to respond to a comment
18 that you made earlier this morning relative to the importance
19 of maintaining the cold part of the steam generator, the
20 driving force for natural circulation in the top of the steam
21 genera'or.

22 And the question that was asked is has this been
23 looked at without reactor coolant pumps, for example, in a loss
24 of off site power? The answer to that is, yes, we have looked
25 at that event in loss of off site power, and in that event the

pmcc 5

1 reactor coolant stopped.

2 The auxiliary feedwater comes on in that circumstance
3 and is admitted at the top of the steam generator and provides
4 cooling of the reactor coolant in the upper region of the
5 steam generator, in order to provide a driving force to
6 induce the natural circulation and sustain the natural
7 circulation in the post-loss of power sequence.

8 Now, I believe in the discussion this morning of
9 what was happening at the Three Mile Island-2 in the first
10 eight minutes of the transient we saw a demonstration there
11 of what we believe the steam generator is boiled dry, and then
12 the auxiliary feedwater came in at the top of the steam
13 generator and was evaporated as it ran down the tubes, and
14 no water was accumulating in the bottom of the generator.

15 But we did see a very significant turn-around, you
16 recall, in reactor coolant system temperature. As soon as
17 that water was introduced in the auxiliary feedwater on the
18 steam generator, that reactor coolant temperature turned
19 around and started back down.

20 So we believe that, on the basis of our calculations,
21 that in this accident condition without reactor coolant pumps
22 we do in fact through the auxiliary nozzles in the top of the
23 generator get the driving force for heat removal and for
24 induced natural circulation at the proper level.

25 MR. ETHERINGTON: That's our closely packed tube.

pmcc 6
1 Does the penetration of the spray -- how far does the spray
2 penetrate?

3 MR. MAC MILLAN: There's a header on the inside of
4 the steam generator which goes around the tube, with holes on
5 the inside of the header which direct the water right at the
6 tubing in the steam generator.

7 MR. ETHERINGTON: The bundle is more like this,
8 isn't it?

9 MR. MAC MILLAN: Yes, we're getting this impact
10 mostly in the outer few rows of tubes.

11 MR. ETHERINGTON: And you're relying on those as
12 your heat sink?

13 MR. MAC MILLAN: Yes, sir. And I believe -- well,
14 we saw in the results today that in fact you do get
15 significant cooling in that condition.

16 MR. ETHERINGTON: But in this case, when they went to
17 natural circulation, the spray was not effective.

18 MR. MAC MILLAN: In this case, by the time they
19 decided to turn off the reactor coolant pumps, as was indicated
20 earlier, we were in a situation where we had such a rate of
21 temperature in the hot portions of the reactor and would not
22 have anticipated in that condition.

23 MR. ETHERINGTON: Almost saturated, I think you
24 referred to 150 pounds per square inch below, didn't you?

25 MR. MAC MILLAN: It was fully saturated and had been

pmcc 7

1 for some time. In fact, you can see on the curves where the
2 saturation temperature and reactor outlet temperature, they're
3 right on top of one another. I think to the second issue that
4 you raise, maybe I misunderstood. We are in the process now
5 of developing the information required to make a transfer at
6 Three Mile Island to -- from forced circulation to natural
7 circulation.

8 MR. ETHERINGTON: My question really related rather
9 to your other plants besides Three Mile Island.

10 DR. CARBON: Bill?

11 PROFESSOR KERR: I don't want to interrupt Harold.

12 DR. CARBON: I thought you were done.

13 DR. SHEWMON: Let me ask the question which may be
14 rephrasing his. Is it part of operating procedure or training
15 procedure for an operator to be asked to take a plant into
16 natural circulation? Does he go through that operation?

17 MR. MAC MILLAN: In the event of loss of outside
18 power that's exactly what he does.

19 DR. OKRENT: If I can pursue it a little further,
20 it seems to me that where we find difficulties in operation,
21 this represents the most serious one, but we've seen others
22 that were, let's say, one step short of this or two steps
23 short of this.

24 It's when the situation was not like the one in the
25 FSAR. In other words, you didn't just lose off site power and

pmcc 8

1 then everything transpired normally. But there would be
2 another complicating factor, whatever it was, either some
3 instrumentation read wrong or a wrong signal point somewhere
4 and so forth.

5 And what I'm still unable to tell is whether for
6 small breaks or for loss of off site power or for a loss of
7 feedwater or for various other transients one could identify,
8 whether in fact there has been a hard look at what you might
9 call degraded functional conditions and how the system then
10 looks different. It's not clear to me that you're having
11 trained the operator to respond to a situation involving just
12 the loss of off site power and getting to natural circulation
13 will prepare him for a compounded set of circumstances.

14 And I think in this sense I really question your
15 confidence that you've done enough analysis. I really question
16 that you can now train the operator for these other things if
17 you yourself haven't studied them in some detail and thought
18 about them under differing sets of circumstances.

19 I think in fact my own feeling is it's two or three
20 weeks after the event. We can sort of sit here and say, well,
21 he should have seen that the temperatures were all giving a
22 question mark, and he should have seen that the pressure was
23 dropping, and he should have seen that it was high in the hot
24 leg and cold in the cold leg and so forth.

eral Recorders, Inc.

25 But I'm reluctant to say that, had I been an

67-244

pmcc 9 1 operator with the training that they received, I would have
2 been able to see an event. I don't know about you.

3 MR. MAC MILLAN: Is that a question?

4 (Laughter.)

5 DR. OKRENT: Yes, indeed. I'm trying to see, for
6 example, with regard to natural circulation, whether in fact
7 we are in such good shape. You provided assurance that the
8 operator is trained to get it into natural circulation from
9 a loss of off site power. But I don't know whether I should
10 feel all that assured from your having told me that this has
11 been tested on a simulator.

12 MR. MAC MILLAN: Okay, Dave. Let me see if I can
13 perhaps come at it this way. In the testimony I did indicate
14 that there were some principles of operation that we felt were
15 very important to reinforce with the operators, and those were
16 that he needed to be aware of what his temperatures are doing
17 in the reactor cooling system, what their relationship was to
18 saturation temperatures and what his water inventory was as
19 indicated by the pressurizer level under a circumstance where
20 he has sub-cooled conditions in the coolant system, and then
21 to take those actions which would drive his system in the
22 direction of maintaining those kinds of core cooling conditions.

23 Now, that's a general principle of operation, and I
24 don't know that I can tell you out of 100 different circum-
25 stances how he might get himself into an unusual or abnormal

DMCC 10

1 situation if he maintains his focus on those principles. It's
2 our belief that he will be able to maintain the system in a
3 safe condition.

4 DR. OKRENT: Let me put it another way. What are
5 the circumstances in which there would be need for some
6 unusual insight or some unusual path to get to natural
7 circulation? In other words, which of those that are not
8 routine, so that you can see whether there are any places
9 where the operator, trying to do what you just said, in fact
10 ended up down the wrong path?

11 MR. MAC MILLAN: I have no answer to that.

12 DR. OKRENT: I think if you don't try to look for
13 those situations, you're in less than the optimum position to
14 be confident that there are none or to give adequate instruc-
15 tions, and I'll leave it there.

16 DR. SHEWMON: You're suggesting a single failure mode
17 for training operators?

18 DR. OKRENT: I'm not sure I want to put it that way.

19 MR. MICHAELSON: I've got a follow-up question.

20 DR. CARBON: You're going to have to wait a minute,
21 Bill, I guess. Just go ahead, Carl.

22 MR. MICHAELSON: Perhaps what Dr. Okrent is alluding
23 to is a very likely situation that you could get into, wherein
24 the system experiences one of these very small breaks of
25 sufficient size where its natural circulation is lost fairly

pmcc 11

1 early in the event. But now you have to resort to some sort
2 of a boiling condensing mode to remove the heat. If at that
3 point in time the operator discovers where his break is and
4 has the capability of isolating it, a natural thing for him to
5 want to do, and the instruction which often exists is to close
6 the break.

7 In that case one has to explain how to get back to
8 natural circulation, since you may not be able to get into the
9 boiling, condensing mode at that point.

10 MR. MAC MILLAN: Well, I don't know how to answer
11 that. I think you would have to look at the sequence of events
12 that would lead to that and determine that your higher pressure
13 injection system was capable of handling that kind of a small
14 break situation.

15 MR. MICHAELSON: The problem you get into is, unless
16 you have pre-analyzed such a situation, it's very difficult
17 for the operator to make an appropriate judgment.

18 MR. MAC MILLAN: In that event where you are still
19 depending on your reactor protection system, the ECCS systems
20 to respond, to get the high pressure injection water into the
21 system, in that sense it's equivalent to a small break analysis
22 that has been done.

23 The essential element again is one of keeping water
24 in the core, and I think, as I said earlier, that those are the
25 results that have come from the analyses that we've performed.

pmcc 12

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. CARBON: You indicated earlier to Dave's question that you do tell the operator how to get into natural circulation with something like loss of off site power. Do you carry that one step farther and tell him how to do this with loss of off site power and, for example, diesels failing?

MR. MAC MILLAN: I may have put you under a misconception here. On a loss of off site power the mode of cooling is natural circulation. So the events that transpire in that case and what he is trained to do in that case, you in fact put the reactor system into a natural circulation mode.

Now, your question was do we then also look at what happens if a diesel fails?

DR. CARBON: It failed to start up.

MR. MAC MILLAN: If all the diesels don't start up?

I don't believe we've looked at that.

end #5

pv 1 DR. CARBON: Could you tell me what kind of tests you
2 run? Well, how often do the plants get into natural
3 circulation? How often are they called upon?

4 MR. MAC MILLAN: Very seldom. I don't have any
5 statistics on that. It's not a very frequent occasion. We did
6 do that at Oconee, as I mentioned earlier.

7 DR. CARBON: But that was probably a special test, as
8 I understood it, at Oconee and Davis-Bessie. Is that correct?

9 MR. MAC MILLAN: I am not sure about that. Was that
10 special test in both those cases?

11 MR. ROY: Yes. For Oconee in dealing with natural
12 circulation tests.

13 DR. CARBON: Are there cases where, aside from those
14 tests, that the plants due to some shutdown condition have gone
15 on to natural circulation?

16 MR. ROY: I believe there have been cases. I believe
17 there have been cases in the loss of offsite power, something
18 like six or eight. But I don't know the duration, you know,
19 for which the power was lost.

20 DR. CARBON: I have another question or two along
21 this line if I can get my thoughts straight here. When you run
22 the tests, are they sort of steady-state tests, or is there any
23 transient involved? And when you have the situation, do you
24 try and take into account the effects that would exist as a
25 result of being a transient somewhat different from your

pv 1 steady-state test?

2 MR. MAC MILLAN: The test is run as a transient
3 because you start with the reactor coolant pump on and you turn
4 the reactor coolant pump off, and there is a transient flow
5 condition going from forced circulation into the natural
6 circulation mode. And what we've done in that circumstance is
7 to try to get a correlation or a benchmarking of our
8 calculational method to say does our calculation method
9 predict, in fact, the kind of transient condition that we
10 observed in the plant. And so that test has really been a
11 benchmark to confirm the validity of the transient analysis
12 technique. So, it is transient; it's not just one steady state
13 versus another. We run the actual transient from including the
14 flow coast down to the pump and then the thermal effects which
15 cause the natural circulation to start.

16 DR. CARBON: And I understood this morning that the
17 Davis-Bessie and Oconee represented the extremes of the
18 Davis-Bessie having the highest steam generator and the Oconee
19 the lowest of all your plants.

20 MR. MAC MILLAN: There are two basic configurations:
21 The arrangement I showed you today is what we would call the
22 "Oconee arrangement," and is typical of all our operating
23 plants except Davis-Bessie. Davis-Bessie has the steam
24 generators elevated relative to the reactor vessel, and that
25 configuration is characteristic of our later plants, including

pv 1 our standard 205 fuel assembly.

2 DR. CARBON: You have put some sort of flapper valves
3 in the core barrel somewhere, have you not, to perhaps help on
4 this? The tests that you've run on natural circulation at both
5 Oconee and Davis-Bessie, do they have these?

6 MR. MAC MILLAN: We call them "vent valves," not
7 "flapper valves." Both Oconee and Davis-Bessie have internal
8 vent valves, and, of course, they were operational during the
9 transient from forced circulation to natural circulation. If
10 there is any tendency to open or to short-circuit flow, we
11 would have seen it in those tests. As far as we can determine,
12 they did not.

13 DR. CARBON: Bill.

14 PROF. KERR: Mr. MacMillan, I think earlier you
15 indicated general agreement with the NRC Bulletin and
16 instructions which were being sent to operators. But I wanted
17 to make certain that you did not have any reservations or, if
18 you did have reservations, what they were, concerning your
19 interpretation of any instructions and any adverse bearing
20 these instructions might have on safety. If you had any
21 comments, I would like to have them.

22 MR. MAC MILLAN: We're in agreement with the
23 recommendations that were made in the Bulletin relative to
24 maintaining high-pressure injection for the 20 minutes or until
25 the low-pressure injections are established at a thousand

pv 1 gallons per minute each and stabilized, and maintaining in the
2 case of the high-pressure injection 20 minutes, maintaining the
3 temperature at 50 degrees below.

4 PROF. KERR: I understand that these recommendations
5 had been discussed with B&W.

6 MR. MAC MILLAN: They are consistent with the
7 informatives we have sent to our customers. The NRC Bulletin
8 and the informatives are consistent.

9 PROF. KERR: Thank you.

10 DR. CARBON: Milt.

11 DR. PLESSET: I think we realize that after the event
12 and further, in view of your training program, that operators
13 are all sophisticated relative to this kind of transient. But
14 if we think back before the event, do you think that an
15 operator would have to be particularly sophisticated to know
16 what was going on during that transient? Did he have the
17 instrumentation he needed, or would he need to have been an
18 engineer or something?

19 MR. MAC MILLAN: You're asking me to speculate on
20 something which I really would rather not speculate on.

21 Perhaps I can answer your question this way: I
22 believe that this information as displayed in the reactor
23 control room should have been adequate for him to assess the
24 situation and appreciate that he had conditions under which he
25 should not have turned off the high-pressure injection pumps

pv 1 and should not have turned off the reactor coolant pumps.
2 These engineers, these operating engineers, are very
3 sophisticated personnel, and I think that they should have had
4 that degree of sophistication.

5 DR. PLESSET: Can you tell me, as a matter of
6 curiosity, what you told the people at TMI-2 during the first
7 few hours that you were involved?

8 MR. MAC MILLAN: I was in Florida at 4:00 in the
9 morning on March 28, and by the time I got reservations to get
10 back to Lynchburg, it was Thursday afternoon, so that I really
11 cannot tell you from firsthand experience what instructions
12 were given to the operating staff in that situation.

13 The degree of communication that we had from
14 Lynchburg to the site was very restricted, particularly during
15 the first two, three, or four hours of the incident. And I
16 would have to say, even going out much further in time, that
17 communication was a very loose connection. And when I
18 mentioned in my testimony that one of the things I am asking
19 this task force to look at is what recommendations should be
20 made for closer coupling with our operating reactors in the
21 situation, that's one of the things that I believe we need to
22 address and see what lessons can be learned from the TMI-2
23 experience.

24 DR. PLESSET: Thank you.

25 DR. CARBON: I would like to ask a question that's

pv 1 similar to what Dr. Plesset was asking. When you think of the
2 operator there and you design the instrument panel and so on
3 for him, what kind of knowledge do you assume he has? How much
4 physics, for example? Do you assume he's taken a high school
5 course in physics 10 years ago or that he's given an extensive
6 several-weeks, several-month course on some basic principles?
7 Just what do you assume? And do you assume that the
8 supervisors have more knowledge of physics; whether they get it
9 formally or informally, it doesn't matter? What kind of
10 assumptions do you make there?

11 MR. MAC MILLAN: Let me first say that I am not a
12 control room designer. As Dr. Okrent said, I am quickly over
13 my head in this arena.

14 But as you know, in the process of licensing senior
15 reactor operators and reactor operators, they go through an
16 extensive program of training which includes basic fundamentals
17 of physics, as it's appropriate to the operation of a nuclear
18 plant. And then, beyond that, of course, they go through very
19 detailed training in the specific equipment that they're going
20 to be operating, and they observe operations of other units in
21 service and go through simulator training where they have a
22 chance to operate the simulator which acts just like a real
23 plant.

24 So, they do have some comprehension of basic physics
25 and engineering principles as it applies to the operation of

pv 1 nuclear plants.

2 Now, I can't answer your question specifically, when
3 the control room is laid out, just what degree or what level of
4 specific training is presumed. That's not my field.

5 MR. ETHERINGTON: I don't want to belabor
6 particularly this question of whether the water was at
7 saturation at the time of the recirculating pump trip, but
8 there might be a misunderstanding. The figure which showed
9 coincidence of saturation temperature with actual temperature
10 covered the first 30 minutes, and at the time of the pump trip
11 the hot leg temperature is showing at 550 degrees.

12 I don't have steam tables here, of course, but I
13 believe that that is being about 1050 psi, and the actual
14 pressure is 1300 psi. So, there would appear to have been an
15 overpressure. I may be wrong in my numbers, but that may be
16 worth looking at at some later time.

17 MR. MAC MILLAN: Harold, the curve I had in mind was
18 Figure 12.

19 MR. ETHERINGTON: Yes, that's right. That's the
20 first 30 minutes.

21 MR. MAC MILLAN: Which does show that even in the
22 first 30 minutes of the transient, while the reactor coolant
23 pumps were operating, we had saturated temperature in the hot
24 leg of the reactor coolant.

25 MR. ETHERINGTON: Even in the first 30 minutes, with

pv 1 no water entering the steam generator.

2 MR. MAC MILLAN: He had water in the steam generator
3 after eight minutes.

4 MR. ETHERINGTON: Well, let's look at the Figure 8.
5 It shows the temperature as a little under 550 degrees.

6 DR. PLESSET: The saturation pressure is 1047.

7 DR. LAWROSKI: You're wrong three degrees, Harold.
8 You're slipping.

9 (Laughter.)

10 MR. ETHERINGTON: The pressure curve, long term --

11 DR. CATTON: Harold, if you'll look at Figure 19 --

12 MR. ETHERINGTON: That's the wrong list.

13 DR. CATTON: It looks like the pressure is somewhere
14 between 1000 and 1100.

15 MR. ETHERINGTON: No. At the time of the trip and
16 before the drop, it's, I guess, 1300, between 1300 and 1400.
17 Then it drops off at the time of the pump trip.

18 DR. SIESS: That scale is questionable.

19 MR. MAC MILLAN: Figure 19 shows pressure inside of
20 the one-hour time frame of somewhere around a little under
21 1100, 1050.

22 MR. MICHAELSON: 1080, I think, is pretty close to
23 what it was.

24 MR. ETHERINGTON: I would assume that that dropoff
25 occurred at the pump trip.

pv 1 MR. MICHAELSON: Mr. Etherington, I can give you the
2 numbers, if you like. I did look them up last night.

3 At that point in time, when the pumps were tripped --

4 MR. ETHERINGTON: Here I have a different curve
5 altogether for the same data.

6 MR. MICHAELSON: You should find about 1080, though,
7 in the system pressure, which was about 534 degrees saturation.
8 The hot leg at that time was at about 540. So, apparently, we
9 were about 14 degrees sub-cool.

10 I think your observation is correct. It appeared to
11 be sub-cooled from the time the pump was tripped.

12 DR. SHEWMON: In your jargon, "sub-cooled" is where
13 you want to be. Is that right?

14 MR. MICHAELSON: That's the right side, at least,
15 yes. It appeared to be about 14 degrees sub-cooled. It's hard
16 to read these curves that precisely; but, certainly, it appears
17 they were sub-cooled, yes. It's getting closer than you would
18 like. In fact, you've got to keep in mind that, you know,
19 where the thermocouple or the RTD is and things of this sort --
20 but it appeared to be slightly sub-cooled.

21 MR. ETHERINGTON: The thing that I am a little
22 surprised at is a lack of insistence to plant operators that
23 they maintain the pressure as high as possible at the time they
24 go into natural circulation. This has not been, apparently --
25 they have not, apparently, been alerted to that. And I don't

pv 1 know whether there's any feeling that they need not be.

2 MR. MAC MILLAN: We obviously would rather have them
3 at high pressure, that they get with the sub-cooled condition
4 before they would attempt a natural-circulation condition.

5 MR. ETHERINGTON: But you don't think it sufficiently
6 important to include it in your instructions to them?

7 MR. MAC MILLAN: Yes, we do.

8 MR. ETHERINGTON: This is something you plan to do,
9 then?

10 MR. MAC MILLAN: Yes, sir.

11 MR. ETHERINGTON: Thank you.

12 DR. CARBON: Ivan.

13 MR. MAC MILLAN: That was one element of the training
14 program that I outlined in my presentation, that they would be
15 looking at getting it from a voided condition to a recovered
16 condition.

17 DR. CATTON: I have a question that has to do with
18 the layout. I noticed your pressurizer is tied in with the hot
19 leg through the loop. Is that on all of the plants? And is
20 there some design reason for doing that?

21 MR. MAC MILLAN: The answer to the question is: It's
22 that way on all the B&W plants.

23 DR. CATTON: Yes.

24 MR. MAC MILLAN: The principal reason for it being
25 that way is to provide flexibility in the running of the pipe.

pv 1 I don't know of any other real fundamental reason for it being
2 that way.

3 DR. CATTION: Thank you.

4 DR. CARBON: Dave.

5 DR. OKRENT: Why don't you get Carl.

6 MR. MICHAELSON: I have a question, and then I would
7 like to solicit a comment on natural circulation.

8 In the case of Davis-Bessie is the auxiliary
9 feedwater fit from the top of the steam generator, or does it
10 flood from the bottom? And if it floods from the bottom, then
11 what would you have to say concerning natural-circulation
12 problems?

13 MR. MAC MILLAN: The question to your question is
14 that at Davis-Bessie the auxiliary feedwater header does not go
15 in at the top of the generator as it does in the Oconee
16 configuration; it goes in closer to the bottom of the steam
17 generator.

18 The reason we felt we could do that at Davis-Bessie
19 was because of the relative elevation of the steam generators
20 with respect to the core, and with the steam generators well
21 above the core, bringing the auxiliary feedwater in at the
22 bottom of the steam generator provides enough thermal head to
23 get natural circulation.

24 The reason the auxiliary nozzles are at the top of
25 the Oconee steam generator configuration is: in order to get

pv 1 cold auxiliary feedwater in those generators at an elevation
2 well above the core, in order, again, to have natural
3 circulation.

4 DR. CARBON: Dave.

5 MR. ROY: Excuse me. Even though that's a raised
6 loop, the natural-circulation situation is even better because
7 the aux feedwater is in at the top, Davis-Bessie being the
8 once-through steam generator, rather than the IEO with the
9 compromiser.

10 MR. MAC MILLAN: I am sorry? You're saying
11 Davis-Bessie has it at the top?

12 MR. ROY: It does have the auxiliary feedwater flow
13 at the top. It was also one of the plants tested under natural
14 circulation; with a very good natural circulation flow, by the
15 way.

16 MR. MAC MILLAN: Our standard plant has the feedwater
17 at the bottom.

18 MR. ROY: Yes. For the raised-loop plants with the
19 205 fuel assembly model, the aux feedwater is at the lower.

20 MR. MAC MILLAN: I am glad you corrected me on that.

21 MR. MICHAELSON: Does that mean, then, that there is
22 a spray tower at the top of the steam generator? Is that
23 right?

24 MR. ROY: Yes.

25 DR. CARBON: Dave.

pv 1 PROF. KERR: Excuse me. Then that really seems to
2 mean that there has not been an experimental test of standard
3 plant kind of configuration for natural circulation. You
4 mentioned Davis-Bessie.

5 MR. ROY: No test yet. The first will be the
6 Bellefonte unit.

7 PROF. KERR: Okay.

8 DR. OKRENT: Earlier in the discussion you indicated
9 that you could provide or perhaps had already provided
10 documentation of the simulator programs. Is it "could" or
11 "have"?

12 MR. MAC MILLAN: We could. We have not.

13 DR. OKRENT: Is this in detail so that it describes
14 fully all the equations and so forth?

15 MR. MAC MILLAN: We could make it that way. We
16 wouldn't normally.

17 DR. OKRENT: And is this a proprietary program?

end#6 18 MR. MAC MILLAN: I doubt it.

19

20

21

22

23

24

25

1 MR. MAC MILLAN: Is it proprietary?

2 MR. ROY: I would say yes.

3 DR. OKRENT: Does proprietary mean that the NRC
4 doesn't have access to it?

5 MR. ROY: No.

6 DR. OKRENT: Could they put it on their computers if
7 it were proprietary?

8 MR. MAC MILLAN: I'd have to guess that the answer
9 to that is yes, they have that authority.

10 DR. OKRENT: All right. Also, you indicated that you
11 thought that you had done a sufficient amount of small break
12 analysis, including breaks below the point of five square foot.
13 Do documents exist that I should have seen on this?

14 MR. MAC MILLAN: I doubt it. The only information
15 we've presented in our licensing dockets has been down at the
16 .05.

17 DR. OKRENT: But since you've done these, this is
18 something that you presumably have then in internal reports
19 and could provide?

20 MR. MAC MILLAN: We could.

21 MR. ROY: We have done the .04 square foot case, and
22 we have done the 0073 square foot case, which corresponds to
23 the stuck open pilot-operated relief valve, and extensive
24 qualitative review of the expected response to small breaks at
25 various other locations. And that material can certainly be

1 made available.

256

2 DR. OKRENT: Well, I gather from Mr. MacMillan's
3 answer that, by either qualitative or quantitative analyses,
4 you have assured yourselves that there were no untoward situa-
5 tions in any break sizes. So I think I for one would like to
6 see such documentation in the near future, to see what does
7 transpire and be satisfied in that regard.

8 A different question. I've heard it suggested that
9 level instrumentation in the hot leg might be practical and
10 might be a way of getting information on the level in the
11 vessel, albeit not directly. Have you looked at that specific
12 alternative as a possible way of providing further information
13 for a B&W plant? Is it practical? Is it impractical? Can it
14 be done only on plants to be built? Or what can you say about
15 it, if anything?

16 MR. MAC MILLAN: That suggestion has been made. We
17 have not looked at it in any detail. I can't tell you whether
18 it's practical or not practical, or whether it can be incorpor-
19 ated or not. I would put that, Dave, in the same category as
20 looking at the reactor vessel level measurement alternatives.

21 DR. CARBON: Chet?

22 DR. SIESS: Would it be possible to explain to me in
23 a relatively short time the principle on which the pressurizer
24 level instrumentation works?

25 MR. MAC MILLAN: I can give you a very simple

1 description, and if that isn't good enough I'll have to call
2 on somebody else.

3 DR. SIESS: Simple will be short.

4 MR. MAC MILLAN: Basically, we're reading the
5 pressure difference between the steam space and the water space
6 in the pressurizer and taking that delta P as an indication of
7 the hydrostatic head. The reference, the line comes outside
8 and it gets cooled just by heat loss, so that in the event you
9 get a rapid depressurization in the reference leg or the instru-
10 mentation leg, it will not flash and lose that.

11 Very simply, that's what we're doing.

12 MR. MICHAELSON: To follow up that comment -- and
13 this is just a question maybe you need to look at to put to
14 bed -- and that is, depending on exactly how that instrument
15 line is routed, it appears that for certain types of breaks in
16 certain locations, it would be possible to heat the reference
17 leg by the fluid emitting from the break.

18 I was wondering, do you know if anybody has checked
19 the instrument panel which is near the relief tank to see if
20 this instrument by chance is routed near there or located on it?

21 MR. MAC MILLAN: I can't answer that. Does anybody
22 know?

23 DR. PLESSET: I think that Dr. Hanauer has a view-
24 graph that maybe he could show to us. Would that be worthwhile,
25 if it's all right, Mr. Chairman?

1 DR. LAWROSKI: It's worth a thousand words.

2 DR. HANAUER: Mr. Chairman, I'm Steve Hanauer of
3 Regulatory staff. The subject of the level instrumentation
4 seems to be of great importance, and so, anticipating these
5 questions, I have a couple of pictorial representations.

6 (Slide.)

7 This shows the general principle. One puts a dif-
8 ferential pressure instrument with two legs, the one in the
9 steam space, the one in the water space. One measures, there-
10 fore, the mass per unit area of the liquid, with the mass of
11 the steam being negligible.

12 Clearly, the situation in these pipes is crucial. The
13 most obvious thing that could go wrong is that this pipe could
14 fill up with water exactly this high and the differential
15 pressure transmitter would read zero. In point of fact, it
16 doesn't look like that; that only shows the principle.

17 (Slide.)

18 In point of fact, it looks like this. This was
19 obtained from some Burns & Rowe drawings at some considerable
20 effort.

21 (Laughter.)

22 DR. HANAUER: You can't believe how much effort.

23 (Laughter.)

24 DR. HANAUER: All of this is inside containment.

25 The containment wall, not shown, is here, and some feet inside

1 the wall is the cylindrical, approximately, shield wall. And
2 the actual differential pressure transducer is located in this
3 annulus, so that the instrument man who goes in and makes
4 adjustments and callibrations is shielded from the primary
5 system.

6 The pressurizer sits maybe 40 feet off the floor,
7 and the taps are approximately 33 feet apart. And instead of
8 the transmitter being located as shown in the schematic diagram,
9 it is in fact 50 or 60 feet away, and the routing is approxi-
10 mately correct and approximately to scale.

11 The question then is: What's in these pipes? The
12 answer is: These pipes are full of water. This lower one is
13 full of water, because when the transmitter is installed there's
14 a collection of valves, drains and the like, not shown, which
15 you manipulate in order to get it full of water, and then
16 there's no further difficulty.

17 This line is also full of water and has to be filled
18 at the time the transmitter is installed, or monkeyed with,
19 after which condensation will keep it full, because this line
20 is cooler than the pressurizer. This is shown in still more
21 detail in this viewgraph --

22 (Slide.)

23 -- which is a view of just the pressurizer. The
24 pressurizer itself is this cylindrical object with hemispherical
25 ends. The pink stuff is the thermal insulation around the

1 cylinder, about which we obtained much more information than
2 anybody here wants.

3 (Laughter.)

4 DR. HANAUER: The yellow thing is the lower pipe,
5 the blue thing is the upper pipe, both drawn to scale. The
6 important question is whether it's inside or outside of the
7 insulation. It's outside.

8 We've done some conduction-convection heat transfer
9 calculations, and in fact, within a few inches of the blue
10 pipes runs at the containment temperature of about 100 degrees,
11 rather than the pressurizer temperature of 650 degrees.

12 DR. SHEWMON: To help me understand that scale
13 drawing you've alleged to have up there, the red insulation
14 is 6 inches thick and the space between the blue pipe and the
15 outside of the insulation is one inch?

16 DR. HANAUER: So it says.

17 DR. SHEWMON: Thank you.

18 MR. MICHAELSON: Steve, did you check to see where
19 the panel is relative to where the dump tank, the reactor
20 coolant drain tank, is?

21 DR. HANAUER: No, sir, I didn't. It could be ascer-
22 tained, but I didn't do it. It is in this annulus outside and
23 you would have to tell me where the dump tank is. It's known.
24 I just don't have it at my fingertips.

eral Reporters, Inc.

25 MR. MICHAELSON: Do you know the panel number?

67-587

1 DR. HANAUER: Not standing here. We wrote a report
2 on it, which will tell you more than you could possibly want
3 to know.

4 MR. MICHAELSON: Okay.

5 MR. TAYLOR: Dr. Michaelson, I believe it is true,
6 however, that the dump tanks, if it were near one of the
7 transmitters, would only be near one of them, because of the
8 physical separation requirements. And there are three separate
9 transmitters, which, when they were all working, were reading
10 identically.

11 DR. CARBON: Steve, some flashing is said to have
12 taken place in the pressurizer line. How much did, or what
13 do you theorize because of the 100 degrees?

14 DR. HANAUER: We've done some calculations on that,
15 and the temperature there is just the point I was making.
16 Initially, the fluid inside, water and steam, is at 650 degrees
17 at 2155 pounds per square inch. There's a temperature gradient
18 in the liquid in the first few inches of this line, this
19 horizontal piece. And as far as we can tell it is horizontal.
20 This horizontal piece will presumably be empty. There will be
21 a stagnant column of liquid, approximately full, from conden-
22 sation. And there will be a temperature gradient in these
23 first few inches of line.

24 We made a calculation and only for the first small
25 number of inches will the fluid be subject to flashing, even

1 during the initial pressure dip down to about 13 pounds per
2 square inch, since the total span is 33 feet. We conclude
3 that less than a foot will flash.

4 We also did calculations on the dissolved gas content
5 and on the potential for sucking fluid out of here by virtue
6 of the velocity past the end of the pipe. Neither one seems
7 to have the potential for significant level instrument errors.

8 DR. SIESS: Steve, mention was made of three trans-
9 mitters. Does that mean there are three reference legs?

10 DR. HANAUER: There are three reference legs, three
11 measuring legs and three transmitters, done at different
12 azimuthal positions in the annulus.

13 DR. CARBON: Are there other questions of
14 Mr. MacMillan?

15 (No response.)

16 DR. CARBON: Mr. MacMillan, could you provide me some
17 documentation on the natural circulation tests that you have
18 run and on the associated documentation where you extrapolate
19 or whatever from the actual test to other conditions, as well
20 as information on the cases where B&W plants have relied upon
21 natural circulation, where they have gotten into natural
22 circulation?

23 MR. MAC MILLAN: Yes, sir.

24 DR. CARBON: Are there other questions?

25 (No response.)

1 DR. CARBON: If there are no further, let's take a
2 break.

3 (Brief recess.)

4 DR. CARBON: Dave?

5 DR. OKRENT: Mr. Chairman, out of listening to the
6 discussions this afternoon and trying to remember what I had
7 read that the staff had recommended to various PWR operators,
8 it wasn't clear to me whether the staff had dealt with whether
9 operators had sufficient guidance with regard to when and how
10 they would go into the natural recirculation mode, should this
11 be required because of some future transient. And I wonder if
12 the staff could help me in that regard?

13 DR. MATTSON: Well, the loss of power transient is
14 a transient that's required in the course of licensing review
15 to be analyzed and accepted for licensing purposes. And loss
16 of power requires the plant to go into natural circulation
17 from full power.

18 I'm not sure what your question is. To the degree
19 we've looked at that, or to the degree we're going to look at
20 it in the future? Which is the thrust, Dr. Okrent?

21 DR. OKRENT: Well, I suspect I probably could have
22 said one month ago, a situation where a relief valve was stuck
23 open in the primary system is a situation that's been analyzed
24 and for which the operator is prepared. Yet, we had a combina-
25 tion of circumstances where things didn't go like the FSAR.

1 Now, I'm trying to understand whether the staff has
2 looked in sufficient detail at possible instances in which one
3 might need to go into the natural recirculation mode and looked
4 at the kinds of things the operator might have to do and when
5 and has decided that adequate procedures exist at all operat-
6 ing PWRs, and just what is the situation in that regard.

7 DR. MATTSON: At this point in time, we haven't
8 looked at those transients that lead to natural circulation
9 and compounded then with the kind of failure which occurred in
10 the power-operated relief valve at Three Mile Island 2, to
11 answer that question for all PWRs. Clearly, that's a question
12 that has to be addressed in the generic program that was
13 described this morning.

14 DR. OKRENT: You know, I've never been able to tell
15 when something that's generic is going to be resolved. We've
16 only very recently been talking about a 10-year-old generic
17 problem.

18 DR. MATTSON: I would recall for you what Tedesco
19 said this morning: that the report on his generic activities,
20 saying what's been done and what needs to be done, is due to
21 be published the end of the month. And I say with some cer-
22 tainty that resolution of that question in the near term is a
23 very important thing to accomplish. I can't tell you that it
24 will be answered tomorrow.

25 DR. OKRENT: If I can put words into your mouth, are

1 you telling me that the question of what constitutes adequate
2 interim guidance for operators with regard to natural recircu-
3 lation load of cooling will be handled as part of the Tedesco
4 study to be published by the end of April?

5 DR. MATTSON: It'll either be in there or a reason
6 given as to why it's not necessary in the short term, or a
7 date set in the near term for accomplishing that, with a basis
8 as to why it's safe to do that in the meantime. I can't
9 prejudge the outcome of that. All I can tell you is that the
10 question will be very seriously and forthrightly addressed
11 over the next two weeks as part of the charge.

12 DR. OKRENT: Harold, did you have anything?

13 MR. ETHERINGTON: No, I don't think I have any
14 questions. I would have thought that whether or not the
15 problems possibly are real or not, we could make some require-
16 ments in a safe direction. That is, we could insist that there
17 be higher pressure prior to the time of going into natural
18 circulation. We could specify some limits on the temperature.
19 These would be in the safe direction and would seem to impose
20 no problem.

21

22

23

24

25

#8

1 DR. MATTSON: Dr. Okrent, Mr. Etherington, I would
2 agree with that.

3 The question that's in my mind is the one that's
4 come up a couple of times today, that you have to set those
5 conservative limits with some caution to make sure that you
6 don't exacerbate another safety concern. And to the extent
7 we can derive such limitations or such guidance within the
8 next several weeks, I'm sure we will.

9 And if it's found to be necessary to set them, and
10 it's impossible to set them, then you'd have a reopened
11 question of continuing plant operation.

12 So it's in that sense that if it's necessary and
13 they can't be developed in that short time, then you have to
14 reopen that question.

15 The indications are so far that that won't be the
16 case, but as I said at the start this morning, there is no
17 question that there are questions that remain unanswered.
18 That's one of them we're working on.

19 MR. ETHERINGTON: The warning that the low
20 temperature at Three Mile Island could have contributed a
21 little to the problem, would this be in order?

22 DR. MATTSON: I think I understand what you're
23 saying. As a result of reviewing the information that's come
24 in for the moment, the things that Steve Varga was talking
25 about off the bat this morning, and as a result of continuing

1 to review the information that we're gathering from you here
2 today and things that are still coming in from the plant, if
3 such warnings can be derived -- it may very well be that they
4 can -- then of course we'd act promptly through the bulletin
5 process to get that information to the operating plants.

6 DR. OKRENT: But I didn't see anything in the
7 responses I've read that addressed the question of natural
8 recirculation. Did you?

9 DR. MATTSON: Well, that's why I said the informa-
10 tion we're gathering here today. I think one of the things
11 I learned this morning was the significance of the attempt
12 to establish natural circulation some hours into the accident,
13 and the relevance it played to being able at that late
14 juncture to turn the accident around.

15 Those awarenesses are coming with each passing day,
16 and certainly if the bulletin needs to be augmented to go to
17 that point, and if on further scrutiny that turns out to be
18 an important issue, then we'll deal with that issue.

19 I think I said this morning that our concentration
20 up to this point in time has been to avoid -- to find ways to
21 assure -- I'll say that again -- to find ways to assure that
22 the initial sequence of events that eventually led to the
23 need to establish natural circulation with this depressurized
24 system with some loss of coolant, that you don't get to that
25 situation.

1 I think what we're talking about now is that even
2 if you did get to that situation, there may be other guidance
3 devices that could be developed. That's certainly a good idea,
4 and we'll be working on them.

5 MR. ETHERINGTON: There is a premise that is
6 probably correct, but I don't wholly accept that the early
7 events are the reason that we couldn't get into natural
8 circulation.

9 I would like to postulate that it's just possible
10 that we'd of had the same trouble even without the early
11 events.

12 DR. MATTSON: Well, I think I might argue with you
13 on that.

14 One of the early events is the failure of the
15 auxiliary feedwater delivery valves to be open, and the
16 subsequent boiling dry of the steam generators, and then the
17 slow recovery level of the steam generators.

18 Had we tried to go to natural circulation without
19 those events having transpired, it would be my judgment that
20 we'd have gone to natural circulation quite normally and quite
21 straight forwardly.

22 MR. ETHERINGTON: You're presuming gross damage, or
23 serious damage to the core during those early transients.

24 DR. MATTSON: No, sir. I was talking in the same
25 sense that we were talking this morning: that after the pumps

1 were tripped at the time the plant tried to go into natural
2 circulation and didn't make it, and subsequently the core was
3 damaged.

4 MR. ETHERINGTON: So you assume there was no damage
5 after that point, then?

6 DR. MATTSON: That's my understanding in reconstruc-
7 tion of the transient, yes, sir.

8 MR. ETHERINGTON: Then I would agree wholly with
9 that. But wasn't an hour and a half enough time for it to
10 recover?

11 DR. MATTSON: I'm sorry?

12 DR. OKRENT: Why did the steam generators not fill
13 up, and so forth? You know, in eight minutes they were turned
14 on.

15 DR. MATTSON: I would point you to a figure -- my
16 figures are the same as yours, although I've got different
17 numbers, and I don't know which one your number is -- but it's
18 the figure that depicts steam generator level in A and B as a
19 function of time after turbine trip in hours. The one that
20 looks like this (indicating). I don't know what your number
21 is. I got these about the same time those were sent down
22 here.

23 By my reckoning, the B pump, the B loop pumps were
24 tripped -- I shouldn't put it on the record without the numbers
25 in front of me. The B loop pumps were tripped at 1-1/2 hours,

1 and the A loop pumps were tripped at 1.8 hours.

2 If you look at this figure, you will see that the
3 B loop pumps were tripped when the steam generator level was
4 at about 5 percent of the operating range, and shortly after
5 the B loop pumps were tripped the A steam generator level
6 began to rise rather rapidly.

7 Yet, the aux feedwater to the A steam generator and
8 the B steam generator had been flowing since about 8 minutes
9 into the accident; but the level in the A and B steam
10 generators hadn't risen out to more than an hour and a half
11 into the accident.

12 MR. ETHERINGTON: Yes, but we don't know how that
13 level was being controlled -- or at least I don't.

14 DR. MATTSON: And I do not, either. And when I
15 said the appreciation was dawning on me this morning of what
16 you were talking about: Was it an operator action that caused
17 the level of the A steam generator to begin to increase
18 abruptly after the B pumps were tripped? It may very well be
19 that when the B loop pumps showed that they needed to be
20 tripped and the operator tripped them, that he took some
21 action to begin to fill the secondary side of the A loop.

22 MR. ETHERINGTON: Or, alternatively, for some
23 reason the water might have continued to flow in, but it was
24 all being evaporated for some reason.

25 DR. MATTSON: For some reason. But, if he was

1 attempting to establish natural circulation -- which he would²⁷¹
2 attempt to do after he turned pumps off, or after he turned
3 the first set off, he would know that he was in the potential
4 jeopardy of having to turn the second set off.

5 And if he was reading his A and B steam generator
6 levels, he knew they were low and he would know from his
7 operating procedures for loss of off-site power that he needed
8 high center of heat, as we were discussing this morning, to
9 establish natural circulation.

10 So he had begun to fill the A and B steam generators
11 to the best of his ability at the time the pumps were tripped.

12 MR. ETHERINGTON: He needed the higher level of
13 the water, but there's no evidence that he had thought of it
14 before 1.8 hours. So why did he suddenly get smart and decide
15 to do this?

16 DR. MATTSON: It may be that he didn't anticipate
17 that he was going to lose the pumps.

18 MR. MAC MILLAN: Mr. Chairman, I believe the
19 reason that the water level was increased at that point was
20 that it's an automatic function of the integrated control
21 system, that when you lose your active coolant pumps, the
22 demand is to increase the water level to approximately 50
23 percent of the operating level.

24 So I believe that was an automatic function resulting
25 from the securing of those reactor coolant pumps.

1 DR. MATTSON: Which would be an automatic function
2 associated with getting optimum conditions for starting
3 natural circulation.

4 MR. MAC MILLAN: Getting the level up for natural
5 circulation.

6 DR. MATTSON: But, John, do you know the answer as
7 to why the level was low up to that point?

8 MR. MAC MILLAN: I don't.

9 MR. ETHERINGTON: Roger, I don't think there's any
10 basic disagreement between us. I think there's just a slight
11 difference in our feeling of the urgency of getting word to
12 the operators at least to watch this situation and give them
13 some kind of a guidance or warning, that's all, the urgency
14 of it.

15 DR. MATTSON: We'll take it in tomorrow morning
16 first thing, sir, and we'll address that question right off.

17 DR. OKRENT: It seems to me there's some obscurity
18 at least among those present here as to why the steam generator
19 level stayed low up to that point. I'm not sure again that
20 this has been factored into your thinking about "are there
21 adequate instructions with regard to natural recirculation
22 modes"?

23 DR. MATTSON: It may not be in the top of my mind,
24 Dr. Okrent. We may be underestimating the work that's going
25 on while this meeting is going on. Certainly there is a lot

1 of it.

2 MR. ETHERINGTON: I know you didn't mean anything
3 by it, but I would like to dispel one possible misunderstanding.

4 You mentioned that I had heard this discussed out
5 at the site. This is true. However, I was concerned about
6 this before going to the site, and Tom McCreless and I spent
7 a couple of hours the night before I went out tryint to find
8 out from the SAR actually what the levels were.

9 And as far as concern over natural circulation is
10 concerned, this is an old interest of mine. It was addressed
11 in the chapter in a book that I wrote on furnace technology
12 in connection with natural draft, and as far as solubility of
13 gases is concerned, this is also an old interest back in the
14 '30s in connection with steam condensers when I was assistant
15 engineer to the Engine Condenser Department.

16 The book was written in 1937, so I'm not quite a
17 Johnny-come-lately in this thing.

18 (Laughter.)

19 DR. MATTSON: I understood that background as I
20 was talking to you, sir.

21 One feature we can't lose track of, I think, in
22 trying to understand this is that the first several hours of
23 this transient were evidently believed by the operating staff
24 to be a rather normal situation that they were dealing with,
25 with an intact system.

1 It wasn't until 2-1/2 to 3 hours into the transient
2 that they realized they had something different than that. And
3 in that sense, there may not have been an urgency to raise
4 that level.

5 I think those are the kinds of questions we have to
6 answer rather quickly in reconstructing that event.

7 MR. ETHERINGTON: I in no way blamed the operators;
8 I just suggest that we try to warn other operators in as timely
9 a fashion as we can.

10 DR. MATTSON: Yes. The point is very well taken.

11 DR. CARBON: Paul?

12 DR. SHEWMON: To make sure I understand the
13 situation, Harold, the things which B&W has urged, and that
14 the staff has urged, would make this a third line of defense
15 if the pressure had been kept up so there had not been flashing,
16 and they had better analyzed whether or not the relief valve
17 was open or shut, then we would of not had to get to the
18 natural circulation.

19 It's just that this is an essential fallback
20 position? Is that the interest in it?

21 MR. ETHERINGTON: That's the interest. I don't
22 think the intention would be to go to natural circulation if
23 you had full power. Just in case you didn't, then you might
24 be forced to precipitously.

25 DR. OKRENT: If they cut the first line, you lose

1 the power to your coolant pumps, possibly -- not necessarily,
2 but possibly.

3 DR. SHEWMON: Then you've still got -- you may have
4 pressure, yes, but the question is whether you are going to
5 have 20 percent of your system, whether you're under-
6 saturated or over-saturated, or which way is up on the scale;
7 whether you've got steam in part of your system may not be
8 the situation there. It is here.

9 Having enough pressure is the first line.

10 DR. CARBON: Does that finish that topic, then?

11 (No response.)

12 DR. CARBON: Let's move on, then, to the next
13 subject.

14 Roger, are you the spokesman for the staff?

15 DR. MATTSON: The next two subjects are:

16 One, the status of the plant today; and then a
17 summary of the activities that are underway in the plant that
18 are in motion for placing the plant in the long-term cooling
19 mode.

20 Vic Benaroya, Branch Chief of the Auxiliary Systems
21 Branch, is going to give us a summary of plant status, some
22 numbers and things like that, to bring you up to date. That
23 shouldn't take more than about 15 minutes or so.

24 Then Carl Berlinger will talk about the ongoing
25 work.

1 MR. BENAROYA: My name is Victor Benaroya. I am
2 Chief of the Auxiliary Systems Branch.

3 First let me give you a brief overview of the
4 NRC organization at the site. There are about 100 NRC
5 personnel at the TMI site, most of them from I&E.

6 There is the NRC Command Center under Harold
7 Denton.

8 There is the I&E operation at the TMI site.

9 There are two main groups of I&E personnel. There
10 is the plant operational surveillance and the radiological and
11 environmental surveillance, which covers both health physics
12 and environmental surveys.

13 The environmental surveys group has a helicopter
14 at their disposal, and a mobile lab.

15 NRR has several groups at the site. In the turbine
16 deck area, there is a group that reviews and approves all new
17 plant procedures, including emergency procedures.

18 The procedures are also reviewed and approved from
19 the ALARA point of view. There is a technical review team
20 to review and approve plant modifications.

21 One group is overseeing waste management activities.
22 All emergency technical specification changes are being
23 reviewed and approved at the site.

24 Then Bennie Ross coordinates the industry group
25 activities with NRC. However, most of the analysis is being

1 in Bethesda. As of 9:00 a.m. today, the heat removal path
2 is from the reactor to the reactor coolant pumps to a pump
3 2-A through steam generator A. Steam lead is through bypass
4 around the MSIV of steam generator A to the condenser.

5 The condensate return to steam generator A is
6 via the condensate pump. The pressure in the reactor is 810
7 psig. The inlet temperature to steam generator A is 250
8 degrees, and outlet is 246.

9 The pressurizer temperature is 534 degrees. The
10 boric acid concentration in the primary coolant is approximately
11 3400 parts per million.

12 The five highest in-core temperatures as of 9:00
13 o'clock this morning are location H-5, 342 degrees -- that's
14 the highest; H-8, 335; G-5, 312; M-9, 299; and L-6, 275 degrees.

15 The letdown flow is varying between approximately
16 10 and 24 gpm.

17 One HPCA pump is running in the makeup mode, and
18 two are on standby.

19 The containment is at -1 pound and a temperature of
20 82 degrees Fahrenheit.

21 Three of the five pumps with a capacity of 170,000
22 cubic feet per minute in emergency mode are operating.

23 One of the two hydrogen recombiners with a flow rate
24 of approximately 95 cubic feet per minute is in service. The
25 other recombiner is on standby.

CR 4051
FMAN t9
c 1

1 The latest hydrogen concentration is around 1.4
2 percent. There's about 17 to 18 percent of oxygen and 80 to
3 81 percent nitrogen. It's estimated that between 150,000 and
4 200,000 gallons of primary coolant, with 5,000 gallons of
5 caustic, is in the containment.

6 A second primary coolant sample, unpressurized, was
7 taken on April 11th. The sample was sent to four labs --
8 Savannah River, Oak Ridge, Bettis and B&W. The analysis from
9 the different labs differed by less than a factor of two.
10 That's pretty good.

11 But unfortunately, any caustic in the water might
12 affect the iodine and cesium. As an example, the Oak Ridge
13 analysis shows that the iodine 131 is 8.2 times 10^3 micro-
14 curies per cc; cesium, 137, 330 microcuries per cc; strontium
15 90, 50; barium, 140, 219.

16 The pH of the primary coolant is around 8, and there
17 was no detectable uranium or plutonium. For a 15 mile radius,
18 2 million population, the total dose was calculated to be
19 approximately 3000 millirem for an average dose of 1 to 2
20 milirems.

21 HEW calculated 3500 millirem, and DOE, 2000 to 2500.
22 The calculation is based on 50 to 100 millirem per day,
23 that higher value based on the highest release during the
24 accident.

25 All three organizations, namely HEW, DOE and NRC,

pmcc 2

1 agree that the maximum dose to an individual is less than
2 100 millirem. Most of the gaseous rad waste is in the
3 containment. The two waste gas decay tanks were vented to the
4 containment after some plant modifications.

5 Today there is practically no gaseous rad waste from
6 degassing. The pressurizer is being degassed into the
7 containment of the reactor building, as it's called in the
8 plant. The pressure in the makeup tank is being increased.
9 As a consequence, there is nothing at the moment going into
10 the waste gas decay tanks.

11 The main activity today is to locate the sources of
12 iodine releases and to change the charcoal filters. There are
13 240 filters that need to be replaced, 160 of those in the
14 auxiliary building and 80 in the spent fuel building. A
15 charcoal filter bank has been installed on the exhaust of the
16 condenser vacuum pumps to reduce the potential iodine releases
17 from that source.

18 A backup charcoal filter to the auxiliary building
19 vent is under construction. There is approximately 50,000
20 gallons of primary coolant in the bleed tanks and approximately
21 10,000 gallons in the miscellaneous waste storage tank from
22 post-accident conditions in unit 2.

23 5600 gallons of post-accident primary coolant was
24 transferred to unit 1 liquid rad waste tanks. All the primary
25 coolant that was in the auxiliary building sumps has been

General Reporters, Inc.

pmcc 3 1 transferred into tanks. A solution of ten percent caustic,
2 ten percent thiosulfate and 80 percent water was sprayed in the
3 sumps, tied on the iodine.

4 At the beginning the generation rate of liquid rad
5 waste was about 100 gallons per day. By cutting down pumps
6 seal leakage liquid rad waste has been reduced to 25 gallons
7 per hour from leakage and 35 gallons per hour from sample
8 decontamination. I should say 100 gallons per hour, not per
9 day. I'm sorry -- for a total of 60 gallons per hour.

10 Under those conditions the holdup volume that's
11 presently available is good for 17 to 20 days. The main
12 activity today is the installation of tanks in the spent fuel
13 pool with a capacity of 100,000 gallons and facilities to
14 accommodate tanks.

15 A multitude of schemes are being considered for
16 modification of the chemical cleaning area to eventually
17 process the primary coolant. That's all I have.

18 DR. SHEWMON: The primary coolants you're talking
19 about is also the stuff that goes in your sumps, not neces-
20 sarily inside your primary system.

21 MR. BENEROYA: No, there is quite a bit that was in
22 the sumps. All has been transferred into tanks.

23 DR. SHEWMON: And they will try to lower the volume
24 or condense it, or how will that be taken off site?

25 MR. BENEROYA: They are proposing to make

pmcc 4

1 modifications in the chemical cleaning area, the chemical
2 cleaning section of the plant, where they're going to be de-
3 stroyed eventually.

4 DR. SHEWMON: Does that end up with solid plus pure
5 water eventually?

6 MR. BENEROYA: It depends on the scheme that they
7 select. It might be clean water. It might be solidified at
8 some point. It could be degasified at some point. This is
9 under consideration.

10 DR. SHEWMON: How do they normally do it in an
11 operating plant?

12 MR. BENEROYA: In many plants they use evaporators,
13 taking the overhead, demineralized, particularly in the
14 bottom, solidified in many areas in many cases.

15 DR. MATTSON: Vic, I think you're talking about the
16 cap gun. Isn't that right?

17 MR. BENEROYA: The cap demineralizers. They have
18 been demineralizing also, which is one of the ways of doing it.
19 They have demineralized quite a bit of coolant already.

20 DR. MATTSON: There's a portable cap gun that was in
21 unit 1 that's been running now for, I guess it must be close
22 to two weeks. There is a larger scale, permanent processing
23 facility being built in the auxiliary building of unit 2, I
24 believe, for processing these wastes.

25 MR. BENEROYA: In the chemical cleaning section,

eral Reporters, Inc.

pmcc 5

1 chemical cleaning building.

2 DR. SHEWMON: With this demineralizer you then
3 take normally with the demineralizer on the primary circuit,
4 at least you backflush. You're doing with this one what you
5 normally, obviously don't - you then take demineralizing
6 material out.

7 DR. MATTSON: Some of the tanks have low level waste
8 in them from normal operation. Process that and dispose of
9 it in the normal manner. Then you capacity for higher level
10 waste in those same tanks. The processing of the higher level
11 waste, I think, as Vic said, there's a variety of schemes
12 being discussed, and that kind of activity will be underway
13 soon.

14 DR. SIESS: What's the status of the instrumentation
15 that you need to monitor the present mode of cooling?

16 MR. BENEROYA: The pressurizer has one good level
17 indicator and one so-so. Also they tried to install a gauge
18 as a backup, and that line was being tested, and it didn't
19 come out very well.

20 DR. SIESS: What other instrumentation do you need?

21 DR. MATTSON: Thermocouples and thermocouple
22 readings in the hot leg are things that are especially
23 important as you go forward into natural circulation. Those
24 are thought to be good for the indefinite future because the
25 transmitters' instruments are hardened in the sense of

pmcc 6

1 radiation. They've been performing well. There's no reason
2 to expect those to be lost.

3 DR. SIESS: That'll take you into transition to
4 natural circulation, and after you get in natural circulation,
5 is there any particular instrumentation that you need that you
6 have any concern about?

7 DR. MATTSON: Yes. There's another instrument on
8 the primary system I should mention, which is primary system
9 pressure. A system is being designed-- I think Carl's going
10 to talk about it briefly -- for positive pressure control over
11 the long term as a backup to that instrumentation.

12 DR. SIESS: Do you know where the instruments in
13 site containment are located with respect to water level in
14 unit 1, I guess it is?

15 DR. MATTSON: As Victor said, there's some uncer-
16 tainty as to where the water level is because of the uncertain-
17 ty as to exactly how much water was delivered from the primary
18 system to the containment floor and exactly how much was pumped
19 over into the aux building early in the transient.

20 But the best estimate says that the water level is
21 in the vicinity of the transmitters that have been failing.
22 Now, those transmitters are also non-safety grade transmitters
23 in the sense that they're used for normal operation, not for
24 safety systems, and they would be predicted to have radiation
25 sensitivity at the stage of the accident, in fact, some time

pmcc 7

1 ago. That's why backup level instrumentation was one of the
2 high priorities early on, in the event that level transmitters
3 were lost. The water level is probably over those transmitter
4 locations today.

5 DR. SIESS: The instrument Steve mentioned are
6 separated. Is there any separation vertically?

7 DR. MATTSON: No, maybe a couple inches, but
8 nothing significant. They're in instrument racks in the
9 bottom of the containment.

10 DR. SIESS: You mentioned that those instruments
11 were not safety grade. The reactor coolant pumps aren't safety
12 grade, are they?

13 DR. MATTSON: In the run modes the reactor coolant
14 pumps are fine. In the start mode there's a sensitivity of
15 one element in the starting circuit when we tripped the pump
16 and had to start a second one, and it started without
17 difficulty. And there's reasonable expectation that, if you
18 had to start another one, it would start.

19 DR. SIESS: But they're not safety grade. This is
20 gratuitous.

21 DR. MATTSON: They're safety grade to a certain extent
22 because of their location relative to the primary coolant
23 system during normal operation. So that they're hardened
24 more perhaps than some of these transmitters that are located
25 way outside the outside containment wall outside the shield.

pmcc 8

1 DR. SIESS: The loop system, the electrical systems,
2 are they expected to survive an accident?

3 DR. MATTSON: The design basis accident doesn't
4 establish the requirements because they're not used for it,
5 but they have some margin because of the location.

6 DR. LAWROSKI: What kind of decontamination factors
7 are you getting on your charcoal filter for iodine removal?

8 MR. BENEROYA: I don't know. Roger, do you know?

9 DR. MATTSON: It's not high. Calculations of how
10 much iodine should be in there say that there should be plenty
11 of charcoal left, but there was a moisture problem because of
12 all the water that was in the building, and so for some reason
13 the CFs are not very high. That's why they went back to a
14 backup charcoal system on top of the auxiliary building.

15 It's been a little slow changing out the filters,
16 and we're disappointed that it's taken so long, although we're
17 convinced they're doing everything they can to get them changed.
18 It's probably going to turn out that the backup system is
19 going to be available at about the same time as the changed one.
20 So we'll have a double filter system. But it's taken a few
21 days longer than we had hoped to get it.

22 DR. LAWROSKI: The ones from the WPPPS site were
23 delivered last -- a week ago?

24 DR. MATTSON: There were 26,000 pound filter banks
25 transferred by CSA from the state of Washington. They're still

pmcc 9

1 being installed on the roof of the building.

2 DR. CARBON: Other questions of Mr. Beneroya.

3 (No response.)

4 DR. CARBON: Thank you very much.

5 DR. LAWROSKI: Could I ask one more question? What
6 else is in the primary sites of boric acid at this time? What
7 else is in the water, the primary coolant, besides water?
8 What is the boric acid concentration?

9 MR. BENEROYA: 3400 parts per million.

10 DR. LAWROSKI: Is it boric acid?

11 MR. BENEROYA: Boric acid.

12 DR. LAWROSKI: I didn't know how serious it --

13 MR. BENEROYA: It is still boric acid. Okay.

14 MR. BERLINGER: Gentlemen, I'll be discussing the
15 proposed TMI-2 long term cooling plant. The licensee and B&W have
16 proposed to use natural circulation for long term core cooling
17 for decay heat removal. The proposed plan is known as the
18 base case summary plan and is shown in my first slide. It
19 should be noted that the base case plan involves several
20 preliminary plant maneuvers and plant modifications.

21 (Slide.)

22 The procedure will start at point A, and initially
23 the system will be degassed by lowering the system pressure to
24 point A prime; the degassing procedure from A to A prime is a
25 maneuver which is needed to remove noncondensables from the

pmcc 10 1 primary coolant and also to eliminate any gas bubbles that may
2 be trapped in the control rod mechanisms in the upper part of
3 vessel.

4 This operation from A to A prime has been completed.
5 A prime pressure was ultimately reached at around 300 psi, so
6 it's lower than is shown on this chart. The plant was then
7 brought back up to point A and from point A to point B is a
8 procedure where the reactor coolant system temperature will be
9 reduced to approximately 230 degrees. I say approximately.
10 At the present time this procedure is ongoing, and the mode of
11 operation is to run the A steam generator in a steaming mode,
12 in which the steam through the main steam line bypasses the
13 turbine.

14 You do have one reactor coolant pump running. You
15 are using for pressure and level control normal pressurizer
16 operating mode, and this procedure going from A to B has
17 reached approximately 250 degrees as far as that cool-down is
18 concerned, and at this point I'm not certain how much further
19 towards the 230 degree mark they'll be able to achieve, but
20 this mode is continuing.

21 DR. MATTSON: It's my understanding that the 250
22 seems to be the natural limitation on this mode of operation.
23 They estimate that they can get to 230. It looks like it's
24 going to bottom out at around 250.

25 MR. BERLINGER: Thank you, Roger. In going from

pmcc 11

1 point B to C the plan is to fill the B once through steam
2 generator water solvent. This will be done on a closed cooling
3 secondary system. Also steam generator A will be isolated, and
4 by operating on only the B steam generator, plan to reduce the
5 reactor coolant system temperature to approximately 100
6 degrees.

7 The reduction from 250 to approximately 100 degrees
8 is made possible by going to the water solid mode of operation
9 on the secondary side. During this mode of operation the A
10 steam generator, which will be isolated, will have a
11 modification, a major modification made to the A steam
12 generator, such that a closed cooling loop type of system will
13 be made available for the A steam generator.

14 In addition this mode of operation is preferable
15 because it enables modifications to be made to the A steam
16 generator and the B steam generator allows the water solid
17 operating point to be reached; rather than from a steaming mode,
18 it will be more or less from an isolated mode and eliminates
19 the potential problem of water hammer.

20 Now, by the time we get to mode point C there will
21 have been modifications to both the B steam generator
22 secondary side, the A steam generator secondary side and, as
23 I'll point out later, there will be some other plant modifica-
24 tions which will be complete.

25 At point C this will be the initiating point for going

pmcc 12

1 into the natural circulation mode. The reactor coolant system
2 will be approximately 100 degrees. It will be using normal
3 reactor coolant system pressure control. A and B steam
4 generators will be operating in a water solid mode on the
5 secondary side.

6 The flow on the secondary side from feed pumps will
7 be in the three to 5,000 gallons per minute range, at some-
8 where in the vicinity of slightly below 100 degrees
9 fahrenheit. In initiating natural circulation mode of
10 operation the reactor coolant pumps will be tripped. Once
11 natural circulation has been established, the reactor coolant
12 system will be brought water solid by turning off the heaters
13 in the pressurizer and allowing the system to be brought solid
14 using makeup; while operating in a water solid mode, the primary
15 system will use a new pressure and volume control system which
16 is being planned for installation, and the system pressure
17 will be progressively reduced in steps, slowly maintaining
18 a stable, subcooled margin and operating in the core region.

end #9

pv 1 In addition, I should point out that the
2 modifications that I have mentioned in general are short-term
3 modifications. For long-term mode, there is an additional,
4 more reliable modification which is planned which will permit
5 the secondary side steam generators to be operated at a
6 pressure in excess of the primary system pressure. This will
7 act to reduce any primary to secondary leakage. This
8 high-pressure system will be transferred into operation when it
9 is available. And it also is a closed cooling loop system, and
10 it will operate at approximately 750 psi and provide flow of
11 approximately 5000 gpm.

12 As I have mentioned, in preparation of going into
13 this preferred mode of operation -- "preferred" being defined
14 by the base case operating plant -- the licensee is performing
15 several plant modifications. And I will describe these at this
16 point:

17 These modifications involve the short-term A steam
18 generator modification and the short-term B steam generator
19 modification, the long-term A and B steam generator
20 modifications and modifications to the decay heat removal
21 system, pressure control system. And at the present time there
22 is an evaluation in process or in progress in which they will
23 be evaluating the potential elimination of the short-term B
24 steam generator modification -- and I will explain that
25 shortly.

pv 1 It should be noted that these modifications are in
2 various stages of design and fabrication and installation, and
3 that the ultimate configuration that will exist at the plant
4 when natural-circulation mode is initiated will be dependent on
5 availability and on schedules.

6 The licensee has been advised by B&W that these
7 modifications should be completed prior to plant transition to
8 natural circulation. But, if necessary, in the event that they
9 have to go to natural circulation before they are planning on
10 going to natural circulation, the available systems have been
11 ready, and they are capable of sustaining natural-circulation
12 operation.

13 MR. MICHAELSON: Question: Maybe I missed it, but
14 would you explain again in the short term how you are keeping
15 the overpressure on the primary side?

16 MR. BERLINGER: In the short term?

17 MR. MICHAELSON: Presently, for instance, now are you
18 keeping the overpressure?

19 MR. BERLINGER: The primary side is maintaining a
20 bubble in the pressurizer.

21 MR. MICHAELSON: Okay. Now, as you go on to the
22 natural circulation, how do you intend to maintain the
23 overpressure?

24 MR. BERLINGER: When you go -- before you go into
25 natural circulation -- no, after you go into natural

pv 1 circulation, you will remove the bubble from the pressurizer
2 and run the primary system water-solid.

3 MR. MICHAELSON: The question is, then: How are you
4 keeping an overpressure on the system? Are you going to put a
5 small pump in? Are you using the main charging pumps?

6 MR. BERLINGER: Okay. This is the new pressure and
7 volume control system, which is in design at the present time.
8 I don't know exactly what stage of construction they're in.

9 DR. MATTSON: I don't believe they're in
10 construction. I believe they're in procurement. And the
11 central part of the design was complete several days ago. But
12 it's a makeup pump with surge tanks on the outlet with the
13 nitrogen overpressure to maintain pressure control.

14 MR. BERLINGER: Right. And the surge tank is really
15 a series of surge tanks, the last one of which has the nitrogen
16 bubble on it, nitrogen overpressure.

17 MR. MICHAELSON: Is the system redundant?

18 DR. MATTSON: I don't remember the answer to that
19 question, Carl, but it's a good question.

20 MR. BERLINGER: The system has two positive
21 displacement pumps. In that respect, it's redundant. As far
22 as the other flow paths are concerned, it does hook into the
23 normal makeup system. I will take that back. It does hook
24 into the normal makeup system, but through the pressurizer
25 spray. I don't know if it's redundant; I really don't know.

pv 1 DR. CATTON: As I understand it, there are going to
2 be two loops on the system, as well; isn't there? And if there
3 are, as I understand it, either one of the loops can have the
4 low flow.

5 DR. MATISON: Let's stick with the pressure control
6 just for a minute.

7 Now, the pressure control system is redundant in the
8 active sense; that is, there are two pumps available to do it,
9 and they've been originally designed to work in tandem. The
10 isolation valves would open and all that good stuff. The
11 passive portion of the system, and the degree to which it's
12 redundant, is, I think, what Carl had aimed at. And I don't
13 remember the drawings. To the extent I could say to you, Carl,
14 it was a good question.

15 MR. BERLINGER: We'll check it through.

16 DR. MATISON: I think the other point here was that
17 the two solid secondary systems are redundant, one to the
18 other; and that's true.

19 (Slide.)

20 MR. BERLINGER: Well, let's start over here. Okay.
21 Depicted on this slide is the short-term A steam generator
22 modification. This modification will utilize existing
23 condensate and feedwater systems. From the main steam line,
24 from the steam generator, there will be a bypass system through
25 the condenser makeup line to the condenser. The bypass line

4051.10.5

pv 1 will bypass the turbine. From the hot well in the condensor,
2 it will go through one of three condensate pumps. Now, one
3 pump will be run, and two will be kept in standby. From there
4 back through the — I take that back. These are the heat
5 exchangers, I think. Let me regroup for a second.

6 Okay. From the condensate pump it will go through
7 these pumps, which is a booster pump, and the main feedwater
8 pump. The impellers on these two pumps will be locked in place
9 and then backed up through the main feedwater line for
10 injection via the steam generator.

11 MR. MICHAELSON: Question: Is the main feedwater
12 pump going to be steamdriven, or are you just driving through
13 it?

14 MR. BERLINGER: The main feedwater pump will be not
15 in operation, it will be idle.

16 MR. MICHAELSON: But you will be running the booster?

17 MR. BERLINGER: The booster will not run, either.
18 It's just relying on the condensate pumps.

19 DR. MATTSON: And they will have emergency power?

20 MR. BERLINGER: That's correct. In the event of loss
21 of offsite power, the condensate pumps will have a backup
22 diesel power system, which is, I think, a 2-1/2 megawatt
23 diesel, which will provide power in the event of loss of
24 offsite power.

25 On the service water system, which is used to cool

pv 1 the condensor, we're going to be using the normal cooling
2 system. But in the event of loss of offsite power, there will
3 be available from a river water source, again, diesel power, an
4 additional source, to take over in the event of loss of offsite
5 power.

6 MR. MICHAELSON: On that slide, is the new line you
7 show up at the top of the condensor going to the spray towers
8 on the condensor? I assume this condensor probably has a spray
9 tower at the top.

10 MR. BERLINGER: I really don't know the answer to
11 that question.

12 DR. MATISON: I should, because I heard it discussed
13 the other night.

14 The point of the question is relative to the
15 location. The point of delivery is, one, to bypass the
16 turbine, and, two, to put it at the point where you know that
17 the condensor can stand the added load of the solid secondary
18 system. That's been looked at, and that's the reason.

19 But where it goes, I just can't remember at the
20 moment exactly which location it goes to. I heard that
21 discussed the other night.

22 MR. MICHAELSON: So how much elevation water do you
23 have in the condensor?

24 DR. MATISON: If I could answer that question, I
25 could answer your first one.

pv 1 But it was chosen on the basis of the elevation being
2 an elevation, and they were certain that would not cause any
3 damage to the tubes in the condensor.

4 MR. MICHAELSON: Okay.

5 DR. MATTSON: And there was some discussion of that
6 because one entry point was evidently at a place where they
7 thought there might be potential for that. Another entry point
8 was at a place where there wasn't potential for that. I don't
9 know which two they were talking about, but they chose the
10 lower one.

11 MR. BERLINGER: Any other questions up to this point?

12 (No response.)

13 (Slide.)

14 MR. BERLINGER: This slide depicts the short-term B
15 steam generator modification. Up to this point there is a
16 suspicion that the B steam generator may be leaking; and,
17 therefore, the licensee and B&W have proposed to use a
18 closed-cycle cooling system to contain any contaminants that
19 might have leaked into or would continue to leak into the
20 secondary system.

21 This modification will utilize existing closed
22 cooling system heat exchangers and pumps. These are
23 cross-connected from the main steam line upstream of the
24 turbine into the feedwater line, downstream up the feedwater
25 pump.

pv 1 In the event of loss of offsite power, diesel power,
2 again, is available through the closed cooling pumps. And this
3 will be as a backup in case there is a loss of offsite power.
4 The water in this system will be demineralized water, and a new
5 mixed-bed demineralizer will be installed.

6 MR. MICHAELSON: Where are the pumps and heat
7 exchangers located?

8 DR. MATTSON: The basement of the turbine building.

9 MR. BERLINGER: That is right.

10 MR. MICHAELSON: Is that right?

11 MR. BERLINGER: Yes.

12 DR. MATTSON: This might be a good slide, rather than
13 going to the next one, to talk about the point that's in
14 controversy at the moment, not in the sense of antagonistic,
15 but in the sense of planning.

16 The closed cooling heat exchangers are 150 degree
17 Fahrenheit design. The manufacturer stated that they're good
18 to 200 without leaking, but they're nonwelded tubes.

19 MR. BERLINGER: Pressed fitting in the tube sheet,
20 yes.

21 DR. MATTSON: So, we initially had a concern that
22 that wasn't a high-quality system in the sense of secondary to
23 tertiary leakage, if you will. About the same time we raised
24 that concern several days ago, they found some heat exchangers
25 and some pumps at the WPPPS site, same place they got the

pv 1 filters, which are good enough for the long-term modification
2 which he's about to describe.

3 So, the question is now whether you can actually
4 achieve the long-term modification of the secondary side steam
5 generator B at the same time you could have achieved the
6 short-term modification and at the same time get a better heat
7 exchanger and better pumps. They're good for 750 pounds. The
8 next one is much better.

9 MR. BERLINGER: Let me point out, Roger, that one of
10 the reasons they're able to get this equipment more readily
11 available, as opposed to the short-term modification, is that
12 this system could be skid-mounted, and it is very much similar
13 to the skid-mounted system that's being developed for the decay
14 heat removal system.

15 DR. MATTSON: That's another alternative also. The
16 point being that the critical path in the construction of this
17 modification is the welding of piping, not the placement and
18 the installation of the heat exchanger at the pump. So it's
19 quite likely they'll make a decision to do the long term and do
20 it in the same time frame that they were originally going to do
21 the short term. That isn't on the critical path yet, as we
22 say. It could take a little time. I would expect it in the
23 next day or so.

24 But the piping layout, the piping procurement, the
25 piping installation is proceeding on the assumption if you put

pv 1 it in the same place it requires the same piping. The pump and
2 the heat exchanger have actually been procured and were
3 supposed to arrive at the site Wednesday.

4 MR. MICHAELSON: Would you care to comment a little
5 bit now on what would happen if you, for instance, had a tube
6 rupture in the steam generator in this situation?

7 DR. MATTISON: That's why it's attractive to go to the
8 high pressure, because then the leakage would be inward instead
9 of outward; and the design that they're proposing is an
10 alternate to the short term. It's a preferable design, there's
11 no question about it.

12 MR. MICHAELSON: But apparently, you can't go to high
13 pressure with these heat exchangers and pumps.

14 DR. MATTISON: These particular heat exchangers, no.
15 With the long-term modifications to both A and B, you can go to
16 high pressure, and that was expected to take on the order of
17 four to five days until this novel concept dawned on people
18 about Friday of last week.

19 MR. MICHAELSON: This is a short-term question.

20 DR. MATTISON: Well, A steam generator is a pretty
21 good steam generator, the way it looks. B may not be as bad as
22 we originally thought. It was in operation for three months.
23 And A looks like it's holding up pretty good at this point.
24 There's no sign that there's increasing leakage there.

25 I think it's more of a plant contamination problem

pv 1 than an offsite-dose problem. If you make calculations, what
2 if you start to get leakage and what if you went to the B steam
3 generator in its current status for steaming, the signs are
4 pretty positive. It looks like, as far as onsite is concerned,
5 that it's not a problem. It would be a problem onsite in the
6 sense of contamination at some low level, certainly, of the
7 turbine building and the condensor. It could, you know, just
8 exacerbate the eventual cleanup problem. We're trying hard to
9 avoid that.

10 (Slide.)

11 MR. BERLINGER: I would like to point out that, as
12 noted on a previous slide and on this one, provision is being
13 made to hook up the long-term cooling system, which will be a
14 high-pressure system. And that system will look something like
15 this.

16 (Slide.)

17 Again, you come into the system as shown on the
18 previous slide. You go through two new heat exchangers, which
19 are welded heat exchangers; they're high pressure. There will
20 be parallel trains. They will be cross-connected, as noted
21 here. The encircled items would not be required if only one
22 steam generator is required for cooldown.

23 DR. MATTISON That was the point we were just talking
24 about a minute ago. I think we're about to come together on a
25 conclusion that the two steam generators, solid, are redundant

pv 1 of one another; hence there is no need to make the secondary
2 cooling system here redundant. So, the box would be removed in
3 the sense that it's not needed for long-term cooling, and in
4 the sense that it cuts down the construction process to get
5 this whole thing finished by quite a lot.

6 MR. ETHERINGTON: Would it be connected alternatively
7 to both steam generators?

8 MR. BERLINGER: Yes. This system would be hooked up
9 to both A and B steam generator.

10 DR. MATTSON: One such system for each of A and B.

11 What I was talking about a few minutes ago is that
12 that one such system for B is in the air on its way to the site
13 now. It will probably be installed first on B, rather than
14 short term, if the schedules and the constructors and the
15 people who have to worry about getting construction people in
16 there and what have you can agree that the two, in fact, can be
17 delivered on the same time frame. There is a need to get on
end#10 18 with the secondary cooling system, and time is of the essence.
19
20
21
22
23
24
25

1 MR. BERLINGER: Okay. As I mentioned earlier, the
2 decay heat removal system is also going through modification.
3 This is being done in two stages, with a third stage to follow.
4 The first two stages are ongoing simultaneously. They consist
5 of taking a look at the decay heat removal system that exists
6 in the plant, running preoperational tests, and if any leakage
7 is determined to exist, to seal the heat as best as can be done.
8 And if that means welding flanges together, that's the way it'll
9 be done.

10 In addition, pump vibration monitoring instrumentation
11 is going to be installed. And at the present time, there is
12 an evaluation ongoing of both the valve and pump seals to
13 determine their radiation resistance.

14 There is also a new decay heat removal system which
15 is being designed and installed. This system will tie into the
16 DHR drop line and the two cold-leg injection lines. It will
17 use skid-mounted pumps and coolers, which will be mounted
18 outside the auxiliary building at ground level.

19 The secondary side of the new decay heat removal
20 system will be a closed cooling system. The new heat exchangers
21 and pumps will be connected to new decay heat service water
22 cooler systems, which are in turn connected through to the
23 tertiary ultimate heat sink, which would be river water, which
24 is river water cooling heat exchangers.

25 In addition, there is what I call a long-term decay

1 heat removal modification, which is really part of the cleanup
2 system which is being developed at site, and this is going to
3 be mounted somewhat underground alongside the auxiliary building
4 foundation. As I mentioned, it's primarily for decontamination
5 purposes later on.

6 DR. CARBON: Let me interrupt just a moment and
7 remind the staff and guests that if you have cars parked in
8 this building, they have to be removed from the garage by
9 7:00 p.m. or I think you don't get them back until tomorrow.
10 Is that correct?

11 (Laughter.)

12 DR. CARBON: If you do have them in this building,
13 get them out by 7:00 o'clock. Go ahead.

14 MR. BERLINGER: That's assuming the meeting ends
15 before tomorrow morning.

16 DR. CARBON: Which it may or may not.

17 MR. BERLINGER: I'm finished with this portion of my
18 presentation.

19 MR. MICHAELSON: I thought that was the case.

20 In considering the present DHR system, that type of
21 pump that is normally used in this system uses centrifugal
22 separators for seal-water cooling, very often, at least. In
23 this particular plant, are they using the so-called cyclone
24 separators for seal-water cooling off the discharge pumps?

25 Let me just say, you may not know. The only point

1 here: that those, cyclone separators have throat diameters of
2 about an eighth of an inch and they're very easily clogged
3 with particles circulating in the system, and you want to be
4 real careful, because if you use the cyclone separator the seals
5 go very fast.

6 DR. MATTSON: Carl, are you referring to the
7 Westinghouse?

8 MR. MICHAELSON: I'm referring to the present DHR
9 system already installed in the plant, which I understand they
10 may consider using.

11 DR. MATTSON: Westinghouse is putting in an identical
12 system which uses skid equipment.

13 MR. MICHAELSON: I might add that the Westinghouse
14 system is also using centrifugal separators.

15 DR. MATTSON: They're not Westinghouse pumps; they're
16 B&W pumps. Let me turn to the B&W people.

17 Jim, do you know the specifics of the design?

18 MR. TAYLOR: They have centrifugal separators.

19 MR. MICHAELSON: Yes, but you've got to be careful.
20 You can't put it in that little bypass circuit for the seal
21 coolant, because you'll clog up the filters in a hurry, unless
22 you put a very large one somehow in such a very small circuit.
23 It's a very small bypass flow, about a gallon a minute, more or
24 less, and it clogs very easily because of the very small throat
25 in the centrifugal separator.

1 DR. MATTSON: I understand your point, Carl. The
2 preferred mode of operation doesn't involve this decay heat
3 removal system. This is sort of a tertiary backup, if you
4 will. Several steam generators, plus the ability to inject
5 high-pressure coolant. In the preferred mode of operation of
6 this system, you'd be drawing from the hot leg of the reactor,
7 and chances are pretty good, I think, that you wouldn't be
8 drawing crud at that location, especially since, from the
9 samples that have been taken, you don't find crud. So the
10 chances are pretty good that, operating with the decay heat
11 removal system, drawing from the hot leg where it normally
12 operates, the system would work.

13 I think it might be more of a concern if you were
14 drawing from the sump.

15 MR. MICHAELSON: Generally, I think that the systems
16 draw off the bottom of the hot leg. I don't know in this
17 particular case. If it does, you've already got a beautiful
18 crud trap that might be full of crud before you ever get started.

19 So just a precaution. If you're going to go that way,
20 keep it in mind.

21 DR. MATTSON: It's been in mind for a couple of weeks.

22 MR. BERLINGER: At this point, I'd like to give you an
23 idea of the ongoing staff review of the proposed natural circu-
24 lation mode of operation. We are reviewing presently informa-
25 tion which has been provided by B&W. We have been in contact

1 more or less constantly with the licensee. We have people at
2 the national labs who are performing calculations for us, as
3 well as consultants.

4 The situation, as you are well aware, is a rapidly
5 developing and changing situation from the standpoint of which
6 configuration we're going to end up in when we do go to natural
7 circulation. The NRC has identified issues in the proposed
8 plans and these will be required to be resolved before we go
9 into natural circulation.

10 DR. OKRENT: Unless you lose your pumps.

11 MR. BERLINGER: That is correct.

12 DR. MATTSON: The issues have to do with some nuance
13 and a difference between emergency procedures going into
14 natural circulation and let's call them more conservative
15 procedures for going in intentionally, and things have to do
16 with what are the proper indicators that natural circulation
17 has been achieved and you stay with natural circulation, as
18 opposed to trying to return to the present mode.

19 MR. BERLINGER: At the present time, we are preparing
20 a report. The report will include these general topics: The
21 description of the core will be characterized; an evaluation
22 of core flow resistance on the basis of both in-house and
23 out-of-house calculations; an evaluation of natural circulation
24 with one or two steam generators in operation, with either of
25 them both solid or both steaming. Core coolability will be

1 discussed in the natural circulation mode. Effects of bubbles
2 on core cooling and natural circulation operation; review of
3 base case summary plans, as I have described here. This is
4 being reviewed in great detail, not only in Bethesda, but also
5 at the site.

6 In addition, it will be an evaluation of alternatives
7 and contingency plans. As an example of alternatives, looking
8 at the use of the A generator steaming with the B isolated;
9 the B solid, A isolated; A and B both steaming; and other
10 combinations similar to that.

11 We're also looking at contingency plans from the
12 point of view of what-if's, that type of question: What if we
13 lost the pressurizer level or we lost off-site power, or we
14 lost natural circulation cooling once it had been established?
15 We're looking at fall-back positions as to whether or not the
16 licensee or B&W has considered all alternatives, and we are
17 trying to understand how they've made their recommendations and
18 make sure they've considered what we feel is an all-inclusive
19 potential problem.

20 We also will address in the safety evaluation the
21 acceptance criteria for establishing natural circulation, the
22 control of primary system pressure and level, and water chemistry,
23 the potential for boron dilution and recriticality, and radio-
24 logical consequences such as leakage, off-gas and others of
25 that nature.

1 Any questions?

2 DR. CARBON: Dave?

3 DR. OKRENT: How many curies are in the containment
4 atmosphere now, approximately?

5 MR. BERLINGER: If anyone here has that number, it
6 would be Mr. Beneroya. The number of curies in the contain-
7 ment?

8 DR. OKRENT: About.

9 DR. MATTSON: A lot.

10 (Laughter.)

11 DR. MATTSON: We'll get the answer, Dr. Okrent. I'm
12 sorry.

13 DR. OKRENT: A lot is sufficient.

14 Now, you've been thinking about different ways of
15 keeping the core cool over the long term, which you properly
16 should. And obviously you're very interested in keeping this
17 radioactivity in this containment. And, if I understand cor-
18 rectly, you're maintaining the negative pressure valve and
19 so forth.

20 Have you developed anomalous possible situations
21 that might require you to change what you're currently doing
22 with regard to the containment? Have you tried to anticipate
23 what events, if any, would lead you to some changed mode of
24 doing what you're currently doing with the containment and so
25 forth and so on?

1 DR. MATTSON: Carl, I think I'd like to ³⁰⁹ answer the
2 question.

3 MR. BERLINGER: I defer.

4 DR. MATTSON: The question of whether steps ought to
5 be taken to alter the configuration of the containment is one
6 that's been in the back of people's minds since early after
7 the initial accident. It's our judgment at this time -- and
8 we've looked at some ways of doing that, primarily at Sandia
9 Laboratories -- it's our judgment that we have time available
10 today, given indicators that we could watch for or are watching
11 for, that if the multiple ways now available to cool this core
12 for long-term should somehow become unavailable, we still have
13 time to consider such modifications. And it's our judgment
14 that, although the probability of a core melt in this plant
15 which has seen this accident is higher than in a new plant, a
16 healthy plant that hasn't seen this accident, the consequences
17 of such a core melt, given the amount of decay that has occurred
18 in the core, are limited. They cannot be as extreme as they
19 could be for core melts in a different plant starting from some
20 other initiating event.

21 Furthermore, it's our judgment that the core melt
22 process itself would take on the order of days, and that the
23 potential for hurting the containment would be something that
24 would take several days. So, given the amount of time that
25 we're convinced we have available, using the backup cooling

1 systems to natural circulation -- first of all, we're convinced
2 natural circulation is going to work. We're convinced we've
3 got margin. But in the event we didn't, there are backups to
4 that. There's high-pressure injection, borated water, storage
5 tanks. There's low-pressure injection from the same point.
6 There's high-pressure recirculation, piggybacking off the decay
7 heat removal system. There's low-pressure recirculation from
8 the decay heat removal system.

9 There will be available, within a very few more days,
10 three trains of decay heat removal systems. You only need one
11 at a time.

12 So that, in the very unlikely event that there would
13 appear negative indicators, at this point in time we believe
14 there is still time to take steps, if warranted, to modify the
15 containment.

16 DR. OKRENT: Actually, you're answering a different
17 question. But nevertheless, I think your answer is reassuring
18 with regard to the question you answered, that you think you
19 have time in that regard.

20 But I was wondering in regard to the activity that's
21 already there, you've tried to think through whether there are
22 any situations that could change what is now a very favorable
23 situation where you have inflow, if I understand correctly, and
24 negative pressure, just to assure yourself that some modified
25 situation couldn't arise out of whatever it is, I don't know,

1 an electrical short or the combination of electrical short with
2 something else, or whatever. So that you have given it the
3 same kind of thorough thinking that I'm hearing is being given
4 to different modes of removing decay heat.

5 MR. BERLINGER: I think it was mentioned earlier
6 this afternoon at the site, we do have a team of NRR NRC
7 people who are removing emergency procedures and contingency
8 plans. These are being very thoroughly developed to handle
9 potential failures that might occur at the facility which
10 would degrade the present operating mode.

11 Included in these are alternatives to getting the
12 plant to a safe shutdown condition, cold shutdown.

13 DR. MATTSON: Carl, I think maybe if I missed the
14 question, you just missed the question, too. The question is,
15 what if you lose the containment penetration seal or something
16 like that.

17 Two things I know have gone on. If you've got sug-
18 gestions, maybe there are more that could go on. But two that
19 I know of is that the question of the potential for shorts in
20 electrical penetrations, leading then to a failure of the
21 electrical penetration, hence a breaching of containment --
22 that's been examined, was examined days ago. And with the
23 equipment that's operating and with the qualifications and
24 penetrations that are there, it doesn't look like a problem.

There was also a question over a week ago as to the

1 status of the containment isolation signals: Were bypasses
2 placed on any of those containment isolation signals? Were
3 any of the valves that didn't need to be armed in fact armed,
4 so that they could be opened inadvertently? A very thorough
5 review was conducted of all containment penetrations, one here
6 in Bethesda, one at the site, one by the licensee at the site,
7 and an independent one by the NRC at the site. And I believe
8 the industry advisory group even got a set of drawings and
9 went through that themselves. It was a couple days of hurried
10 activity on that some time ago.

11 That also was verified as being in an okay condition,
12 a credit to the operator. They had already considered it taken
13 care of.

14 A third thing that has gone on in this general area
15 is that the licensee has been urging the installation of a
16 method of measuring the water level in the sump, for several
17 reasons. One, to get a better fix on the location of that
18 water level relative to the instruments, the idea being that if
19 it's very close, it might be possible to drain off a small
20 amount of it and store it in tankage that's now being installed,
21 tankage that's still available, and remove that source of
22 instrumentation failure, if it is one.

23 Another thought being to get these high-level liquid
24 wastes inside of containment under control soon, and an idea
25 of what precisely the level is is a first step to doing that.

1 There are some difficulties with proceeding with
2 those things. One difficulty is that to take such a measure-
3 ment, you have to open a valve inside containment. If you open
4 a valve, then you have to answer the question, are you sure
5 you can close it. That's being very carefully reviewed, with
6 some backup provisions for backflush and that kind of thing.

7 Other than those three, I don't believe that --
8 nothing, to my knowledge, more has gone on for the event in
9 which you lose the containment, which has performed magnifi-
10 cently in this event, other than the isolation difficulty early
11 in the event.

e-11

12

13

14

15

16

17

18

19

20

21

22

23

24

eral Reporters, Inc.

25

1 We know that the leakage from containment -- none can be found.
2 There was some worry earlier but it turned out to be water that
3 spilled over from the Aux Building, upper Aux Building. The
4 galleries are dry and there's no source of leakage that I know
5 of.

6 DR. LAWROSKI: Are you going to be obliged to remove
7 the filters, the charcoal filters?

8 DR. MATTSON: Everybody's gotten a little out of his
9 league today at one time or another. I'm afraid that's a
10 question I can't answer, Steve. That's not my field. I don't
11 know if we've got people here who can.

12 DR. LAWROSKI: Have you thought about removing cryo-
13 genically the charcoal for the noble gases?

14 DR. MATTSON: It's a good question. I can't answer it.
15 It's something that ought to be factored in. I do know that at
16 additional management structure for waste management, as we move
17 now from the more urgent times to looking forward to the long-
18 term cleanup of TMI-2 a new management structure was supposed to
19 have been in place there today with just that kind of focus. So
20 perhaps those kinds of ideas are best handled there. I'll see
21 that yours is factored in.

22 MR. ETHERINGTON: Roger, how soon will it be before
23 you can stop cooling altogether and just let it sit?

24 DR. MATTSON: There are varying estimates. Certainly,
25 such a time does occur and 60 to 100 days, depending on who you

1 talk to and his state of optimism. Stop cooling in the sense
2 that it's just a swimming pool.

3 MR. ETHERINGTON: Just letting it go through the
4 insulation in the building.

5 DR. MATTSON: That time is shorter if you conceive
6 of flooding the containment which is also a backup in some of
7 these far out scenarios -- flooding at least to a certain level.

8 MR. ETHERINGTON: Can it stand the pressure?

9 DR. MATTSON: That's being looked at by people who are
10 proponents of that particular scenario for the long term, if
11 you got into difficulty.

12 DR. CARBON: Are there other questions?

13 (No response.)

14 DR. CARBON: We thank you.

15 (Brief recess.)

16 (Executive Session.)

17 DR. CARBON: Let's continue in Executive Session at
18 this time.

19 Open executive session.

20 I think perhaps the best thing we can do at the moment
21 is to try and lay some plans for the remainder of our meeting.

22 And the logical, I guess, obvious question that comes up is, Do
23 we want to prepare a letter at this meeting, and if so, what
24 general topics do we want to put in it. We, of course, did
25 write a letter I guess about a week ago -- 10 days ago --and we

1 will meeting again three weeks from now. I'd like to get ex-
2 pressions of opinion from you as to whether we should prepare
3 a letter tomorrow morning specifically.

4 DR. PLESSET: We are having a subcommittee meeting
5 next week, is that correct?

6 DR. CARBON: Yes. The current plans that have been
7 laid out with respect to continued activities in this general
8 vien are, of course, our meeting today and tomorrow. Then we
9 have a subcommittee set up which will meet a week from today and
10 a week from tomorrow -- a two day meeting. Depending on whether
11 we get airline reservations, maybe no one will be there

12 I'll go back and say that we're trying to set up a
13 meeting here in Washington a week from today and a week from
14 tomorrow with the subcommittee of Mssrs. Okrent, Plesset, Siess,
15 Mark, Michaelson, and myself. Mr. Michaelson is a consultant
16 and the intention is that this will be a discussion session. We
17 do not plan any presentations by any group, but rather a discus-
18 sion of the implication of what's been going on -- the inter-
19 mediate and longer term kinds of things. That's in answer to
20 Dr. Plesset's question.

21 Part of the purpose of that meeting a week from today
22 will be to lay out longer term plans to serve as sort of a
23 screening steering committee, make plans to bring to the full
24 committee for activities continuing on down the road.

25 MR. FRALEY: You mentioned that is going to be here

1 in Washington. We announced it originally in Los Angeles but
2 we're trying to change it to Washington

3 DR. CARBON: At the moment, I think no one has --

4 DR. SIESS: If you can get to Denver, you can get to
5 Los Angeles.

6 DR. OKRENT: I have no trouble getting to Los Angeles.

7 (Laughter.)

8 DR. PLESSET: If nobody else is going to say a word,
9 I would say that at the moment I think the letter that we
10 already sent to the commissioners seems better and better, at
11 least to me, as time goes on. I don't know whether we should
12 really try to write another letter at this time or wait until
13 after the next subcommittee meeting, to see what the full commit-
14 tee would like to do on the basis of that.

15 However, I would defer to more knowledgeable people;
16 that was my view. I like that letter now very much -- better
17 and better.

18 (Laughter.)

19 DR. CARBON: Dave?

20 DR. OKRENT: I'm not sure whether I know how to answer
21 your question without having some discussion about things like
22 the following: Are there specific measures related to the B&W
23 plants that the commissioners would like to have comments on?

24 If we can decide that there are none of these that would need to
25 -- one possible inclusion if we would decide that there are some

1 -- might lead the other way, as an example.

2 DR. SIESS: Can you remind me what the staff was sup-
3 posed to have a position on, by midnight tomorrow night?

4 Darrel Eisenhut was going to have something done by
5 midnight tomorrow night.

6 MR. FRALEY: I thought he said the rest of the answers
7 went in by midnight tomorrow. Wasn't that it, to the remaining
8 questions that I&E posed?

9 DR. MATTSON: Yes. And then I think they said that
10 the review would be complete by Friday.

11 DR. CARBON: I think in answer to Chet's question, a
12 week ago Darrel had indicated that the responses to 0509A were
13 due in last Thursday or thereabouts. And by tomorrow night,
14 midnight of the 17th, you pretty much have your position on
15 things that you're recommending in response to the words that
16 came in.

17 DR. MATTSON: So Mr. Vargo's presentation this morning
18 represents somewhat of a slip from what Mr. Eisenhut estimated.
19 I would hope the summary you heard this morning would suffice
20 for the general nature of what we're receiving so that we can
21 keep pushing to get the thing done by Friday, or sooner if that's
22 possible.

23 DR. SIESS: Well, the point is that one thing this
24 committee does is to give the commission advise relating to
25 positions the staff has taken. We also give them advise where

1 the staff has not yet taken positions. But it appears that the
2 staff will have no formal or new position regarding other B&W
3 plants or other PWRs, other than what has been put out in the
4 I&E Bulletins so far.

5 But we have seen I&E Bulletins related to other PWRs
6 since last week. And the staff has no formal position yet on
7 the procedures for going to natural circulation other than the
8 earlier things we've heard. It's still under review.

9 DR. MATTSON: Which natural circulation -- the one at
10 Three Mile?

11 DR. SIESS: At Three Mile. I think the two immediate questions
12 are operation of other plants, and what's being done at Three Mile. We've
13 heard all you know about that and what you plan to do?

14 DR. MATTSON: Right.

15 DR. SIESS: And you're still reviewing and approving?

16 DR. MATTSON: Yes, sir.

17 DR. CARBON: Dave?

18 DR. OKRENT: One of the items in IE Bulletin 79-05A
19 related to the review of any transients similar to the
20 Davis-Besse event. Any others which contain similar elements --
21 I guess that's what's called Item 2.

22 I must confess I had thought that sometime during
23 today either from the staff or from B&W, we might have had some
24 detailed discussion as to what the input of these events was,
25 and so forth. Not that the time wasn't spent very interestingly

1 but somehow we didn't get to that area. It's, I guess, not
2 inconceivable to me that we might still hear from one or both
3 of those groups before tomorrow noon, in this area, that might
4 or might not provide a basis for some committee thinking. So
5 there's, at least to me, an example of one of the things that
6 we didn't do, and there might be others of this sort that at
7 least we might reflect on.

8 DR. SIESS: Could we ask the staff to what extent they
9 reviewed the utilities' submittals on that item?

10 DR. MATTSON: I think Mr. Vargo summarized that this
11 morning, saying that he didn't think that the staff was going
12 to find in the OSA responses, any startling type transients
13 that they weren't already aware of and in the process of evalu-
14 ating under the program that Mr. Tedesco is responsible for. I
15 thought he indicated this morning that he is not at a point yet
16 where he can draw conclusions from looking at those transients.

17 Clearly he would be at a point by the end of the month
18 to report. It might be, that meeting with him again tomorrow
19 might be counterproductive to generating that information. It
20 might also be a few days down the road. It wouldn't be counter-
21 productive in the sense that after he's had a chance to look at
22 it a little more and his people have, it would be a good oppor-
23 tunity to have an exchange with this committee or some subcommit-
24 tee and let him say what he's learning and what his thoughts are,
25 so that you can have input to that process before it's finished.

1 I'm certainly not reluctant to do that. I think if
2 we bring him down here again tomorrow morning, he's not going to
3 be in a position to say anything much different than he said
4 this morning on the same subject.

5 DR. PLESSET: We didn't have a meeting scheduled with
6 the commissioners tomorrow?

7 DR. CARBON: Yes, we do -- unless it's impossible for
8 us to get together at the agreed upon time. But yes, we have a
9 meeting scheduled.

10 DR. SHEWMON: What time is it scheduled for?

11 DR. CARBON: The end of the afternoon. We had had it
12 scheduled for 2:30 to 3:30. They wanted to postpone it until
13 3:30 to 4:30, and that won't work for us. Currently, we're try-
14 ing to see if it can be 3 to 4.

15 DR. OKRENT: Well, if I can pursue it a little bit,
16 Dr. Mattson, there was this memorandum dated February 28th from
17 Mosley to Thompson, concerning notification of licensing boards
18 which referred to an event where pressurizing levels went off
19 scale and thus and so, forty comments by J.S. Creswell and
20 Streeter. I don't think we've ever had the opportunity of
21 getting comments from the staff about this and whether it bares
22 the general question of behavior of these reactors in transients.

23 DR. MATTSON: That's what I'm saying. That's what
24 Tedesco is doing, and that's what his report is going to be.
25 To the extent, he could summarize it today and answer your ques-

1 tions, he did. The particular memo you referred to had several
2 features in it.

3 One had to do with the level indicator, which is some-
4 thing that Steve Hanauer addressed this afternoon. I think we
5 do know much more about that subject today than we did at the
6 time of the Board notification. There are other elements in that
7 memorandum dealing with the transient behavior for the B&W
8 reactor, which are being studied in a way that Tedesco described
9 this morning.

10 I guess I don't understand your point.

11 DR. OKRENT: I guess -- I had assumed that there had
12 been staff review of this transient, and actually the previous
13 one.

14 DR. MATTSON: Staff review of the Davis-Besse tran-
15 sient? Yes there was, and I believe a report to the committee.

16 DR. OKRENT: That may be, but in fact I can't recall.

17 DR. SIESS: We were concerned about how hot it got in
18 the pressurizer.

19 DR. MATTSON: That was a year ago or more. It sticks
20 in my mind as about that time frame.

21 DR. OKRENT: While I was away -- I'm probably asking
22 about something that everyone else is familiar with.

23 DR. MATTSON: Is what you're looking for is a review
24 of the Davis-Besse transient, as to what happened, and what was
25 looked at, and why it was safe to go on after that transient?

1 That was done.

2 A review of the Davis-Besse transient, in light of the
3 Three Mile Island event isn't complete. That's what Tedesco is
4 doing now in the course of looking at all those other transients,
5 in light of the Three Mile Island event. That isn't done yet.

6 DR. OKRENT: Okay.

7 DR. MATTSON: If it's the former, we can certainly
8 get you a copy of it. And the latter, what I said earlier
9 applies.

10 DR. CARBON: Does that finish your comment, Dave?

11 DR. OKRENT: For the moment.

12 MR. CASE: I think it's fair to say you know every-
13 thing we know, and that you know everything we're doing. Unless
14 we work some more, we can't tell you.

15 MR. ETHERINGTON: Could I ask, is the pressurizer
16 spray designed to take care of the rate of rise that we infer
17 from the measurements taken up at the pressurizer level?

18 DR. MATTSON: Let's see, is the pressurizer spray --

19 MR. ETHERINGTON: As the level rises, there's adiabatic
20 compression of the steam and the steam will go on to superheat,
21 except the spray is supposed to cool it. Is the spray able to
22 take care of that rate?

23 DR. MATTSON: I don't know the answer to that question,
24 but that would be sort of a normal thing for the spray capability.

25 MR. ETHERINGTON: Was the rate of rise observed

1 greater than the design rate?

2 DR. MATTSON: I don't know, Mr. Etherington.

3 MR. MAC MILLAN: What was the accident that was invol-
4 ved here, Harold?

5 MR. ETHERINGTON: That will cause an increase in the
6 steam temperature.

7 MR. MAC MILLAN: Right.

8 MR. ETHERINGTON: Does the pressurizer spray take care
9 of the rate that you observed, the rate and the magnitude.

10 MR. MAC MILLAN: In the early phases of the transient,
11 there's a rapid rise in pressure.

12 MR. ETHERINGTON: Rapid and big-wise.

13 MR. MAC MILLAN: It's not competent to handle that.
14 That's why the electromagnetic relief valve was opened. Even
15 with the electromagnetic relief valve open, the pressure con-
16 tinued to rise until the reactor scrammed -- the reactor shut
17 down. That turned the pressure off and brought it back down.
18 The spray is not capable of handling that rapid an increase in
19 pressure.

20 MR. ETHERINGTON: But the electromagnetic valve is
21 capable of limiting the temperature rise. Obviously, it is.

22 MR. MAC MILLAN: In this transient, the relief valve
23 opened. But with the reactor still running, it could not turn
24 around the pressure, and the pressure did not turn around until
25 after the reactor scrammed. Then in a combination of a

1 scrambling reactor and with an electromagnetic valve open, it
2 turned the pressure around, and the code safety valves did not
3 relieve this.

end 12

4 MR. ETHERINGTON: Thank you.
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 DR. MATTSON: Now that I understand the question, I
2 agree with the answer.

3 DR. CARBON: Roger, were there a couple of cases prior
4 to the accident that we're discussing where they had a pressur-
5 izer level, indications that it went off the scale?

6 DR. MATTSON: Well, the question of a pressurizer-
7 level indication has been something of recent concern within the
8 staff and the nature of the concern was the kind of thing that
9 Steve Hanauer was explaining with his three slides up there
10 earlier this afternoon. To some extent I think that concern has
11 been resolved by some pretty intensive looking post-Three Mile
12 Island. Whether it's really resolved -- I guess I haven't been
13 tapped in that closely to that element over the last couple of
14 weeks.

15 The question is raised in the board notification, the
16 question that was raised by the internal memorandum in the reac-
17 tor systems branch, to the extent are those fully resolved? The
18 work that Hanauer has done, it's not completed at this point.

19 MR. FRALEY: Roger, I understood there were two inci-
20 dents where the pressurizer level, you know, went to zero during
21 transience when relief valves opened and perhaps failed to close.
22 I'm not too sure on that latter. And there was some concern
23 that the bubble from the pressurizer got out into the primary
24 cooling system, but calculations indicate that it did not.

25 I understand that this happened twice at Three Mile

1 Island. I think it was Unit 2, but it might have been Unit 1.
2 Do you have any information on that?

3 DR. MATTSON: You're over my head again. Unfortunate-
4 ly, a lot of my people have gone.

5 MR. FRALEY: I was told it happened at Three Mile Island, also.

6 DR. MATTSON: You're talking about something I haven't heard
7 mentioned.

8 DR. PLESSET: What difference does it make? Unless it's non-
9 condensible you wouldn't care if it got out into the primary.

10 MR. FRALEY: Most of the hydrogen that's in the primary
11 coolant system is up in the steam space of the pressurizer.

12 DR. PLESSET: Now you're talking about the accident.

13 MR. FRALEY: I'm talking about other accidents where
14 the pressurizer level was lost and there was concern, you know,
15 that the bubble from the pressurizer got out into the system.
16 Part of that is steam but part of it is hydrogen.

17 DR. PLESSET: Should they have significant hydrogen in
18 the steam generator bubble?

19 MR. FRALEY: I believe they had quite a bit. I'm not
20 sure how much.

21 DR. PLESSET: Do you know about that -- a gas like
22 hydrogen in the steam generator?

23 MR. MAC MILLAN: I'm sorry, I didn't hear the question.

24 DR. PLESSET: It's been suggested that there's hydro-
25 gen in the bubble in the steam pressurizer in normal operation,

1 let's say, which would be a noncondensable gas. Is that the
2 case?

3 MR. MAC MILLAN: There is some hydrogen in the pres-
4 surizer. We maintain a hydrogen overpressure in the makeup
5 tank in order to maintain an excess of hydrogen in the reactor
6 coolant system. And to the extent that spray water containing
7 dissolved hydrogen goes into the pressurizer, it will relieve the
8 hydrogen in the pressurizer and preferentially seep the gaseous
9 base. So there is some hydrogen in the pressurizer bubble.

10 DR. PLESSET: If the pressure is high enough, it might
11 redissolve.

12 MR. FRALEY: So that's the equilibrium condition.

13 DR. PLESSET: Okay.

14 MR. TAYLOR: The sampling of the steam space in that
15 pressurizer usually produces a partial pressure or concentration
16 in the 15 to 40 cc per liter range which is just about the same
17 concentration that you have in the makeup storage tank where the
18 partial pressure is about -- the gas pressure is about 40 psi.

19 DR. MATTSON: Given all that, which is what I under-
20 stand to be the facts, I still don't quite understand, Ray, your
21 point.

22 MR. FRALEY: Well, we heard that these two incidents
23 had occurred, and I was wondering if there was anyone on the
24 staff who knew about them and could describe them to us. It
25 might help in connection with these other concerns about other

✓ 1 types of transients.

2 DR. MATTSON: Well, I certainly asked to the limit I
3 that I understand what two things you heard about. But maybe we
4 ought to talk on the telephone and you give me some more specific
5 information and we'll get the answer to you. I can't place what
6 you're talking about.

7 DR. SIESS: I can give you specific information on
8 one. It's on LER, Three Mile Island.

9 DR. SHEWMAN: It was in my handout today.
10 There is no number on it. This is a special report
11 transmitted with a letter July 24, 1978.

12 MR. MATHIS: 7821-3L

13 DR. MATTSON: If it's an LER, of course it's in
14 Tedesco's scope and he would try to explore it.

15 MR. FRALEY: I though maybe the project people had
16 evaluated it earlier.

17 DR. MATTSON: The LER may very well have been evaluated
18 but I didn't do it. It's over my head.

19 DR. SIESS: Would 7832 be an LER number?

20 DR. MATTSON: Was the -- the first time you gave me
21 7821.

22 DR. SIESS: One incident was on March 29, 1978.
23 Another was on April 23, 1978.

24 DR. MATTSON: This is EMI 1.

25 DR. SIESS: EMI 2.

1 DR. CARBON: Dave, I guess that finished your question
2 to Roger somewhere back there, is that correct?

3 I guess we're still at the point of trying to make
4 some decision. I guess the only firm -- well, two -- comments
5 so far: One, perhaps there's nothing to write on, and Dave's
6 other point that perhaps we ought to discuss some of the things
7 related to the B&W plants.

8 Harold, do you have comments?

9 MR. ETHERINGTON: No. I don't feel impelled to write
10 a letter so soon after the other one. I believe the staff has
11 said they will give some consideration to a warning to operators
12 to watch out for this conversion from enforced circulation to
13 natural circulation. And if I understand that correctly, I
14 don't think it's necessary to write a letter on that point. And
15 that's the only one I feel a little uneasy about.

16 DR. CARBON: Steve?

17 DR. LAWROSKI: It seems to me that's a very reasonable
18 position unless something develops between now and tomorrow when
19 we will have discussed this further. We still have another
20 executive session tomorrow.

21 DR. CARBON: All morning.

22 MR. ETHERINGTON: Things are moving rather quickly now
23 and there will be new slants coming out, I think. I think it
24 hasn't quite crystallized to the point where we want to be too
25 specific about additional concerns.

1 DR. CARBON: Comments?

2 MR. MATHIS: No.

3 DR. OKRENT: I think we heard from B&W this afternoon,
4 I guess, that in general they had no problems with what was said
5 about -- by the staff. In the bulletins, I'm not sure we had
6 the benefit of detailed discussion by B&W of the various points
7 in the Bulliten 79-05A. I don't know whether they think they
8 could discuss this during this meeting, but if they had some
9 information or opinions and so forth that they thought were
10 relevant, it could be useful. And I think there might be time.

11 DR. CARBON: I think we have plenty of time in the
12 morning if we want to ask for more information.

13 Let me ask, Did you hear Dr. Okrent's comment here,
14 and could you respond to it, John?

15 MR. MAC MILLAN: I apologize. I was reading LER --
16 whatever -- and I didn't hear his question.

17 DR. OKRENT: I was saying that there might be various
18 specific comments that you could make, you in the general sense
19 -- the people from B&W, concerning the several points raised in
20 Bulliten 79-05A. I mean, I assume that you're active in working
21 with the various utilities in responding to 79-05A, and that you
22 have thoughts on what are the factors that relate to the various
23 items. And if so, that could be interesting for us to hear.

24 MR. MAC MILLAN: I thought that was the thrust of a
25 portion of my testimony this afternoon, that in fact addressed

1 each of the six items which were identified in any I&E Bulletin
2 and indicated how we assessed the relative importance of those
3 factors.

4 DR. OKRENT: Well, I agree that you discussed at least
5 portions of the Bulletin this afternoon. I guess it wasn't
6 clear to me that there weren't more things you could say about
7 measures in here. Maybe I'm wrong.

8 MR. MAC MILLAN: I guess I'd have to know what ques-
9 tions you might have and then would have to respond to those.

10 MR. CASE: I think as a general matter, it seems
11 fair to me, correct me if I'm wrong, that you're agreeing with
12 what's in the Bulletin.

13 MR. MAC MILLAN: I think I said in my statement that
14 in essential agreement with the findings of the NRC in them --
15 bulletins that have been issued, 05 and 05A. In fact the
16 advisory, I think I said this, the advisory is that we send to
17 the utilities, were in congruence with the I&E Bulletin 79-05A
18 relative to the importance of maintaining the pressure in a
19 sub-cool condition and keeping the HPI pumps on for a period of
20 time on the order of 20 minutes.

21 DR. SIESS: Suppose that some other responses from the
22 applicants suggested that keeping the pumps on arbitrarily for
23 20 minutes might not be desirable and that they had another
24 option?

25 MR. MAC MILLAN: I have not read all of the responses,

1 but I believe that one of them did raise that concern.

2 DR. SIESS: I think it was Duke.

3 DR. MATTSON: That is one of the points that is being
4 iterated in the process of reviewing the responses. It's clear
5 that that is an important safety question to ask. But I think
6 it's also clear, as I understand, what Vargo said this morning
7 and what I heard him say last night, that that problem is in
8 hand and will be dealt with in the NRC response, the licensee's
9 response to the Bulletin.

10 MR. CASE: I haven't heard any comments from any
11 sources that that is detrimental to safety. The question was
12 raised about damage to the plant and the water level of the
13 containment -- that kind of concern. But as a matter of fact,
14 we discussed the same thing with the other PWR vendors and they
15 all agreed in essentially the same language and the same length
16 of time as not being detrimental to safety and appropriate for
17 this interim period.

18 DR. SIESS: That's not what I read here. It says:
19 Depending upon the nature of the low pressure transients,
20 appropriate action may be required for the operation of the
21 higher pressure injection-system and/or the reactor coolant
22 pumps, in order to prevent an unsafe reactor-coolant-system
23 condition.

24 DR. MATTSON: Well, that was the initial response to
25 the Bulletin, as I said.

1 DR. SIESS: I was speaking to Ed. You agree with me,
2 Ed disagrees.

3 MR. CASE: I'm not up on that comment.

4 DR. MATTSON; I don't think I'm disagreeing with Ed.
5 What Ed said is right. There was a point of understanding to
6 work out with that particular licensee as to the intent of the
7 procedures in the Bulletin. And having communicated that intent,
8 my understanding is that the difference between the licensee
9 and the staff is gone, and that that will be documented in the
10 course of the staff's response to the licensee's response.

11 DR. SIESS: I'll wait.

12 DR. CARBON: Gentlemen, I wonder if we're at the point
13 of saying let's stop for the evening and think about it over-
14 night and perhaps discuss in the morning Dave's point about
15 specific matters related to B&W plants. And certainly, if we
16 end up having a meeting with the commissioners tomorrow after-
17 noon, we'll want to go over our beliefs and stands with consid-
18 erable care to reach a commission position. So I guess where we
19 write the letter --

20 DR. LAWROSKI: I thought you said commission.

21 DR. CARBON: I meant committee. So maybe it's not too
22 crucial at the moment whether we aim toward a letter or simply
23 discussion. If that seems reasonable to you, we'll adjourn for
24 the evening and take up at 8:30 again tomorrow morning.

25 (Whereupon, at 7:45 p.m. the hearing was recessed to be
resumed at 8:30 a.m., Tuesday, April 17, 1979.)

A STATUS REPORT
TO THE
ACRS

GENERIC REVIEW OF
FEEDWATER TRANSIENTS IN B&W REACTORS

67-342

APRIL 16, 1979

GENERIC REVIEW GROUP

PURPOSE

TO PERFORM A GENERIC ASSESSMENT OF
FEEDWATER TRANSIENTS IN B&W PLANTS
IN LIGHT OF TMI-2 EVENT TO 1) ESTABLISH
BASIS FOR CONTINUED SAFE OPERATION OF THESE
PLANTS IN THE SHORT TERM AND 2) DETERMINE
REVIEW AREAS FOR LONG TERM REASSESSMENT
OF B&W PLANT DESIGNS TO MEET NRC REGULATIONS

B&W PLANTS (9)

INCLUDED IN GENERAL REVIEW *

- THREE MILE ISLAND UNITS 1 & 2 (PA)
- CRYSTAL RIVER 3 (FL)
- RANCHO SECO 1 (CA)
- OCONEE UNITS 1, 2 & 3 (SC)
- ARKANSAS ONE UNIT 1 (AK)
- DAVIS-BESSE UNIT 1 (OH)


- GENERIC REVIEW WILL ALSO INCLUDE
PRELIMINARY CONSIDERATION OF OTHER
VENDOR PWR PLANTS

F.W. TRANSIENTS IN B&W PLANTS
(PRECURSOR TO TMI 2 TYPE EVENT)

DATE	PLANT	PORV		HPI
		ACTUATED	STUCK-OPEN	INJECTION
6/13/75	OCONEE-3*	✓	✓	✓
6/12/76	OCONEE-2	✓		
9/24/77	DAVIS-BESSE-1*	✓	✓	✓
3/20/78	RANCHO SECO			✓
12/4/78	OCONEE-1	✓		✓
3/28/79	TMI-2	✓	✓	✓

*INDICATES TWO EVENTS SIMILAR TO TMI-2

GENERIC REVIEW AREAS (B&W)



67-346

- . PLANT DESIGN FEATURES (2)
- . OPERATIONAL ASPECTS (3) (4) (5)
- . LICENSING BASIS (1)
- . I&E BULLETINS (6)

PLANT DESIGN FEATURES

- PRESSURIZER - LEVEL
 - POWER OPERATED RELIEF VALVE
- PRIMARY COOLANT SYSTEM CONFIGURATION
- ONCE-THROUGH STEAM GENERATOR (OSTG)
- FEEDWATER SYSTEM
- CONTROL AND SAFETY SYSTEMS

67-347

LICENSING BASIS

- TRANSIENT ANALYSIS METHODS
 - VENDORS
 - STAFF
- GDC - SRP
- TECHNICAL SPECIFICATIONS
- OPERATING PROCEDURES
- OPERATOR TRAINING

Verdun






FIGURE 2

THREE MILE ISLAND UNIT 2
 LOFW TRANSIENT MARCH 28, 1979



RELAP4 ANALYSIS versus TRANSIENT DATA
 SOLID-RELAP4 DASHED-TRANSIENT

FIGURE 3



253-79

K-E 10 X 10 TO 1/2 INCHES
KLUFFEL & BROWN CO. NEW YORK

46 1320







FIG 2


TIME 2 - TURBINE / REACTOR TRIP AT 0400 ON 03-28-79







TMI - 2 TURBINE / ROOM Trip NT, 0400 ON 03-28-79




16 X 10 TO 1/2 INCH 2 X 18 INCHES
REUFEL & BAKER CO. MADE IN U.S.A.

46 1320

LCR TO WITSPANGLER

IMI 2 TURBINE/REACTOR TRIP AT 0400 ON 03-28-77




TIME IN SECONDS

67-357

..LCR TO WH SPANGLER

TMI-2 LDFW ON 3/28/79 (97% POWER)




TIME AFTER TURBINE TRIP - MINUTES

FIG 9

CCR TO WIT SPANGOLF


THICK LOW ON BY 28/79 (97% POWER)



LINK TO W # SPANOPAC
KOE 10 X 10 TO 1 INCH 7 X 10 INCHES
KAUFEL & ESSAN CO. WASH DC

46 1320


TMI-2 LOFW 0400 3/28/79



LCE to W. H. Spangler

THI-2 LOFW ON 3/28/99

(97% Power)



32

28

24

20

16

12



8

4





TIME AFTER TURBINE TRIP - MINUTES



THI-2

F/G. 12








**IMAGE EVALUATION
TEST TARGET (MT-3)**








**IMAGE EVALUATION
TEST TARGET (MT-3)**






**IMAGE EVALUATION
TEST TARGET (MT-3)**



TRIP-2 405W ON 8/28/79 (77% POWER)
LCR to WH SPANGLER 0350 3/30/79



PRESSURIZER LEVEL (INCHES)

TIME AFTER TURBINE TRIP (HOURS)

FIG 13

LCR to WH SPANGLER 0830 3/30/19





FIG. 14

LCR to W H SPANGLER 0840 3/30/79

TIME IS 4:07:10 ON 3/28/79 (77% POWER)




89-003

TIME AFTER VOIDING TRIP - MIN.

FIG 15

LCR to WH SPANGLER 0845 3/30/79

TIME IS 4:07 PM ON 3/28/79 (77% POWER)




TIME AFTER TURBINE TRIP (MIN)

FIG. 16

LCR to W. H. Spangler

TRIP TO LORAIN ON 3/28/79 (1979 BUZZ)



LCE to D.H. Spangler

HT 2 10FW DIS 3/28/79 (17% POWER)





FIG 18

46 1320

K-E 18 X 18 TO 1/2 INCH 7 X 18 INCHES
KEUFEL & GIBER CO. MADE IN U.S.A.

68 006

LCR to W.H. Spangler




700-89

FIG 19

see to W.H. Spangler

THIS IS LOG ON 3/28/79 (97% POWER)


OTSG STARTUP LEVELS - INCHES OF WATER



TIME AFTER TURBINE TRIP - MINUTES


FIG. 20

600-89




PRIMARY SYSTEM

NUCLEAR STEAM SYSTEM



SECONDARY SYSTEM



SIX SIGNIFICANT FACTORS

DELAYED AUXILIARY FEEDWATER

- PILOT-OPERATED PRESSURIZER RELIEF VALVE NOT RESEATING AND LACK OF RECOGNITION OF THIS EVENT
- SECURING HIGH PRESSURE INJECTION PREMATURELY
- CONTAINMENT ISOLATION
- INAPPROPRIATE EMPHASIS ON PRESSURIZER LEVEL INDICATION
- SECURING REACTOR COOLANT PUMPS

PRINCIPLES FOR CONSIDERING FUTURE ACTIONS

- ASSURANCE THAT SYSTEMS IMPORTANT TO SAFETY ARE AVAILABLE
- FOCUS ON FUNDAMENTAL PHYSICAL PROCESSES WHICH ASSURE CORE COOLING
- CONSIDER ALL ACTIONS IN THE CONTEXT OF TOTAL PLANT SAFETY

TMI-2 INCIDENT TRAINING

SCOPE

- DISCUSSION OF TMI-2 TRANSIENT
- SIMULATOR DEMONSTRATION
- HANDS-ON OPERATOR INCIDENT RECOVERY TRAINING
- ALL REACTOR OPERATORS

DURATION

I DAY

START DATE

APRIL 9, 1979


TMI-2 OCCURRENCE - TECHNICAL REVIEW COMMITTEE

CHARTER


- REVIEW TECHNICAL ASPECTS OF THE TMI-2 OCCURRENCE
- DEVELOP RECOMMENDATIONS FOR EQUIPMENT IMPROVEMENTS, OPERATOR INTERFACE, RECOVERY REQUIREMENTS AND INCIDENT SUPPORT.
- ASSESS IMPACT OF THE TMI-2 OCCURRENCE AND POTENTIAL RESULTING CHANGES IN REGULATORY REQUIREMENTS ON NUCLEAR POWER GENERATION DIVISION TECHNICAL ACTIVITIES.

PRESSURIZER LEVEL
INSTALLATION
TMI-2


PRESSURIZER



SHIELD WALL




PRESS.
LEVEL
TRANSMITTER




PRESSURIZER
THREE MILE ISLAND NUCLEAR STATION UNIT 2

68-017

MEASURING PRINCIPLE



TMI RECOVERY
BASE CASE SUMMARY
Revision 1



- (1) Degas at A; Lower Pressure (A→A') while degassing, then return to A.
- (2) Continue Design/Installation of static and active systems for primary makeup/pressure control and secondary cooling system for "B" S/G.
- (3) Reduce temperature (A→B) by steaming on "A" S/G
- (4) Take "A" S/G solid - drop primary temp. to minimum (B→C)
- (5) Trip RC Pump "A" - Establish natural convection - Establish cooling to "B" S/G if available.
- (6) Drop primary pressure to selected value (C→D)
- (7) Take primary system solid - Control pressure & makeup with static or new active system

END POINT

Primary - Natural Circ, solid liquid, Long-term P/V Control
Secondary - Solid water, Long-term Heat Dump System


Approved for Issue:

R. Arnold
R. Arnold

RA:clb

SHORT ERM - STEAM GENERATOR 'A'


FIGURE 1



STEAM-STEAM GENERATOR B

FIGURE 2

MS. V48/7B
17:00




68-021

REV. 1. 1/6
11:00

LONG TERM GEN 3 AEB

FIGURE 3



68-022

NUCLEAR REGULATORY COMMISSION

ADVISORY COMMITTEE ON REACTOR SAFEGUARDS

IN THE MATTER OF:

SPECIAL MEETING

Place - Washington, D.C.

Date - Tuesday, 17 April 1979

Pages 335-466

Telephone:
(202) 347-3700

ACE - FEDERAL REPORTERS, INC.

Official Reporters

444 North Capital Street
Washington, D.C. 20001

68-023

NATIONWIDE COVERAGE - DAILY

7904230171

1 PUBLIC NOTICE BY THE
2 UNITED STATES NUCLEAR REGULATORY COMMISSION'S
3 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
4

5 Tuesday, 17 April 1979

6 The contents of this stenographic transcript of the
7 proceedings of the United States Nuclear Regulatory
8 Commission's Advisory Committee on Reactor Safeguards (ACRS),
9 as reported herein, is an uncorrected record of the discussions
10 recorded at the meeting held on the above date.

11 No member of the ACRS Staff and no participant at this
12 meeting accepts any responsibility for errors or inaccuracies
13 of statement or data contained in this transcript.
14
15
16
17
18
19
20
21
22
23
24

CR 4126

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

UNITED STATES OF AMERICA
NUCLEAR REGULATORY COMMISSION
Advisory Committee on Reactor Safeguards

Special Meeting

Room 1046, 1717 H Street, N.W.,
Washington, D.C.

Tuesday, 17 April 1979

The Special Meeting was called to order, pursuant
to adjournment, at 8:30 a.m., Dr. Max W. Carbon presiding.

PRESENT:

Dr. Max W. Carbon, Chairman
Dr. Milton S. Plesset
Mr. Harold Etherington
Dr. Stephen Lawroski
Mr. William M. Mathis
Dr. David Okrent
Mr. Jeremiah J. Ray
Dr. Paul G. Shewmon
Dr. Chester P. Siess

Also Present:

Raymond F. Fraley, Designated Federal Employee
James F. Jacobs

(Recording of the special meeting was
commenced at 9:15 a.m.)

P R O C E E D I N G S

1
2 DR. SIESS. Assuming it was analyzed.

3 I'm not sure that this particular sequence was
4 analyzed, but it's different, what I think we're interested in.
5 And one aspect of different is worse, or potentially worse,
6 what we're concerned with.

7 MR. MATHIS: Well, I support Dave's position, except
8 I'd like to move into it a little bit earlier and say that we
9 should concentrate on those items of instrumentation that will
10 assist the operator and give him detection of when he is getting
11 into some trouble and thereby hopefully prevent any kind of an
12 accident. Let's worry about it before the fact rather than
13 after.

14 DR. OKRENT: I'm in favor of both areas. The thermo-
15 couple one was an effort to help him not get into worse diffi-
16 culty. In any event, as you can certainly tell, I certainly
17 favor them getting a better handle on it before it degrades.

18 DR. SHEWMON: I guess my feeling is we can write one
19 so vague and general that we'd be another five years having
20 to define it to our satisfaction before we did something--

21 DR. OKRENT: I think it's true that the Staff can
22 take another five years. I don't know why they took that long
23 this time, in fact, because the matter I think was clearly
24 defined the first time and they persisted in not looking at
25 this I think for some while and finally, after it being some

eb2

1 years a generic item, started to accept it. And then I didn't
2 understand why they put it in terms of reactors to be built.

3 I think it is time that we took a fairly strong
4 recommendation on the situation.

5 DR. SIESS: I agree. I'm just trying not to hang
6 it on Reg. Guide 1.97, which is already hung up.

7 DR. OKRENT: I tried to say we shouldn't recommend
8 it in terms of 1.97 in the beginning of my comments.

9 DR. CARBON: Fine. Go on to the next.

10 DR. SHEWMON: I don't think there is general agree-
11 ment until we see what we're talking about.

12 DR. CARBON: Well, to try something.

13 DR. SIESS: We have 1.97 in the folder. I don't
14 think it will do what we want.

15 DR. OKRENT: Now an area where I'm left -- what's
16 the word? -- well-versed and feel little bit less sure in my
17 own mind is the following:

18 For things like, for example, the need for natural
19 circulation or for things like the need for systems that have
20 to work if you lose main feedwater or so forth, one can ask the
21 question whether there can be steps taken in the current opera-
22 tion to reduce the frequency of challenge of systems that have
23 to work.

24 Now one question I raised yesterday was whether,
25 for example by using base load or base load most of the time

eb3 1 rather than load following, that would lead to a significant
2 difference in this sort of situation. Again I don't have any
3 direct knowledge, any specifics and so forth.

4 There may be other things one could do to decrease
5 the frequency of challenge. I do have the feeling that there
6 were quite a few challenges arising from the feedwater inci-
7 dents, for example, but they weren't related to the question of
8 base load or load following. Maybe certain kind of challenges
9 do go that way.

10 I'm not in a position to make a recommendation. It
11 looks to me like we might suggest an early study of this area;
12 that is, whether the number of challenges to these systems can
13 be appreciably reduced. It's a somewhat vague kind of a sug-
14 gession, but maybe Harold or somebody can offer comments on it.

15 DR. SHEWMON: Have you heard of any evidence that
16 you think would be particularly onerous or could upset the
17 system?

18 MR. ETHERINGTON: No, no particular problems.

19 DR. SHEWMON: I haven't either.

20 MR. RAY: I'm not versed with the widespread appli-
21 cation of reactors in the entire industry but the couple that
22 I know don't follow loads. They go on because of the over-
23 whelming economy of the operation at base load and they don't
24 swing. The economy of operation of a power system would dic-
25 tate that kind of operation.

eb4

1 If the day ever came, using the past tense, where
2 you had 90 percent of your capacity on the system then you
3 would have to have load-follow characteristics and capabilities,
4 but I would think that in general it would be cheaper to use
5 one kind of peaking capacity to do that, and that would be much
6 more flexible from an operating viewpoint.

7 Certainly the Staff would have information that
8 could tell us whether or not there is a predominant operation
9 within the industry of load-following with nuclear plants.

10 DR. SHEWMON: I think the question of operator
11 preparation for these things is certainly a point that comes
12 up. Do we feel that's so much within the purview of the Staff
13 and so much on everybody's mind at this point that we would
14 rather watch and listen than make recommendations in the area?
15 It's certainly nothing we have to bring to anybody's attention
16 I guess, where some of these others are points that we feel
17 have been neglected and might continue to be neglected.

18 DR. CARBON: Well, I don't know. I'm mixed up on
19 the last trend of this point here.

20 I think Dave's basic point has to do with looking
21 toward challenges.

22 DR. OKRENT: The frequency of challenges. Well,
23 let me put it this way--

24 DR. CARBON: And that's independent of--

25 DR. SHEWMON: I wasn't speaking to that point. I

eb5

1 thought we had left that. I don't know that there is consider-
2 able support for the concern, but then he may well be right.
3 I was bringing up a different point.

4 DR. CARBON: Well, back for a minute on it, it seems
5 to me very reasonable to look into whether challenges fre-
6 quently occur and if there are, to try to reduce them. It may
7 be that in some of the cases there could be simple changes made
8 that would reduce the frequency of challenge.

9 MR. MATHIS: Well, most of the challenges to the
10 various systems come from the method of testing. They are
11 challenged and tested so frequently we wear them out in a lot
12 of cases.

13 DR. SHEWMON: And then they're out of service when
14 you need them.

15 I think what Dave is suggesting here is just not in
16 the experience of the people. I haven't heard of it; Harold
17 doesn't, off-hand. Certainly the maintenance and checking
18 operations has continually been brought up as a source of danger
19 to the system, usually the source of excursions.

20 DR. OKRENT: Well, I don't want the load-follow
21 question to cloud the issue. The real question in my own mind
22 is whether there should be a look at the frequency of challenge
23 because certainly to think about things probabilistically, if
24 you consider driving a car, for example, if every time you came
25 to a stop light, somebody came through the other way, when you

eb6

1 had the green somebody came through late and charged through,
2 most of the time you might see him and stop and either have
3 him miss you, but there could be an occasion when you didn't
4 and he hit you. So that's a question of frequency of challenge.

5 And it's similar for any time when you have to react
6 in haste, or whatever it is, in order to meet a challenge.

7 Again, maybe this is an item that we might flag as
8 one that might be put down for relatively early review by the
9 Committee and ask that the NRC Staff be thinking about it so
10 that when we have time in the not too distant future to talk on
11 it, say, there has been some preliminary thinking done.

12 It may be that out of the task force that they're
13 talking about that I guess Tedesco is dealing with that they'll
14 develop some ideas in specific areas.

15 DR. SIESS: What kind of challenge are you talking
16 about? Loss of feedwater in particular, or anticipated
17 transients in general?

18 DR. OKRENT: Well, I really thing both. Loss of
19 feedwater is in vogue at the moment but I think the question
20 warrants a more general look.

21 DR. SIESS: There has been a pretty extensive chal-
22 lenge now of anticipated challenges.

23 DR. OKRENT: But that was related to a challenge on
24 the defective system, the scram system.

25 DR. SIESS: But there are other historical ones,

eb7 1 what anticipated transients to think about and whether they
2 represent a single category in terms of what happens, or
3 different ones, and they could certainly look at those and see
4 how they might be affected by a load-following mode versus base
5 load.

6 DR. LAWROSKI: I want to bring up another suggestion
7 for the Committee.

8 DR. CARBON: Are there more thoughts on this parti-
9 cular one?

10 MR. RAY: Maybe in view of Dave's last comment, it's
11 an item that would be worthy of addition to our list of items.

12 DR. CARBON: It could be.

13 MR. RAY: The B categories. You'll remember we had
14 A, B, and C.

15 DR. SHEWMON: Generic?

16 MR. RAY: The list that was made up at the last
17 meeting. Today we acted only on the letter to the Commission.

18 MR. LIPINSKI: In connection with looking at the
19 challenge rate, we should also consider the difference between
20 once-through steam generators and recirculating steam genera-
21 tors in doing these studies, and the effect on loss of heat
22 sink.

23 The other one that was alluded to yesterday was
24 to mitigate the transients on loss of heat sink by not delaying
25 the scram. In the particular case where you lose your heat

eb8

1 sink and delay the scram, the area under the power curve repre-
2 sents the energy that has to be absorbed by the primary system.
3 This gets translated into system temperature increase, volume
4 increase, pressure rise and level rise, pressure increase and
5 if the pressurizer doesn't have enough volume, then you pass
6 water through the valves.

7 So the benefits of scrambling early on loss of feed-
8 water or turbine trip should be included in this.

9 DR. CARBON: Let's go on.

10 DR. OKRENT: Why don't we let Steve Lawroski have
11 a turn?

12 DR. LAWROSKI: I'm going to raise-- The point that
13 I yesterday mentioned was one of my concerns, and that is the
14 matter of the releases of iodine. It's been some time since
15 plans were laid at Three Mile Island to get another charcoal
16 filter in operation, but I think we might suggest -- and I would
17 like to have the Committee consider whether or not we should
18 suggest to the Staff that it re-examine the situation with
19 respect to iodine removal.

20 It seems that the performance of the equipment in
21 this regard there has been marginal, and we would have been
22 considerably worse off had we not had as good a containment as
23 appears to be there. I don't know who built that but it
24 apparently has stayed tight; otherwise we might have been see-
25 ing larger-- I know it is being maintained negative, but the

eb9 1 fact that it is tight makes it easier to do so at negative
2 pressure.

3 But I think we ought to look again to see why it is
4 that the charcoal filters presumably lost their capacity for
5 removing the iodine because of moisture.

6 DR. SHEWMON: How are these things normally designed?
7 Certainly in a water cooled reactor there is very likely to be
8 water and steam running around.

9 DR. LAWROSKI: Yes. That's why I'm concerned. If
10 you should encounter moisture, I don't know what measures are
11 taken to get around that.

12 MR. RAY: Steve, would some kind of a chemical bank
13 through which you pass this--

14 DR. LAWROSKI: I don't know. But the releases here
15 have-- Well, one attempt to mitigate them was to add some
16 hydroxide of thiosulfate to the liquid wastes which presumably
17 were both in the aux. building and I guess in the reactor
18 building which had sizable quantities of radioiodine.

19 But we ought to look, I think, again at whether we
20 really have as good information as we should for contending
21 with iodine. It's one of the more important, if not the most
22 important, fission product to prevent from releasing.

23 MR. RAY: Certainly this would be a good research
24 item.

25 DR. LAWROSKI: I don't know that the details involve

eb10

1 this particular one.

2 MR. CROCKER: The filters that are on the vents from
3 the containment normally do have a preheater to make sure
4 that there is no moisture getting into the charcoal filter
5 banks. My understanding is that the iodine from the TMI
6 accident is from the sump water that actually got pumped out
7 into the auxiliary building, and in the process of cleaning it
8 up now, we are having trouble with the iodine releases.

9 The filter banks in the auxiliary building, while
10 there is charcoal there, I do not believe they normally con-
11 tain a preheater to get rid of moisture. You wouldn't expect
12 to have moisture up in the 70 to 80 percent range out in the
13 auxiliary building normally.

14 DR. SHEWMON: The heated water doesn't get rid of
15 it. Is it particulate water, droplets, that are particularly
16 bothersome? The relative humidity would change? You might in
17 essence destroy any droplets but you don't get rid of water by
18 heating it.

19 MR. CROCKER: No, the idea is the charcoal filter
20 banks-- The moisture apparently gets on the charcoal and it
21 will not absorb the iodine, so the idea is to preheat the air
22 coming through or the gases coming through so you can get rid
23 of the moisture.

24 DR. SHEWMON: It's getting rid of it that bothers
25 me. You think it then does not absorb when it is hot air but

eb11

1 the iodine still does if it's at higher temperature, which is
2 apparently what happens?

3 MR. CROCKER: I'm getting considerably out of my
4 field but I think that's correct.

5 DR. OKRENT: I'm a little curious about this. If
6 they hadn't gotten water into the auxiliary building but if
7 they had gone onto the RHR mode and recirculated water with
8 pumps in the auxiliary building, we have heard expressions of
9 concern that there might be leaks over a period of time and
10 you might have gotten into a position where you had both iodine
11 in the atmosphere in that building and moisture from another
12 source.

13 So we could have gotten to this situation possi-
14 bly down another route. So I think the question that Lawroski
15 raises in terms of the auxiliary building and what provisions
16 it has should be followed. In fact, there is clearly a longer
17 term need to look at whether the RHR system as currently de-
18 signed is less of a desirable, you know, fallback or, in fact,
19 I suppose I might say the first line of defense than the Staff
20 and everyone else has been defining it as.

21 In other words, if you're really concerned about
22 leakage arising from the RHR system and not that we're reluctant
23 to use it on a short or long term, now what is this all about?

24 So I'd like to take Lawroski's question and Crocker's
25 answer and suggest there is a broader area. I'm sure the Staff

eb12

1 is conscious of this, I have no doubt. But it's something I
2 think the Committee may also want to look at. I'm not suggest-
3 ing we make a recommendation today, however.

4 MR. FRALEY: There's another point, that the radio-
5 activity was contained inside the containment and in some ways
6 it's fortunate that it's a concrete containment that provided
7 considerable shielding for activities onsite.

8 It may be that for other kinds of containment it's
9 more important to get that activity inside the containment down
10 so that you can do onsite activities after an accident of this
11 nature. I think that needs some thought.

12 DR. OKRENT: I think we always have shielding now.

13 DR. SIESS: We don't have any containments without
14 concrete.

15 DR. OKRENT: San Onofre 1 used to be a steel shell
16 but it is changed now.

17 DR. SIESS: Those thicknesses vary.

18 MR. FRALEY: But we normally concentrate on the
19 control room. We do not examine carefully other onsite acti-
20 vities that may be needed, like hooking up the hydrogen burners.

21 DR. LAWROSKI: But not being able to get that iodine
22 out of that volume of gas has hampered activities on the site
23 and getting on with what needs to be learned about the acci-
24 dent.

25 DR. SHEWMON: My comment is tangential. I don't know

eb13

1 whether to raise it or not, but it seems to me that something
2 which was very nearly absent the first week or two days of the
3 accident was adequate chemical knowledge or capability in the
4 Staff of even knowing where to go to ask the right question,
5 or even what the right question was.

6 I don't know whether it's a research project or not.
7 Certainly an organization and staffing and some research capa-
8 bility in the area of water chemistry and things of this sort
9 would have been a fair help in mental anguish to the public
10 and the statements made.

11 DR. CARBON: Are there further comments on Steve's
12 point here?

13 Dave, I know, has more points. Would other people
14 like to inject some at this point?

15 Let me turn to the consultants and see if there are
16 any points they would want to raise.

17 MR. LIPINSKI: I have a long list of items if you'd
18 like me to run through them.

19 DR. CARBON: Why don't you start?

20 MR. LIPINSKI: We've talked about the instrumentation
21 to follow the course of an accident. We discussed the require-
22 ments for meeting full range. We also made the point during
23 the early phases of an accident environmental considerations
24 are not that important, therefore, this business of full range
25 is.

eb14

1 Consideration of new instrumentation, new instru-
2 ments, reactor water level was one of the missing parameters.
3 Now containment water level is a missing parameter.

4 As to whether natural circulation is present, that
5 can be developed by proper instrumentation to give direct
6 readout to the operator.

7 The suggestion of giving the operator a chart to
8 tell him where he is with respect to T saturation, he can
9 actually have a presentation given to him based on the margin
10 from the hottest point in the core with respect to the actual
11 system pressure, and then naturally core outlet temperatures
12 are very beneficial. But as has been pointed out, they're not
13 put there for the operator only to get core operating perform-
14 ance information. That should be a requirement for operator
15 information with respect to reactor performance.

16 I have already made reference to the benefit of an
17 early scram on loss of heat sink.

18 In connection with the instrumentation to follow
19 the course of the accident, we have seen miscellaneous charts
20 presented, taken from various points in the control room in
21 an attempt to try to do a point-to-point correlation between
22 charts to see what the sequence of events were.

23 There are systems in operation called sequence-of-
24 events recorders where you take selected variables, select a
25 sampling rate, and record these continuously prior to an

eb15

1 accident. If an accident does not occur, the information is
2 erased, and new information is continued to be recorded.

3 If the variables go out of bound the system is
4 triggered, you retain the data and you continue to record after
5 the accident is initiated. It's kind of like a flight recorder
6 in an airplane. You can then recover this information and
7 get a time sequence correlation of events to help determine what
8 it is that took place.

9 Such a system is in operation on the EBR 2 reactor
10 in Idaho.

11 This particular event caused one of the steam genera-
12 tors to fail. I think the reliability of the heat source
13 should be reassessed. The system only has two steam generators.
14 Fortunately one is still working.

15 In the case of the Clinch River reactor, the three
16 heat transport systems were considered insufficient for resi-
17 dual heat removal. That system is required to have the separ-
18 ate heat removal system.

19 Now I should draw a correlation. You can blow
20 sodium once through a system and dump it into the containment
21 because that's your design basis. So the water reactor does
22 have a benefit in terms of the coolant. But the general ques-
23 tion of heat dump reliability I think should be reassessed as
24 to whether the numbers that come up in this exercise are ade-
25 quate.

eb16

1 There was a problem with the gas bubble in the
2 reactor. There should be a remote operate event on top of the
3 reactor vessel such that if there's any gas bubble formation
4 in that vessel you have the opportunity to release it from the
5 control room.

6 Similarly, at the highest point in the system
7 natural recirculation should be established. There should be
8 some control to vent that system if gas does form at the
9 highest point.

10 We talked about the safety power-operated valve not
11 having direct position indications. It's only inferred from
12 solenoid operation.

13 All the safety valves in the system should have
14 direct position indication of their stems. That has to be in-
15 ferred in terms of what their status is. In this particular
16 case the downstream thermocouple does provide additional infor-
17 mation. Even though the position indicator would say the valve
18 is closed, it still may simmer. Consequently, the thermo-
19 couple provide additional information.

20 We have discussed this once in a previous meeting
21 in terms of status indication of all emergency equipment. The
22 emergency equipment is different from the plant protection
23 system equipment. In the case of the gravity-driven rods if
24 we have a power failure, generally we have an automatic actua-
25 tion of that system.

68-041

eb17

1 The emergency equipment is designed with a reverse
2 feature. You must apply energy to actuate the final device,
3 be it a valve or a motor.

4 We discussed previously when breakers have been left
5 open on safety systems. All the safety equipment should have
6 indicators on it such that you can determine the status of the
7 safety system from the control room as to its availability
8 such that if a signal calls for actuation, you have some degree
9 of assurance that that system has been set up and it will
10 actuate when called on.

11 DR. OKRENT: What about block valves?

12 MR. LIPINSKI: I would put indicators on all valves
13 that had to do with the operation of the safety system. It
14 should be indicated that they are not in proper position for
15 safety system actuation, and this would include breakers. If
16 the switch is not in the proper position it should be so indi-
17 cated.

18 You can carry this further with interlocks to pre-
19 vent operation, and this is also something that should be con-
20 sidered. Indication is a minimum. As to whether you inter-
21 lock is another consideration.

22 Dave has already made the point on the failure end
23 of the plant control system and the challenge rate that is
24 given to the plant protection system and the engineered safety
25 features. I'd simply like to reemphasize that this is an

eb18

1 important consideration.

2 Now, in designing safety systems the single failure
3 criterion is invoked and what this does is improves the re-
4 liability of the safety system and insures the availability of
5 a safety system when it's called on.

6 When we do our transient analysis I think a similar
7 rule should be invoked such that when you do your transient
8 analysis you should also then invoke a single failure to see
9 what the effect is.

10 Now we've concentrated on having safety systems
11 available to perform their function but we have not looked at
12 them to see what the effect is if we can't prevent them from
13 continuing to perform their function; namely, if a valve doesn't
14 close or if water does not stop being injected, then I think
15 this should be a consideration in our transient analyses.

16 As we always look in a forward direction, the ques-
17 tion is if we cannot prevent a system, once it has been acti-
18 vated, this should also be a consideration.

19 DR. SHEWMON: Let me stop and back you up one.

20 On that one, what we assume or push upon the appli-
21 cant is to make it safe and if they have it hung with enough
22 hangers and have, where we put it in the plant, it's certified
23 as safety grade, then it's assumed to work invariably. Is that
24 the philosophy?

25 MR. LIPINSKI: No. The philosophy is if it is

eb19

1 safety grade, then you'll get it when you want it. But the
2 reverse is not necessarily true, that having had it, can you
3 get rid of it? And in this particular case, with the relief
4 valve open, it went in the proper direction to the initial
5 benefit but not being able to close it got us into trouble.

6 DR. SHEWMON: Let me back you up one further.

7 You had one on challenge rate of the plant protection
8 system. Can you be more explicit on what you suggest there?

9 MR. LIPINSKI: Well, as was pointed out, there are
10 no criteria that say that if a control system fails more fre-
11 quently than a certain number then it is unacceptable. I've
12 been involved with the Canadians. They do have such a number
13 that says that if the control system has higher than a certain
14 failure rate it is totally unacceptable, and they've got to take
15 measures to reduce the failure rate to the prescribed number.

16 DR. SHEWMON: Is the failure rate the result of it
17 not performing satisfactorily on a periodic check?

18 MR. LIPINSKI: No. It's in the event that you get
19 safety actuation or the system goes out of limits when it's
20 called on to do so. In other words, feedwater can go in both
21 directions. You can have excess of feedwater and you can have
22 loss of feedwater, and if it does this as a result of a failure
23 it's classed as a failure. It's not performing as it's in-
24 tended.

25 And if it does it more frequently than a prescribed

Feb 20

1 number, then you must take measures to correct it. And they
2 have prescriptions as to what the numbers are.

3 DR. SHEWMON: You're talking about plant protection
4 systems now, or are you talking about normal equipment?

5 MR. LIPINSKI: We're talking about control systems
6 that challenge the safety systems. The Canadians do have
7 numbers that apply to their control systems such that if the
8 control systems malfunction more frequently than prescribed,
9 action must be taken.

10 We do not have such numbers. I think consideration
11 should be given to performance requirements on control systems.

12 DR. SIESS: Are these performance criteria based on
13 actual operation experience or on calculated failure rates?

14 MR. LIPINSKI: No, the criteris as to whether you're
15 conforming or not is based on actual operating experience be-
16 cause they have a calculated number that sets the prescription.
17 But then after you go into operation, if your statistics of
18 failure exceed that number then you must correct your system.

19 DR. SIESS: And the limit is on over-all control
20 system failures or--

21 MR. LIPINSKI: It depends on the particular system.

22 DR. SIESS: I mean do they have a separate limit on
23 feedwater malfunctions and another one on some other control
24 function?

25 MR. LIPINSKI: This I couldn't say. I'm familiar

eb21

1 with the fact that they do have limits on the control system.
2 Just how they are apportioned between the systems I couldn't
3 say.

4 DR. SHEWMON: Could we get a copy of the documents,
5 or whatever they call their Reg. Guide or something that he's
6 referring to?

7 MR. FRALEY: The Canadians?

8 DR. SHEWMON: Yes.

9 MR. LIPINSKI: The information I have is in the form
10 of a set of Vugraphs that were given at a meeting with the
11 presentation. I can forward them to the Committee. As to
12 whether you can get the equipment information also I don't
13 know.

14 MR. FRALEY: If you'll give me the information I'll
15 find out.

16 MR. LIPINSKI: Okay.

17 DR. LAWROSKI: You said one of the steam generators
18 failed as the result of this. Have we had that ascertained?

19 MR. FRALEY: I think it has been unclear whether
20 that's the generator that's actually leaking. It apparently
21 is available as a heat removal source if it is not degraded,
22 but there is some concern about leakage which is an off-again,
23 on-again kind of thing. It may be leaking and it may not.

24 DR. CARBON: If Walt is finished, let's take a ten-
25 minute break.

eb22

1 (Recess.)

2 DR. CARBON: Let's go ahead with our discussion.

3 Steve, you wanted to make a couple of points?

4 DR. LAWROSKI: Yes.

5 In addition to having remote capability, for example
6 venting the reactor vessel that Lipinski mentioned, there are
7 other things that he has probably included, but people continue
8 to examine this accident and see what should be done should
9 another one like it ever occur, in order to be better prepared.
10 And that would include such things, for example, as looking
11 into provisions for remotely being able to sample -- being able
12 to sample remotely some of the important systems like the
13 primary system, for example. There had to be real limitations
14 on the number of samples taken because of the concern for over-
15 exposure.

16 We're pretty well set up with plants to take sampling
17 under normal operations but very poorly, not only with respect
18 to primary coolant but some of the other things, for example
19 getting good samples of the containment, and perhaps there are
20 other things.

21 Another item that-- I'm sure this will receive a
22 great deal of attention by industry and I hope by the NRC as
23 well, and that's the matter that apparently has been so long
24 neglected despite the experiences of the Chalk River accident
25 some years ago, the SL-1, namely the lack of emergency equipment

eb23

1 having been carefully planned for and provided to be able --
2 and have it available for dispatching.

3 That equipment should include such things as -- I
4 will just cite an example -- robots that are available with
5 capabilities that are fairly broad in what they can do. I
6 think a great deal more needs to be done. And of course the
7 matter of emergency planning, if Dr. Moeller were here, he
8 would certainly comment on. But I think this is something we're
9 going to need to discuss at some length, and we'll need to
10 follow up to see what industry and the NRC have developed, to
11 see whether we consider it adequate or not.

12 DR. SHEWMON: Could I comment on one of those?

13 On the remote sampling, the sampling of both con-
14 tainment and primary cooling system are entirely set up for
15 normal operating conditions only? Is that it?

16 DR. LAWROSKI: Pretty much so. I think I'm correct
17 in saying that. It has required quite-- It was quite diffi-
18 cult to arrange for the primary coolant samples. I believe
19 we have gotten -- what? -- a total of two so far, Larry?

20 MR. CROCKER: I'm trying to get a reading on the
21 latest right now. I don't know how many they've taken,
22 Dr. Lawroski.

23 DR. LAWROSKI: This may mean something like long
24 lines that are shielded and that one is capable of taking out
25 a large volume before you get the representative sample.

eb24

1 DR. SHEWMON: I fully agree. I just hadn't realized
2 whether--

3 DR. LAWROSKI: Isn't that true? I'll ask
4 Mr. McMillan if that isn't so?

5 MR. MC MILLAN: I think I'm correct in saying that
6 there have been two depressurized samples taken of the reactor
7 coolant system. And over the weekend they took a pressurized
8 sample in order to get an evaluation of the gas.

9 DR. SHEWMON: The question is the design procedure
10 for accident conditions.

11 MR. MC MILLAN: It's for normal operations, sampling
12 the reactor coolant to determine the gas concentrations and
13 determine the pH levels and the impurities in the reactor
14 coolant system. They did take samples here through that sampling
15 system. And as you point out, they do have to circulate this
16 sample for some time in order to make sure they're getting a
17 representative sample.

18 They can do that while they move away from the
19 sampling site but in order to get the sample, get it into a
20 bottle and get it into a flask, there is a radiation exposure
21 in an accident condition with the levels they presently have.

22 The first sample they took had a contact radiation
23 level of 1,000 r per hundred milliliter sample. The subsequent
24 one, taken I guess ten days later, that radiation level had
25 dropped off to about 17 r, but it was a 40 milliliter sample,

eb25

1 somewhat smaller than the original.

2 But that still is a significant radiation level and
3 the system is not built to do post-accident sampling.

4 DR. LAWROSKI: The long delay in being able to get
5 another primary coolant sample meant that we weren't as early
6 knowledgeable about whether or not, for example, core melting
7 had occurred.

1.070

8 MR. MC MILLAN: I think that's right. Of course
9 there was a great deal of interest on our part as to what the
10 dissolved gas level was in the sample and therefore, the need
11 to take a pressurized sample. And that has only been accom-
12 plished over the past weekend.

13 DR. OKRENT: While Mr. McMillan is standing, do you
14 happen to know when there was an indication on some instrument
15 that looked at the primary system liquid itself, that the
16 activity in the primary system has gone well beyond what one
17 would consider normal so that it indicated either that many
18 fuel elements had perforated or something equivalent to that?
19 Is that information now available to B&W?

20 MR. MC MILLAN: Specifically I don't know the answer
21 to your question. I don't know when they first got an indi-
22 cation of the high radiation levels in the coolant.

23 The first place where that would be-- The first oppor-
24 tunity you'd have would be to notice the high levels in the
25 letdown system let down into the makeup tank and then back into

eb26

1 the reactor coolant system. And I believe the first indication
2 would have been in high radiation levels in the gas base of
3 the makeup tank. I don't know specifically when that was first
4 observed, but we can find that out.

5 DR. OKRENT: There's been a long-standing generic
6 item concerning instrumentation to provide early warning of
7 gross failure of a fuel element. I was just wondering whether
8 the instrumentation that would normally be associated with the
9 primary system and its appendages gave early, definitive indi-
10 cation that something like this had occurred and whether this
11 information was clearly available to the operator and so forth,
12 whether it was on a basis that you could translate it from the
13 fact that you had perforation to you had fission products
14 moving out into the coolant outside the gap.

15 Again this could have been intelligence telling you,
16 at least let's say after two hours, you shouldn't assume you
17 had your original geometry or something like this. It could
18 have given perhaps earlier warning.

19 But what I'm trying to ascertain now is what the
20 system was and in fact whether it gave information directly to
21 the operator.

22 MR. MC MILLAN: I simply don't know the answer to
23 the question. I think that's something that ought to be deter-
24 mined. In fact, I can't answer it.

25 DR. OKRENT: While we're talking about topics I

eb27

1 would call attention to that. It's a generic item which, for
2 many years, again the Staff seemed not to be able to find a
3 real reason to pursue. Maybe now they will re-look at it

4 MR. MC MILLAN: I think maybe I ought to say some-
5 thing in response to that, and that is in the post-accident
6 evaluation of the sequence of events that took place and the
7 assessment of what the condition of the core was, it's the
8 consensus of those who have looked at it that the significant
9 damage to the core occurred in the time frame in the two- to
10 four-hour period after the accident was initiated. That's in
11 the range of 6:00 a.m. to 8:00 a.m. on the morning of March
12 28th.

13 That you'll recall is in the time period after the
14 reactor coolant pumps were secured.

15 I don't believe, from what I have been able to
16 assess of the situation, that at that point the operator-- Let
17 me say that differently.

18 I believe at that point in the incident the operator
19 recognized he had a serious problem on his hands, and the evi-
20 dence of additional indications of high fission product levels
21 in the letdown I don't think would have caused him to do any-
22 thing different. But obviously that's speculation on my part.

23 DR. CARBON: Dave, I was making a note while you
24 were discussing this. Would you repeat for me the--

25 DR. OKRENT: I was just saying for a long time there

eb28

1 has been a question about whether it could be useful to have
2 instrumentation that would give early warning of gross fission
3 product release, if you will, from a small portion of the core,
4 or something equivalent to this.

5 And while I'm not able to say what the operator knew
6 or what he could have done, I think, for example, if there had
7 been knowledge at four hours that the fission product level
8 corresponded to not just gap activity but from the fuel being
9 at substantially higher temperatures than you would normally
10 have expected, again that would have given some intelligence
11 to people that they didn't have.

12 Again, this event has occurred. I hope there are
13 no future events of similar seriousness, but I myself don't
14 know why we don't use tools that exist like thermocouples and
15 devices that can measure radiation that could give useful in-
16 formation. I have for a long time not understood this. And
17 after a postmortem like this, I find it even less understand-
18 able.

19 MR. LIPINSKI: There is one other source of informa-
20 tion and that is the neutron flux in this reactor. It's nor-
21 mally a quiet signal. At the presence of boiling in the core
22 you do have boiling that can be detected in the flux signal,
23 and it was an appropriate signal processing. This can be an
24 indication that boiling is taking place in the core.

25 I've not seen the flux traces as to what was

eb29

1 displayed on them, but this is another possibility.

2

DR. LAWROSKI: The covering of the core has always

3

been given special importance. Could you tell us how much this

4

was emphasized in the training of personnel in the instructions?

lb

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

LC agbl

1
2 MR. MC MILLAN: Dr. Lawroski, I'm going to have to
3 plead ignorance on that particular point. I'd be happy to
4 try to get an answer to that from the people who are specifically
5 involved in our training program.

6 I think you're asking in detail what we instruct
7 the operator as to the importance of maintaining the cooling
8 configuration, forced circulation or, in the absence of forced
9 circulation, making sure he has subcooled water in the core.
10 And that really ought to be answered by somebody who is on the
11 firing line day-to-day with the operators, and I prefer to handle
12 it that way.

13 DR. LAWROSKI: I'd like to see, if there is a
14 tabulation, what are the parameters that he might avail him-
15 self of to provide assurance that he, indeed, has the core
16 covered.

17 MR. MC MILLAN: Okay.

18 DR. CARBON: And in that connection, would you include
19 not only a list of the parameters, but an idea of the priorities
20 or the importance that is attached to each one?

21 I mean, sometimes a person can be given a list of
22 a couple of hundred items, but some of them surely get high
23 attention, high priority, high emphasis. And if you could
24 clarify or spell out that aspect, it would be useful.

Ace-Federal Reporters, Inc.

25

MR. MC MILLAN: Okay. We'll do that.

DR. SHEWMON: I would like to ask the Staff if there's

agb2

1 another chronology which lists when activity spikes were
2 either in the letdown tank or what information was available
3 on the activity.

4 In looking over the chronology, it was obviously
5 developed by somebody who has a profound interest in thermo-
6 hydrology but much smaller interest in activity levels. Yet
7 some of this is available in the -- a lot of it is available
8 in the control room, I would expect. Am I not looking at the
9 right list or doesn't the list exist or what?

10 MR. CROCKER: The only list I have seen are the
11 ones the Committee has available to it. I can check and see
12 if we do have something else on the radiation level chronology.

13 DR. SHEWMON: In the plant or in the letdown level
14 accumulator, wherever it comes. There have to be failed fuel
15 detectors on the primary circuit. These things certainly read
16 up there in the control room.

17 MR. CROCKER: Yes.

18 DR. SHEWMON: And when it goes off-scale, it might
19 not give Dr. Okrent all he would like, but it sure does let the
20 operator know that something is out of normal.

21 MR. CROCKER: I can check that back through and
22 see what we can get for you.

23 DR. LAWROSKI: Still on the same topic, essentially
24 the same question I would like to see posed that we have
25 asked Mr. McMillan to provide, but now ask of the Staff.

agb3

1 Because it's not only for E&W reactors that the core must be
2 covered but for all reactors, therefore, what have they done
3 in connection with looking at the qualification of license
4 operators in this regard.

5 MR. CROCKER: I can get that for the Committee,
6 Dr. Lawroski.

7 DR. CARBON: Can you get as well specific informa-
8 tion on the Three Mile Island operator training?

9 MR. CROCKER: I'm sure we have it, yes. We'd
10 probably have to back it back out of the system. But it must
11 be available, Dr. Carbon.

12 DR. CARBON: Good.

13 Jerry?

14 MR. RAY: Max, you may recall in our last meeting
15 we discussed the idea of an on-line computer to assist the
16 operator as to what the status of his plant was. After
17 Harry Walter's suggestions of the need for monitoring informa-
18 tion to the operator and the last several points that Dave has
19 brought up, I think that we -- I would suggest that we take
20 a very active aggressive attitude toward this and recommend
21 an on-line computer be added to the plants at the earliest
22 possible date.

23 Now this can be used to survey, if you will, on
24 command from the operator all of the plant status items:
25 the valves that are supposed to be closed for normal operation,

agb4

1 the valves that should opened for normal operation and so on.

2 Temperatures, thermocouples in the core could be
3 transmitted into the computer and at his option, he could press
4 a button that would test, if you will, and survey all his valve
5 positions for that configuration of plant.

6 The computer could be programmed as to what would
7 be normal for this plant's condition and respond after having
8 checked the transmitter or the converter, if you will, at the
9 various points for desired information and give him a positive
10 indication.

11 He could very quickly, in effect, as many times
12 during his shift as he wanted, check whether or not some
13 abnormality has caused maloperation of automatic controls and
14 closed the valve that should be open and so on.

15 To the extent that you might formulate, by the
16 various engineering disciplines, the transient development or
17 the consequences of a change of status within the core or within
18 the pressurizer or within the steam generator, to the extent
19 that that can be formulated and incorporated into the computer
20 program or the brain of the computer, as it were, he can check
21 whether or not he's on the verge of an emergency.

22 All of this has been done in the electric power
23 transmission systems. There are on-line automatic monitor and
24 control computers which the system operator -- and it's
25 particularly useful in large scale interconnections of systems.

agb5

1 He has meters in his station, all of the current transmission
2 lines, the generation out of generating plants, individual units
3 as well as total plants, it's all available to him.

4 And incidentally, the breaker positions are brought
5 into that position. And he has a dedicated series of cathode
6 ray tubes that are colored, set up on a console.

7 One could survey the high tension, and does. The
8 high tension may be the 500 Kv system, another one the underlying
9 transmission system, the 230 Kv and so on. But as many times as
10 he needs to tell him the information that's critical to specific
11 portions of his system.

12 He also has the transmission substation delineation
13 in the single line, if you will, of all the major transmission
14 subs.

15 Well now, the limit here is how much he can formulate
16 and incorporate into the computer program. And the last time
17 we did talk about this, we relegated the status of such a
18 suggestion to D. I think it should be an A.

19 It's a simple matter. For instance, in the electric
20 systems, the computer has been endowed with a program which will
21 calculate the load flow on the system and it also knows what
22 the emergency capabilities -- the normal capabilities and the
23 emergency capabilities of the various transmission elements for
24 particularly the more important ones, the backbone of the system.

Age-Federal Reporters, Inc.

25 And when anything happens on the system that would

agb6

1 overload that line, it immediately telegraphs this into the
2 computer and an alarm sounds and he looks up at the CRT that
3 has that delineation on it and he sees a red figure that tells
4 him what the load is, and the fact that, if it isn't relieved,
5 something is going to reswitch the system, reconfigure it, as it
6 were, and he's going to have a burndown and so therefore he
7 goes to work.

8 Now he can also ask it what the proper configuration
9 should be to eliminate that overload, he doesn't have to remember
10 that, the computer knows that. And if he has a line that trips,
11 he can ask the computer what's my next emergency that I should
12 be concerned about and, therefore, what should I monitor and
13 watch.

14 These things have been done. And there really is
15 no reason why we should wait. To the degree that we want
16 monitoring of valve positions or temperatures in the thermo-
17 couple -- thermocouple temperatures from the core and so on,
18 it's just a matter of putting the right components into the
19 system to pick this up and crank it into the computer.

20 DR. CARBON: Thank you.

21 Dave?

22 DR. OKRENT: As you know, I'm interested in the
23 topic Jerry Ray just mentioned. I think myself that there are
24 some things that one could do early, there are other things that
25 will take a reasonable amount of time before they can be

agb7

1 implemented.

2 But I think we should consider the possibility of
3 staged use of computer guidance, computer aids to the operator.

4 The topics I had remaining on my list, in no
5 particular order. One that I think I will mention now as
6 something that perhaps we would like to hear from the Staff at
7 a future time is whether our experience at Three Mile Island
8 raises any questions for sites that have shared facilities.

9 And, as an example which may or may not be relevant,
10 I think sometimes there may be a shared auxiliary building.
11 Assuming that there is, and assuming that they had an accident in
12 one plant that required recirculation of an active fluid into
13 the auxiliary building with the kinds of concerns from leakage
14 and so forth that there have been on the Three Mile Island 2
15 system, have some impact that I think -- that may not be a good
16 example.

17 But at any rate, it seems to me that some looking at
18 shared facilities probably warrants attention, but I'm not
19 suggesting that that's an immediate item. I just wanted to
20 mention that.

21 Another item that I would like to raise for
22 Committee consideration is a little bit related to points raised
23 by Lawroski and Lipinski, namely, should we recommend an
24 initiation of what we might call contingency studies. These
25 can take various forms. And we've heard a couple of specific

agb8

1 types of such things mentioned.

2 I, for one, think worthwhile for both the industry
3 and the NRC to give this some early attention and to see what
4 kinds of things are developed out of such studies and see what
5 kind of things one might want to recommend for implementation
6 in, say, various stages, various periods of time.

7 But I think different people looking at this matter
8 from their own perspective will have ideas that when we have
9 them all before us for consideration will be more useful than
10 from a single perspective. I have certain suggestions, but I
11 know there are others that I would think of.

12 So I don't know whether at this meeting or a meeting
13 soon, but I would suggest that the Committee seriously consider
14 recommending all contingency studies at a relatively early
15 time so we can see what makes sense to do.

16 DR. CARBON: I personally share that view to a
17 strong extent.

18 DR. OKRENT: I don't have too many more things on
19 my list.

20 Carl Michaelson mentioned, I think it was yesterday
21 and he has mentioned it before, that one sometimes has to be
22 careful about the isolation of breaks. I think he's mentioned
23 that you can have a problem in isolating small breaks under
24 some situation.

25 It might be a possibility for isolating initially

agb9

1 a medium sized break, I don't know. I don't know whether that
2 requires any special kind of training or information or so forth
3 that we're now able to define, but I think we ought to ask the
4 NRC Staff to think on this, to let us hear in the not too
5 distant future whether they see any unusual circumstances that
6 could arise from this kind of situation.

7 It might be a situation that occurred because the
8 operator was doing what he was supposed to do by procedures.
9 It might be a situation where the operator thought it was a good
10 idea, there were no procedures, and he didn't necessarily have
11 the information or really all of the analytical capability
12 right on-hand to foresee what the consequences might be.

13 And maybe this has all been studied and people
14 have ascertained that there are no untoward results. But I,
15 for one, would like to see this given at least a sort of a
16 short-term review if it hasn't been done.

17 And then if significant areas arise out of a short-
18 term review, then they can look at it in a more sophisticated
19 way. In other words, I would prefer not to see three years of
20 study using the TRAC code before I got any information on the
21 subject.

22 I would recommend, if it has not already been looked
23 at adequately, that we get a sort of elementary examination to
24 see what are the important questions.

25 I don't know whether Carl has anything to add in

agbl0

1 that area.

2 MR. MICHAELSON: I was going to comment on that
3 area in just a little bit.

4 DR. OKRENT: Okay.

5 I think the only other comment or question that I
6 have is one, again, that the Committee may want to think on,
7 and that's whether we want to recommend that the NRC get its
8 own capability for simulation of what I will call anomalous
9 transients for the kinds of reactors it's licensing.

10 These would be transients that go beyond what the
11 operator is trained for on the commercially-available simulators
12 and so forth, and this would be aside from anything that the
13 industry might decide to do on its own volition. I think we
14 heard that they have not done a large amount of such studies,
15 or at least those we've spoken to. But it seems to me that
16 this could be an area for early consideration by the NRC.

17 And you know, in discussions about the safety
18 research program, people asked are there things you can do with
19 a million or two million dollars if you could find it from the
20 LOCA ECCS program. Well, here's one area -- or maybe four
21 million dollars, I don't know.

22 DR. CARBON: That covers them, then?

23 DR. OKRENT: Yes.

24 DR. CARBON: Carl, can I call on you for comments?

25 MR. MICHAELSON: There were a few items that I did

agbl1

1 want to discuss here.

2 First of all, I would like to continue to endorse
3 the ACRS letter that was sent a week or so ago. I think -- at
4 least from what I've heard here so far seems to substantiate
5 the concerns that were expressed in this letter.

6 So, getting on to more specific questions which are
7 now coming up, one of which Harold Etherington has pursued,
8 is the question of natural circulation. I think this is a very
9 important question for the operating plants.

10 I have some questions or concerns about it that
11 really need to be considered. They may have come out just a
12 little earlier this morning. For instance, the availability of
13 the pressurizer heaters on the diesel generators. I think it's
14 important that the pressurizer heaters be on the diesel
15 generators because after loss of off-site power, it's imperative
16 to retain pressurizer control as long as possible.

17 I would think the NRC would like to go and check
18 real quick to find out which plants can put their pressurizer
19 heaters on the diesels. I would also recommend that they be
20 put on in dual banks, namely, a portion of the heaters on one
21 generator and another portion on another generator.

22 This really isn't all that difficult to do and it
23 can be very helpful.

24 DR. SHEWMON: What sort of power are we talking about
25 there?

agbl2

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

MR. ETHERINGTON: 1800 kilowatts, I believe, isn't it?

MR. MICHAELSON: 1600 to 1800 kilowatts. It's a substantial load. You might be able to show by analysis that maybe you don't need all that.

MR. ETHERINGTON: That's in several banks or so.

MR. MICHAELSON: That's right, seven or eight banks or so. It may be shown by analysis that you don't need to retain all of them for the retention of the condition that you want. It takes some analysis.

I think it should be looked at, though, because if the plant is not prepared to go on the diesels then, as soon as the pressurizer proceeds to cool off, you can start creating difficulties.

This natural circulation is a fairly complex question. I think that became apparent from some of the B&W discussion that we had at Three Mile Island. It's a quite complex condition, and it's very important that you retain an adequate thermal center, an adequately high thermal center.

So to do this, it's important to know what the temperature conditions are around the loop. And I think Mr. Etherington has pointed out now that you don't want, of course, to approach the saturation condition.

I would question whether or not the thermocouples in the hot leg are really necessarily indicative of whether or

agbl3

1 or not natural circulation is in progress. You can, for instance,
2 lose natural circulation and have the thermocouples in a hot leg
3 level off very nicely at what appears to be below saturation
4 conditions when, in reality, the core is getting very hot and
5 the voids are forming in the core and the top of the reactor
6 vessel.

7 So it's important to look at more than just the hot
8 leg. The temperature on top of the core is a very good thing
9 to compare, and I think this was brought out a little earlier
10 this morning, that you really want to monitor the top of the
11 core as well as the hot leg.

12 DR. SHEWMON: Let me stay with that for a minute,
13 Carl. The flow meters don't work down there. You're telling
14 me that it takes a fair amount of sophistication, at least, to
15 get it from the thermocouples around and you could be confused.

16 Just how does an operator tell unambiguously that
17 he has established and maintained natural circulation?

18 MR. MICHALESON: Well really he can tell it with
19 reasonable certainty if the thermocouples at the exit of the
20 core, which are basically on top of the fuel, are really the
21 same as the thermocouples in the hot leg and that the cold leg
22 thermocouples indicate an appropriate delta-T which he could
23 be instructed to know how much it should be. If you've got
24 that situation, things should be all right.

25 DR. SHEWMON: How far down from the pressure

a gbl4

1 temperature are the hot leg temperature indicators?

2 MR. MICHAELSON: The hot leg, it's up from the
3 pressure vessel.

4 DR. SHEWMON: From the top of the core. How far
5 apart are the thermocouples? Is one well out of the way of the
6 other?

7 MR. MICHAELSON: Generally, the thermocouples for
8 the exit temperatures are up along the hot leg and vertical
9 section up near the flow meters somewhere generally and well
10 removed from the core.

11 And of course then we have the temperatures
12 immediately above the core, at least as far as we know, on the
13 B&W plants. And we have the cold leg temperature below the
14 pump a little bit. I'm not sure exactly, I think it's a foot
15 or so.

16 So it's important, I think, to instruct the operators.
17 And I assume that this is already going on, but I think it is
18 well to reiterate that the instructions must be written for
19 natural circulation and they must include monitoring all the
20 things that might help to assure the operator -- not again
21 mislead him because he may be only watching, say, the exit
22 temperature up near the flow meter and again get misled.

23 A couple of other points on natural circulation.

24 Of course, we certainly do need some good procedures. But the
25 next question one has to ask then is, well, what about single

agbl5

1 failures during natural circulation, should we assume that
2 natural circulation will be done without single failure analysis?
3 We also have to ask, how about unwanted actions during the
4 natural circulation course? These are actions generated by
5 spurious opening of valves or things of this sort.

6 These are questions which I think some guidance
7 needs to be provided on.

8 Going to another subject, that's the question of
9 these very small breaks that one can experience, such as with
10 open relief valves. It's quite important, I think, to get on
11 with the analysis of these very small breaks as soon as possible
12 and I think that's what the ACRS letter basically was saying.

13 I think to verify how well this is being done, it
14 would be ideal to have this as an early agenda item to find
15 out just where we're really at before making further judgments
16 on operating plants.

17 In this regard, of course, there's the question of the
18 suitability of hot leg instrumentation, which I assume is being
19 pursued now for both its practicality and its usefulness.

20 Another consideration relative to this is the one
21 that you brought up, Dr. Okrent, the question of operator
22 intervention in an undesirable fashion.

23 An example, for instance, is he may have a very small
24 break loss of coolant accident in progress and he finally
25 figures out where the break is and has the capability, in some

agbl6

1 cases, to isolate it. For instance, a letdown line break can
2 be so isolated.

3 If he isolates it after he has lost his natural
4 circulation, which is usually very early in the game, but before
5 he has established a proper evaporation condensation mode of
6 operation, to terminate it at that point means he must somehow
7 get back to natural circulation since he is not yet functioning
8 using the steam generators as condensers.

9 Unless this situation is analyzed, it would be
10 highly desirable for him not to intervene and interrupt the
11 break, particularly if your analysis shows if you don't inter-
12 rupt the break that you can then take care of it in the
13 condensing mode. So it really needs to be considered.

14 DR. PLESSET: While you're on that, it seems to me
15 that there should be no problems in principle or difficulty
16 in making these small break analyses. Do you agree with that?

17 MR. MICHAELSON: Yes.

18 DR. PLESSET: Sometimes large breaks give you a
19 lot of trouble.

20 MR. MICHAELSON: These are so slow moving --

21 DR. PLESSET: Yes.

22 MR. MICHAELSON: -- that you could do them by
23 step-wise calculations, sort of on the back of an envelope.

24 DR. PLESSET: Right.

25 MR. MICHAELSON: They're not highly sophisticated.

agbl7

1 At least I don't believe they would be highly sophisticated
2 calculations.

3 DR. PLESSET: I would tend to agree with you. So
4 it's not a difficult task to do these thoroughly and to cover
5 a spectrum of possibilities.

6 MR. MICHAELSON: I would not think so. A computer
7 would be desirable mainly to mechanize the process, so you
8 could look at a lot of possibilities. But as far as the degree
9 of difficulty, I think it is strictly -- you could do it strictly
10 by static calculations a step at a time.

11 Again for the very small break analysis, it's
12 quite important to have procedures to either, you know, make
13 sure that the operator is adequately instructed as to whether or
14 not he could intervene in the process and that could be verified
15 by calculation.

16 If the calculations show that intervening at any
17 point in time is an acceptable process, then certainly
18 instruct the operator to isolate the break if he can figure out
19 where it is and has the capability to isolate it.

20 One subject which hasn't been mentioned too much
21 but I think is one which we perhaps need to think about a little
22 bit relative to an event of this sort, and that is the possi-
23 bility for hydraulic instabilities that you can get into.

24 Here we're talking now about a core dryout situation
25 wherein cold water was being injected into a superheated steam.

agbl8

1 This can create some rather severe flash condensing phenomena,
2 when you inject cold water into steam.

3 And we haven't really kicked that one around too
4 much, but I don't want to lose sight of it because it can cause
5 warping of the core barrel and things of this sort. So perhaps
6 at least it's worth thinking about.

7 I'd like to --

8 DR. OKRENT: Excuse me. In that regard, is there
9 any prior problem in the secondary generator? Are they designed
10 for dryout and then cold water coming in and so forth?

11 MR. MICHAELSON: I don't know the details of that.
12 I would think that would be a good question, though, to ask the
13 appropriate people, yes.

14 I was more concerned about the safety injection
15 in close proximity to the annulus of the reactor and the fact
16 that late in the game we appeared to have dried out this region
17 and it was occupied by superheated steam, since the core vent
18 valves can open under this condition and, therefore, one might
19 be concerned.

20 And this would depend very much on the injection
21 rate, which might, on occasion, have been very low and then
22 turned up with very high values.

23 We don't know yet the time history of how this thing
24 went out in time when they starting doing a large number of
25 maneuvers.

agbl9

1 But in such maneuvers wherein you essentially shut
2 off the cold water and then later inject it very rapidly, it
3 is a good setup for flash condensing the steam in the region,
4 and that creates then some good knocking.

5 DR. SHEWMON: I don't understand. It seems to me
6 you're talking about flash evaporation as much as flash
7 condensing. You're at one end of the scale and I'm at the other.

8 MR. MICHAELSON: Right. You could do both, of
9 course. In this case you have a pipe filled with high pressure
10 high temperature steam in which you suddenly splash cold water,
11 which then creates an ideal condensing media.

12 It's like a spray tower, I guess, in a way, because
13 the water is coming in vertically and splashing around --

14 DR. SHEWMON: You're using that as sort of a
15 pressure reduction and inversion?

16 MR. MICHAELSON: This is what you have to look at.
17 People have gotten into the situations wherein they have steam
18 filled pipes in which they inject cold water, feedwater lines
19 particularly, they've done this sort of thing.

20 They allowed the water to disappear from the
21 feedwater line and then bring a slug of cold water in, and it
22 creates hydraulic instability. You get flash condensing of
23 steam.

24 And I'm just saying again this is something that one
25 ought not lose sight of to make sure it is not instrumental,

agb20

1 the effect here. Because there is no provision to gently
2 inject this into the pipe, or to try to keep it from rapidly
3 condensing the steam.

4 DR. PLESSET: You could get first a collapse and
5 then a re-expansion.

6 MR. MICHAELSON: As I understand it, it's primarily
7 the collapsed steam that does that.

8 DR. SHEWMON: Do you get a water hammer? Is it
9 first cousin to that?

10 DR. PLESSET: Yes.

11 MR. MICHAELSON: You trap steam bubbles in a water
12 line, for instance, in the process of drying out and refilling,
13 and the rapid condensation creates a little problem.

14 I want to go on to another subject which was kicked
15 around just a little bit ago. I guess I'm going to have to be
16 the devil's advocate on this one, because I can't fully agree
17 with the idea of using status monitoring in an extensive sense.

18 In a process system, a fluid hydraulic process
19 system, it's very difficult -- it's possible but extremely
20 difficult to monitor all the kinds of things that can prevent
21 the system from working, keeping in mind you're talking about
22 instrument valves, you're talking about the process valves
23 themselves, you're talking about seal water coolers on pumps,
24 water coolers on motors, literally hundreds of valves which
25 would have to be monitored if you want to assure yourself that

agb21

1 every aspect of this system is ready to run.

2 I've looked at it myself a little bit because I
3 think, again, it's an ideal thing to think about. But when you
4 start looking at the practicality of it, it's really hard to
5 justify.

6 You can create safety problems, of course, by
7 unusual degrees of complexity, which this would entail, and
8 it's just not practical on, say, a half inch instrument valve
9 to try to figure out how to put a limit switch on it to monitor
10 its position. The limit switch is bigger than the valve.

11 It just creates a number of problems and then you
12 have to multiply them by thousands, and it gets very complex
13 to do. So I think at that point you have to trust administra-
14 tive procedures.

15 DR. LAWROSKI: Wouldn't you be farther ahead to
16 at least get the DC valves displayed and --

17 MR. MICHAELSON: By all means, all main line process
18 valves should have status monitoring, that includes maintenance
19 valves particularly, because those are the kind the LERs
20 indicate people forget to open when they finish their maintenance.

21 But to go down into the ancillary systems, and
22 attempt to monitor their status is very difficult on fluid
23 systems. It's relatively easy on electrical portions. But
24 on the mechanical portions, it becomes quite difficult.

25 DR. CARBON: Any other questions of Carl?

agb22

1 Is Dr. Stratton here at the moment?

2 Do other members of the Committee have topics they'd
3 like to bring up here? We've covered a fairly extensive list.

4 MR. FRALEY: Well there are some that people are
5 already looking at, and that is the provisions for containment
6 isolation. And certainly the sump pump system, which I
7 understand on some plants has a radioactive monitor which
8 isolates them when it starts to pump radioactive water, but on
9 this plant did not.

10 That is an area that needs further consideration,
11 and the signals for isolating the containment, at which you
12 do or don't isolate, but of course the Staff is looking hard
13 at that.

14 The other thing that was mentioned was hardening
15 some normal equipment, so that it will operate under accident
16 or quasi-accident conditions. In fact, most of the equipment
17 that's running is not safety-grade, although it may have been
18 hardened with respect to certain things.

19 And of course that would include the upgrading of
20 the RHR system, perhaps to higher pressure and higher capacity.
21 Lipinski mentioned the need for improved reliability in the
22 heat sink, and it might be accomplished by hardening the RHR
23 system and expanding it and then you wouldn't need to rely on
24 the steam generators.

25 So those are areas which I think may warrant further

agb23

1 attention.

2 DR. CARBON: I think it would be appropriate here
3 to recount, to review, just make a list of the things we asked
4 the Staff yesterday or this morning to provide.

5 I wonder if I could go around and ask, do you have
6 such a list, Ray, or do you have part of a list?

7 Or, Jim, do you have a list, could you read off the
8 list?

C2 9 MR. JACOBS: It's going to be hunt-and-peck and
10 hunt-and-find.

11 MR. FRALEY: Why don't we take a few minute break
12 and maybe we could organize it better.

13 DR. CARBON: Let's take a short break, then, and
14 then, Jim, will you go through that, please?

15 (Recess.)
16
17
18
19
20
21
22
23
24

ld ebl

2.020

1 DR. CARBON: Let's go ahead with the meeting.

2 Jim, can you recount the things that we asked the
3 Staff to provide us yesterday, or the comments that were made
4 to the Staff on things that we want to see them do, with per-
5 haps emphasis on the last points?

6 MR. JACOBS: I think I can. I will try to give them
7 in the chronological order in which they were asked during
8 the meeting.

9 First, it was requested that an analysis be performed
10 on the power-operated relief valves to determine whether they
11 can close under all of the fluid conditions they are likely to
12 see, including steam, water, and a mixture of the two.

13 The Staff was asked to assure that the small break
14 can be analyzed so that the wrong conclusions are not made by
15 plant operators.

16 The Staff was asked to provide an analysis of the
17 fission products that were found in the primary coolant samples.
18 I understand they have analyses. They just didn't have them
19 with them.

20 The Staff was asked to provide documentation on
21 natural circulation tests and on cases where B&W plants have
22 had to rely on natural circulation cooling.

23 DR. CARBON: That was requested of the Staff or of
24 Babcock and Wilcox?

25 MR. JACOBS: I'm not sure who it was requested of,

eb2

1 but it was following Dr. Hanaeur's presentation.

2 The Staff was requested to provide adequate instruc-
3 tions to operators on danger signals and how to get the plant
4 into natural circulation mode.

5 They were asked to provide additional information
6 on the radiation levels of the Three Mile Island containment
7 atmosphere.

8 They were asked to look at the difference between
9 the traditional steam generators versus the once-through steam
10 generator with respect to loss of heat sink.

11 And also they were asked to assess the benefits of
12 early scram on turbine trip and/or loss of feedwater.

13 DR. CARBON: What was the last one?

14 MR. JACOBS: To analyze the benefits of-- I think I
15 have this one reversed, the benefits of early scram on the loss
16 of feedwater and turbine trip. They come simultaneously,
17 practically.

18 DR. PLESSET: What was the one before that? Once
19 through versus--

20 MR. JACOBS: Once through versus the traditional
21 steam generators, and with respect to their reactions, I guess,
22 with regard to loss of heat sink, or how you lose the heat sink.

23 DR. PLESSET: In transient conditions.

24 MR. JACOBS: Yes.

25 And then both Babcock and Wilcox and the Staff were

eb3 1 asked to assess the level of training with regard to the need
2 to get plants -- the degree of emphasis in training on the need
3 to keep the core covered, and that was asked both of Babcock
4 and Wilcox and the Staff.

5 The Staff was also asked for identification of the
6 emphasis with regard to the training of Three Mile Island
7 operators specifically.

8 DR. CARBON: This came up this morning.

9 MR. JACOBS: Many of these things came up this morn-
10 ing.

11 The Staff was also asked to provide a chronology of
12 the radiation level readings taken out of the plant during
13 transient.

14 That completes my list.

15 DR. CARBON: The last one, would you repeat it?

16 MR. JACOBS: A radiation level chronology from the
17 instrumentation during the transient at Three Mile Island.

18 DR. CARBON: Gentlemen, I guess I would ask at this
19 point, again raise the question, do we want to put any of these
20 things, recommendations, whatever, in a letter to the Commission
21 today, or do we want simply to discuss them or to handle them
22 at some later date?

23 The first question: Do we want to write a letter
24 to the Commission?

25 MR. MATHIS: Max, I don't think we've got time,

eb4

1 really, to write a letter. Can we give our impressions to the
2 Commissioners verbally, and maybe we'd want to follow up with
3 a letter later on. But we have to establish some priorities.

4 The list we have developed so far is lengthy and
5 we need to say Okay, what are the things that need to be done
6 now with what we have available. And that I think could be done
7 verbally.

8 DR. PLESSET: I think that's well put, and I would
9 concur with what Bill has said.

10 I think we should be prepared, if we are meeting
11 with the Commissioners, to discuss some of these things ver-
12 bally if that's not too difficult for the Chairman to organize.
13 I think we do want to write a letter but I think we need a
14 little time to get better organized so we can do it more care-
15 fully and in a less rushed atmosphere. We don't have much time
16 today.

17 DR. OKRENT: When do we meet?

18 DR. CARBON: We're scheduled to meet at 3:30. It's
19 recognized that some of the people will need to leave.

20 MR. FRALEY: For those of you who are heading to
21 Dulles, we're trying to get a car standing by so that you can
22 stay as late as possible, and we'll tell you what time that is,
23 to get you out to catch your flights.

24 If there is anything else we can do for anybody else
25 to arrange special transportation so you can stay a little

eb5

1 later, let me know.

2 Mr. Etherington?

3 MR. ETHERINGTON: I'd like to get out as soon as I
4 can. I'd like to get away at 4:00.

5 DR. PLESSET: I have to get out to Dulles a little
6 bit ahead of that because I don't have a ticket yet.

7 MR. FRALEY: Mr. Muller has volunteered to do what-
8 ever is necessary so you don't need to leave any earlier.

9 DR. OKRENT: I was going to suggest that if we broke
10 for lunch relatively early today, one or two of us could try
11 to write something down. It might look like a list from which
12 we made comments to the Commissioners; it might end up being
13 partly something that we could transmit in writing. We don't
14 have to reach a judgment until we see how successful people who
15 write something down are, and where the Committee thinks it
16 wants to be, you know, whether it thinks it wants to discuss
17 the points orally or some of them transmit in writing.

18 But it might be useful to do that in any event.

19 DR. PLESSET: I think that's right. I think the
20 advantage of thinking in that term is that since there are a
21 lot of the members who aren't here, if we had something written
22 down that Ray could use in the next few days to get in touch
23 with the other Committee members and maybe read it to them and
24 get suggestions, that would accelerate it quite a bit.

25 DR. OKRENT: But in any event, if you'd like, we

eb6

1 could try that. I don't know what your image of when lunch was
2 going to be is.

3 DR. CARBON: Well, the image was 12:30.

4 DR. OKRENT: Did you have something else you were
5 going to cover between now and 12:30? I don't recall.

6 DR. CARBON: No, just the continuation. This ques-
7 tion, do we write a letter, and then presumably we do want to
8 have a meeting with the Commissioners and we'd be prioritizing
9 all the topics we mentioned this morning and agreeing as to
10 which ones we want to bring to their attention, and what we
11 would say.

12 DR. OKRENT: I would suggest that you move up lunch
13 to maybe twelve o'clock or some such time, and that we have
14 discussion and additional comments until then, and then a
15 couple of us can try to -- or more can try to, right here in
16 this room, if Mr. Fraley could bring a sandwich in.

17 DR. CARBON: Is that agreeable?

18 DR. LAWROSKI: I think so.

19 Does the Staff have anything over and above what
20 was given to us yesterday that may be important for us to know?

21 DR. CARBON: Not that I'm aware of. The Staff has
22 not said anything. I'm looking for Larry. He's out for the
23 moment, I guess.

24 DR. LAWROSKI: Has anything further developed, any
25 other developments? Are they closer to decisions about getting

eb7 1 this thing into cold standby, or what-not?

2 DR. CARBON: I have no knowledge. When Larry comes
3 back--

4 DR. OKRENT: I must say I find it a little curious
5 that we have only Larry here today. I must say-- I'll just
6 let that stand.

7 DR. CARBON: Well, let's then do move lunch up to
8 whenever it's a reasonable time.

9 I wonder if it would be appropriate to go through
10 our list of items here and see which ones strike people as
11 important in terms of bringing them to the Commissioners'
12 attention, either by letter or in the meeting today, and get
13 some idea of what we as a group consider to be the important
14 topics to bring up.

15 Does that strike you as reasonable?

16 If so, let me go through the items real quickly, the
17 things that Jim Jacobs just read off:

18 Analysis of power-operated relief valves to see that
19 they close properly, and so on.

20 Is that one that we want to--

21 DR. SIESS: I don't understand it.

22 DR. CARBON: Can you refer again?

23 MR. JACOBS: It was a question asked by Dr. Plesset,
24 and I think perhaps he can probably phrase it better than I can.

25 DR. PLESSET: This is a question of the pressure.

eb8

1 the force on an open valve when you have a flow, possibly of
2 low quality, going through it which might prevent a valve
3 which has a closed signal from closing.

4 I made estimates of this and some of those forces
5 could be very high.

6 Now Hanaeur was here when I mentioned this and he
7 said they're concerned about this and have done some analysis
8 also in connection with ATWS.

9 So it's an item of some significance. I don't know
10 whether this had anything to do with that electromat relief
11 valve on the pressurizer because if they got some high velocity
12 flow, particularly if it had some water in it, it might not
13 close. I don't know. He didn't know either, and I haven't been
14 able to find out.

15 DR. SIESS: This applied to power-operated relief
16 valves like here, pilot-operated relief valves. What about
17 safety valves?

18 DR. PLESSET: It's a pretty general point.

19 Do you know, Harold, if they've been looking at this
20 beyond-- Has it been looked into --

21 MR. ETHERINGTON: No, I don't.

22 DR. PLESSET: -- in connection with the closing of a
23 valve?

24 MR. ETHERINGTON: I haven't had any discussion on
25 this. I think the question of water hammer, though, when a

eb9

1 slug of water hits is important.

2 DR. PLESSET: That's an additional point. It's a
3 possible source of damage to the valves.

4 DR. SIESS: Can we try to categorize these as to
5 short or long term?

6 DR. CARBON: Yes, we could.

7 DR. SIESS: I would tend to think that would be long
8 term; you know, whether or not this valve stuck open, there
9 are other small break LOCAs that could get you into similar
10 situations. This is just one in the category, and it differs
11 from other small break LOCAs in that it has occurred. And I
12 may not be right there.

13 But it seems to me it's a little longer term.

14 Obviously if the valve, that particular valve, has
15 got a history of sticking open, I mean power-operated and
16 pilot-operated, both, WASH-1400 assumed 10^{-2} probability with
17 a factor of 10 either way. And that's why they've got a block
18 valve in front of it, I would suspect.

19 DR. PLESSET: Yes, but the operator might not have
20 had a signal. The signal might have been that the solenoid
21 was energized and that would indicate that it was closed, and
22 it might not be able to close.

23 DR. SIESS: Yes. But that's a different question as
24 to whether he knows when it's closed.

25 DR. PLESSET: That's also part of it.

eb10

1 DR. SIESS: I think that would be independent of how
2 reliable it was.

3 DR. PLESSET: Well, I think we have a kind of a mix
4 of long-term questions and some immediate short-term questions
5 that apply to this incident, and then some general suggestions
6 such as Carl Michaelson has made, Okrent has made, and Lipinski.
7 And I thought that those would be more what we want to consider
8 right now than some of the queries of the Staff. Presumably
9 they'll come back with answers, one way or the other.

10 DR. SIESS: As I was listening to some of the points
11 raised this morning I was trying to put them in three cate-
12 gories: prevention, mitigation, and then recovery. I think
13 Steve had a number that related to difficulties at Three Mile
14 in knowing the situation which relates to recovery from an
15 accident. It wouldn't have much help in preventing or mitigat-
16 ing.

17 I don't know whether we could try to classify them
18 that way, prevention and mitigation for similar plants.

19 DR. CARBON: We could give it a try. It seems to
20 me they might fall in either category, they might be either
21 long term or short term, but still we might bring them up today.

22 DR. SIESS: I would certainly be in favor of keeping
23 our recommendations or comments to the Commission on short to
24 medium term, and have more time to review the long-term things
25 and sharpen up our questions on them, or broaden our questions

eb11

1 on them. We might go either way.

2 DR. CARBON: Short to medium term then.

3 Where do you classify this one, Milt, the one on
4 the analysis of power-operated valves?

5 DR. PLESSET: Well, that's going to take some time.
6 I'd say that's long term. Chet has pointed that out and I
7 agree to that.

8 DR. CARBON: The second one then was to assure that
9 small breaks could be analyzed so that the wrong conclusions
10 are not made by operators.

11 DR. PLESSET: They could be analyzed. I think I
12 brought this out with my exchange with Carl. The question
13 really is can the operator deduce the proper conclusion from
14 what happens. Is that agreeable?

15 DR. SIESS: It seems to me there are a number of
16 things there. There are ultimate courses for small breaks.
17 The point Carl made about isolating a small break at various
18 times into the excursion might give different results, the
19 small break that grows into a larger break, and that can occur
20 at different times. This would be a pipe break that started
21 off as a crack and opened up.

22 It might be the same problem with large breaks,
23 large breaks that are made from small breaks by a valve that's
24 closed and doesn't close all the way.

25 DR. PLESSET: I think this is an important item.

ebl2

1 DR. SIESS: We mentioned this in our previous letter.
2 DR. CARBON: Yes.
3 DR. SIESS: Do we have copies of that previous
4 letter?
5 DR. PLESSET: Did we mention it this way?
6 DR. SIESS: It's not in the folder.
7 DR. CARBON: It was handed out yesterday.
8 DR. SIESS: I didn't get it.
9 It's being handed out today, again, I see.
10 (Document distributed.)
11 MR. RAY: It's in the third paragraph of the letter.
12 DR. PLESSET: It's essentially in there.
13 DR. SIESS: We could obviously elaborate on that but
14 I don't think we'd justify doing much elaboration now, but I
15 don't think it would hurt, in our discussion with the Commis-
16 sioners to repeat this recommendation and indicate that we
17 made it in that letter because we thought it was an early-term
18 matter and we still think it is -- if we agree to that.
19 DR. CARBON: Is that agreeable?
20 (Indications of assent.)
21 Let's do so.
22 DR. PLESSET: I think we might mention the further
23 analysis is of concern, but that's not all going to be imme-
24 diate; it's going to take some time.
25 DR. CARBON: Number three on Jim's list was providing

eb13

1 analyses of fission products from primary coolant samples. I
2 guess that would be long term.

3 Number four--

4 DR. LAWROSKI: It's more in the nature of providing
5 appropriate samples.

6 DR. CARBON: Number four, documentation on natural
7 circulation tests in cases where B&W plants have had to rely
8 on natural circulation. I think that was primarily to B&W.

9 MR. ETHERINGTON: This is the kind of thing you
10 usually ask the Staff without worrying the Commissioners about.

11 DR. CARBON: Number five, adequate instruction to
12 operators on danger signals and how to get plants in natural
13 circulation.

14 DR. OKRENT: The previous letter dated April 7th,
15 in that letter we limited somewhat, and it might pay to
16 consider specifically calling out the natural circulation ques-
17 tion.

18 DR. CARBON: Is everyone agreeable to that?

19 DR. PLESSET: It would be nice to have the data
20 that we asked the Staff for regarding the occasion on which it
21 was required, or as the result of some tests, were they good
22 tests or not.

23 Are we ready to do that?

24 DR. OKRENT: I think it wouldn't hurt to indicate
25 the importance of the operator being better informed about

eb14

1 when and how to go into natural circulation, and the possible
2 need to develop further knowledge. I think that is something
3 we can do.

4 DR. CARBON: Is it agreeable to include this one,
5 number five?

6 Number six I think was simply asking for information
7 on radiation levels at the Three Mile Island containment.

8 DR. OKRENT: Not just the containment. The question
9 in people's minds there was interest in what information was
10 available when, and in what detail concerning, for example,
11 levels in the primary coolant as well as elsewhere in the plant,
12 as to whether or not this would give you or did give other
13 insights into what was going on besides that which was avail-
14 able from other information.

15 It's a question of what was actually measured, and I
16 suppose where it was displayed, which would also be relevant.

17 DR. CARBON: Is that one to bring up today?

18 DR. OKRENT: I don't think I would bring it up to
19 the Commissioners.

20 DR. CARBON: Number seven was the difference between
21 traditional steam generators and once-through steam generators
22 with respect to the loss of heat sink in transient conditions.

23 DR. SIESS: The loss of which heat sink?

24 MR. JACOBS: The steam generator.

25 DR SIESS: Is this the question of the difference

eb15

1 in inventory?

2 DR. PLESSET: There are two aspects of it. For
3 example, in load-following how does the once-through compare
4 in its stability of behavior with the conventional steam
5 generator? I had a broad question for the Staff as to the
6 difference between the once-through and the conventional steam
7 generators in transient conditions.

8 There's another aspect that Harold brought up and
9 that's in connection with the steam generator as a heat sink,
10 once-through versus the conventional. I think that's another
11 question.

12 DR. CARBON: I guess that's long term, isn't it?

13 DR. PLESSET: I would think so, but I think it's
14 kind of important.

15 DR. CARBON: Do you want to say anything about it
16 today?

17 DR. OKRENT: It's something we ought to examine in
18 Subcommittee meetings or Full Committee meetings in a little
19 more depth I think myself.

20 DR. PLESSET: And get some Staff information which
21 I was hoping was what we would have, unless Harold has something
22 more specific about the heat sink problem.

23 MR. ETHERINGTON: No, what I think we need is a
24 better basic understanding of how these function in the natural
25 circulation mode. Is it a matter for analysis and probable

eb17

1 experiment?

2 DR. CARBON: Number eight, benefits of early scram
3 on loss of feedwater, particularly the benefits of an early
4 scram.

5 Is that the point Walt was making?

6 MR. LIPINSKI: Yes, loss of feedwater.

7 MR. SIESS: Earlier than 12 seconds?

8 MR. ETHERINGTON: The temperature I think rises
9 about four degrees a second at full power, so that early scram
10 does mean something. If you can knock six seconds off the
11 scram time, that's 24 degrees of temperature rise. This would
12 assume no heat removal of course.

13 DR. CARBON: Did you finish, Harold?

14 MR. ETHERINGTON: Yes.

15 DR. CARBON: Repeat it, would you?

16 (Laughter.)

17 MR. ETHERINGTON: If you were taking no heat out
18 of the system this would raise the temperature of the primary
19 system about four degrees, as I recall, but of course you are
20 removing heat. You don't actually get that rise. It is just
21 a measure of how much heat you would remove if you scrambled
22 earlier.

23 MR. LIPINSKI: That's precisely the point. Because
24 if it's eight seconds, it's eight full power seconds into the
25 primary system. That has to be stored.

ab18

1 MR. ETHERINGTON: That's another way of putting it,
2 yes.

3 MR. LIPINSKI: If you scram earlier it just buys
4 you a little more time by getting you that additional energy
5 by scrambling.

6 MR. ETHERINGTON: It became important in this case
7 because the steam generator went dry. It wouldn't be so im-
8 portant in the ordinary way.

9 MR. LIPINSKI: Here you still didn't have feedwater for
10 eight minutes so it would only change the front end of the
11 curve and the temperature still would have risen with time.

2.440

12 DR. SIESS: What kind of scram signal are you think-
13 ing about? Turbine trip or--

14 MR. LIPINSKI: Closure of the feedwater valve or
15 closure of the turbine valve.

ld

16
17
18
19
20
21
22
23
24
25

LE agbl

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. SIESS: They deliberately designed these not to trip on turbine trip.

MR. LIPINSKI: One would have to take a look at the systems to determine where the best place is to take a signal, I wouldn't want to design it right now.

DR. SIESS: Does loss of off-site power cause scram?

MR. LIPINSKI: You don't have any place to dump your load.

DR. SIESS: Does loss of off-site power cause immediate scram?

It's one of the most likely transients, the loss of feedwater, but does the loss of off-site power itself cause scram? Can B&W answer?

MR. TAYLOR: The loss of off-site power will cause you to scram because you immediately lose all four reactor coolant pumps.

MR. ETHERINGTON: Isn't it more direct than that, don't you lose power to the breakers, the scram breakers?

MR. TAYLOR: No.

DR. OKRENT: I think the point under discussion should be looked at. I think we're going to have to look at the multiple ramifications of the question and see what are the advantages and disadvantages of any proposed change of this kind.

agb2

1 So I don't think it's an item that we would identify
2 to the Commissioners. I think we should somehow in the near
3 future initiate obtaining information ourselves from the Staff
4 on that.

5 DR. CARBON: Any disagreement with that?

6 MR. MICHAELSON: Could I comment a little bit on
7 that?

8 The comment that I would like to make, Dr. Okrent,
9 is that the very small break analysis, of course, pertains not
10 just to B&W type plants but to Combustion and Westinghouse as
11 well, and that is where you are involved in the U-tube type
12 steam generator and would therefore need to look at its
13 particular characteristics for the small breaks.

14 DR. OKRENT: I agree.

15 DR. CARBON: Going to Number Nine:

16 "To assess the level of training with
17 regard to the degree of emphasis on the need to
18 keep the core covered information from Three
19 Mile Island especially."

20 That was the request for information by us this
21 morning.

22 DR. LAWROSKI: It's the importance of keeping the
23 core covered in all reactors.

24 DR. PLESSET: That should be addressed to all
25 reactors.

agb3

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. LAWROSKI: Yes.

DR. CARBON: Do you wish to say anything today?

DR. LAWROSKI: I think it remains still very important. I'm sure the people have heard about it but it doesn't hurt to reiterate it.

DR. SIESS: What was it?

DR. LAWROSKI: The importance in the operator training of making sure that the core is always covered.

DR. OKRENT: You may not always be able to keep the core covered.

DR. LAWROSKI: Or that it get, cooled as well, if you can't keep it covered.

DR. SIESS: That's the importance difference, I think. Keeping the core covered is nice, but keeping the core cool is what we want.

DR. SIESS: If the operator were looking at temperatures rather than level indications, he'd be in an entirely different situation.

DR. LAWROSKI: He has to look at whatever information was useful to ascertain that.

DR. OKRENT: I think this is a subset of the general question that, in fact, was identified in our letter. And I for one, would like to learn what is known about these transients and what is learned in the near future and how this relates to operator training and the information that can be made available

agb4

1 to them.

2 I'm not quite sure what I would tell Commissioner
3 Bradford if he asked now what should we go out and tell the
4 Staff to tell the operators to do if all we said was tell the
5 operators to keep the core covered.

6 (Laughter.)

7 DR. CARBON: Well where do we stand?

8 DR. PLESSET: There was one that Michaelson brought
9 up and that's regarding --

10 DR. CARBON: Are you still on --

11 DR. PLESSET: I thought we finished with that --
12 I'm sorry, I thought we were finished, go ahead.

13 MR. RAY: Is the need here to decide what they
14 should tell the operators, or that we emphasize the need for
15 training, regardless of what training has been done before,
16 emphasize now to the Commissioners that there is an urgent need
17 that operators be training specifically in this area. I think
18 that's the important thing.

19 DR. CARBON: That could be one definition of this,
20 yes.

21 DR. OKRENT: Again, though, I have a feeling we have
22 to be careful about giving an operator very strong guidance
23 with respect to a specific situation which may lead him to
24 react adversely to the next situation.

25 So I guess this is why I've been sort of urging

agb5

1 some rather aggressive program of looking at what I will call
2 anomalous transients and so forth and see what are the various
3 ranges of things that can develop and what should the
4 instrumentation be doing and what are the various actions --
5 if there is then a clear pattern and the operator always can
6 look at two instruments and from these know what to do, then
7 it's simple. If there are some where he has to keep another
8 factor in mind, you know, then his instructions have to be
9 somewhat different.

10 This is the only hesitation I have. What is it
11 you are going to have the people tell the operator to look
12 for? He's been trained to handle a range of things already and
13 we're thinking about the other things, and do they all have
14 one pattern to them.

15 DR. SIESS: I agree with Dave. This is a very
16 complicated subject. It gets down to what's the operator going
17 to do, what's the machine going to do, what's automatic, what
18 isn't. And it's going to require a lot of study.

19 It's the man/machine interaction all over again.
20 And I think the analyses have to be made looking at things the
21 operators could do wrong that they should be told not to do
22 and things they should do right that they should be told to
23 do and keep the list as simple as possible. It's not something
24 you're going to come up with in a couple of weeks.

25 DR. CARBON: Shall we, then, drop this and not cover

agb6

1 it today?

2 Item Number 10, I think, was simply asking for
3 information, the chronology of radiation level of the transient
4 at Three Mile Island.

5 I then go back to the about 29 items that we listed
6 this morning, and let's try and go through those very quickly
7 to see what you want to do, to which you want to put high on
8 the priority list.

9 The first one was natural circulation.

10 Harold, do we want to say more?

11 MR. ETHERINGTON: I personally don't, I think I've
12 said enough.

13 DR. SIESS: I think we should inform the Commissioners
14 that we have expressed a number of concerns about the ability
15 to get to natural circulation and stay there, and that these
16 were addressed to the Staff and B&W and I suspect some of them
17 apply to other PWRs. But addressing it to the Staff certainly
18 took care of that. But I think we should tell the Commissioners
19 about that.

20 DR. CARBON: Does that seem reasonable?

21 MR. ETHERINGTON: Yes.

22 DR. CARBON: Good.

23 And Number Two?

24 DR. SIESS: I think it might be worthwhile to make
25 clear that our concern about natural circulation is of two

agb7

1 kinds. One is natural circulation in Three Mile Island 2,
2 which is under some abnormal conditions now and there are a
3 number of proposals which the Staff is looking at very thoroughly,
4 but also the question of natural circulation as the standard
5 procedure for a number of transients.

6 MR. ETHERINGTON: I think Number Two has been so
7 well analyzed I'm not really concerned about it, the Three
8 Mile Island.

9 DR. SIESS: That's Number One.

10 I think if we just mention natural circulation,
11 they're going to take it in the context of Three Mile Island.
12 So I think when you make the point, make it clear that we're
13 not that much -- that we're concerned, but we think that that
14 is in good hands, but we're looking at the other cases where
15 natural circulation is the expected mode of operation after
16 certain transients.

17 DR. CARBON: And Number Two is whether thermocouples
18 below the core are being utilized in an optimum way, having the
19 temperatures available and off-scale, use of existing equip-
20 ment, action in this direction.

21 MR. RAY: What would you think of the merits of
22 extending that to suggest that they be qualified as safety
23 equipment? They're not qualified now as I understand it.

24 DR. SIESS: Do we know whether the other FWR vendors
25 also have thermocouples at the top of the core?

agh8

1 MR. ETHERINGTON: Some do but they also say they're
2 not replaceable, they expect them to last a long time, but when
3 they go they have no intention of replacing them.

4 DR. SIESS: I recall that from several years back
5 and I don't know whether things have changed or not. They were
6 in there for pre-op testing and early tests and verification
7 of analyses.

8 Are they replaceable?

9 MR. RAY: I don't see why they should be.

10 Bill, do you know what the element in the thermo-
11 couple and its circuitry is that might be susceptible to
12 short life? Is it the insulation?

13 MR. MATHIS: I'm not familiar enough with it.

14 MR. RAY: If it is insulation, there's a lot of
15 development that has taken place in the cable industry with the
16 development of insulation that is better able to live through
17 radiation conditions and so on. How severe those are compared
18 to Three Mile Island, I don't know.

19 DR. SIESS: How many thermocouples are still
20 operating at Three Mile Island Unit 1? Can B&W answer that?

21 MR. TAYLOR: 49, Dr. Siess.

22 DR. SIESS: At Unit 1?

23 MR. TAYLOR: Oh, at Unit 1, I can't answer that.

24 I don't know of any problems with them.

25 DR. SIESS: Are they replaceable in your reactors?

endLE

LF

agb9

1 MR. TAYLOR: Yes.

2 DR. CARBON: Jerry, I wonder if that might not be
3 one we could leave as a little bit longer term.

4 MR. RAY: Okay. It's something I think maybe some
5 information might be obtained on the insulation of leads that
6 would be connected in series with the thermocouple elements
7 if that is the weak spot, and I suspect it is.

8 DR. CARBON: I think we could ask the Staff for
9 that.

10 DR. LAWROSKI: I'm not sure I understand what you
11 mean when you say used optimally.

12 MR. RAY: Let's say to endow the components that
13 are in the thermocouple circuits with the capability to last
14 as long as possible in the environment that is characteristic
15 of where they're going to be. They include containment if
16 this is the way they're handled or if they're taken to a con-
17 verter or a transmitter within containment, that that element
18 also be qualified.

19 DR. CARBON: I think Steve is asking a different
20 question. This was Dave's point.

21 I think what he meant was -- although he can speak
22 for himself, I think he was saying that there are thermocouples
23 there. Make use of them.

24 MR. RAY: Oh, yes. All I'm doing is expanding the
25 requirement.

68-103

agbl0

1 DR. CARBON: The original point in the optimum way
2 was to get them out, get temperatures where you can read them.

3 MR. RAY: Use them, in other words.

4 DR. LAWROSKI: This is what you mean by optimum?

5 Okay, I just wanted to be clear.

6 DR. CARBON: Is that correct, Dave?

7 DR. OKRENT: Yes.

8 MR. RAY: My thought was an extended requirement.

9 DR. CARBON: Well with regard to the optimum way
10 sort of thing, do we want to make comments on that today?

11 DR. OKRENT: I think it's reasonable to recommend
12 implementation of changes expeditiously to use such thermo-
13 couples as are available. I would not propose any early
14 requirement that they be safety-grade or so forth. I think
15 we should look at that in connection with other kinds of
16 instrumentation.

17 DR. SIESS: You're saying if they have them, fix
18 them so they can use them.

19 DR. OKRENT: Right.

20 DR. SIESS: If they will read 800 or 900 degrees
21 or 1000, have them record that or display it.

22 DR. OKRENT: Both record and display.

23 DR. SIESS: But if they're not there, don't put them
24 in right away or --

25 DR. OKRENT: I wouldn't make it a regulatory

a gbl1

1 requirement.

2 MR. FRALEY: I would like to suggest that you also
3 add to the same recommendation thermocouples in the tailpipes
4 of the relief valves. I think if they shut those relief valves
5 early in the transition, it will not be a very significant
6 event.

7 B&W tells us there are thermocouples in the
8 tailpipes. I think they're printed out on the same computer
9 printout. I think they also ought to be made readily available
10 to the operator and any other indications of holes in the primary
11 coolant system, pump seals or whatever else is available.

12 I don't know that there are others but, whatever
13 there is available, I think if we're able to isolate it earlier,
14 it would much a much less serious transient. And if it does
15 happen to the tailpipes, that's because no one told us.

16 DR. CARBON: Is that acceptable to everyone, that
17 we will mention this topic and include both the core thermo-
18 couples and the tailpipe thermocouples?

19 This is taking a long time and I'm wondering if
20 there's any way we could do this in a quicker fashion.

21 DR. OKRENT: I have a suggestion, that most of you
22 go out to lunch and a couple of us try to write something for
23 you to look at.

24 DR. CARBON: Including picking up the ones from
25 these?

agbl2

1 DR. OKRENT: We'll try to make it a little bit on
2 the long side, so that those of you unlikely to -- well you
3 might be interested in it, in what we try to include but there
4 would be some guess involved.

5 DR. PLESSET: That sounds like a first rate
6 suggestion.

7 I was just going to mention one thing, Dave. This
8 idea of the pressurizer heaters having emergency capability --

9 DR. OKRENT: I would assume that would be on our
10 list.

11 DR. PLESSET: I thought that was a very good, a
12 very useful suggestion.

13 DR. CARBON: It sounds like a good suggestion.

14 Does anyone want to bring anything else up before
15 we break for lunch? Would you like to ask any people in
16 particular to stay with you?

17 DR. OKRENT: My experience is that Siess is very
18 skillful, but he has a lunch date already, I believe.

19 Carl and Harold Etherington, if they can stay.

20 DR. CARBON: You don't have a lunch date by
21 definition.

22 MR. ETHERINGTON: Okay.

23 DR. CARBON: Carl, can you stay and Walt?

24 MR. LIPINSKI: Yes.

25 MR. MICHAELSON: Yes.

agbl3

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. CARBON: Let's break for lunch, then, for an hour.

(Whereupon, at 12:20 p.m., the hearing in the above-entitled matter was recessed, to reconvene at 1:20 p.m., this same day.)

1Fcont'd
agbl

3.090

AFTERNOON SESSION

(2:00 p.m.)

DR. CARBON: Let's resume the meeting.

You have in front of you a draft letter, the first page of which is typewritten, the rest of it in handwriting. The secretaries are typing the rest of it right now and maybe by the time we get through, we'll have a typed version.

I would think maybe it would be appropriate to -- certainly either for us to read through it by ourselves or perhaps, better yet, to ask someone to read through it.

Dave, would you be willing to read through it?

DR. OKRENT: If you like.

Let me say first that what we tried to do is pick out those items on which we thought the Committee might want to make a comment at this meeting, and then we tried to phrase these in the way that the Committee might put it into a letter. We didn't know whether the Committee wanted to write a letter or not. We may have erred in our choice of which topics the Committee thinks it wants to comment on.

So with those apologies....

DR. CARBON: Okay. Fine.

DR. OKRENT: "During its Special Meeting, April 16-17, 1979, the ACRS continued its review of the circumstances relating to the recent accident at the Three Mile Island Nuclear Station Unit 2.

agb2

1 During this review, the Committee had the benefit
2 of discussions with representatives of the Babcock,
3 and Wilcox Company and the Regulatory Staff. The
4 Committee provided a first interim report on
5 April 7, 1979.

6 "Natural circulation is an important mode
7 of reactor cooling, both as a planned process and
8 as a process that may be used under abnormal cir-
9 cumstances. The Committee believes that greater
10 understanding of this mode of cooling is required
11 and that detailed analysis should be developed by
12 Licensees or their suppliers. The analyses should
13 be supported, as necessary, by experiment. Pro-
14 cedures should be developed for initiating natural
15 circulation in a safe manner and for providing the
16 operator with assurance that circulation has, in fact,
17 been established. This may require installation of
18 instrumentation to measure or indicate flow at low
19 water velocity.

20 "Normal operating limits are reviewed by
21 the Regulatory Staff in detail and are formalized
22 in the Technical Specifications for the unit. Shut-
23 down procedures are also reviewed by the Staff, but
24 the Committee believes the review may not be made in
25 the same depth as the operating limits. The Committee

agb3

1 suggests that consideration be given to requiring
2 the Licensee to prepare a formal document for NRC
3 approval, defining limits for shutdown modes."

4 By the way, these are not necessarily in a logical
5 order. They were stapled together at random.

6 "The Committee recommends that contingency
7 studies be made for operating nuclear power plants
8 to ascertain what additional measures might be taken
9 to limit the extent and consequences of a serious
10 accident.

11 "The ACRS recommended that operating
12 power reactors receive priority with regard to the
13 definition and implementation of instrumentation
14 which provides additional information to help
15 diagnose and follow the course of a serious accident.
16 This should include improved sampling procedures
17 under accident conditions, and techniques to help
18 provide improved guidance to off-site authorities,
19 should this be needed. The Committee recommends that
20 a phased implementation approach be employed so that
21 techniques can be adopted shortly after they are
22 judged to be appropriate.

23 "The ACRS recommends that a high priority
24 be placed on the development and implementation of
25 safety research on the behavior of light water reactors

agb4

1 during anomalous transients. The NRC may find it
2 appropriate to develop a capability to simulate a
3 wide range of postulated transient and accident
4 conditions in order to gain increased insight into
5 measures which can be taken to improve reactor
6 safety.

7 "The ACRS wishes to reiterate its pre-
8 vious recommendations that a high priority be given
9 to research to improve reactor safety.

10 "The exit temperature of coolant from the
11 core is currently measured by thermocouples in many
12 PWRs to determine core performance. The Committee
13 recommends that these temperature measurements, as
14 currently available, be used to guide to operator
15 concerning core status. The range of the information
16 displayed and recorded should include the normal
17 operating range as well as the maximum temperatures
18 which can be expected under accident conditions. It
19 is also recommended that other existing instrumenta-
20 tion be examined for its possible use in assisting
21 operating action during a transient.

22 "The use of natural circulation for decay
23 heat removal following a loss of off-site power
24 sources requires the maintenance of a suitable over-
25 pressure on the reactor coolant system. This

agb5

1 overpressure may be assured by placing the pressuri-
2 zer heaters on a qualified on-site power source with
3 a suitable arrangement of heaters and power distri-
4 bution to provide redundant capability. Presently
5 operating PWR plants should be surveyed expeditiously
6 to determine whether such arrangements can be provided
7 to assure this aspect of natural circulation capa-
8 bility.

9 "The plant operator should be adequately
10 informed at all times concerning the conditions of
11 reactor coolant system operation which might affect a
12 capability to place the system in the natural circula-
13 tion mode of operation or to sustain such a mode.
14 Of particular importance is that information which
15 might indicate that the reactor coolant system is
16 approaching the saturation pressure corresponding to
17 the core exit temperature. This impending loss of
18 system overpressure will signal to the operator a
19 possible loss of natural circulation capability. Such
20 a warning may be derived from pressurizer pressure
21 instruments and hot leg temperatures in conjunction
22 with conventional steam tables. A suitable display
23 of this information should be provided to the plant
24 operator at all times. In addition, consideration
25 should be given to use of fuel exit temperatures,

agb6

1 where available, as an additional indication of
2 natural circulation."

3 "Consideration should be given to the
4 desirability of additional status monitoring on
5 various engineered safeguards features and their
6 supporting services to help assure their avail-
7 ability at all times.

8 "The ACRS is continuing its review of the
9 implications of this accident and will provide further
10 advice as it is developed."

11 DR. CARBON: Paul?

12 DR. SHEWMON: There's a general question with
13 regard to what the NRC should have available to it the next
14 time that a grass fire develops of some sort. We don't
15 address ourselves to that at all. There's an awful lot on
16 operations of reactors in here.

17 My strong feeling is that they were quite weak
18 with regard to anybody who understood chemically what was
19 going on or might be going on inside the core of that reactor,
20 And this made them come out with the statements which were,
21 you know, which scared people and were dead wrong.

22 And in general, there is a weakness in the water
23 chemistry effort because they apparently feel it is so well
24 under control, they don't do very much on it. I don't know
25 that -- I guess it's a heartfelt conviction at this point,

agb7

1 which is totally not reflected in here. And maybe they
2 appreciate all this now, but then they probably appreciate most
3 of what we're saying to them anyway, and so that's not a
4 reason for taking it out.

5 DR. CARBON: Dave?

6 DR. OKRENT: Well, I think at least in part what
7 Paul is referring to was the concern for possible oxygen
8 buildup in the primary system, which when people looked at
9 more carefully, they decided that recombination would go
10 rapidly and you wouldn't get it. So that alleviated what I
11 understand to be one of the concerns of people working 24 hours
12 around the clock on Friday, for example, and Saturday.

13 I think, in fact, had people studied what I will
14 call degraded accident conditions, they might have developed a
15 transient where you released a certain amount of hydrogen in a
16 reactor system that was bottled up, and they would then have
17 been forced to ask themselves where does this hydrogen go and
18 does it develop a bubble and do you get oxygen and so forth
19 in the same way that, in fact, the LOCA has been studied
20 exhaustively.

21 So what I'm getting at indirectly is if, in fact,
22 there were more examination of what I have called anomalous
23 transients and so forth and not just how to prevent them but
24 what happens if they occur even though you have tried to prevent
25 them, you might then have studied some of these conditions.

agb8

1 DR. SHEWMON: You might. But then my main point
2 was that they said, you know, you've got all this hydrogen up
3 there, the rate of oxygen buildup is the following, it can
4 become explosive, you know, it's dangerous nonsense and if they
5 had known how to ask the right question they would never have
6 come out with those. That's partly a weakness I think they
7 recognized.

8 There's the broader question of what we suggest
9 they do so that they can, on the scene, cope with predictable
10 consequences and marshall their forces somewhat better in
11 that way.

12 I don't think any bunch of thermohydraulics people
13 running contingency problems with any kind of a computer are
14 ever going to come up with this kind of information that will
15 be of any use to somebody facing another problem. It's just
16 different kinds of people talking about different things at
17 different times.

18 DR. CARBON: Would you care to put a paragraph
19 together to be mixed in here for consideration?

20 DR. SHEWMON: I could, yes.

21 DR. CARBON: Fine.

22 DR. SHEWMON: There are two questions, though.
23 There's one, the chemical capability, and the other is, do we
24 wish at all at this point to get into advice on what sort of
25 things they might do so that they would have a squad and a home

agb9

1 base group organized to advise them competently on questions
2 of this sort the next time it comes up. There are two
3 questions, I think.

4 DR. LAWROSKI: I think the latter needs more time
5 to develop. I think it's going to take quite a bit of thinking
6 on their part and on our part.

7 DR. SHEWMON: I don't say we're ready, I say it's
8 something we have completely ignored or skipped.

9 DR. CARBON: Are there other comments, general
10 comments?

11 DR. SIESS: I guess this is general, at least
12 three of these items relate to natural circulation. I think
13 we might try to consider them together, when we do.

14 That's the last one, the one on the pressuri-
15 zer heaters and the diesel and the saturation pressure
16 indication.

17 DR. OKRENT: That's true. As I tried to indicate,
18 they were stapled at random.

19 DR. CARBON: Bill?

20 MR. MATHIS: Well the last item on the introductory
21 portion of the letter is really a long-term kind of item.
22 The first item of the handwritten items is also long-term.

23 DR. CARBON: Which was your first one?

24 MR. MATHIS: The last paragraph on the typewritten
25 portion, Page Two.

agbl0

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. CARBON: Oh, yes.

And the first handwritten one, you say?

MR. MATHIS: The first handwritten one, which is
Number Six.

Number Seven again is pretty much the same thing,
it's long-term.

Then we get into near-term things, which I think
is more a propos for today.

There are some other things, though, that really
aren't in here yet. I think one of the things that Walt
talked about this morning is something that could be implemented
early in the game, on the indicators on valve position. And
then other items --

DR. OKRENT: Excuse me. We tried to cover that
on the last page, but in a general way.

MR. MATHIS: Well, some of the other specifics,
maybe we don't want to hit them here, but we talked about
emergency planning and these were things that would be appli-
cable to other plants that are running today that should look
at these kinds of items. Sampling capability, we talked about
that in general.

DR. CARBON: Review shared facilities, that's not
in here.

DR. OKRENT: We didn't know whether we wanted a
little more information on that or not. We didn't know whether

1 agbll we should try to write one there or not. We ran out of time.

2 MR. MATHIS: I realize that.

3 DR. OKRENT: Again, if you have appropriate words
4 there, I think you ought to try.

5 MR. MATHIS: I said my piece this morning. I
6 didn't think we had time to do this. I'll quit.

7 DR. CARBON: Chet?

8 DR. SIESS: Well, are we going through the items --

9 DR. CARBON: I'm not sure, I got diverted here a
10 moment and I didn't catch the last of Bill's comments.

11 DR. SIESS: He was mentioning items he thought
12 might not be included, are we still on that subject?

13 DR. CARBON: We're still on the general.

14 Bill, the comments you were making about items not
15 included, I missed part of that. Did it turn out that essen-
16 tially all of them are included in a general way, or are there
17 some that --

18 MR. MATHIS: Well, some of them are, Max. I didn't
19 attempt to go through that in that much detail.

20 I guess the problem I still have is, is this the
21 time and do we want to devote this much attention to what I
22 consider longer-term items such as research and development
23 kind of things?

24 I agree we need to get into that, but I question
25 the advisability of attempting to do it today. We could

agbl2

1 mention it but, I mean, to put it in writing, I just don't
2 feel we're ready.

3 That's the end of my comment.

4 DR. SHEWMON: Is that with regard to the whole
5 letter or just with regard to some of the particular items?

6 MR. MATHIS: Item-by-item.

7 But, if you want to get into the question of
8 whether or not we should write a letter today, then I would
9 still vote no on a letter today.

10 DR. CARBON: Are there other general comments?

11 (No response.)

12 DR. CARBON: Do we want to go through item-by-item,
13 or make a decision first on whether we're talking about writing
14 a letter or discussing this with the Commissioners?

15 DR. OKRENT: I think if we're going to discuss
16 this with the Commissioners, and if we are able to complete
17 a letter that we think is okay except for editorial matters
18 which we can leave to the Chairman, then I would favor us
19 trying to do it. I don't know whether time permits.

20 I am not inclined to leave matters in or out on
21 the basis of whether they are something that can be implemented
22 immediately or not. I think I would take each item on its
23 merits.

24 DR. CARBON: I'm not sure but that we could finish
25 all of it in an hour if we chose to.

agbl3

1 MR. ETHERINGTON: It'll be a record if we do.

2 DR. SIESS: It'll be a miracle if we do.

3 MR. MATHIS: Could I add some other comments?

4 Maybe the thing to do is to put together really
5 an outline here, and it's pretty well done, of things that we've
6 considered, things that should be brought to their attention.
7 Just talk to this point this afternoon and then follow up with
8 a letter. Is there anything wrong with that approach, rather
9 than attempting to rush into it this fast?

10 DR. CARBON: It could certainly be done.

11 DR. PLESSET: I was out of the room, I'm afraid,
12 for a critical moment. How come this was delivered to everybody
13 in the room essentially, because this is so far, in my view,
14 to the kind of letter we will write that it seems unfortunate
15 that it be given out in written form. I hope people are aware
16 that this may not be related to what we write when we write
17 a letter.

18 DR. OKRENT: I gave preliminary comment before I
19 read it when I was asked to read it.

20 DR. PLESSET: That this was scratch paper?

21 DR. SHEWMON: I'd be interested in discussing
22 that. Usually we are in closed session when we write letters.
23 Today we hand out drafts yet.

24 DR. CARBON: It seems in compliance to what we're
25 supposed to do, though.

ugbl4

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. SIESS: Mr. Chairman, I would like to suggest we go through this item-by-item but group the three items -- group the items as we can see it. I can see a grouping of three on natural circulation.

I think one criterion as to what we discuss with the Commissioners today versus what we might put off until the next meeting should be the degree of specificity that we have in the recommendations. Some of these are a little more general, and they tend to be what was described as terse, technical and cryptic, and I think we could improve on them with time. And I'll comment on those as we go through them.

But I propose we start with the three items that relate to natural circulation and see whether we agree on them.

DR. CARBON: It sounds fine, let's do it.

Dave, would you go through paragraph by paragraph?

DR. OKRENT: I'll try.

end1F1

1F2 wbl

1 DR. CARBON: And which are the three that --

2 DR. SIESS: Natural circulation is the first item
3 on the first page, the second paragraph. Pressurizer heaters on
4 page ten, and the item on page eleven. I guess eleven and
5 twelve is the same item, and they both refer to natural circu-
6 lation and I think they are related to it.

7 Do you agree, Harold?

8 MR. ETHERINGTON: Yes.

9 DR. OKRENT: Logically they should have been ar-
10 ranged in such an order.

11 DR. CARBON: Why don't you combine those three and
12 go ahead, then?

13 DR. OKRENT: "Natural circulation is an important
14 mode of reactor cooling, both as a planned process
15 and as a process that may be used under abnormal cir-
16 cumstances. The Committee believes that greater under-
17 standing of this mode of cooling is required and that
18 detailed analysis should be developed by licensees or
19 their suppliers. The analyses should be supported, as
20 necessary, by experiment. Procedures should be developed
21 for initiating natural circulation in a safe manner and
22 for providing the operator with assurance that circula-
23 tion has, in fact, been established. This may require
24 installation of instrumentation to measure or indicate
25 flow at low water velocity."

wb2

1 DR. SIESS: You mentioned abnormal circumstances.
2 As I understand it, natural circulation is a mode you get
3 into on loss of offsite power. Is that an abnormal circum-
4 stance?

5 MR. ETHERINGTON: Is it intended to mean something
6 more abnormal than that?

7 DR. SIESS: You don't have any problem with getting
8 into natural circulation in a routine normal loss of offsite
9 power?

10 MR. ETHERINGTON: You shouldn't have.

11 DR. SIESS: Okay.

12 DR. OKRENT: I think then we skip to page ten, or
13 No. 10, it's not really page ten. I'll try to read with more
14 volume.

15 "The use of natural circulation for
16 decay heat removal following a loss of offsite
17 power sources requires the maintenance of a suitable
18 overpressure on the reactor coolant system. This
19 overpressure may be assured by placing the pressurizer
20 heaters on a qualified onsite power source with a
21 suitable arrangement of heaters and power distribu-
22 tion to provide redundant capability. Presently
23 operating PWR plants should be surveyed expeditiously
24 to determine whether such arrangements can be provided
25 to assure this aspect of natural circulation capability."

wb3

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR. CARBON: Comment?

(No response)

DR. CARBON: Go on to No. 11, then.

DR. OKRENT: "The plant operator should be adequately informed at all times concerning the conditions of reactor coolant system operation which might affect a capability to place the system in the natural circulation mode of operation or to sustain such a mode. Of particular importance is that information which might indicate that the reactor coolant system is approaching the saturation pressure corresponding to the core exit temperature. This impending loss of system overpressure will signal to the operator a possible loss of natural circulation capability. Such a warning may be derived from pressurizer pressure instruments and hot leg temperatures in conjunction with conventional steam tables. A suitable display of this information should be provided to the plant operator at all times. In addition, consideration should be given to the use of fuel exit temperatures, where available, as an additional indication of natural circulation."

I guess that was fuel subassembly exit temperatures.

DR. SIESS: The last sentence seems to relate to

wb4

1 the comment about the core exit thermocouples.

2 DR. OKRENT: Yes.

3 DR. CARBON: Is there comment on that paragraph?

4 DR. SIESS: Those are the three items on natural
5 circulation. Would it be appropriate to follow those with the
6 one on Item 8 about core exit temperatures?

7 DR. OKRENT: Either that or the one -- the shutdown
8 mode review. Take your choice. We can leave that really for
9 editorial--

10 Shall I read the exit temperature one?

11 DR. CARBON: Hold up just a second.

12 Is there general agreement that these three
13 paragraphs are important, pertinent, and so on?

14 DR. OKRENT: If we're not careful we'll have time
15 left over.

16 DR. SHEWMON: This is on page 8 that we just got
17 done reading?

18 DR. CARBON: No. Ten and eleven.

19 SHEWMON: Okay.

20 DR. OKRENT: Eleven and twelve.

21 DR. SHEWMON: Have you done page 8 yet?

22 DR. OKRENT: I was just going to start 8.

23 "The exit temperature of coolant from
24 the core is currently measured by thermocouples in
25 many PWRs to determine core performance. The Committee

wb5

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

recommends that these temperature measurements as currently available be used to guide the operator concerning core status. The range of information displayed and recorded should include the normal operating range as well as the maximum temperatures which can be expected under accident conditions. It is also recommended that other existing instrumentation be examined for its possible use in assisting operating action during a transient."

d 1F2

lg ebl

1 DR. CARBON: Is there comment?

2 DR. SHEWMON: I have no complaints at all down to
3 about two-thirds of the page, and then we go into the range of
4 information displayed. I don't know whether this is a new
5 paragraph. If it's not a new paragraph, it seems to me the
6 maximum temperatures which are expected under accident condi-
7 tions, all of a sudden we're off to several thousands degree
8 that that's not the kind of thermocouples we have. It's a
9 completely different recommendation.

10 DR. OKRENT: You're right. Accident conditions is
11 an ill-defined term.

12 I think what we mean, and which is not stated here
13 is they should take these thermocouples up to the full range
14 for which they are capable.

15 DR. SHEWMON: The full range of existing equipment,
16 and not cut it off.

17 DR. OKRENT: This would give information as you can
18 with those thermocouples and it doesn't say that the thermo-
19 couples have to cover all possible temperature ranges. I think
20 that's something that could be picked up.

21 DR. SIESS: Why don't we simply say "extended for
22 an appropriate amount beyond the normal operating range."

23 If their capability was pretty high you might not
24 want to go up higher because it might affect your sensitivity
25 accuracy at the lower levels where you need them for something

eb2

1 else.

2 DR. CARBON: Walt?

3 MR. LIPINSKI: The conventional thermocouple up
4 there has considerable range and if these are digitized, it is
5 just a question of whether you want three digits, nine, nine,
6 nine, or four digits. And if they have the capability of going
7 up and giving the information, then I would recommend that they
8 go full range, up to their destruction point.

9 DR. OKRENT: Why not say:

10 "The range of instrumentation information
11 displayed should encompass the capabilities of the
12 thermocouple."

13 MR. ETHERINGTON: "The range of the information."
14 Does that mean the instrument range or....

15 DR. SHEWMON: Is the instrument you're talking about
16 the thermocouple?

17 MR. ETHERINGTON: Does this mean the range or the
18 scope?

19 DR. SIESS: Why don't you say:

20 "The information displayed should include
21 the full capable range of the instrumentation of the
22 thermocouples."

23 DR. OKRENT: I think we know what we mean here, and
24 perhaps somebody would like to reword it.

25 DR. SIESS: Not today.

eb3

1 Larry Crocker is sitting here. He knows what we
2 mean.

3 DR. SHEWMON: The full capable range of the thermo-
4 couples.

5 DR. OKRENT: Shall I go on then to the bottom of
6 the first page?

7 DR. CARBON: Just a second.

8 Is there general agreement that this is a pertinent
9 and important paragraph? I guess so.

10 Go ahead, yes.

11 DR. OKRENT: At the bottom then of the first page:

12 "Normal operating limits are reviewed by
13 the Regulatory Staff in detail and are formalized in
14 the Technical Specifications for the unit. Shutdown
15 procedures are also reviewed by the Staff, but the
16 Committee believes the review may not be made in the
17 same depth as the operating limits. The Committee
18 suggests that consideration be given to requiring the
19 licensee to prepare a formal document for NRC approval,
20 defining limits for shutdown modes."

21 DR. CARBON: How about you starting off by defining
22 what you mean by "limits for shutdown modes." I don't really
23 know what you're talking about.

24 DR. OKRENT: Harold, do you want to try?

25 MR. ETHERINGTON: There are procedures. We know

eb4 1 that. And they are looked at by the Staff. But there's no
2 formal document that says when you shouldn't transfer from one
3 mode of cooling to another.

4 DR. SIESS: By "mode of cooling" you mean going to
5 RHR?

6 MR. ETHERINGTON: Yes.

7 DR. SIESS: Because the Staff has recently been
8 reviewing procedures for getting to cold shutdown in quite
9 considerable detail on all the plants, and I was trying to
10 relate this to those studies. They've been looking at the
11 ability to get to cold shutdown using only safety grade equip-
12 ment, but I guess the limits aren't in there.

13 MR. ETHERINGTON: I would suggest we drop this par-
14 ticular item.

15 DR. SIESS: I would suggest we drop it until we have
16 time to discuss it further and sharpen it up, which I don't
17 think we can do in the time we have today, --

18 DR. CARBON: Is there agreement on that?

19 DR. SIESS: -- although if we finish up as Dave
20 says in the next ten minutes, we can come back to it.

21 DR. CHEVMON: Is this the whole paragraph, or the
22 last sentence?

23 DR. SIESS: The whole paragraph.

24 DR. OKRENT: We'll put it in deferred status.

25 DR. SIESS: Okay.

eb5

1 DR. PLESSET: That's called limbo.

2 DR. OKRENT: Now let's see if there's some logical
3 order to the remaining items.

4 There is one at the very back, number 14:

5 "Consideration should be given to the
6 desirability of additional status monitoring on
7 various engineered safeguard features and their
8 supporting services to help assure their avail-
9 ability at all times."

10 DR.SHEWMON: That has to do with computers and so
11 called human-machine interface problems, the man-machine inter-
12 face problems, and so on?

13 DR. OKRENT: This could apply to important valves,
14 breakers, or so forth, that might not now have status indicated
15 automatically in the control room. I think Michaelson made
16 the point that we want to be careful about trying to do it with
17 all systems.

18 DR. SHEWMON: Does "status monitoring" imply more
19 subtle things like status of the system vis-a-vis the satura-
20 tion pressure and temperature?

21 DR. OKRENT: No. I think in this case what is in-
22 tended is is the valve open or closed; equipment.

23 DR. OKRENT: It's an effort to respond to this
24 matter which was discussed, but we didn't try to give a detailed
25 recommendation.

c4

eb6

1 MR. RAY: If you will tolerate a little word engineer-
2 ing I would suggest you put either the word "facility" or
3 "equipment status monitoring," to avoid the misunderstanding.

4 DR. OKRENT: How about "additional equipment"?

5 MR. RAY: Okay.

6 DR. OKRENT: "Equipment status monitoring."

7 MR. RAY: Whether or not you want to indicate now
8 the idea of a computer is immaterial. It's just that if you
9 did mention it now you might stimulate some development at an
10 earlier date than would otherwise be the case.

11 DR. OKRENT: My proposal is the letter be called a
12 Second Interim Report, and then propose a third one.

13 DR. SHEWMON: I don't understand that as a response
14 to the question of whether we should put the word "computer"
15 in the paragraph.

16 DR. OKRENT: I was being facetious. Some of these
17 things we can do without computers and some of them will re-
18 quire computers.

19 DR. SIESS: If there's too much on the computer they
20 don't see it.

21 DR. CARBON: Is there general agreement on this
22 paragraph? It says "additional equipment status monitoring."
23 Insert the word "equipment."

24 Let's go on to the next one.

25 DR. OKRENT: In no particular order. I suppose we

eb7

1 can look at number two now.

2 "The Committee recommends that contingency
3 studies be made for operating nuclear power plants
4 to ascertain what additional measures might be taken
5 to limit the extent and consequences of a serious
6 accident."

7 DR. SIESS: That's one that I think needs to be ex-
8 panded on to where it is clearer. I don't think anybody would
9 know where to start with just "contingency studies," unless
10 it is-- I mean if it is urgent enough that we want to mention
11 it now I think we could be more specific, and if it is not that
12 urgent, we can wait until it can be made more specific.

13 I don't know whether this covers emergency plans,
14 offsite state plans, or what.

15 Mr. Chairman, I move we defer this until it can be
16 expanded, which may be later today or it may be at the next
17 meeting.

18 DR. SHEWMON: Is there agreement?

19 Let's defer it.

20 DR. OKRENT: The next one, which is called six:

21 "The ACRS recommends that operating power
22 reactors receive priority with regard to the defini-
23 tion and implementation of instrumentation which pro-
24 vides additional information to help diagnose and
25 follow the course of a serious accident. This should

eb8

1 include improved sampling procedures under accident
2 conditions and techniques to help provide improved
3 guidance to offsite authorities, should this be
4 needed. The Committee recommends that a phased
5 implementation approach be employed so that techni-
6 ques can be adopted shortly after they are judged
7 to be appropriate."

8 DR. CARBON: Is there comment?

9 DR. SIESS: I guess I still have the problem of
10 whether if somebody got this just in writing, whether they would
11 know how it relates to Reg. Guide 1.97, whether they would
12 start thinking that, or would they look beyond it.

13 The first sentence, you know, doesn't get you off of
14 1.97. The second sentence tends to move you quite a ways away
15 from it because the two examples that are mentioned are not
16 related at all to what is in there.

17 DR. OKRENT: The two examples I think augment what
18 is now in 1.97.

19 I don't feel, in order to make this recommendation,
20 we have to solve problems, in other words come up with a whole
21 list of instrumentation.

22 DR. SIESS: No, but is this an endorsement of 1.97
23 and then going a little beyond it? Is that your thought?

24 DR. OKRENT: I don't know what the word "endorsement"
25 means in that context.

eb9

1 DR. SIESS: Is this in addition to, rather than
2 instead of 1.97?

3 DR. OKRENT: I think myself that specifically 1.97
4 can be improved upon. In other words, we could do better than
5 1.97. In fact I'm sure of it.

6 DR. SIESS: I agree.

7 DR. OKRENT: So now I don't know whether it's in
8 addition or instead of.

9 In fact, one of the things that I mentioned earlier
10 was the R³C Committee sort of took the position that they would
11 apply it not only to plants being constructed but operating
12 plants should be looked at on a case-by-case basis. But what
13 this tries to do is to say operating reactors get priority,
14 and if you have things you decide are useful, don't wait until
15 you have the whole story.

16 DR. SIESS: In practice, only position C-3 is getting
17 the treatment you mentioned. There is nothing being done about
18 position C-1 and C-2. They've got a Task Action Plan which is
19 trying to figure out what should be done, and it is only the
20 wide-range instrumentation that they're requiring even on new
21 plants.

22 DR. OKRENT: I don't really think it's all that
23 hard to figure out something you can do with the existing
24 technology. That's all.

25 DR. SIESS: No, it's just that hard to do it in

eb10

1 accordance with the provisions of the Regulatory Guide, which
2 is very formal.

3 DR. OKRENT: That's why I do not wish to endorse
4 the Regulatory Guide per se.

5 DR. SIESS: That's what I'm trying to understand.

6 I think I can go along with this paragraph a lot
7 better than I can go along with Reg. Guide 1.97, as long as
8 this paragraph doesn't mean do what is in 1.97 and then go
9 beyond it.

10 DR. OKRENT: I don't think it says that.

11 DR. CARBON: Is there general agreement on it?

12 Fine. Go on.

13 DR. OKRENT: I guess we didn't read what is on page
14 7, or number 7.

15 DR. SIESS: Incidentally, a couple of items we have
16 already discussed, like core exit thermocouples and saturation
17 pressure monitor sort of follow from this, too.

18 DR. OKRENT: We regard to core exit temperature, we
19 made the recommendation that you've got to use it. This is now
20 in terms of things that they should add.

21 DR. SIESS: And it sets a different kind of priority,
22 I think.

23 DR. OKRENT: Yes.

24 "The ACRS recommends that a high priority
25 be placed on the development and implementation of

eb11

1 safety research on the behavior of light water reactors
2 during anomalous transients. The NRC may find it
3 appropriate to develop a capability to simulate a
4 wide range of postulated transient and accident
5 conditions in order to gain increased insight into
6 measures which can be taken to improve reactor
7 safety.

8 "The ACRS wishes to reiterate its previous
9 recommendations that a high priority be given to re-
10 search to improve reactor safety."

11 Henry Meyers is sitting in the room and I will just
12 jog his memory that we didn't get money last year and we didn't
13 get money this year, so even if it's not in the letter, still
14 it's encouraging.

15 DR. CARBON: Is there general agreement on this? Is
16 the last sentence intended to be part of the--

17 DR. OKRENT: It doesn't have to be; either way.

18 DR. PLESSET: Leave it out.

19 DR. OKRENT: It's related. This is in fact-- It
20 could be interpreted as an aspect of one of the things that
21 was to be done in the research to improve reactor safety.
22 There's a topic called man-machine interaction. That's why I
23 included it, sort of as part of the same thought.

24 DR. CARBON: I have no objection to--

25 DR. SIESS: I think if we wrote a letter we could

eb12

1 include that and say:

2 "....research to improve reactor safety
3 which includes at least one item especially pertinent
4 to this problem."

5 DR. OKRENT: Well, in fact it includes what I would
6 call contingency matters. What are contingency matters? Fully
7 vented containment is one.

8 DR. SIESS: That helps me understand it.

9 DR. OKRENT: Good.

10 MR. RAY: I suggest we leave it in.

11 DR. SIESS: Which one? The last sentence?

12 MR. RAY: Yes.

13 DR. SIESS: As a separate paragraph, or add it into
14 the previous paragraph?

15 MR. RAY: Yes.

16 DR. SHEWMON: I have trouble with it. We sort of
17 write a report each year on this saying we're in favor of reactor
18 safety. Why reiterate it?

19 DR. OKRENT: Unless something has happened recently,
20 the last time I heard, they were still waiting to have some
21 Committees in Congress approve the allocation of money or some-
22 thing, and there was only half of a rather modest amount.

23 DR. SHEWMON: But the whole research program is to
24 improve reactor safety.

25 DR. SIESS: Let's not get into that.

eb13

1 DR. SHEWMON: Well, then why get into this whole
2 paragraph? That's what I'm trying to understand.

3 DR. SIESS: The distinction has been made between
4 confirmatory research and research to improve reactor safety,
5 and it's not at all clear what the Congress meant or what the
6 NRC meant, and I don't think this is a suitable time to debate
7 it.

8 But research to improve reactor safety has a very
9 specific meaning within the Commission now, and in the law,
10 and it's a separate line item in the budget.

11 DR. CARBON: Is there general agreement to leave it
12 in?

13 DR. LAWROSKI: I think it should be left in.

14 DR. SHEWMON: I second.

15 DR. CARBON: To leave it in?

16 DR. SHEWMON: You said to do what?

17 DR. LAWROSKI: Leave it in.

18 DR. SHEWMON: Oh.

19 MR. RAY: I second.

20 DR. CARBON: Unless Paul wishes otherwise, I will
21 just assume there is a consensus, but if you want I'll take a
22 vote.

23 Let's leave it in and go ahead. The last sentence
24 becomes part of the preceding paragraph.

25 DR. OKRENT: Now Paul, you wrote a paragraph, didn't

eb14

1 you?

2 Can we have it?

3 DR. SHEWMON: There are two things that are new in
4 front of you. Mine is the second sheet. I will edit it
5 slightly.

6 "The NRC should re-examine their organi-
7 zation and capability in the area of chemistry, es-
8 pecially water chemistry. It has very limited re-
9 search expertise in this area to call on in time of
10 need. This was obvious from the misinformation that
11 was the basis for disturbing speculation and possi-
12 ble hydrogen-oxygen explosions in the reactor pres-
13 sure vessel a few days into the accident."

14 DR. LAWROSKI: Water chemistry has had a connotation
15 that doesn't include this. It's primarily aimed, as you well
16 know, Paul, at treatment to help minimize corrosion.

17 DR. SHEWMON: I think they're weak there, too, but
18 that's a separate point.

19 DR. LAWROSKI: This matter of misinformation, I
20 think the misinformation was the lack of somebody -- I don't
21 know whether it was in Bethesda when -- I'm only getting this
22 third hand, I believe. Maybe it is even fourth hand, that in
23 asking for some information, the requesters failed to indicate
24 that the system was under some, you know, 1,000 or 1,500 psi.
25 Without that information of course you'll get the radiolysis

eb15

1 rate of water.

2 DR. SHEWMON: That's my point. You have to have a
3 certain amount of sophistication that's needed to ask the right
4 questions about it.

5 DR. LAWROSKI: I don't know whether that was a lack
6 of expertise or just the failure to--

7 DR. SHEWMON: You don't know whether it was organi-
8 zation or capability, to go back to the first line. We agreed,
9 though, that there was misinformation.

10 DR. LAWROSKI: Yes-- Well, I don't know that I
11 would define it as misinformation as opposed to lack of infor-
12 mation.

13 But in addition, this is a sort of a small sample of
14 what should be included in the subject. I think the whole
15 matter of how to fix iodine in the water and so on might be at
16 least as important as the example cited here. And of course
17 if we're going to talk about all power reactors, there's a little
18 bit of the familiar stress corrosion.

19 DR. SHEWMON: That gets back to water chemistry.

20 DR. LAWROSKI: Yes, that's water chemistry again.

21 I think this needs to be reworked considerably.

22 DR. SIESS: Steve, fixing iodine in the water, would
23 that come under the heading of the contingency studies men-
24 tioned elsewhere if we started listing them?

25 DR. LAWROSKI: It could.

ebl6

1 DR. SIESS: It's mitigation-recovery related.

2 DR. LAWROSKI: Yes. And of course there's the other
3 aspect of iodine, to learn better when the charcoal filters
4 will work with adequate decontamination factors, and when they
5 won't. We heard a little bit from Larry Crocker. I'm not sure
6 that there's not a lot more to it.

7 We also have the whole matter of recombination.

8 DR. OKRENT: I think Shewmon is correct, that we
9 didn't really talk about what we might call response capability
10 for the NRC to an accident. I think myself that it's a rather
11 complex question.

12 Should there be another serious accident likely to
13 be different in nature and pose another set of questions, I'm
14 not sure what one would decide constitutes a reasonable defi-
15 nition of adequacy. I don't know whether we are going to
16 assume that they should know each power reactor as intimately
17 as the reactor designer, the vendor and so forth, so that they
18 can say Well, all these pumps are off a switch to the other
19 pump, and so forth and so on, or if you get into a degraded
20 condition. I think it's an important area to think on, and I
21 don't think it's going to have a simple answer myself.

22 I would myself suggest that we identify this one
23 for early discussion. I don't know whether that will mean
24 early resolution from our point a view, except a general
25 recommendation, but certainly for early discussion, and an

eb17

1 effort to be detailed in our discussion just to see sort of
2 what is the nature of the problem and what do we think is
3 practical, and so forth.

4 DR. SHEWMON: We've shifted the problem from chemis-
5 try to response capabilities, which covers a very broad water-
6 front again. And if that's the pleasure of the Committee we
7 can do it, but we started out on one term and ended up on
8 another.

9 DR. SIESS: But the thrust of your paragraph is that
10 it had limited expertise to call on in time of need. I think
11 they managed to call on a great deal of expertise from through-
12 out the country, maybe not as rapidly as we would have liked.

13 I think the Commission and the NRC Staff are well
14 aware of the deficiencies in their response capability, the
15 term "deficiency," I would say, not expertise deficiency. And
16 they're going to be giving it an awful lot of thought. And
17 until we can give them some help on it, I think we ought to
18 defer it. I think they know they've got a problem.

19 If we can make any constructive suggestions, fine,
20 but I don't think we need to tell them they've got a problem.
21 Everybody else has.

22 DR. LAWROSKI: Some of the people involved in this
23 question in NRC, I know for a fact that they know from their
24 experience connected with the Navy PWR experience, that they
25 knew that, by the weekend, as you were talking about, that the

eb18

1 rate of radiolysis was such that the rate of recombination was
2 rather modest. And they knew that.

3 DR. SHEWMON: I asked how did the laws of chemistry
4 change.

5 DR. LAWROSKI: But I think it gets into the broader
6 question.

7 MR. RAY: I don't have any trouble with the thought
8 of deferring it, but if there is a deficiency in the area of
9 water chemistry, whether it's water chemistry as we know it
10 for treatment in order to avoid contamination of tubes and so
11 on, or whether it is to remove iodine from fluid, or whether
12 it is to not make misstatements as in here, I think it ought
13 to be addressed as early as you can and not let it go, in terms
14 of a research project to be done later or initiated earlier
15 because it is apt to drop through a crack.

16 And I think if there's any organization that should
17 have it in the area of this type of chemistry it's NRC. Defer
18 it, yes, but give it a priority so that at your next meeting
19 you can pick it up.

20 DR. CARBON: It sounds like it's the general con-
21 sensus to defer it to perhaps about our next meeting, or some
22 early time. If so, let's go ahead.

23 DR. LAWROSKI: My only point, Jerry, is that the
24 example cited is what I would call a second derivative.

25 DR. SHEWMON: Write a better example then.

eb19

1 DR. CARBON: Is there another paragraph to the
2 letter?

3 DR. OKRENT: No, there are two that we put aside
4 in case you had time. At the bottom of the first page there
5 was one concerning shutdown procedures. Now do you want to
6 look at it again?

7 DR. CARBON: Let me defer that question for a moment
8 and take up a little logistics, I guess.

9 We have a meeting with the Commissioners at 3:30
10 and as we left it last time, lots of people would have to leave
11 about 4:00, and I guess the meeting would essentially end then.
12 But is there any new information then, Ray, with respect to
13 when people can get to the airport? You were talking about
14 special cars and all that kind of thing.

15 MR. FRALEY: I think five members have to leave at
16 four o'clock.

17 DR. CARBON: So there's no change.

18 DR. SIESS: How many does that leave then?

19 DR. CARBON: After four o'clock, you and myself and
20 Paul and Jerry, four of us, with one, two, three, four, five
21 I guess leaving.

22 DR. SIESS: Who will be here after four?

23 (Show of hands.)

24 DR. CARBON: Four of us after four, Chet and Paul
25 and Jerry and myself.

eb20

1 DR. SIESS: How can we have a meeting with the
2 Commissioners with only four of the members?

3 DR. CARBON: We have a half-hour meeting then, from
4 3:30 to 4:00.

5 Another bit of logistics. We won't have a meeting
6 afterwards, so I think we have to clear these things up now.

7 We had aimed toward a Subcommittee meeting here in
8 Washington next Monday and Tuesday. As I had indicated
9 earlier, it is turning out to be completely impossible, I
10 believe, to get hotel reservations or to get us here, even if
11 there were hotels. So unless I'm mistaken, we've all agreed
12 to defer the meeting one week, which will make it two weeks
13 from yesterday, whatever date that is, April 30th and May 1st.

14 DR. SHEWMON: What's the Subcommittee?

15 DR. CARBON: Dave Okrent is the Chairman, and Chet
16 and Milt.

17 DR. SHEWMON: The Three Mile Island Subcommittee?

18 DR. CARBON: That's right.

19 MR. FRALEY: It's the Subcommittee on Long-Term
20 Implications of the Three Mile Island Accident.

21 DR. CARBON: One question that may come up this
22 afternoon, and I would seek your thoughts on it:

23 What is our stand with regard to contingency plans
24 for going onto natural circulation at Three Mile Island?

25 Harold, could you summarize?

eb21

1 MR. ETHERINGTON: I don't quite know what you mean.
2 We have no plans.

3 DR. CARBON: I mean what is our thinking about their
4 plans.

5 MR. ETHERINGTON: The thing is being so completely
6 considered by a high-grade technical group and everything I
7 heard was in line with our thinking. I think we need have no
8 concern at all.

9 DR. CARBON: Does anyone have any other views than
10 that?

11 MR. RAY: I would endorse Harold's statement.

12 DR. PLESSET: They're very concerned, aren't they,
13 Harold?

14 MR. ETHERINGTON: Yes.

15 DR. CARBON: I believe that takes care of the odds
16 and ends, so to speak, particularly the logistics, and we'd
17 be prepared to go back to the two paragraphs that we left out.

18 DR. SIESS: Mr. Chairman, it's conceivable the
19 Commission might ask us if we have any comments on the I&E
20 bulletins that were sent to Westinghouse, Combustion Engineering
21 and all PWR plants. Are we prepared to answer?

22 DR. PLESSET: You're prepared evidently.

23 DR. SIESS: There are minor, but not significant
24 differences. They address the same thing but they are more
25 tailored to particular plants than the other PWRs. On the BWRs

1 they just said "Take a look at things like this."

2 Isn't that right?

3 MR. CROCKER: Yes, sir.

4 DR. SIESS: I could tell you what the differences
5 are but I would have to dig it out.

6 We do think it was a good idea to be a little more
7 specific in relation to the other vendors, and ask them to come
8 up with some answers, which is what these did.

9 The first round, they only got the B&W notice for
10 information. The second round they got ~~it~~ with the response
11 request. I think that ~~was~~ appropriate.

2A wbl 1

2 DR. LAWROSKI: I just wanted to report that I'm
3 not in disagreement with Paul. I agree with him that there
4 is good evidence that the NRC's expertise in water chemistry
5 leaves something to be desired. And I'll try to work up a
6 paragraph on this subject that will cover this.

7 DR. CARBON: Fine.

8 Dave.

9 DR. OKRENT: Let's, if we can, look at the two
10 paragraphs that were deferred. Let me propose that we take
11 the shorter one first and discuss a couple of different kind
12 of contingency matters.

13 Let me offer this comment: I myself don't think
14 that the probability of another serious accident occurring
15 in the coming year is very large. So from that point of view
16 you might say that this is not a high priority matter.

17 On the other hand, my experience is that it takes
18 time for people to address this matter if you can get their
19 attention. I think it's time we got people's attention and
20 that they do start addressing the question of contingency
21 measures seriously to see what it is one can do. You don't
22 always have days in which to react for various postulated
23 accidents. And so in some cases it's only what you've done
24 beforehand that you would have available.

25 In fact, the partial availability of the auxiliary
building is an example.

wb2 1 So I would think that it's appropriate to have
2 the operating power plants look at this matter, and it doesn't
3 matter too much area they start looking at as long as they end
4 up picking up the several areas that are involved. And if the
5 Staff also starts thinking about this with them at an early
6 time I think there are some measures that one could do for
7 operating plants that if a situation arises that could be
8 useful. And they need not be terribly expensive if you've
9 thought about them before.

10 DR. CARBON: The thought here is for both the
11 operators and the Staff to be looking at these?

12 DR. OKRENT: I would think so.

13 DR. SIESS: What are we going to do with this
14 paragraph? If we're going to tell the Commissioners, you know,
15 if it is something to tell them today where it can be explained
16 I've got no problem. If it's going in writing in three lines,
17 I've got a problem. I need the kind of explanation Dave
18 just gave and some for-instances.

19 I think it can be tied into the research on
20 improved safety and so forth.

21 So what are we going to do when we meet with the
22 Commissioners? Is somebody going to read these off to them?
23 Are you going to read them, Max?

24 DR. CARBON: I guess, tentatively, yes, I will
25 read them. Unless it would be more appropriate for Dave.

wb3

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

DR, OKRENT: Oh, no.

DR.SIESS: And do we think we might put these in a letter next month when we've had a chance to cogitate a little bit?

DR. CARBON: I would believe from what the group has said that we'd want to put many of them into a letter.

I would also believe that we have considerable freedom to add to and supplement.

DR. SIESS: I'm just a little concerned about oral advice, even with a transcript being kept.

MR. FRALEY: We would have this typed up in final form and you could read it to the Commissioners and make it available, just as you would an ACRS letter.

DR. PLESSET: Available to whom?

MR. FRALEY: To anyone.

MR. ETHERINGTON: With an indication as to the basis for the letter that may be written next time?

MR. FRALEY: An indication of what it is that we read to the Commissioners at this meeting.

MR. ETHERINGTON: No; but would we tell the Commissioners that we're going to write you this letter?

MR. FRALEY: I'm not addressing that.

(Laughter)

MR. RAY: Why don't you refer to it as a list of things discussed at your meeting?

wb4

1 DR. CARBON: Or a list of the things we discussed
2 and we're in reasonable consensus that these are important
3 points that we wanted to call to their attention.

4 DR. SIESS: It's not a list of things, it's a
5 list of recommendations.

6 DR. OKRENT: And how about the other paragraph?

7 DR. SIESS: I'd have no problem with it. In fact
8 I think it's a much cleaner way to do it. Even the Com-
9 missioners could pull out the paragraphs we've agreed on in
10 here. And they need very little editing, and it's not import-
11 ant anyway.

12 Do you want a motion?

13 DR. SIESS: The paragraphs that I think we have
14 agreed on and I will include in the motion are the first and
15 second paragraphs on the first page of the blue material;
16 the second and third paragraphs on the second page, and the
17 last two lines as part of the third paragraph; all the material
18 on page 3 which carries over to page 4, and all the material
19 on page 4, but obviously the next to the last paragraph there
20 becomes the last paragraph of the letter.

21 I have a suggestion, and I'll be glad to give it
22 to the Staff: it's not that important; except as to the first
23 four paragraphs.

24 Did everybody locate the ones?

25 I'd like to move the final on this letter.

wb5

1
2
3
4
5
6
7
8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

VOICE: Second.

DR. CARBON: Is there discussion?

Those in favor of the motion indicate by a show
of hands.

(Show of hands)

DR. CARBON: Six.

All opposed, by hand.

(Show of hands)

DR. CARBON: Two. It's six to two.

I guess I don't remember Roberts' Rules of Order
correctly, but I think that's valid, isn't it?

DR. SIESS: No. It's a substantive issue and we
have to have a majority of the full committee.

DR. OKRENT: Right.

DR. SIESS: I assume that the noes were no in a
letter at this time rather than noes on the positions in the
letter.

MR. MATHIS: Right.

DR. SIESS: Is there objection to reading these
to the Commission?

DR. SHEWMON: No.

MR. MATHIS: No.

DR. SIESS: Mr. Chairman, I would interpret the vote
as that these represent the position of the Committee and that
they can be transmitted to the Commission.

wb6

1 DR. CARBON: We have fourteen members currently.

2 DR. SIESS: So we have a majority. All present
3 agree this is the position, and the majority agreed that you
4 can present it to the Commission.

5 MR. RAY: If I could be the devil's advocate
6 for a minute, suppose the Commissioners ask you what you're
7 going to do with these? Are you going to send me a letter or
8 not? What's the answer?

9 DR. CARBON: I guess my answer is I don't know.

10 MR. ETHERINGTON: We'd like to but our rules don't
11 permit.

12 (Laughter)

13 DR. SIESS: The objection was simply to a letter
14 at this time, I believe.

15 MR. RAY: That's right. And I would suggest that
16 would be that we're going to have another meeting shortly at
17 which time these will receive final discussion.

18 DR. CARBON: I still don't know, but....

19 MR. RAY: But you're not going to admit it.

20 DR. CARBON: Are there further topics anyone
21 wishes to bring up?

22 Bill?

23 MR. MATHIS: Mr. Chairman, there's been a lot of
24 discussion, mainly yesterday, on the subject of operator
25 training which is a topic we have not addressed here. Do we

wb7

1 wish to comment on that this afternoon? Or are we apt to be
2 questioned on it by the Commissioners? Do we have a position;
3 let's put it that way.

4 DR. CARBON: I don't personally recognize a
5 position. I recognize many people are quite concerned, interest-
6 ed in the subject. But what our position is I'm not sure.

7 Do you want to pursue it beyond that?

8 MR. MATHIS: No. I just tossed it out on the table,
9 that's all.

10 DR. CARBON: I guess we'll adjourn this meeting
11 th en, and we will meet with the Commissioners upstairs to
12 three-thirty.

13 (Whereupon, at 3:20 p.m., the special meeting
14 was adjourned.)