

OCT 11 1977

Docket No. 50-320

MEMORANDUM FOR: H. Silver, Light Water Reactors Branch No. 4, DPM  
 J. Wetmore, Standard Technical Specifications Group, DOR

FROM: D. F. Bunch, Chief, Accident Analysis Branch, DSE

SUBJECT: THREE MILE ISLAND UNIT NO. 2 TECHNICAL SPECIFICATIONS

Enclosed are the Accident Analysis Branch's comments on the Three Mile Island Unit No. 2 Technical Specifications. It should be noted that the Technical Specification containment leak rate of 0.13% is more restrictive than the 0.14% value we found acceptable in the SER dose calculations.

This review was coordinated by C. Ferrell, Site Analyst, Section B, Accident Analysis Branch.

Original signed by:  
 Delbert F. Bunch

D. F. Bunch, Chief  
 Accident Analysis Branch  
 Division of Site Safety and  
 Environmental Analysis

Enclosure:  
 Three Mile Island Unit No. 2  
 Technical Specification Changes

Distribution:  
 Docket Files  
 NRR Rdg. File  
 DSE Rdg. File  
 AAB Rdg. File  
 AAB Files

cc: w/enclosure  
 H. Denton  
 D. Muller  
 R. Vollmer  
 S. Yarga  
 J. McGough  
 D. Bunch  
 L. Soffer  
 C. Ferrell

7904270458

Der 455

83 107

M 4

|        |           |               |           |          |  |
|--------|-----------|---------------|-----------|----------|--|
| x27917 | OFFICE →  | DSE:AAB       | DSE:AAB   | DSE:AAB  |  |
|        | SURNAME → | C. Ferrell:dr | L. Soffer | D. Bunch |  |
|        | DATE →    | 10-11-77      | 10-11-77  | 10-11-77 |  |

A