

UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION I  
631 PARK AVENUE  
KING OF PRUSSIA, PENNSYLVANIA 19406

MAR 17 1976

Metropolitan Edison Company  
Attention: Mr. R. C. Arnold  
Vice President  
P. O. Box 342  
Reading, Pennsylvania 19603

License No. CPPR-66  
Inspection No. 75-14  
Docket No. 50-320

Reference: Your letter dated February 13, 1976  
In response to our letter dated January 13, 1976

Gentlemen:

The items discussed in the referenced letters were reinspected during our inspection conducted on February 23-25, 1976.


Regarding the documentation relating to pipe lugs BSH-88 and BSH-89, the inspector has now reviewed Packing List No. 165-W which indicates acceptability of these components. These records appear to have been on site prior to installation or use, and so this part of the item of noncompliance is withdrawn.

The documentation package relating to pipe spool piece 2-DH-124 has been reinspected and the results of this inspection indicate that one or more of the requirements of Specification 2555-64 were not met prior to installation or use as required by Criterion VII, Appendix B, 10 CFR 50. Specifically, vidigage measurements were not available on site at the time of installation. Therefore, this item is still considered to have been an item of noncompliance.

Our inspector reviewed your corrective actions regarding these matters during his inspection of February 23-25, 1976, and we have no further questions.

Should you have any further questions, we would be pleased to discuss them with you.

Sincerely,



Robert T. Carlson, Chief  
Reactor Construction and  
Engineering Support Branch



790430 0490

Dtes 494

92 296

cc: R. L. Wayne, QA Manager, Design and Construction  
T. M. Crimmins, Jr., Safety & Licensing Manager  
R. W. Heward, Jr., Project Manager  
W. A. Verrochi, Vice President, Design & Construction  
Gerald Charnoff, Esquire  
Miss Mary V. Southard, Chairman Citizens for a Safe Environment

---

bcc:  
IE Mail & Files (For Appropriate Distribution)  
PDR  
Local BDR  
NSIC  
TIC  
REG:I Reading Room

---

---