4/5/79

50-320

ner

-> B Z

EFFORTS RELATED TO EQUIPMENT SURVIVABILITY

- FEEDBACK ON RADIATION WITHSTAND CAPABILITY OF FOXBORO AND BAILEY TRANSMITTERS
 - Naval Reactors No experience with either Bailey or Foxboro transmitters (of Designs used in commercial plant).
 - No experience in weapons area. However, Sandia contacted Bailey and roxboro. No additional Sandia information on Bailey's, but certain Foxboro pressure transmitters are equipped with hardened amplifiers (RC 22-PT1 through 8 which are used to measure reactor coolant pump seal cavity pressure). They have survived tests involving exposure to 2 x 10⁸ R/hr. Therefore, should (ing reactor coolant pump pressure transmitters .a.l, these hardened transmitters should be available as backup to measure reactor coolant pressure.
- II ESTIMATES OF FAILURE TIMES FOR PRESSURE TRANSMITTERS AND OTHER VITAL EQUIPMENT DUE TO RADIATION

Approach:

. 1

I

Knowing radiation withstand capability of equipment (based on test), calculate dose rate due to containment atmosphere and water at bottom of containment, and estimate equipment and lifetime.

Basis for Dose Rate Calculation:

- (a) Assume containment air sample represents containment atmosphere.
- (b) Assume water in containment has some constituents as coolant sample taken on 3-31-79.

Results:

ORNL has calculated dose at location of pressure transmitters to be 1 x 104 R/hr.

Bailey transmitter BY is qualified to 1×10^5 R Using dose of 1 x 104 R/hr, one would expect this instrument to survive only about 10 hours. Since several of the Bailey transmitters continue to function, we are assuming that the dose calculation is grossly in error. Without a better estimate of the source terms, particularly a good estimate

97 216 7905110271

2.8

of the activity of the water in the containment sump, it is impossible to estimate failure times of vital equipment.

III ASSESSMENT OF CRITICAL EQUIPMENT

а.

· · ·

- Have established design radiation level and location inside containment of all Foxboro, Bailey pressure and differential pressure transmitters and Rosemount Temperature sensors (see Enclosure 1).
- Have established location of all critical components of decay heat removal system (have not established design radiation levels).
- We are looking at reactor coolant pumps (Allis-Chalmers). We will provide additional information later.
- Fan cooler motors we have established that they were tested to 10⁹ Rads.
 - Containment isolation values we don't believe external radiation is a problem. Radiation inside of value is estimated to be 2000 R/hr. Assuming seat can take $\sim 10^6$ to 10^7 , seat will last 22 days. However, radiation level should drop with time. Therefore, value seat may last substantially longer.
 - Effect of dumping 250 gpm of coolant on containment floor has been calculated (see Enclosure 2 and Enclosure 3) times when various pieces of equipment would be flooded are enclosed.

Enclosure 1 4-3-79 BY W INSTRUMENTS INSIDE CONTAINMENT BACKBONE) FOR PRESENT OPERATING IA - JAST MENNICAN By ITSENT MODE IR - INST MOUNTER Abert PAD 2726 1EVSL PAD PARAMATER TYPE INST IDENT # LEFEL MOUNTINE ATSCUIP EVEL DESIEN 2'5 SEBFRESS- SPGB-PT/ - IMA13 Fox ENCH 10-107 RC. FLOW LAA - RC 14A - DPT-3+4 - IMA 19+15 BANKER BY ____ 30 PRE BES - RC.1 - LT 1, 243 - IR-424+425 BAILEY BY 10-10" 3'6 SG & PRESS - SP 6B- PT2 - IR-428 Frx F.116H 107 IR: 425+426 BRILEY BY 105-102 RC. FLowLph - RC 14A - DFT 1+2 IR- 429 + 430 13 ANGY BY 105.102 £C143 - DFT314 REFLIG LAB BAILEY BY 105-10 RCF-W-PB RC145 - DFT 1+2 IM-12413 BAILEYBY 10-10 SCALENEL STIA-LT 2+3 IR-426 BALLEYBY 105-12 SE"A" LEVEL (S.W) SPIA LT 445 IR-426 18-10 SG"B" LEVEL SPIB 17/2+3 IR-428 SAILEY BY 10.10 SC B LEVELS. () SFIB LT4+5 BRILEYBY IR-428 10-107 2 SCALEVEL SPIA LTI BRILEY BY . IR: 426 107 SGA PRESS 11- SPEA PT/42 Fox EliGH IR-426+424 107 RC PRESS (W.R.) RC3A PT3+4 FoxEllGH IR425+427 Frx Ellen 107 RC PRESS (NR.) RC3A PTS IR 424 Fox F116H 10? RC PRESS(W.R.) RC3B PT3 IR+29 ACTEMP(MR.T.) RC5A TE 2+4 Ress = min (177 / 108 AC TEMP (MRTG) RCSB TE 244 RESERANT 1774 10? ALLOP RETERP (WRTH) RCHSATE ALICA RCTEAP (WRTE) RC LSATE 243 B LOCA RCTEMP (WRIM) RCLSB TEI B Leep RETEMP (WRTC) RCISETE243 97.218 PRZ TEMP RCZTE 142

Enclosure 2

FLOOD TIMES

@ 250 GPM = 15000 GPH 12" = 74,330 gal 1'' = 6194.215.000 G/HR = 2.42"/HR. Starting Point = 2 feet Steam Gen Press Loop B (1 of 2) 2 hrs 10 min Reactor Coolant flow Loop A (2 of 4) 4 hrs 50 min Press Level (3 of 3) 7 hrs 30 min Steam Generator Press Loop B (2 of 2) Reactor Cool Flow Loop A (2 of 4) React Cool Flow Loop B (2 of 4) (Loop A) (Steam Gen Lev (Operate Range; (2 of 5) (5 Total) (Steam Gen Lev (Start-up Range) (4 of 5) (Loop B) (Stm Gen Lev Full Range(1 of 5) (5 Total) Stm Gen Lev (Operate) (3 of 5) Stm Gen Level (Startup Range)(5 of 5) Stm Gen LevelA (full Range) 5 of 5) == 15 hrs 45 min Stm Gen Press Loop A(2 of 2) React Cool Press Loop A & of 2) Wide Range React Cool Press Loop A (1 of 1) Low Range React Cool Press Wide (1 of 1) LOOP B 39 hrs, 40 min Penetrations (Start) D.H Valves for shutdown cooling 49 hrs, 40 min Reactor Coolant PUmps 8 day, 16 hrs, 50 min.

97 219

Enclosura 3

TRANSMITTER SUBMERGED STATUS

Elevation above ground level

2'-5" ,	-Steam Gen. Press. Loop B (lof2)
3'-0"	-Reactor Coolant Flow Loop A (20f4)
3'-6"	-Flood Level (Based on transmitted site calculation: -Press. Level (3of3) of 4/5/79)
	Stm. Gen. Press Loop B (20f2)
	React Cool. Flow LoopA (20f4)
	React. Cool. Flow Loop B (20f4)
	Stm. Gen Lev. Loop A (operate range)(20f5)
	" " "" (start-up range, (4of5)
	" " " " B (Full range) (lof5)
	" " " B (operate range) (3of5)
	" " " B (start up range) (5of5)
	React. Cool. Pump Seal Cavity Press. (80f8)
5'-2"	Stm. Gen. Lev. Loop A (Full range) (5of5)
	Stm. Gen. Press. Loop A (20f2)
	React. Cool. Press. Loop A (20f2)Wide range.
	" " " A (lofl)Low range.
	" " Loop B (lofl) wide range.
10'-6"	Bottum of the lowest Electrical Penetration
12'-0"	Bot:om of the motor housing of the D.H.Valves
	for shutdown cooling.
46'-0'	Bottom of the motor housing of the Reactor
	Cooling Pumps.

A. Q. What is the status of environmental qualification considerations of the TMI-2 facility?

2. 2

S. 1. 3. 1

B. Much of the equipment currently being relied upon in the present (418) mode of operation, (forced circulation of the RCS and heat rejection to the main condenser through a steam generator), are not safety grade equipment and therefore not covered by NRC requirements. All instruments important to the present mode of operation, i.e., RCS parameters, are located in the annulus between the shielding wall and the containment wall. These instruments, based on available information, will function with doses up to 10' Rad. Estimated dose rate is 10⁴ rad/hrs. Therefore, this dose will be reached in approximately 40 days. Other equipment in the containment is generally estimated to be able to function with doses between 10° to 10° Rad. The dose rate in the containment is estimated to range from 800 to 2000 Rad/hr. A critical component is the surge capacitor on the reactor coolant pump motor, that is variously estimated to have a life of 18 to 125 days.

Water level in the containment is estimated to be over there above the floor. Therefore a steam generator level and RC flow instrument may be submerged. Nine other instruments, including pressurizer level, are mounted 6 to 12 inches higher and could be near the water level.

Additional details are provided in the attached memorandum.