


LOSS OF RCP EVENT TREE



50-320
M. Cunningham
RES/PAS

117 177

7905160019

Mark
SO-320

APR 23 1979

MEMORANDUM FOR: Robert J. Budnitz, Deputy Director
Office of Nuclear Regulatory Research

THRU: Anthony R. Duhl, Director
Probabilistic Analysis Staff
Office of Nuclear Regulatory Research

FROM: Raymond DiSalvo
Probabilistic Analysis Staff
Office of Nuclear Regulatory Research

SUBJECT: VENTED CONTAINMENT CONCEPTUAL DESIGN AT THREE
MILE ISLAND - 2

Reference: R. J. Budnitz to File, Same Subject, April 10, 1979.

The following actions were taken in response to the reference memo:

1. On April 10, 1979, Sandia Laboratories and Battelle Columbus Laboratories assembled task forces to work on the problem at my request.
2. BCL provided calculations of containment atmospheric conditions and airborne radioactivity as functions of time assuming core melt.
3. Sandia developed several alternative schemes for venting and recirculating the containment atmosphere.
4. Mark Cunningham and I defined the functional requirements of the system, clarified the constraints on construction and operation, and discussed with Tom Telford (NRC) and Jim Thiesing (Bechtel) at TMI-2 the feasibility of various alternatives.
5. A draft conceptual design and backup information were telecopied to the site on April 14, 1979, for review and comment.
6. Comments were factored into a revised design and lists of options for construction and operation of the system.
7. Two revisions were telecopied to the site on April 14 and April 15. The final design is attached.
8. I was notified by Telford that the design was presented to Mattson (NRC) and the utility for their information.

117 178

7905160018 p

Robert J. Dudnitz

-2-

APR 23 1979

I intend to take no further action on this matter unless otherwise directed.
I estimate that this exercise required less than one person-month of effort.
I will be glad to discuss with you any aspect of the work performed.

Original signed by
Raymond DiSalvo

Raymond DiSalvo
Probabilistic Analysis Staff
Office of Nuclear Regulatory Research

Attachment: Conceptual Design

bcc w/enclosure: H. Cunningham

Distribution:
Subject
PAS Reading
CIRC
CHRON
DiSalvo Reading
McGrath Reading
Buhl Reading

RES/PAS
RDiSalvo:psr
4/16/79


RES/PAS/DD
PE/cGrath
4/ /79

RES/PAS/D
ARBuhl
4/ /79

117 179


R. DiSalvo

4/15/79, 1700 hr.



1700 hr.

R. D. Salvo



contingency if closed access, radiation levels in nook area are tolerable in emergency

status of isolation values inside

A4V3A-33 : A4V2E-23

css of power failure mode;

contingency if closed

access, radiation levels in

nooks area are to be sold

in emergency

- 99% decontamination possible with controlled flow, < 5 cm diameter bubbles.


7/10/77

1700 hr.

supercedes previous versions

R. D. Salvo

CONCEPTUAL DESIGN FOR TMI-2 VENTING



Component loss
2 exhaust lines

AHV2; 10" to normal
AHV2S; 6" H₂ control

AHV7; 10" to blind flange
2 in. lines

AHVIA-18 36"

2 sets of isolation valves inside

AHV3A-23; AHV2A-23

sets of power failure mode;

emergency if closed

cess, radiation levels in

backup area are tolerable

emergency

3 x 10⁶ BTU/hr on site

- inlet lines and tanks shielded or underground

- cooling required to condense steam, cool gases

(hold at 70 psia without cooling, reach saturation in 36 hr, 40°F/hr)

- level control to prevent overflow; keep backups dry

(hold at 70 psia, 4 days to fill tanks)

- 99% decontamination possible with containment

- option is to place tanks in spent fuel

pool; coolers and pumps operational (2000/hr)

- Total core inventory heat load is 10⁷ BTU/hr

- passive backup by separators

- 2nd backup by separators

- 3rd backup by separators

- heat load of 2000/hr

- 2nd backup by separators

117 182

CONSTRUCTION OPTIONS

OPTION 1: AS SHOWN

OPTION 2: DELETE BACKUP FILTERS

OPTION 3: INSTALL ADDITIONAL H_2 RECOMBINEERS DOWNSTREAM OF SC213322S

OPTION 4: PUT SCRUBBING TANKS IN SPENT FUEL POOL #2

OPTION 5: DELETE RECIRCULATION LINE TO CONTAINMENT

OPTION 6: ADD HYDROGEN COMBUSTION MECHANISM

OPTION 7: VENT DIRECTLY TO SPENT FUEL POOL #2

OPTION 8: VENT DIRECTLY TO STACK

OPERATION OPTIONS

VENT PRESSURE

TIME DEPENDENCE OF PRESSURE

USE OR BYPASS SCRAMBERS

USE OR BYPASS BACKUP FILTERS

RELEASE THROUGH STACK


RECIRCULATE TO CONTAINMENT

H₂ CONTROL

NON EMERGENCY (NON-CORE-MELT) CLEANUP

T/C MAPS

50-320
RES/PAS



Date 4/6/79

B out

Time 1000

Pressure 11.25 psi

Inlet 255 F

Inlet 252 F

Time 560 F

Pressure 2.42"

SG 11 110 Lp 355"

SG 6 14 Lp 303"

Down Flow

1 B started


P 12 - 1.2 psi

Temp 13

Kory - lost in
before Pump 1-A

LOCATION OF FUEL ASSEMBLIES
BURNABLE POISON ROD

THREE MILE ISLAND NUCLEAR STATION



7905160020

CONTAINMENT:

Pressure -1.20 psi Temp. 83 F Level of Water

117 185

	1	2	3	4	5	6	7	8	9	10	11	12	13	14
A														
B							294	295						
C						296			308	296			296	
D					296					319				293
E				296			313		340		245			
F			298				276	222				293	292	
G		293			364	325			336		327		295	
H	292				335			468	296				292	
I					301						324	292		
J		293	293			221					293		?	
K			293				297		355	333				?
L				296				316	303					
M					305	308				295		294		
N						302								
O							293			293				
P														
Q														

Date 4/6/79

Time 1447

SS.
Pressure

inlet

inlet

Pressure

Pressure

SS SGIT

SS SGIS

Flow Flow

CONTAINMENT:

Pressure Temp. Level of Water 117 186


B out "10" or "1A" RF

to landing transient, plus TC reading vari-
widely if one starts out but my
suspect.

? no reading

LOCATION OF FUEL ASSEMBLIES &
BURNABLE POISON RODS

THREE MILE ISLAND NUCLEAR STATION



Hydrogen Conc In-line: Reconnector