

May 18, 1979

NRC/IE
STATUS LOG

4/1 - 5/1/79

RECORD



7530-00-222-3525
FEDERAL SUPPLY SERVICE

(GP 3)

150 1243

7905210 190 P

4/1/79

Emergency Procedures Reviewed By IK

1. Pressurize Degas Procedure
2. Waste Gas Filter Troub
3. Emergency Procedure for Sampling MVT-1
4. Venting Makeup Gas Spare To Vent Header
5. Check of Waste Gas Decay 30B
6. Fill OTSG to 95%
7. H₂ Recombiner Operation

4/21/79 - DEBRIEFING - SEYERIT to GRIER

HIGGINS
800
Stelli has initiated planning to mobilize decon crews to clean up aux bldgs. Tentative plans would give IE general oversight resp, with a total team, including management, HP, etc to whatever agency is used - merely informed

Waste gas decay tank sample taken @ 4:15a.
can't transport to BETTIS due to weather

IE onsite has responsibility to develop PN info and fax to IE:HQ at 0630 and 1830 each day

State agency found significant I^{131} in milk samples. Split sample with PA state found no I^{131} .

Containment spray is reported to have activated at ~1400 on 3/29 when pressure spike of ~30# occurred in containment. Tanks reportedly increased (emptied) from 50% to 30%

Gas held up tank analysis - 56% H₂; N₂ 43%; O - 0% - Thinking is don't return to containment as this would increase H₂ by 0.5%
~~150~~ 128

Recombiners - Hooked up, ready to warm up one - second unit to be backup. Capacity is

calculated to be 5 cu ft/hr removal - for
90% removal of H₂ ~ 2000 hrs required.
Generation rate of H₂ in containment is initially
expected to exceed removal (50-100 cu ft/hr.)
Pad level at piping surface is calculated to
be 40 ft/hr. Plan to have in service by 1200 today.

Bubble may be gone by 1200 today
present calculations based on 100# pressure
drop. Trying to get better definition by cycling
pressure between 900-1100#. Bubble size
presently $\frac{47}{47} \frac{ft^3}{ft^3}$ @ 0740

S.G. A - still not filled for heat sink in
case of RCP failure. Considering filling
and using condensate pumps with flow
thru steam lines to condenser instead of
RTH_(DH), due to possibility of RTH_(DH) system leakage
of high level activity.

B&W LCR to Met Ed says instruments are effected
to starting failing at an exposure of 10^5 rads.
 10^5 rad exposure reached on 4/1/79

RCS flow Xmitters on both loops failed 4/2
Hanau wants details on inst's to determine failure modes

Core flood tanks approved for isolation, not
yet isolated

(S)

Walking robot from OR not yet in service
checking out remote (radio) control. - Sampling

Containment H₂ 2.4%; O-17.6% N₂ 79.9%

PAO offices set up in middletown
telephone 944-4796; 944-4943

TE individual entered ~~Avx Bldg 8~~ f in
violation of RWP in that he did not have a
survey meter

1015 Approval ~~for~~ to place recombiner in use
was granted w/20 minute delay to permit
ARMS to get airborne

1040 Bubble size believed to be zero,

1200 Radiation measurements 4/1 4/2
Containment - Personnel Access 15 MR 100 MR
- ATM10 Sample(contact) 350 MR 850 MR
- Top of dome 4 MR

1346 Recombiner in service -

1419 - Temp @ 450°F will heat 1300°F,
reaction Temp in ~ 3.5 minutes
No leakage - reading 400 mrad at
reactor chamber

150 128

1510 (from Beckman in U-2 CR)

- Over flights are reporting 50-200
mwh over screen house and
stack. No abnormal readings
in CR. No plant operation
changes except recom biner
in operation. Recom biner
contact readings: 700 mwh.
on pump; 90 mwh on heater
chamber. The recom biner is
expected to be at operating
temperature (1300°F) shortly and
then will require ~ 1 hr to
stabilize. It is presently
passing 60-65 c.f.m.

1630 IE:HQ requested that continuous
contact be maintained between
the control room and IE:HQ.

1640 Grier wants IE opns to log 10 highest
core thermocouple readings or core map
~ hourly.

1905 Region III personnel arrived at airport (Wenick, Brown,
McGregor, Jorgenson) and will go to the Flyway
Hotel.

1915 State has ordered TMI to stop all liquid discharges. This is apparently because of iodine being found in a ~~water~~ water sample of water being discharged to the river recombiner operating O.K.

2225: Verday called. Isachet that they were increasing the temperature of the recombiner by 700°F to try to improve its efficiency. The latest Hydrogen purity measurement is 2.3%. New inline H₂ analysis is being installed. It is being installed in the main pipe line into the plant at 7:00 AM.

4/3 0025: Reported of a release from either the reactor building - some technical opinion: and is being confirmed. No 2.1 o.

0033 Dick Wilson, GPU identified, as per our review the sequence of events. Our highest priority is to obtain info on equipment breaking on Wed. But we are not to ask operator to obtain data to the detriment of safety.

0039 Inform by Higgs that Laramie stated that Shultz had been briefed & could say.

0055 Finished decont with off going shirt - still dry. On H₂ Recombiner running - 2nd in stby status - Running unit had hi fl. rate - max up cold temp 102° (\approx 1300 vs 1200). calc H₂ $\left[(T_a - T_b) / 125 = H_2 \right]$ went from 1.9 to 2.3%. 2.3 conclusion more accurate. Left 11-12 days to get to below 1%. Plan to save SG - don't know how it needs ≥ 2.5 hrs.

150 120

0058 Release evaluated as due to on line ~~H₂~~
analyzer - "terminated" TMI prior

0115 Recent wdtf re release back up - worst case 30 hr
projected 70 hr.

At 0110, B. Jorgenson, RIII was advised by
Victor P. Orlando, GPU that turbine sump
overflow @ present conditions would be 70 hr,
worst case 30 hr.

0500 1 AM release evaluated as due to venting of the
MUT @ 6 psig to the vent header (done
periodically @ 6 psig) because of vent header
leakage. Offsite dose detected was a still
to 1.5 mR ~3 mi downwind, with rapid return
to 0.02 mR.

4/31/79

0830 Shift change debrief

Making up to basic acid mix tank

Release at 0200 attributed to leak between
MUT and compressors

Containment and gas decay tank samples
sent to Bettis on 4/2 appears to be bad samples.

150 150 SG "A" still @ 34", expect to fill 415 lines solid
within 3 shifts - 415 pipes hangars joined
so springs all not supporting

Cont'd 0830 debrief

Flood tanks isolated 4/2

Recombiners - cycling hourly with H₂ concentration reading 1.9-2.3% at 65 cfm. direct contact on 2" pipe is 5-19 R.

Bubble is calculated to be 50-125 cu ft

Na OH Tank @ 30' and being increased to full
- Tank aligned for containment spray, if needed

1043. Online H₂ analyzer secured after
0020 release. Analyzer uses a 2 cc
sample that is released after analyzing.
Has not been placed back in service

0950 - Commenced filling SG A to 95% from
34%

1100 SG B sample data for 0700 provided
 $I^{131} = 2.9 \text{ pCi/ml}$; $I^{133} = 8 \times 10^{-2}$; $Ce\ 134 = 8 \times 10^{-3}$;
 $Ce\ 136 = 1.8 \times 10^{-2}$; $Ce\ 137 = 3.2 \times 10^{-2}$

1430 β ZR₁ ^(1/3) level transmitter failed low (LT-1)

1520 4 hours away from hooking up topside rig to
pressurized sample line

150.138

1500 H₂ analyzer did not give puff
(see 043 entry). It was making tank
vent to gas header
H₂ analyzer not working due to low
flow.

2320 Notified that a sample is being taken
from the waste gas decay tank.

4/4

0700 PZR level transmitter (LT-2) has
been acting up - presently stable.
Contingency plans ~~are being~~ ^{are} formulated
for action to take if transmitter
fails.

Waste gas decay tank sample
was not taken (as planned) this
shift.

4/4 0857 - Shift debrief

- Concerned about loss of PZR lvl instrumentation
(lost CTI - now deenergized & LT2 is erratic)
Today working on correlating MWT and using a
Krise gauge across steam dome and PZR sample
lines to read PZR lvl.

- I¹³¹ in aux bldg has increased and is now
100 to 1000 times MPC. Considering putting
NaOH on aux bldg floor. 150 137

Cont'd delivry

- plan to sample RCS by use of robot today @ n 1100.

1000 Question came up concerning who has responsibility, IE or NRR for assuring that Tech Spec requirements are adhered to. NRR says IE has that responsibility & should identify any significant NC to NRR. NRR has authority to review & Waiver. All procedures that contain alignments or operations that deviate from T.S requirements should be identified on the procedure by IE.

1026 - Joel Luberman, Pa DER stated that he and State of Md had discussed discharge of industrial wastes. Joel stated that neither Md or Pa have a hold on the industrial waste discharges. Md told Pa that Pa has lead on this matter.

1130 RCS sampling delayed beyond 1400 due to tubing across floor in front of sample panel ad dumb "herbie" can't step over it.

1300 Joel Luberman, Pa DER stated that the FDA analysis of river water showing I^{131} was a lab error - No I^{131} . PN 79-67I, page 2 contained this error. "I" is now corrected.

4/4 - 1515 - relayed TMI-2 power data to AL David Bettis. Except for 17.5 hour period on 3/5-6 (LX shut down) power level has been above 90%. Since 3/6/79 to time of incident, power level has been 96-98%.

H4-1600 Aux Bldg sample taken in puddle
near tendon access area. Rad levels reported
in area 450 r/hour. Analyses done by
B&W Mo $99 - 8.9 \times 10^{-3}$; $I^{131} - 0.67$; ~~$Cs-134 - 7.7$~~
 $Cs-134 - 9.9 \times 10^{-4}$; $Cs-136 - 1.85 \times 10^{-3}$; $CS-137 - 4.08 \times 10^{-3}$
 $La-140 - 5.026 \times 10^{-3}$. Sample reading 40 mR/hr

John Collins - NRA said You can't charge for what Ed
to put hydrazine in all but old water puddles/
sumps to tie up T-31. Not done as of 1725.

1748 Unit 2 Fuel Bldg area monitor 10041,
No change from previous readings

Initiated pressurizer spray

2256 1ml. sample from the 281 ft elev of the Auss
Bldg was delivered to the NRC trailer for counting
& analysis. George Smith had requested the sample
for analysis.

150 134

4/4/79 2315

Bethis reported an error in their previous report on the 3/31/79 containment gas analysis. Error due to their use of an incorrect base volume.

Analysis	(Initial Report 3/31)	(Reported 4/4/79)
	Incorrect Result	Correct Result
Xe 133	1.5×10^9 dpm/ml	$26 \mu\text{Ci}/\text{ml}$ 5.8×10^7 dpm/ml
Xe 133M	3.5×10^7 dpm/ml	$7.9 \mu\text{Ci}/\text{ml}$ 1.75×10^7 dpm/ml
Xe 135	1.8×10^7 dpm/ml	$3.5 \mu\text{Ci}/\text{ml}$ 7.8×10^4 dpm/ml
I 131	1.4×10^5 dpm/ml	$0.025 \mu\text{Ci}/\text{ml}$ 5.6×10^4 dpm/ml

4/5/79 0250

While venting the PZR (thru the PZR vent line) for 10 minutes, the PZR level decreased from 213" to 204" and pressure decreased from 1020 psig to 975 psig. This response of level and pressure tends to substantiate the lack of, or small size of, any bubble in the Rx vessel.

(NOT RELATED TO INCIDENT)

0448 A shipment of solid waste left the site at 1650 on 4/4/79. Another shipment is being prepared.

1050 Water level in reactor building
B&W calculates 268,000 gals.
levels probable
max $39:2"$
min $35:8"$

0940 Bubble calculation shows "0" bubble
150 135

4/5/79 1600

During review of draft procedure Z-28, OTSG Level Control During Natural Circulation With Level Higher Than Normal, IE identified a step that will violate TS 3.4.5, OTSG level. The procedure calls for 480° while the TS requires the level to be between 18° & 440° for modes 1-4 (mode 4 is above 200°). NRR & Met Ed notified by IE reviewers

1630 ^{GAS} WASTE _A TANK B BEING VENTED
INTO CONTAINMENT

2300 The venting of the B waste gas decay tank did not take place as stated above. It is currently scheduled for after the 11-7am shift comes on. The ARMS chopper is in the air at 2315.

4/6

0100 Hold on venting waste gas decay tank to containment. Reported leak in line. Hydro of line and repair of gas identified leaks to be ^{done} ~~repaired~~ prior to venting. Not expected this shift.

11 of 39

~~Two~~ pressurizer heaters are inoperable. Some of the remaining filter bkr's are tripping spuriously.

150 136

0310 Started discharging IWGTS to river.

Release rate of 100gpm being diluted by 58000 gpm of cooling tower effluent.

Last sample taken on IWGTS at ~~30020~~ on 4/6/7 showed I_{131} activity to be $\approx 2.3 \times 10^{-5}$ ucif/ml

0547

Started venting "A" Waste Gas Decay Tank to containment. Plans are to decrease WGDT pressure from 84 psig to 15 psig at a ~~3.86/hr.~~ rate of 3 psig/hr.

0600 (Re 0310 entry) stopped discharging IWGTS to river at 0400. Taking sample; plan to continue discharge following sample results.

0615 Resumed discharge of IWGTS. Sample results indicated I_{131} activity to be 2.1×10^{-5} ucif/ml.

0630 Terminated venting of WGDT due to high activity in auxiliary building.

0745-4/6/79 Debriefing

- Eleven of 39 ft² waters impermeable - installing higher air-breakers to increase current flow to HTRs

Cont'd debrief 4/6/79

- Let down flow decreasing - considering securing ^{seal} flow to non-operating LCP. operating LCP is an internal seal flow.

Scoping work involved to install three additional decay heat systems with remote control valves to back up the installed 2 systems. Target date for work completion is 5 days.

- Established ^{negative} containment pressure of 2" to prevent collapse of tanks in containment.

4/6

0950 from Roger Zavadonski in 11-2 CR
S.W.D.G.T. - 1A being released to contain-
ment since 0920. No problems.
Monitor H.H. - 3240, reading c. 60-80 m/s.
IWST discharged 0310-0400 and
resumed at 0615.

Unit 2 Misc Waste Tk. being pumped
to Unit 1 " ". Tank level
at 0800, 4/5 was 8'9". At midnite,
was reading 6' vents to unit 1 78.8

1100 Have experienced a gradual letdown decrease
to a low of ~ 2 gal. Throttled back or intermediate
cooling to heat up letdown line to remove some
plate out. Flow now ~ 5 gal

1100 Continue vent - "A" waste gas decay tank.
pressure decreasing $\approx 5\#/\text{hr}$

1320 RCP 1A tripped - Not planned - may have been intermediate cooler interlock.

TMI operations are entering seal cooler room with pre-determined start times. Previous seal room radiation levels were measured at 150 r/hr at door.

1405 - Notified entry had taken place with no over exposures

1425: Cause of RCP 1A trip not known at this time 2A operating ok. Seal water flow to 1A & 2A. Core T/C's not read yet. Press. appears (eyeball) to have increased to 1300#, Tf appears to have increased to 50°F. Intermediate cooler SW. may have caused trip - flooding of sw. may have occurred. Reviewing all intermediate cooler interlocks

No environmental changes resulted as a result of this event.

1449 - reported ^{RCS} no pressure spike during pump outage. Spike was on RCP seal pressure

1600 Waste gas tanks "A" being vented to containment
Tank "B" pressure is also decreasing. Common connect valve between tanks is leaking, resulting in both tanks being vented simultaneously

4/6/79

2300 Continued venting waste gas decay tanks all shift. Pressure down to 43 & 40 psig

2330 Started borating between 2245 & 2250. Going to 4000 ppm

4/7/79

0300 Small release while venting MDT - secured within 1 minute. Rad increase from .02 to .07 now detected, rapidly returning to .02. Notified Pa

~1400 Started pumping Misc Waste Th to Blvd Th. Plan to the pump Aux bldg. pumps to Misc Waste Th. then use NaOH.

4/7/79

1945- Started procedure Z-57. Lowered RCS pressure to 750 (actually 731) by ~2040 and to 702 psig by 2236. All readings look normal

2206 Small release when MD tank was filled too fast and caused burp. Vent monitor went up by a factor of 10 to 4×10^5 . Dropped to 4×10^4 by 2200. ARIIS was notified & sent up to survey.

150 146

4/8/79

00:08 - Cycling buns in 50?? psig steps to decrease to 500 psig.

0645 ~~Reset~~ Reset the time history lost - no quantification

0654 - Be Hertzen has set of t/c readings preceding & after NRR trip / shift - will bring out with him - NRR wants.

0735 - @ 550#

0855 - NRR approves depressurization to 500 psig

0930 - Boom cone in PS a/o 4/7 minute, 2329 rpm

ALL REQUESTS FOR INFORMATION, WITH THE EXCEPTION OF
H-2 PLANT PARAMETERS AVAILABLE IN THE CONTROL ROOM,
SHOULD BE COMMUNICATED THROUGH IE TRAKER.

~1315 - Repressurizing to 1000 psig + filling S6s to upper heat removal steaming level.

1445 - At 888#, starting to depress in 50# increments to 500#. Will require NRR ok at each 50# increment.

2245 • Reduced RCS pressure from 800 to 500 in 50 psig increments per procedure. Nothing unusual noted.

- NRR approved temporary procedure change to Z-57 to allow pressurizer level to go to 150 inches
- Lost level indication on B s/s prior to 1500 reading

080 - Update from last shift - depressurized to ~425# going back up to ~1000# for more depressurizing
150 148

4/9/79

from Conte, U-2 Ch \sim 1200
 $\frac{\text{low}}{\text{high}}$ RFW

Concentrated hot level spill in U-1 And Bldg
while transferring from Cont. Waste Storage Tk to
Classification Drum. White + 4 H₂O going to
investigate.

1430 - Update from Conte
Priority Items

- None U-1 waste thru Cep - Jan
- U-2 Make room in Water Tanks
- May Add of Bldg. radiation levels to issue RWP's
- Primary Lysine pump failed upon 2 glands pump
became inoperable while testing 7 Seism
~~and~~ Pxz level backup instrument.
- Scoping job for installing backup filters
in Pump bldg.
- Plant ops personnel are performing check of
DK Sys. pressure interlock.
- Evaluating pulling breakers for CTV's
- Recalculating control points - considering more
back
- "B" S6 sample reading 246 Ci/ml T

4/9/79 2400 - Received notification that NRR has approved
procedure to pull RCS sample. Mathon says
Met Ed will be ready to pull the sample about
0110. The ARMS helicopter people have been
notified. Met Ed will wait till they are in the air

to 0545 APR - Recirculating sample sink. ~0620-0630 sample time.

No plans to degas / debaron until 0522 local inst satisfaction resolved. - In one thermocouple 399 - with histogram of Readings : $201^{\circ}-210^{\circ}$, 1 ; $251^{\circ}-260^{\circ}$, 1 ; $281^{\circ}-290^{\circ}$, 27 ; $291^{\circ}-300^{\circ}$, 10 ; $301^{\circ}-310^{\circ}$, 5 ; $311^{\circ}-320^{\circ}$, 1 ; $331^{\circ}-340^{\circ}$, 1 ; $351^{\circ}-360^{\circ}$, 1 ; $371^{\circ}-380^{\circ}$, 1 ; $391^{\circ}-400^{\circ}$, 1. NRR believes TIC's are valid based upon intent from noise monitoring but hasn't explained the below Te values (just the high & bulk ones appear to have been checked??) - low readings are being discounted by NRR.

100603 - 2 bigs - 4 samples - BeH₂ & B₄W selected as priority. ORNL & Savannah River to assist big location - trouble down route to D. Donaldson @ 0603. - Need to follow up later (might as well get 6-12 bigs - this is going to happen again).

0733 - RCS sample drawn

1005 - from Rick Conte

Priorities

- Complete packing breakin on RW pump
- Pre Hrs. cable drying
- Installation of charcoal filters on condenser vacuum pump exhaust - problem: must secure pump thereby losing vacuum.
- Filling Boric Acid Mix tank.
- Talking about obtaining RB sump sample
- Pre level instr LP-2 acting erratic also C200; now on LP-3. Holding up on depressurization to 300# until LP-2

problem is resolved.

- Met Ed has set 150" lower limit on Pz level.
- Still looking into advisability of disabling GTR's breakers.

0903 + 1130 Sewage transfer to truck

$$L \cdot 3 \times 10^{-7} I^{131}$$

$$L \cdot 5 \times 10^{-7} I^{133}$$

$$L \cdot 40^{-6} Cs^{137}$$

1320 - Started depressurization to 500 #.

1450 - from Rich Conte

LP-2 tracking; LP-3 on computer. Problem evidently resolved. Established hold on further depressurization to 300 # (now at 450 #).

Loop A narrow range pressure instrument O.O.S. Checking out problem.

1520 - Looking for NRR approval to proceed with depressurization using ^{tension} Pz level Heisee gage installation for pressure correlation. NRR reviewing.

4/10/79 16-24^{PM}
~~4-12~~ Shift -

Raised RCS pressure and holding under 1000 psig (986 psig @ 2300).

Primary sample left site N 2240

Discussed Met Ed HP training and possible waiver or alternatives with Al Gibson. He will pursue this with Met Ed tomorrow.

150-144

4/10/79

16-24 AM
4-12 shift

Discussed with Al Gibson Met Ed's desire to move radiation zone control points back to normal control points to ease the burden on masks. Al Gibson will pursue.

2000 - Commenced Pzz level reduction from 232" to 100".

00-08 Shift 4/11/79

0140 Licensee requested to transfer U-2 Bleed Tk to U-1 ^{Radiowaste} Misc. waste Tk. Sought NRC approval. Subsequently determined that transfer was not needed immediately. Does NRC have to approve? (Kluyver says no)

0230 Pre system sample landed at Oak Ridge (per Mike Wilbur, IE:149).

0248 Pzz level indicator, L P-2, failed high.

0258 " " " " resumed indication

0305 " " " " , failed high.

0310 - Pre system sample landed at Augusta, Ga. for Savannah River (per Mike Wilbur IE:149).

0318 Pzz level indicator L P-2, resumed operation. After second LP-2 failure, CR operators began taking base line data for plant water inventory determination of Pzz level (EP 21).

Z 50, Rev. 3, Husse Rig procedure still not approved. Reportedly there are problems with calibration. Please determine cause of delay.

150 148

0400 Plant Status:

Latchdown 22.5 gpm	MU pump 1B operating
RCP 2A in operation	Cond. " 1B "
S.G. A - Level 335"	RB fan clrs. 3 of 5 "
Press 14 psig	CV sump level - 30"
SG B - Level 350"	RB press. - 0.6
Press 13 psig	MUTL level 62"
RCP Bleed Th. 1A - 10.8'	press 0
1B - 13.8' (to Misc. Waste)	
1C - 13.4' ContWTh2 - 1.8	
Burst Level 54'	RCP 2A motor shaft - 8m
Waste Gas Decay Th A - 35'	motor X - 1.6m
B - 32'	Y - 1.8m

0800-1600 4-11-79

1020 Pwr lvl indicator LT-2 continuing erratic behavior
(~~251X~~ spikes in past 12 hrs.) - anticipating failure

1120 - recd info from calc - B&W reported 340# from bottom -
no other info.

1424 - SUCATE - Starting pressurized 25# cycle to 300# for degas.

1600-2400 4/11/79

150 146

1820 TMI-2 pri sys press 515 psig

1845 @ 1830 500 psi T C's see TC sheet.

Pressurizer press. indication has gotten worse over

@ \pm 30 psi swing. Calc done following ~~per~~ procedure requirements below 500 psig.

2115 Pressure level LT-2 is now lost
~~One~~ (at 2044). One level indicator
LT-3 left which appears to be off as much
as 30 inches. They now say LT-3 is OK

2135 Stack gas radiation monitor has started an
upward trend.

@ 2042

Pressure pres	448 psi	8H	396
" temp	473 °F	6G	311
" level	184	5G	353
A Tc	282	5H	384
B Tc	280	9M	341

8 miles
limits
8 miles
@ 2052

Pressure pres	406 psi	8H	387
" temp	461 °F	6G	312
" level	190	5G	354
A Tc	282	5H	385
B Tc	280	9M	342

150 147

2235 Unit 2 starting to depressurize to 350 psi

2245 HQ said that Commissioners Greford, Cham
and their staffs will visit tomorrow, 4/12/79

Per pres	350 psi	8H	389
" temp	452 °F	6G	314
L.D 16.4 gpm " level	205 in	5G	355
A Tc	281 °	5H	386
B Tc	279 °	9M	342

2335 NRR OK to increase to 300 psig

4/12/79 00-08 Shift

010 Completed 3rd cycle to ~ 300 psig. Noise detection equipment recorded very little gas evolution. Increasing pressure to ~ 1000 psig & will hold.

At 0100
~0200, temporary cond. storage to overflow tanks (2) left site without H₂ release. One truck previously sampled at 1 E-06 mcf/ml. L¹³. Contacted Pa. State Police to intercept & escort return to site for survey & resampling. Truck located at I-81 Harrisburg Truck Stop (~5 mi from Harrisburg) and returned to site at 0305. Were enroute to N.J. for repairs. IE-HP surveyed tank externally - no indication of leakage or rad. levels. Sample of liquid content obtained. Waiting for results. Shift Sup't. initiated procedure to require both property release and H₂ release for all shipments off site.

0500 - 798 "Aux. Bldg. Exhaust Filter Changeover procedure ready for PDRC approval after incorporation of IE-HP comments. No NRR approval will be required to implement this procedure. (No ^{NRR} reviewers on site.) Implementation imminent.

0610 - Tank Sample results: ~~PP~~ 6.4×10^{-5} in³/cc.
gross β (MFC 3×10^{-7} in³/cc. F¹³)

0700 Plant Status

Ledown	19.8 gpm	Contain. press	-1.0 *
RCP 2A	on operation	Contain. temp.	83 °
Par pressure	971 #	Contain. Atm. H ₂	1.76 2
Par temp.	552 °	Highest Core Thermocouples	
Par level	226 "	8H - 387 °	6G - 306 °
"A" loop temp	282 °	5G - 347 °	5H - 377 °
"B" loop temp	280 °	9M - 337 °	

0800 - Started working E 98

0800 - State of Pa is in normal notify procedure from 7PM to 7AM. - will be there during the days: 783-8150 is the Nite Civil Def. (PEMA) number.

1830 Direct line from JF trailer to State of Pa, will not be manned by state between 7PM and 7AM. If contact with state is necessary contact the Pennsylvania Emergency Management Agency (PEMA) at 783-8150 between 7PM & 7AM.

2100 Pre. level transmitter
1T-2 is now working again
according to Hobbs.

4/13/79 00-08 Shift

0100 - H₂ recombiner tripped. H₂ ~ 1.48
0210 - Met-Ed Shift Supr. requested NRC approval
for procedure Z-93 VR Bldg. Sump Level
Measurement". Met-Ed ready to implement -
NRC reviewers on site. Discussed proced-
ure with U-2 Control Rms. General scheme
is to tap into "B" DH loop downstream
of DH-V6 with Hesse gage; then to crack
DH-V6. The procedure contained no
provision for ensuring that DH-V6 would
not lose possibility of debris preclus-
ive seating. Suggested that Met-Ed
make contingency plan for back flush line.
Connections appear to be available. Also
suggested that during last leakage test
the "B" loop ^{ALS} indicated leakage. Met-2
will check out before proceeding.

0255 - Problem with H₂ recombiner is
burned out heaters. Unsure if heaters
will be replaced or second recombiner
cut in

0615 U-2 CR reports 2' hole in tent around
job area for Z-98. Also, HP has invalidated
the RWP for the job. Reason unknown at the
time.

0610 (late entry) - Frank ¹⁰⁰ ~~putting~~ Discharging WDLT-11A
to river (Sogata). Started discharge at 0535.
Total conc. 2.16×10^{-3} Ci/ μ (1.0 MPC)

4-13-79

0800 - 1600

0920. Control room advised by licensee and relayed to
IE trailer that the licensee will commence cool-
down @ $2^{\circ}\text{F}/\text{hr}$ @ 1000.

1600 - 2400

1940 U2 control room - APR-219 is being
taken out of service while a
new stack monitor is being installed.

2100 U2 control room - replacing charcoal filter
is being delayed until next shift.
They are going ahead with replacing
APR-219.

2130 @ 2100

bar pres 829 psi	74	346
" temp 537°F	74	350
" level 156 in	56	321
Tc A 250°F	66	283
Tc B 246°F	91	309
let down 199 6PM	61	282
cont. pres -0.8		
" temp 84°F		150 151
-0.4 $^{\circ}\text{F}/\text{hr}$		

2130 AT H₂ expert now onto

2330

HPR press	845	84	345
" temp	536	54	349
" level	154	56	320
T A	249	86	281
T B	246	9M	310
L D	19.6	6L	282
Cant press	-1.0		
" temp	85		

4/14/79 Shift 00-08

0140 - USAF plane landed at HIA to receive pressurized RCS sample for transfer to Allied Chemical at INEL Idaho Falls.

0150 - RCS sample ready for delivery to TA.

0235 - HPR returned to service.

0300 - RCS sample left site.

0320 - " " at HIA. (ETA-045 EST.)

0400 - " " enroute to INEL, Idaho Falls.

- Filter replacement job resumed after decon of HPL-228 (Aus Bldg Vent Monitor) T channel. HPL-219 still alarmed with external monitor hook-up underway.

0600 - Filter job halted until next shift. Max exposure 55 mR/hr by dosimeter. One filter changed out.

150 153

1820 Recombiner ready to start - valve
lineup is in progress

2230 H₂ Recombiner back on line (~2000
° is warming up, but is not
yet up to temp & processing.

2330 - Filter replacement job halted
due to lack of air. (7 filters
have been removed - 1/2 of "A" bank)

4/15/79 00-08 Shift

0500 - Filter removal job resumed

0700 - H-2 CR reported that 17 of
ninety filters have been removed.
(2330 entry of 4/14 possibly in error.)

1700 H₂ = 1.46%

4/16/79 00-08 Shift

- Late Entry 0732 4/15 - Any Bus. exhaust fan
tripped (AH-8C). Fan restarted at 1214 after
jumping fire system controls. (Previous trip occurred
at 4/11/79 at 0123 & restarted at 0345. Presumed
same cause, however, both supply & both exhausts were running
at that time) 150 153

0500 - Recirculating preparatory to drawing PCS sample

0615 - PCS ^{gas + water} sample drawn ^{gas} to B&W Lynchburg
for analyses.

161330 Jack at 25 has back pain - sent took him off watch - he went to army hospital

~161400 Sent rough list of IG franchise record to Bob Pavlus for R&F release info.

1515 - Rec'd Memo from Diver to Smith which directs 1E to begin preparing daily PN - It directs the 1E Shift Sup to have prepared by 0700 starting 4/17.

Rec'd a Computer Print out from TMI/GPU for their document file indexed by keyword -

Rec'd a copy of a Task Status Report (Construction Work)

Rec'd copy of GPU's Prel. sequence of events

GPU data (Running Tap Parameters) collectors are moving to the site tonight - will be providing the data sheets twice per shift starting tonight

Aux Bldg Filter C.D. did not progress on this shift due to air supply problems - elevator not controlling

2000 Unit 2 CR has started radioing the Unit 2 vent radiation monitor readings to us every hour & we are passing them on to GEC Smith's fellows at the other end of the trailer. These readings are being recorded in the back of this log.

Unit 2 P.R. notified us that, in order to repair the Unit 1 aux. bldg. elevator they were going to have to pump contaminated water out of the elevator shaft. To do this they will be transferring water as follows:

- ① auxiliary sump to aux. sump tank by neutr. tank.
- ② misc waste tank to bleed tank
- ③ Elevator shaft into aux bldg. sump

2300 - Resumed work on charcoal filter elements replacement
- H₂ concentration 1.36% 150 155

4/17/79 00-08 Shift

0330 - Twenty charcoal filter elements replaced
- Started spraying Aux Bldg. floor with sodium thio + hydroxide.

0415 - Pumped aux. R sump to main waste tank.
- U-2 CR reported that H₂ supply lines to Core Flood Thru indicating 20+20 R/L at 2 points. Believed due to leakage thru CFT check

valves. Licensee intends to pressurize with

N₂ to blow back into CFT's.

Completed to blow back to CFT. Level is reduced substantially
06000 (20R/hr → 5R/hr + 10R/hr → 30-50mL/hr.)

0630 - Loop A T_c = 244F

Loop B T_c = 241F

0800 TO 1600 —

0940 - Talked with Tom Harvey
(Fed Reg Preparers Office in Phila)
gave him status per the P.R.

1145 - Rec'd copy of proposed modified TS.
for review - Harpster reviewing —

Control Room Status Report as of 1215 —

1. Aux Boiler Feedpumps (2) ^{to complete by midnite} one vibrating
badly, one leaking oil - could cause
long term problems w/ (Condenser Vacuum)
attempting to repair one that has excessive vibration

2. Aux Bldg Filter replacement - continuing
on a one for one basis (slow) ^{31 Total as of 1600}
^{150 156}

3. Pressure Level - Ch 2 + 3 still operating
Tests run so far on the DP cell index
poor correlation. Licensee continuing
to work on a priority basis. ¹⁶⁰⁰ _{per hr} ^{in states}

4. Incinerator preparing Loss of Condenser Vacuum
Procedure - NER has provided comments

5. Make Up Tank now being continuously
vented to Waste Gas Tanks — (Had been
previously pressurized to store sample)

6. Unit 2 Vent Ebulition Monitor
continuously ~~venting~~ making discharge.
Drift samples being taken to verify —

7. Considerations ^{for initiating O₂ control in the}
~~for initiating O₂ control in the~~ air being
discussed along with secondary
chemistry control.

8. Decon of the D.G. Rooms continuing
(11) upper level was reported completed
working lower level —

1745. Passenger level transmitter LT-2 has
failed again. Status on this gear
calibration has not changed.

2100 Told V-2 P.R. to bring 4 DOF radios
& antenna wire that is in the C.R. to the
IE trailer at the end of the shift

2235 Passenger level LT-2 is working
again

150 158

4/18/18

00-08 . 1) Control room injectors are to call the IE shift supervisor with the plant status and operations in progress every four hours. This information is to be included in this log to allow the preparation of the daily PN. Additionally at the end of each shift the offgoing watch will bring a copy of the shift activity item list to the IE shift supervisor.

PASS ON TO YOUR WATCH!!

0530 50 filters have been changed in Aix Building

at about 0330 the B Reactor Gen was started for surveillance. To account with this an increase was noted in next monitor. The engine was received at ~0430 and the readings started to decrease.

The licensee made aerial survey over river and trailer city. Results are not yet known.

0630 Makeup tanks were also being filled during increase of activities noted above.

0900 Attended Arnold Briefing
(See latest Planning Mtg noted)

Status Aux Boiler Feed Pump 1A back
in service - Both Pumps now usable.

Personnel - Licensee still working,
now have a hi capacity test pump
for establishing a better return leg.

Filter change out progressing - Had
a snow pass out in the area
around 3:30 PM so had a small
perturbation - Number 63 ~~Accident~~ ⁹⁰ status
in

It is emphasized that when "A"
train change out is complete and
prior to start up, the (NRC) want
advance notification to set up
monitoring.

Rad Temp level determination is
on hold. Licensee would like to open ~~for~~
DTRV-2 & get a pressure reading.
NRR has not concurred in opening the
valve. This position is the valve should
not be opened —

219 Rad Monitor is O.D.S. —

1889

Attended Technical Group Meeting

Status of items is as follows:

1. Aux building charcoal filter

changeout should be complete
the morning of 4/19/79. 63 cartridges change
as of 2040. Next they plan to change out the
top filters in the fuel handling
building shield.

2. Pressure level determination backups

Use a RTD to mesg steam phase
temp. & calc. satn pressure.

Use the Heise gauge to measure
water phase pressure with the
pressure diff. indicative of
water level. They are
now taking data to calibrate.
Will calibrate for 130 to 300
inch range

3. Pressurized Sample - started

recirculating @ 2001 & will
take sample at ~ 2100

Sample will be flown to Idaho
BW/Idaho/Met Ed. plan to get together
by phone to work out differences
of opinion relative to sampling
& analytical techniques.

150-160

4. Cooldown rate - plan to open turbine admission valves to try to increase

1800 (cont'd)

cooldown rate

5. Hydrogen addition - BW wants this done due to concerns related to chloride stress corrosion. It is not of immediate concern, but should be done before the reactor coolant temp decreases to 150°, since O₂ removal is not as effective at temps < 150°.

6. Reactor building sump level measurement. Decided not to open DH-V6B at this time. Radiation measurement indicate that it may be leaking and if it is they may not need to open. They are letting pressure stabilize & see what kind of indication they get on the Heise gage. IE it is not for opening DH-V6B until absolutely necessary due to the potential for radiation release.

150 168

7. Decontamination - (W) should finish decontaminating the diesel building tonight. Several suggested that consideration be given to painting the decontaminated floors since they are sure to be contaminated again & paint would ease

subsequent decontamination:

B It was mentioned that where extensive welding is going on around charcoal filters that scavengers with their own charcoal filter be ~~permitted~~ to remove ~~the~~ smoke from the system.

9. Noise experts say that noise analysis indicates there is little, if any, debris in the bottom of the River or floating around.

10. Discussed best action to take if a RCP is lost: i.e. start another pump or immediately go on natural circulation. One person expressed concern that starting a pump could cause the inner barrel to shift (this apparently happened on SAVUD) resulting in shifting the damaged core. All but one were for starting another pump - AIRR is going to look into this further.

2245 Pressurized primary coolant sample is leaving TMI for Harrisburg airport.

2315 HPR-219 is still out of service.

Glohr says the licensee is developing a scheme to determine instantaneous iodine release ratio.

2330 LT-2 pressurizer level indicator has stopped again.

4/19/19

0030 The HPR-219 is still OOS. samples (water) are being taken every 4 hrs.

0300 Repairs are being made to admit steam to main turbine.

0500 Filter replacement should finish this AM, we need to get with NRC to see if they want to look at RCP test procedure.

Also a memo in CCR appears to modify the start-up sequence of EP-32; NRC should be made aware of this. Stat of RCP if no file.

150 161

0805 - Med-Ed gave NRC six hours notice for starting of the "A" And Bldg Train after Filter change out -

Shaubky to coordinate with Joe Logan
S-2 Control - ie what do we want
Met Ed to do -

Rec'd word that they are detecting
instability in LT-3 similar to
that found in CT-2 \approx 48 hours
before failure - CR has initiated
procedure EP 2j (P2c level control
using MVT Level) to begin checking
correlations -

Notified that the CT-2 problem
appears to be only a meter problem
that can be fixed - continuing to
run EP 2j however -

1130 The last filter cartridge is going
in - \approx 1 hour A Train will be
ready to run - Delayed to \approx 2:30pm

1:45pm - Rec'd call from State Police
asking if the 1 mile radius
air restriction was still in effect.
Per Stello "yes" They were informed.

150 F65

Status

Alternate P2R level - Hisse needs to be valued in - had problem with dosimeters will someone taking reading soon -

Filter Replacement - complete - however inspection found some tears in the downstream HEPA's ≈ 20 will have to be replaced - apparently torn during filter C.D.. Filters are available no time estimate yet on replacement

Turbine run - started steam flow to turbines (≈ 85 RPM) trying to establish a $2^{\circ}\text{F}/\text{sec}$ blowdown rate. 2:00 PM Tc is $\approx 19^{\circ}\text{F}$ looks good.

Hydrogen addition started (7.5 liters) into MVT at 106PM flow ~~is~~ hope to reduce O₂ level

D6 Room Decon -

Sump Level Determination - Hisse gage reading (1.5 psig) relates to a 54" sump level in the RB. This is questionable -

4:45 PM - Cl reported that the HEPA filter C.O. would not be completed and the A Train started until dayshift tomorrow. along with getting the filters installed is the consideration of having ~~the~~ the stack monitor 219 operable for A train start up --

1800 Status

- ① Cooldown rate is 2.27/hr. Cooldown to limit of 160°F.
- ② Pressure level. Heise sys have developed for 130 - 250 inches. They are working on completing the calibration. LT-3 is still healthy.
- ③ ^{8 cont} Sump level measurement. Radiation measurements indicate DH-168 is leaking. On April 6th downstream of the valve read 125 ppm and the same spot reads 5 now. Heise gage indicates 53 each sump level which no one believes. They plan to take more extensive radiation surveys to ~~see if~~ and try to determine if other valves are leaking.
- ④ HEPA filter replacement in progress & should be complete on 0000-0000 shift

(5) Hydrogen addition is complete.
A pressurized primary coolant sample is scheduled for 0700 Saturday to evaluate the effect of the hydrogen.

(6) HPR-219 still out of service

2320 ~~WPAF says they have stopped sending us~~

~~RECORDED~~

2320 V-2 CR says they can't get a good estimate for completion of the HEPA replacement at this time. The job is going slower than expected.

4/20 00-08

The results of the RC sample sent to Lynchburg on 4/18. are as follows:

TO. 41.8 cu/Kg	Xe ¹³³ 17.9 mc/cc
H ₂ 21.9 "	Xe ¹³¹ 10.12 mc/cc
N ₂ 18.1 "	I ¹³¹ .032 "
O ₂ 1.9 "	pH 8.3
No det. K _p or Xe	B 356.8 ppm 150 168

a radiation detector has been installed by
Heini Baugy at DHV-66, initial reading 192 m.
The readout is by the control panel.
This is to check the leakage past DHV-66.

0800 — A Train Filter change out —
and have 2 to change + repair of
Smoke detectors.

0900 - Attended 0900 staff mtg —
Gisela —

Cold down will be leveled off at
 $\approx 175^\circ$ ~~at~~ This is due to a need to
take into consideration NDT limits
($160^\circ F$) and possible instrument error.
Turbine to be ~~overhauled~~ used to
maintain temp —

Precipitated sample will be taken tonight
and sent to Forschung —

For alternative level indicators
still working — present option is
not correlating well — additional
discussions to be held regarding the
use of a constant pressure leg —

1330 - Glenn Walton / Sbanday reported a possible problem relative to the Foundations for the new 2500 kW Diesel Generators. The foundation as, presently installed, (crushed rock and ties) do not appear to be sufficient when the vibration from operation is considered - He talked with Ned Tripathi / Novak who concurred and agreed to discuss a fix with GPO.

Item of interest - after much discussion about the need for mods to A OT56 for solid operation. It was concluded that based on previous tests, A OT56 could be made solid with existing installation with no problems - Procedure is to be prepared -

Note: - Requested Const Insp (Walton) to obtain drawings/sketches of systems being built, (Will do in AM)

- 2:00 Attended 1000 Tech Review Meeting - Status is:
- ① Rad releases from site averaging 0.45-0.5 curios/day
 - ② Cool down - stabilized at 175°F - have throttled back on turbine
 - ③ Alt pressurizer level mess - plan to install a reference leg. Procedure is being approved - they still need more data for good calibration
 - ④ Now do not think there is leakage past DH-V6P. Temps there now "reading zero"
 - ⑤ "A" filter train not yet in service. Broken is with the heat sensors in the filters of protection system. A short is giving an indicator of a fire and prevents opening the dampers ^{now} isolating Train "A"
 - ⑥ Primary sample now rescheduled for 0700 on 4/22/79

150.171

- 2155 Unit 2 CR just said that the train B deluge sys tripped & isolating train B and, since it was on for ~2 min, flooding train "B". The water would drain down into the aux building pump & probably result in a ground release.
Also since "A" and "B" trains are now bypassed the building exhaust

is now unaffected. They plan to start up train "A" in 15 min.

Ground survey teams were dispatched to pull samples. ARM's helicopter will be up in 45 min.

1 - 2233 "A" train is ~~not yet~~ in service.

Building vent moisture on top of the aux. bldg. definitely showed an increase in iodine out Vite vent, but we don't have a definite reading yet.

2301 Phase C security alert on island. A guard found the exterior door to V-1 doors unlocked. No one was in diesel room. Additionally a gate (30) on N-W corner of security fence was found to be unlocked when guard twisted lock and it fell open in his hand. A search of V-1 and V-2 was conducted. No intruders were noted. Phase C ended at 2335.

Informed R. Carlson of event & explore. He is IE:I duty officer.

2345 Placed train A aux bldg Vent Filter in service.

AMS flight 2330-0030 deleted no 150 172
14/21 airborne activity.

0300 ±15 started fan in Fuel Gas by Butyl Seal system in preparation to start slaving channel

filter in Train B. saw a slight increase
on P2NO monitor to 8.5×10^{-6} ccf ml. People
usually don't confirm this reading.
Trains will be ready today - NER part
at 6. They will share with us and we
will then do the move.

0330 lost Hemocytometer. still have high
6 readings.

R.I. office is down to one person 24 hr
coverage. If you cannot reach the duty
officer on the open line, try 1-215-337-
5000 or 4488-1000 (ET).

(4/21)

0700 - we2 Train being moved to the
Island. Had line 5 way communication
lost -

9:00 AM Mtg Status

- I levels - down by factor of 2 offsite MDA
- MDT cubicle Air Sample Taken ~~not~~ analysis
not completed
- Hot well activity 1.2×10^{-7} T₁₃₁ - (expected)
- air Ejector condenser 1.1×10^{-10} upstream of filter

Will be working at FH 8 Filter change out
since ~~the~~ levels on filters were found in

B
e
t

Alternate Pres Level - seems to be
a hot case - don't seem to be able
to keep the steam supply leg full -
(DHE outlet valves)

Can DNV 1, 2, 3 be given? Proposed
a megger check and phase check to
be done today.

2:30 PM - Terminated communication from Trache
City New NRR Tab #1 Nos 782-3950
3951, 3952 -

It was reported that the Waste Gas
Decay Tank A pressure is 15 psig as
read on the local gauge. B Tank is 21 psig

Megger & Phase checks of DNV 1, 2, 3 & 171
have been completed - readings look ok -

150 174

2030 Attended 1800 status meeting. This meeting
will be held in Trache 23 until Monday.

- ① Met-Ed said I put the plant
vents seems to be trending downward
- ② Aux. filter "B" train changeout
should begin this shift.
- ③ Alternate pressurizer level ones still
working on - they will be raising and lowering
pressurizer level tonight with a. changes
in nuclear tank level will occur

which could result in a radiation release.

2245 Momentarily start changing "A" train filters for fuel handling building.

2300 Status

- ① plant computer not working therefore, no routine TC readouts, etc.
- ② "A" fuel handling building filter status same as @ 2245
- ③ "B" train aux bldg filters probably start changeout on days 2 or 4/22.
- ④ Alt pressurizer level determination status unchanged.
- ⑤ Cooldown rate - holding @ 175°F
- ⑥ Iodine release trending downward.

4/22 A NPF review team move to Stilo indicates they believe we have established a QA function at TMI-2 with a resident QA staff knowledgeable in Mech, Elect, Civil Engineering, and NDE to provide daily surveillance of the activities.

0600 Whole body count on work who lost air supply
while working on filter change was 3.9 200f MPBB.
0200 C/B on H₂ recombination trip at. still out at
0715 -

0900 Mtg States

Fluxes .2-.3 c/day trending down

Pressurized sample to be taken AM -

Alternate PZR level - still working

- Fuel Handling Building Filter
change out 40 of 60 changed -

1130 - Pressurized sample taken and
being shipped by license to B&W
Lynchburg -

Alternate PZR Level - new piping
mg & cell built with tee to facilitate
Dead Weight Tester when it arrives.
now being installed.

Recd copy of Bulletin 79-05B
ref. B&W Plants - reset PZR
set point & reset Hi Press set point
TMI-2 recd for info only -

2140 Control Room Unit 2 status of the plant

- ① Recombiner was restarted. They could not find anything wrong with it.
- ② "A" train fuel handling building filters changeout is complete.
- ③ Aux. bldg. "B" train filter changeout should begin soon.
- ④ HPR-219 & the two radiation monitors were going to pull their sample off of the ~~sep~~ same sample line using a standard "T" rather than a sample splitter. Our inspectors questioned this and since they do not have a sample splitter available they will use one instrument ~~match~~ with the other as a backup. This is still being evaluated.

The following info. was obtained in the 1800 status meeting

- ① Preliminary ~~and~~ results of the pressurized reactor coolant analysis by BTW today:

23.8 cc/kg H₂ Boron 2937 ± 20 ppm

< 9.9 cc/kg N Xe 133 7 μ c/cc

< 1.1 cc/kg O₂ Xe 131 m 6.8 μ c/cc

ice 200 m³/hr on contact, 30 m³/hr @ 3 ft.
shielded sample vessel 2.1 m³/hr on contact, 130 m³

@ 1 ft., 30 m³ @ 3 ft. 150 177

② A procedure to be used to put the plant on natural circulation in case the RCP is lost should be approved for use soon. Procedure issued (EP-32) @ 2215 a copy is in this book.

③ Decision was made not to deliberately go on natural circulation until the decay heat system is upgraded (leaks in sys. stopped or minimized) and a mechanism for going solid on OTSG "B" to use it as an alternate heat sink has developed. This means it will take 8 days or longer before they are ready to deliberately put Unit 2 on natural circulation. This will be discussed further at the 0900 meeting on 4/23/79.

④ Alternate pressure level determination - see attached handout for description of methods being evaluated. The dead weight tester for Method #1 should arrive at the site on 4/23

⑤ Moseley and Davis will probably visit the site on Wed or Thurs (4/25 or 4/26).

4/23.

① 0300 completed warden FHB Train H. Need some smoke detector and QC checks yet.

② We need definitely as to what role we are to play with respect to procedures, ie license & operating by memo etc and abating procedures PDE has approved without our concurrence. Additionally we need to emphasize the accuracy of logs and charts to license. They all not inaccurate or marked. The reconstruction of current events will be next impossible.

③ Work in progress to place the pumps for SG-B long term cooldown and the HX is being cleaned.

④ The dead weight timer is here. Another correlation with Heise Gauge is in progress.

30445 A new filter for weekly surveillance for level being increased to 300" for this test.

⑤ Have moved 35 new filters for Train B ABV system into Aux Building. No replacement filter yet.

(2)

0600 A. Waste evapourate condensate storage tank is being discharged to the river. The tank contains effluent from Cap-Ban processing. Purified by filter before release.

Status as of 0900 Meeting

Filter Changeout - A FNIS complete however, problem exists with Deluge System. Heat Sensor is grounded out. System Isolated and ~~not~~ being worked on.

Condenser A.E. Monitor - Mad out sporadic 1000-3000 counts - air sample $< 2.5 \times 10^{-10}$ T_{1,31} 2.6×10^{-9} ~~✓~~ no immediate concern - This is also monitored by ¹⁰³ ²¹⁹ in the stack.

EP-32 Does of RCP and initiation of Natural Circulation. B+W committed to brief each of 6 crews on procedure. Stello requested that our CR Inspector sit in on this session for each shift and provide feedback ~~if we have any problems.~~

Ref: 4/23 Backshift (6000-0800) entry

D - regarding any procedures that NRC approves. Stello's instructions to us are to monitor the procedures and any changes made - If changes are made without visible NRC approval we are to immediately bring them to NRC's attention

Regarding the quality of the log or marking of recorder charts - We should bring it to the attention of Miller (or Supl) if this is unsuccessful we are to inform Stello who will talk to Arnold — The same goes for other concerns of this type —

1930 In the 1000 meeting it was stated that IFE inspectors were holding up the decom work because hoods were not properly qualified.

Both Herb Cook and Duane Boyd were contested and they both stated that IFE did not put a hold on the work. They said that the licensee asked IFE if the hoods were qualified & IFE told them "no" but IFE did not stop or put a hold on the work

2025 Status as of the 1800 tech. group meeting:

- ① Sample results for the 4/22/79 pressurized sample were given out. See Miss Info notebook.
- ② The schedule to be followed in the process of deliberately attorney natural circulation was passed out.
Target date is 5/2/79. See Miss Info notebook.
- ③ @ 2020 Unit 2 control room said that it would be at least one hour and may not be until 2300 or 2400 ~~ET~~ before "A" train fuel handling building are returned to service.
- ④ The next R coolant sample (#5) is scheduled for 0500 on 4/25/79.
- ⑤ Alt. pressure level determinator - no change.
- ⑥ The 0900 Task Mgmt / Schedule Meeting will be in Arnold's trailer - on the island.

150 182

2130 Unit 2 control room - licensee found another heat detector damaged and the fuel handling "A" train filter may not be placed incisive this shift.

2210 Unit 2 control room notified us that the 8B neutralizing tank overflowed while they were sampling 2 into it from the makeup tank. A level indicator was not functioning resulting in the overflow. The water flows into the aux. bldg. surge. The aux. bldg. vent monitors increased from 200 mR to 200,000 mR/hr. Some ~~other~~ monitor remains unchanged. The licensee is spraying down the area.

Ground survey team was sent out and ARMS sent up. NRR trailer notified (Volmer)

2245 Aux. bldg. vent monitors are now trending down.

4/24

0600 Continuous readout on HP-719 is out of service.

- (1) 28 of 90 Train B Auxiliary Building filters have been changed.
- (2) Train A Fuel Handling Building is still not in service.
- (3) No increase in release may result if Neutral tank overflow as indicated by 219 cycles at 0.400

0630 (1) Train Aa FHB placed in service
~ 2000 GFM

(2) ~ About 40 filter bags in Train
B of Oak Ridge

0745: W. Ruhmann was entrained on loads of
dolting while going through uncontrollable
area of D-1 - FH Building & D-2 FH Building.
The licensee is investigating the source
of the contamination.

1100 - Morning meeting items

- (1) Wed 4/25 - POC review of Nat. Recieve. procedure -
NRR & 18 attendance requested & committed.
(Haverhill lead for 18) [Goal is to be ready for Nat. Recieve.
by 5/2.]
- (2) 2 of 3 Fire Protection pumps oos - vendor called in
(today) - one of the 2 oos expected back on today.
- (3) Watch turbines for offsc solid evolution.
- (4) Alt. PSER level - believed by licensee to
be good for 150"-300" level by maintaining
@ 200"-250" indicated level.

Revolving hot
~1130 ~ Main pump ^{had} tripped due cooling water pump trip - stay
cooling water pump on, MU pump on, cause being
investigated

1:15 Mr. Higgins: NI-2 source range mob - Scaled low
I & C checking. 150:184

1508

Secondary xient - water hammer in steam lines - so turbine was tripped - being brought back on - $\sim 10^\circ/\text{hr}$ heatup ^(from 10 min) - $T_{C\text{at}} = 177^\circ$ now
[even cutting in feedwater from every Sudwater nozzle] no damage ident yet. Sudwater has a main nozzle.

1520

xient cause - change in gas flow caused compression & water in steam lines - will take $\sim 1\text{hr}$ to drain - heatup is $\sim 12^\circ/\text{hr}$ in primary.

1620

Predicted 4 hrs $\sim 230^\circ$ primary temp to get turbine on line - heatup $\sim 10^\circ/\text{hr}$ now.

2000 - Attended 1800 tech group meeting. Status:

- ① Startup rate $\sim 6.3^\circ/\text{hr}$
- ② 73 trays replaced in the "B" train of the aux. bleed filters. Should be finished tomorrow, 4/25/79
- ③ Alt pressure level max - not taking data since the turbine trip.
- ④ RCS sample # 5, scheduled for 0500 on 4/25/79

1501185

Shift 4/25

- 10 Please note the attached copies from the HP log. A shipment of solid waste is planned on 4/25. Make sure OSP (Wayne Kyr or Joel Lubman, 492-7767) ~~is~~ notified and that the various states involved are notified.
- 10 "B" train aux fly filters changeout is complete. No estimate as to when "B" will be put in service.
- 30 Place Train B of Air Facility Filter in service.
- 15 (1) Concern raised by J. White of supplying D-2 RCS with people in FH Building.
(2) Also concern of horizontal dredge of new filter train and supply capability.

4/24/79

0300 report that HPL-219 is
not working properly - switch
0100

0530 - HPL-219 appears to
be back in line. Will
try for 0600 readings

0555 - Call from Party
had to ship metal
planks - probably 4/24 for #1

(1) - 7 drums of compacted
radioactive - 0.168 mCi
55 cuft - (#79-38)

(2) - old air filters - to shipped
in Super-Tiger Container

(3) - 9 - 50 cuft liners in
shielded box. containing
solid waste -

0630 - ops reports established
flow through a "K" Train
of fuel handling building
filters.

The State of Pa representative
was informed with the plan
liquid release and all analytical
data was given to him

16/80 E.E. TROONously

18/80 John Sculian noted that
Met-O-Dex is planning on
making a solid waste
shipment on 4/25/79.
See previous entry
on shipment description.
Shipment is tentatively planned
to be made to Barnwell,
South Carolina.

NOTE: WE MUST NOTIFY
OSP WHEN THE SHIPMENT
IS FIRMED UP.

10/80 Bob Sjodin reported
that 3 routine flights
were made during
4/24/79. No liquid
drum shipping were
noted.

Fire Pump Situation: 1:45 pm, 4/25/79

Unit 1 Circ. Water Flume pump (diesel) is available.

Unit 1&2 River Intake diesel fire pumps are OOS.

Unit 1 River Water Motor driven fire pumps also OOS.

Licensing is reportedly working around the clock to get 1 in service and is considering the alternatives of getting another pump on site or using a fire station pump as standby pump on site.

Tech Specs required:

2 pump info - 7 days to resolve, or report in 30 days
more than 2 info - establish back up fire water supply in 24 hrs, + special report to Comm

Does NRR waive any T.S. requirements in this case? Disc.
with V. Stello - he wanted more info on pools / ETR.

2:29 - Unit 1 RWE diesel inoperable for ~ 1 day or more. Tech Rep at. - maybe long term prob?

Unit 2 RWE diesel - came on in auto this AM due low fire header - overheated, plus bypassing water - Tech Rep recommended shutdown, let cool down - will restart then & expect to declare. will know in ~ 1 hr if OK.

Motor driven pump - skipping on pools.

govern below cooler tower - suit for cooling towers & fire pump -
has some acty. yard drains drain into dam, then to river.
that has some contamination. - a + 9pm leakage to river -
dig hole just pre- measurable acty. < mpc was going
to seven - corrective measure was fire hose to river side
- of dam to dilute ditch. - that dropped fire press,
~~concerning unit 2 pump to come on - ditch~~
stopped - have adequate fire hose pressure now (~90#)
~~attempts~~ full - they have passed the word (mc)
that fire syste. not to be used for non-fire
purposes w/o notifying control room.

other calls for info:


- no plans to restart turbine. No new energy fed to A' S.G.
- EPA supposed to arrive today with a two truck analysis group
- Fed agency daily summary to be recd & distributed
by IE - but Dackn EPA wouldn't sign agreement.

150-190

3: Unit 1 Motor driv. pumps - being reinstalled to system -
motor in shop - checking out windings/bearings - expect
to reinstall by 260700 with exception of coupling -
realign/bent by noon tomorrow - (motor wasn't a
problem - pump was)

Unit 2 Riv.Wet. Diesel - working days only - head
removed - cylinders out - Cummings set 6 rings parts

Unit 2 Rio Wat Creek - temporary now - no prob
- in commission.

1615 - Relayed 16: concerns - (Choudary) - shared by Libanski, &
about "Oxygen Lancing" method of cutting precast
in Axx bldg. method is Mg-O₂ flame ($\geq 2500^{\circ}$
& concrete melts. Q $\approx 1400^{\circ}\text{C}$ ($\approx 2500^{\circ}\text{F}$) -
flame turns cement into gypsum + water - concrete
is dehydrated & water boils at top of concrete surf
Q $\approx 7\text{ ft}^2$ - 8 in lanced hole in test block - 
In Axx bldg. - rebar (code limit on temp
is 1100°F) - extent of propagation of heating
than code allowable temp of rebar is unknown &
ASCE - no analysis of structural impact available
yet... Choudary & Libanski consider ox. lancing
unacceptable - John Collins, NRR, asked
to set up meeting w/ the  - Choudary also
said coring would be about as fast as O₂ lance

26/11/00 Discussed O₂ Lancing with  - Frank Setago
Don Anderson: B&R - Osha Micheda, Howard Carter: GPC -
Alex Matketha. Basic concerns are Sun heat
- propagation & its extent - effect on rebar & rebars to
concrete interface & how far propagation will extend
- problem: Cor-boring alternative scheduled by  as 21-25
150-179.1 m - days - (unavailable to Shell) -  continues
with qualification of method / factors & obtain
basic - from research paper on method - NRR&IE const
they know people at B&R (Micheda) have substance here
- Shell's decision was to do what can be done but

The problem - but need the holes cut & don't wait 25 days.

(R)

Call Chaudhary, RI for "Ozancing". - 269-7793 home
No. if not still on site

2300 RCP 2A still on and A OTSG is steaming to main condenser via MSIV bypass line and turbine bypass valve. B OTSG is being drained (since ~9 am) through the normal sample line (~1&1/2") to the sample sink. This is giving ~0.25 gpm. A second drain path is being pursued using a 1/2" CO line off of the normal sample line and directing that to the sample sink. This is expected to drain ~10 gpm.

Prer P = 847 psig ; Prer T = 537°F ; Prer L1 247;
Loop A = 224°F ; Loop B = 222°F ; Cont. Press = -0.7 psig

Thermocouples: 5H = 295°F

5H = 311°F

5G = 282°F

6G = 251°F

9M = 275°F

3G = 252°F

150 192

See attached draft report from CR
inspectors for more detail.

Segment of completed note (75.55
get down) so will log later.
Finger prints made by Mr. W.

Unit = Piedmont Farmer and Cooper
new tree horizon is broken
U. - 100' from W. - 10' over
some broken sand if bed
well cut before river is 30'
in a sand cap.

Choate and Steeber attended natural
disaster training class. Handbooks are
on file for review.

Temporary feed ^{imp} bin in place on
L 312. Temporay grass from 15'
gradient horizon to downstream is
FLW-26A & FLW-11-A (2 m.).

Schedule 37 bins to be used in
natural circulation next Tuesday or Wednesday

New Building Foundation may soon be
being top tested today. Getting ready
to cut into steel tonight or tomorrow

4/21. 0115. Zepel indicator on A OTSG was lost or lost watch. Using an external cl/p for level control LT-3 on ppr in becoming noisy (spike).

0300 LT-3 put down. Spiking has stopped.
0430 Questioned user of service air as no signal off procedure could be found. Pulled men on service air out of A/C Bld until procedure was accomplished.

27/0115 - LT-3 failed between 9:00 & 9:15 a.m. Plans to go to natural Recite were for 1100. Using UP 21. Last PSZR level was 214"

6/20
1130 - Rec'd call from Patty McCormick, Gov. Press Ofc. - questions for reporters - told her what plans were for natural Recite today - should received press inquiries - told her I'd call back about whether press conf was planned - found out on DRR that none was planned, & that expected transient on Nat Recite was expected to last up to 6 min - but no cooling in core. - called back but P. McCormick out - left no. for her to call back. 150 194

7/151 Told P. McCormick that LT-3 failure had resulted in Nat Recite plans for today - that the transient was expected to last up to 6 min - that should remain subcritical - precautions made to monitor & check for minimization probability of off-site consequences

- 1:37 Bypass valves, "B" SG, being opened now.
- 1:38 ARMS is seeing something - no quantification - unable to correlate to what is going on.
- 1:47 Bypass open ~ 20%: no increase @ Condenser air ejector exhaust (748)
- 2:08 Estimated stat - $\dot{X}_e = .15 \text{ m}^3/\text{hr}$ ($7 \times$ background), $50 \times$ @ 400 ft ARMS ($5 \times$ background)
- 2:09 RCP 2nd tripbed.
- 2:42 10^{-8} I in U-2 control - going into stacks - Higgins carrying out with unnecessary people.
- 2:53 Masks off - going on MPC hrs - 30 hr

2350 - On about a minute. Estimated feed to OTSG from pump - feed into Core important cause in drop. Poles are in steady state at 70° in the late OTSG 2 cold, the OTG is cold and then after RCS add RCS valve control (pressure level) now being done by main valves.

4/28 0110 second attempt the B ^{OTSG} ~~OTG~~ by shorting the steam bypass valves. This is to see if I^{131} increase was due to SG.

0200 determined the I^{131} spike to be an internal reading. B OTSG still isolated.

150 195

10 - Date for 9 a.m. mtg

Natural circulation cooling continues on the "A" steam generator. Core coolant inlet and outlet temperatures are 169°F and 183°F , respectively. The highest incore thermocouple reads 319°F . Good correlation exists between the Heise Gage and Mass Balance Calculation methods of determining pressurizer level.

(Note - the mass balance calculation error is cumulative, & therefore must produce a less accurate result with as time passes - this was not brought out at the meeting) \Rightarrow LT-3 intermittent valid indicate nuclei to zero

110 - 9am status mtg items

- ① Water buildup in U-2 - too hot to xfr to Unit 1, need CatGum II to be finished.
- ② PSER level - controversy over most valid method between Human Ops & Engg. (are also looking hard @ this) - Arnold directed that even going solid was the less uncertain condition & errors should be started in that direction.
- ③ Call question on aux Bldg filter had seepage - George Smith & J. Cunningham following up.
- ④ Arnold placed hold on feedwater mod cut into "A" S.G. Bypars. 150 196
- ⑤ Primary Nat - B&W evals do not significant with $\text{pH} > 7.5$
- ⑥ concern of over potential for loss of Nat Recirc expressed due to reduced flow as heat source diminishes. Heat balance to be run.
- ⑦ A circuit was added - B today (there is a 32.5 KV line from to site - xfrred down & parallel to Circulate)

4/30/79
0000

On natural circulation. B OTSG isol.
LT3 operating since ~ 8 am. Only
level indicator on A OTSG is a
temporary one.

See 1800 meeting notes. GPU is
reviewing whether or not to
proceed to solid circulation of OTSG.
This is because they might not
be needed by the time the system
are completed.

Cut ge- auxiliary building roof
ventilation system is expected to
be made ~ILOC. Still a problem
to calibration of monitors. HPs
will review data to be provided
by GPU in the morning.

2:

0630 Water was transferred in U-1 as follows:
(1) Top-Gre / Hal TK #1 to WOLT-11A #8
(2) WOLT-9 to Hal TK #2.

5/1/79

0000 On natural circulation. B OTSG being de-
and is pressurized with nitrogen. H₂
recombiner secured.

150 197

Feed and steam line modifications +
solid secondary cooling are continuing.

Cut is expected to be made any time
for auxiliary building roof ventilation system.

Calibration of monitors is still incomplete but
was supposed to be completed about midnight.

400 Started cut into ventilation stack. 55 has
no orders to place in service.

170 B. MFW is ready to refill.
Coolant sample to be drawn today.

445 - Data for 9 am mtg

150 198

① vent stack cut complete - Harben stated he believes NRC is
set w/ call of bad seasons - need to get to him if
that isn't so.

② ④ effort on core baring - DHR order - need regular
input from Curr on status / delays / shed - b/w 9 AM &
5 PM mtgs (5 vs 6 now)

③ "A" SC Aux heat removal - on hold: mat'l's, fab, design

④ GPU presented short term recommendations for nat. circ: pri. heat
floating, set by decay heat & secondary conditions; pri. max
500# (procedure to be written today), prior level $\geq 250^{\circ}$
a 90' solid (\approx one floor press wait), SG "A" steaming,
400-430", on bypass, SC B isol (seal drain - Arnold
questioning that), no pump 6 hrs sacked out, interim.

Closed cooling secured, MWT temp $\leq 150^{\circ}$ but as close
as poss., MW water de-assert. Btw concerned about
sealing seal valve. Slow because cold yet "ceramic"

dump is started.

011430 Question concerning Aux Filter Cart : conversion of readings to done ; how to operate (esp freq of readings) ; alarm setpoint bars - all relayed to Herber Bus AM - Also relayed these & concern about carties & swashb fittings to Ron Tool , & Glenn Wallin is following that issue too. Higgins called in control room to see if ok to put system in bus - I said no - G. Smith concurred - J. Cunningham said these 1/second shift sup also was against this. Cunningham met w/ Sid Porter (n late) and he received acceptable answers verbally - OP procedure to go thru PORC yet. I.E. point is that we've been asking the same questions for 25 days & have been told the answers would be to us shortly. - Those questions are simple - what does a reading mean ? what readings will be taken and when ? what does an alarm mean to operation ? what a series or carties portends to swashb fittings ?

TWA

944-7631

Beech

HIRPSTER

150 2301

Note:

Plant using total flow rate of 31950 m^3/hr

Eberline Instrument Readings HPR-210 Part 2 Fort Radiation Monitor

HPR-210

Readings in $\mu\text{C}/\text{cc}$

Date	Time	Particulate	I+31	Gas
4/16	2000	1.32×10^{-5}	1.55×10^{-6}	1.08×10^{-5}
	2100	1.19×10^{-5}	8.62×10^{-7}	1.54×10^{-5}
	2200	1.21×10^{-5}	7.97×10^{-7}	6.3×10^{-6}
	2300	4.36×10^{-5}	7.96×10^{-7}	1.02×10^{-6}
	2400	1.56×10^{-5}	7.97×10^{-7}	1.02×10^{-6}
4/17	0100 ^{Filter changed}	4.89×10^{-6}	2.60×10^{-7}	.005
	0200	5.36×10^{-6}	3.70×10^{-7}	0
	0300	8.03×10^{-6}	4.31×10^{-7}	0
	0400 ^{Filter changed}	4.7×10^{-6}	1.30×10^{-7}	0
	0500	5.2×10^{-6}	2.58×10^{-7}	0
	0600	5.5×10^{-6}	2.9×10^{-7}	0
	0700	6.09×10^{-6}	4.98×10^{-7}	↓
	1000	5.74×10^{-6}	4.1×10^{-7}	↓
	1315	5.63×10^{-6}	2.5×10^{-7}	0
	1415	5.99×10^{-6}	3.9×10^{-7}	1.0×10^{-6}
	1515	6.43×10^{-6}	5.3×10^{-7}	
	1730	6.76×10^{-6}	3.46×10^{-7}	
	1800	7.4×10^{-6}	5.25×10^{-7}	
	1900	8.07×10^{-6}	7.82×10^{-7}	
	2000	6.50×10^{-6}	1.91×10^{-7}	
	2100	7.84×10^{-6}	4.94×10^{-7}	
	2200	8.5×10^{-6}	7.10×10^{-7}	
	2300	9.78×10^{-6}	1.03×10^{-6}	150 202
	2400 ^{Filter changed}	2.09×10^{-6}	2.19×10^{-7}	
	0100	7.96×10^{-7}	4.82×10^{-7}	
	0200	8.72×10^{-6}	6.03×10^{-7}	
	0300	9.5×10^{-6}	7.5×10^{-7}	

<u>DATE</u>	<u>TIME</u>	<u>PARTICULATE</u>	<u>I₁₃₁</u>	<u>GIFSECS</u>
4/13	0400	1.2×10^{-5}	1.4×10^{-6}	2.6×10^{-5}
	0430	$\frac{1.4}{8.3} \times 10^{-5}$	2.1×10^{-6}	8.3×10^{-5}
	0500	- 1.21×10^{-5}	1.65×10^{-6}	4.35×10^{-5}
	0600	- 9.10×10^{-6}	6.26×10^{-7}	1.61×10^{-5}
	0700	- 8.98×10^{-6}	6.04×10^{-7}	8.98×10^{-6}
	0815	- 9.01×10^{-6}	3.06×10^{-7}	2.98×10^{-6}
	0930	- 8.93×10^{-6}	5.14×10^{-7}	ND A 0 - 6
	1100	- 8.42×10^{-6}	4.4×10^{-7}	ND A 5 - 6
	1215	- 8.24×10^{-6}	3.06×10^{-7}	ND A 0 $\times 10^{-6}$
	1430	- 8.48×10^{-6}	5.01×10^{-6}	2.88×10^{-7}

150 203