

EMERGENCY OPERATING PROCEDURES

4377

No.	TITLE	DRAFT REVIEW		STATUS of Comments or Rewrite	APPROVAL			NRR SIGNER
		IE	NRR		PDRC	SUPT	W NRR	
1	Loss 1A RCP - ST 2A	✓	✓		✓	✓	✓	NOVAK
2	LOSS RCP 1A+2A STL Men 2B	✓	✓	NRC Comment SENT 4/2	✓	✓		
3	LOSS ALL RC Pumps NAT-CIRC.	✓	✓	NRC Comment SENT 4/2	✓	✓		
4	NO RCP'S / NOT NAT-CIRC GO TO HPI	✓	✓		✓	✓		
5	LOSS OF LETDOWN (RCP RUNNING) ALLOW GO SOLID	✓	✓	Rewrite NRC Comment 4/3			✓	Novak 4/4 No co. Review fill out by -N
6	RCP Seal Failure	✓	✓		✓	✓		
7	Loss Offsite Power	✓	✓	Rewrite RCD 4/3				
8	LOSS MUT Level	✓	✓	COMMENTS SENT 4/3				
9	LOSS MU Pumps + HPI	✓	✓	COMMENTS SENT 4/3 Rewrite reqd. 1930 4/3				163 296
10	DELETED							
11	Loss of ^{OH} Pwr Level chart Deleted Procedure	✓	✓		✓	✓	✓	Novak 4/7
12	LOSS RCS Press Trd	✓	✓	7905230	108	P		

EMERGENCY OPERATING PROCEDURES

No.	TITLE	DRAFT REVIEW		STATUS OF Comments or Rewrite	APPROVAL				NRR SIGNER
		IE	NRR		PDRC	SUPT	W	NRR	
13	Loss of RC Temp Instrument								
14	Loss of RC Flow Instrument								
15	Loss of DTSG Level Instrument								
16	Loss of Source Range Instrument								
17	RCV-137 STUCK OPEN (PER VENT 1")	✓	✓	COMMENTS SENT 4/3					
18	RCV-2 STUCK OPEN (Elec. Motor Relief VLV Block)	✓	✓	COMMENTS SENT 4/3					
19	RCV-2 STUCK OPEN EM Relief VLV BLOCK VLV	✓	✓	COMMENTS SENT 4/3					
20	RCV-137 STUCK SHUT	✓	✓	COMMENTS SENT 4/3					
21	Total Loss of P _{3r} Level Indication	✓	✓	Comment sent 4/3					
22	Loss of P _{2r} Level Indication ^{2 see EP. 11}								
23	Loss of P _{2r} Temp Indication	✓	✓					4/3	Hazetis
24	Loss of DTSG Press. Indication								163 297
24	Response to H ₂ Recombiner Alarm Indications		✓		4/3	4/3	4/3	4/3	W.A. Burch

