



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

TJL

May 29, 1979


Docket No. 50-485

Rochester Gas & Electric Corporation
ATTN: Mr. J. E. Arthur
Chief Engineer
89 East Avenue
Rochester, NY 14649

Gentlemen:

This Information Notice is provided as an early notification of a possibly significant matter. It is expected that recipients will review the information for possible applicability to their facilities. No specific action or response is requested at this time. If further NRC evaluations so indicate, an IE Circular or Bulletin will be issued to recommend or request specific licensee actions. If you have questions regarding this matter, please contact the Director of the appropriate NRC Regional Office.

Sincerely,


for Boyce H. Grier
Director

Enclosures:

1. IE Information Notice No. 79-13
w/enclosures
2. List of Information Notices Issued
in 1979

cc w/encls:

C. R. Anderson, Manager, QA
Lex K. Larson, Esquire
N. A. Petrick, Executive Director, SNUPPS
Gerald Charnoff, Esquire

273 016

7907030072,

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

IE Information Notice No. 79-13
Date: May 29, 1979
Page 1 of 4

INDICATION OF LOW WATER LEVEL IN THE OYSTER CREEK REACTOR

Summary

A loss of feedwater transient at the Oyster Creek facility on May 2, 1979, resulted in a significant reduction in water inventory within the reactor core shroud area as measured by one set of water level instruments (triple low level), while the remaining level instruments, sensing from the reactor annulus area indicated water levels above any protective feature setpoint (Figure 1). The water level within the core shroud area was reduced below the "triple low level" setpoint of 4-feet, 8-inches above the top of the fuel.

Subsequent analysis by the licensee has determined that the minimum collapsed water level (solid, without steam voids) over the top of the fuel was 1 to 1-1/2 feet.

Coolant sample analyses and offgas release rates indicate that no fuel damage occurred.

General

Oyster Creek is a non-jet pump BWR with licensed power of 1930 MWt. The plant was first made critical May 3, 1969.

Status Before Transient

Operating at near full power with the main parameters at levels as follows:

1895 MWt power level
79" Yarway (13'4" over top of fuel) reactor water level
1020 psig reactor pressure
 7.1×10^6 #/hr feed flow
 14.8×10^4 gpm recirculation flow rate (4 pumps)
12 psid core Δp

Equipment Out of Service (OOS)

"D" recirc pump OOS due to seal cooler
"B" startup transformer OOS for inspection

DUPLICATE DOCUMENT

273 017
Entire document previously entered
into system under:

ANO 7906060164

No. of pages: _____