



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION I
631 PARK AVENUE
KING OF PRUSSIA, PENNSYLVANIA 19406

TERA

TERA

June 11, 1979

Docket Nos. 50-352
50-353

Philadelphia Electric Company
ATTN: Mr. V. S. Boyer
Vice President
Engineering and Research
2301 Market Street
Philadelphia, PA 19101

Gentlemen:

This Information Notice is being issued to call to your attention an aspect of the Commission's regulations which IE inspectors have found is not always being fully implemented. No written response is required. If you have questions regarding this matter, please contact this office.

Sincerely,


for Boyce H. Grier
Director

Enclosures:

1. IE Information Notice
No. 79-14
2. List of Information Notices Issued
in 1979

267 043

7 907020050 Q

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

IE Information Notice No. 79-14
Date: June 11, 1979
Page 1 of 1

SAFETY CLASSIFICATION OF ELECTRICAL CABLE SUPPORT SYSTEMS

Summary:

The NRC inspection staff has found that in several cases, facilities under construction have not applied the pertinent quality assurance requirements of 10 CFR 50, Appendix B to the design, procurement, and installation of cable trays and their support systems for Class IE electrical cables. This notice is being issued to all applicants for, and holders of construction permits, to remind them of the Commission's regulations on this subject.

Description of Circumstances:

1. In the Commission's Regulations for Licensing of Production and Utilization Facilities - 10 CFR Part 50, Criterion 2 of Appendix A, states in part that "Structures, systems and components important to safety shall be designed to withstand the effects of....earthquakes....without loss of capability to perform their safety functions...."
2. The Commission's Regulations on Reactor Site Criteria, Part 100, Appendix A, define a "safe shutdown earthquake," (SSE) and generally identify the structures, systems and components which are required to remain functional during such an earthquake.
3. Regulatory Guide 1.29 "Seismic Design Classification" states in pertinent part:

"C.1. The following structures, systems and components of a nuclear power plant, including their foundations and supports (emphasis added) are designated as Seismic Category 1 and should be designed to withstand the effects of the SSE and remain functional. The pertinent quality assurance requirements of Appendix B to 10 CFR 50 should be applied to all activities affecting the safety related functions of these structures, systems and components."

"C1.q. The Class IE electric systems, including the auxiliary systems for the onsite electric power supplies, that provide the emergency electric power..."

No written response to this information questions regarding the matter, please contact the NRC Regional Office.

DUPLICATE DOCUMENT

267 044
Entire document previously entered into system under:

ANO 7906290214

No. of pages: 3