



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

TIC

JUN 11 1979


In Reply Refer To:
RII:FJL
50-416
50-417

Mississippi Power and Light Company
ATTN: N. L. Stampley
Vice President of Production
P. O. Box 1640
Jackson, MS 39205

Gentlemen:

This Information Notice is being issued to call to your attention an aspect of the Commission's regulations which IE inspectors have found is not always being fully implemented. No written response is required. If you have questions regarding this matter, please contact me.

Sincerely,


James P. O'Reilly
Director

Enclosure:
IE Information Notice
No. 79-14

POOR ORIGINAL

269 116

7907020

214

Q

Mississippi Power and
Light Company

-2-

cc w/encl:
C. K. McCoy
Plant Manager
Post Office Box 756
Port Gibson, Mississippi 39150

269 117

~~7906200014~~

UNITED STATES
NUCLEAR REGULATORY COMMISSION
OFFICE OF INSPECTION AND ENFORCEMENT
WASHINGTON, D.C. 20555

June 11, 1979

IE Information Notice No. 79-14

SAFETY CLASSIFICATION OF ELECTRICAL CABLE SUPPORT SYSTEMS

Summary:

The NRC inspection staff has found that in several cases, facilities under construction have not applied the pertinent quality assurance requirements of 10 CFR 50, Appendix B to the design, procurement, and installation of cable trays and their support systems for Class IE electrical cables. This notice is being issued to all applicants for, and holders of construction permits, to remind them of the Commission's regulations on this subject.

Description of Circumstances:

1. In the Commission's Regulations for Licensing of Production and Utilization Facilities - 10 CFR Part 50, Criterion 2 of Appendix A, states in part that "Structures, systems and components important to safety shall be designed to withstand the effects of....earthquakes....without loss of capability to perform their safety functions...."
2. The Commission's Regulations on Reactor Site Criteria, Part 100, Appendix A, define a "safe shutdown earthquake," (SSE) and generally identify the structures, systems and components which are required to remain functional during such an earthquake.
3. Regulatory Guide 1.29 "Seismic Design Classification" states in pertinent part:

"C.1. The following structures, systems and components of a nuclear power plant, including their foundations and supports (emphasis added) are designated as Seismic Category 1 and should be designed to withstand the effects of the SSE and remain functional. The pertinent quality assurance requirements of Appendix B to 10 CFR 50 should be applied to all activities affecting the safety related functions of these structures, systems and components."

"C1.g. The Class IE electrical systems for the on-site electrical emergency electric power

No written response to this information questions regarding the matter, NRC Regional Office.

DUPLICATE DOCUMENT

269 118

Entire document previously entered into system under:

ANO

7906290214

No. of pages:

2