



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION III  
799 ROOSEVELT ROAD  
GLEN ELLYN, ILLINOIS 60137

TIC

JUN 11 1979

Docket No. 50-461  
Docket No. 50-462

Illinois Power Company  
ATTN: Mr. W. C. Gerstner  
Executive Vice President  
500 South 27th Street  
Decatur, IL 62525

Gentlemen:

This Information Notice is being issued to call to your attention an aspect of the Commission's regulations which IE inspectors have found is not always being fully implemented. No written response is required. If you have questions regarding this matter, please contact me.

Sincerely,

*James G. Keppler*  
James G. Keppler  
Director

Enclosure: IE Information  
Notice No. 79-14

cc w/encl:  
Central Files  
Director, NRR/DPM  
Director, NRR/DOR  
PDR  
Local PDR  
NSIC  
TIC  
Mr. Dean Hansell, Office of  
Assistant Attorney General

269 155

7907020254

U.S. NUCLEAR REGULATORY COMMISSION  
OFFICE OF INSPECTION AND ENFORCEMENT

REGION III

June 11, 1979

IE Information Notice No. 79-14

SAFETY CLASSIFICATION OF ELECTRICAL CABLE SUPPORT SYSTEMS

Summary:

The NRC inspection staff has found that in several cases, facilities under construction have not applied the pertinent quality assurance requirements of 10 CFR 50, Appendix B to the design, procurement, and installation of cable trays and their support systems for Class IE electrical cables. This notice is being issued to all applicants for, and holders of construction permits, to remind them of the Commission's regulations on this subject.

Description of Circumstances:

1. In the Commission's Regulations for Licensing of Production and Utilization Facilities - 10 CFR Part 50, Criterion 2 of Appendix A, states in part that "Structures, systems and components important to safety shall be designed to withstand the effects of....earthquakes....without loss of capability to perform their safety functions...."
2. The Commission's Regulations on Reactor Site Criteria, Part 100, Appendix A, define a "safe shutdown earthquake," (SSE) and generally identify the structures, systems and components which are required to remain functional during such an earthquake.

3. Regulatory Guide 1.29 "Seismic Design Classification" states in pertinent part:

"C.1. The following structures, systems and components of a nuclear power plant, including their foundations and supports (emphasis added) are designated as Seismic Category 1 and should be designed to withstand the effects of the SSE and remain functional. The pertinent quality assurance requirements of Appendix B to 10 CFR 50 should be applied to all activities affecting the safety related functions of these structures, systems and components."

"Cl.q. The Class IE electric systems, including the auxiliary systems for the on-site electric power supplies, that provide the emergency electric power..."

No written response to this information notice is required. If you have questions regarding the matter, please contact the NRC Regional Office.

Attachment: List of IE Information Notices Issued in 1979

DUPLICATE DOCUMENT

Entire document previously entered into system under:

ANO

269,156  
7906290214

No. of pages:

2