



Docket No. 50-346

License No. NPF-3

Serial No. 525

LOWELL E. ROE

Vice President
Facilities Development
(419) 259-5242

July 9, 1979

Director of Nuclear Reactor Regulation
Attention: Mr. Robert W. Reid, Chief
Operating Reactors Branch No. 4
Division of Operating Reactors
United States Nuclear Regulatory Commission
Washington, D.C. 20555

Dear Mr. Reid:

We are transmitting under separate cover five (5) copies of our seismic reanalysis and evaluation for the Davis-Besse Nuclear Power Station Unit No. 1. This seismic reanalysis and evaluation is being submitted in accordance with Section 2.C.(3)(r) of our Facility Operating License No. NPF-3 and follows the guidelines transmitted by your letter of January 30, 1979.

In this reanalysis we have not completed the Qualification Summary of Equipment for all of the equipment listed in Attachment 1 to your January 30, 1979 letter. This is a result of the difficulty encountered in obtaining some of the additional vendor information requested. We are actively pursuing obtaining the additional information required and are planning to submit it in a supplement to our reanalysis by October 31, 1979.

We are confident that this reanalysis and evaluation demonstrates that the Davis-Besse Nuclear Power Station Unit No. 1 can be safely shut down and continued shutdown heat removal accomplished in the event of a Safe Shutdown Earthquake having an acceleration of 0.20g.

After your review of our reanalysis and evaluation should any further information or clarification be needed, do not hesitate to contact me or any of my staff.

Yours very truly,

Lowell E. Roe / ERM

LER:CLM

dh a/4

323 074

None 1/5