

Unit 2

LICENSEE EVENT REPORT

Report No. LER 2-79-32/IT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

P A P B S 2 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
9 14 15 25 26 57 CAT 58

REPORT SOURCE L 6 0 5 0 - 0 2 7 7 7 0 6 2 6 7 9 8 0 7 1 1 7 9 9
60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

In response to the analysis required by IE Bulletin 79-02, Rev. 1, 1243

seismic class I supports have been analyzed. Ninety two supports have

safety factors less than five based on a design basis earthquake. Eight

of these have safety factors less than one; i.e., may fail during a de-

sign basis earthquake. Safety significance is minimal, because calcula-

tions indicate supports will withstand the operating basis earthquake.

O & S R Committee approved continued plant operation.

SYSTEM CODE

CAUSE CODE

CAUSE SUBCODE

COMPONENT CODE

COMP. SUBCODE

VALVE SUBCODE

S H 11

B 12

A 13

Z Z Z Z Z Z Z 14

Z 15

Z 16

LER/RO REPORT NUMBER 17 7 9 21 22

1

SEQUENTIAL REPORT NO. 0 3 2 24 26

1

OCCURRENCE CODE 0 1 28 29

REPORT TYPE T 30 31

REVISION NO. 0 32

ACTION TAKEN F 18 33

FUTURE ACTION F 19 34

EFFECT ON PLANT Z 20 35

SHUTDOWN METHOD Z 21 36

HOURS 0 0 0 0 37 40

ATTACHMENT SUBMITTED Y 23 41

NPRD-4 FORM SUB. N 24 42

PRIME COMP. SUPPLIER Z 25 43

COMPONENT MANUFACTURER Z 9 9 9 9 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

The cause of this occurrence was inadequate initial support design.

Seismically qualified pipe support modifications are expected to be

complete by July 13, 1979.

FACILITY STATUS

% POWER

OTHER STATUS

METHOD OF DISCOVERY

DISCOVERY DESCRIPTION

E 28

1 0 0 29

U/3 at 100% 44

D 31

Work in IE Bulletin 79-02 46

ACTIVITY CONTENT RELEASED OF RELEASE

AMOUNT OF ACTIVITY

LOCATION OF RELEASE

Z 33

Z 34

NA

NA

PERSONNEL EXPOSURES

DESCRIPTION

0 0 0 37

Z 38

NA

PERSONNEL INJURIES

DESCRIPTION

0 0 0 40

NA

NA

LOSS OF OR DAMAGE TO FACILITY

DESCRIPTION

Z 42

NA

NA

PUBLICITY

DESCRIPTION

N 44

NA

NA

NAME OF PREPARER

M. J. Cooney

PHONE

(215) 841-5020

NRC USE ONLY

7907180509

347

259

974 16 000