

Alabama Power Company
600 North 18th Street
Post Office Box 2641
Birmingham, Alabama 35291
Telephone: 205 323-5341

F. L. CLAYTON, JR.
Senior Vice President

Alabama Power
the southern electric system

May 31, 1979

Docket No. 50-364
NRC IE Bulletin 79-04

Mr. James P. O'Reilly
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N.W.
Suite 3100
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

In response to IE Bulletin 79-04, Incorrect Weights for Swing Check Valves manufactured by Velan Engineering Corporation, dated March 30, 1979, Alabama Power Company submits the following response to Items 1 through 5 for Farley Unit 2.

Item 1: List all Seismic Category I piping systems where 3, 4, or 6 inch diameter Velan swing check valves are installed.

- (a) Boron Thermal Regeneration (2 valves)
- (b) Waste Process (3 valves)
- (c) Chemical and Volume Control (11 Valves)
- (d) Safety Injection (11 valves)

Item 2: Verify for the systems identified in Item (1) above that correct check valve weights were used in the piping analysis.

All Velan swing check valve weights from certified vendor drawings were compared to the check valve weights specified in IE Bulletin 79-04. No discrepancies were found.

Item 3 thru 5: These items in the bulletin are not applicable since the correct valve weights were used in the analysis.

Yours truly,

F. L. Clayton, Jr.
F. L. Clayton, Jr.

FLCJr/KAP:bjh

336

350

790719016 Q79057
FICIAL CO

USNRC REGION II
ATLANTA, GEORGIA
A9:11

Mr. James P. O'Reilly
PAGE 2
May 31, 1979

DISTRIBUTION

cc: Mr. R. A. Thomas
Mr. G. F. Trowbridge

336 351