

QUAD-CITIES NUCLEAR POWER STATION

UNITS 1 AND 2

MONTHLY PERFORMANCE REPORT

JUNE 1979

COMMONWEALTH EDISON COMPANY

AND

IOWA-ILLINOIS GAS & ELECTRIC COMPANY

NRC DOCKET NOS. 50-254 and 50-265

LICENSE NOS. DPR-29 and DPR-30

415 263

7907240 322

R

TABLE OF CONTENTS

- I. Introduction
- II. Summary of Operating Experience
 - A. Unit One
 - B. Unit Two
- III. Plant of Procedure Changes, Tests, Experiments, and Safety Related Maintenance
 - A. Amendments to Facility License or Technical Specifications
 - B. Facility or Procedure Changes Requiring NRC Approval
 - C. Tests and Experiments Requiring NRC Approval
 - D. Other Changes, Tests and Experiments
 - 1. Special Tests
 - E. Corrective Maintenance of Safety-Related Equipment
- IV. License Event Reports
- V. Data Tabulations
- VI. Unique Reporting Requirements
 - A. Main Steam Relief Valve Operations
 - B. Control Rod Drive Scram Timing Data
- VII. Refueling Information
- VIII. Glossary

I. INTRODUCTION

Quad-Cities Nuclear Power Station is composed of two Boiling Water Reactors, each with a Maximum Dependable Capacity of 769 MWe net, located in Cordova, Illinois. The Station is jointly owned by Commonwealth Edison Company and Iowa-Illinois Gas & Electric Company. The Nuclear Steam Supply Systems are General Electric Company Boiling Water Reactors. The Architect/Engineer was Sargent & Lundy, Inc. and the primary construction contractor was United Engineers & Constructors. The condenser cooling method is a closed-cycle spray canal, and the Mississippi River is the condenser cooling water source. The plant is subject to license numbers DPR-29 and DPR-30, issued October 1, 1971 and March 21, 1972 respectively, pursuant to Docket Numbers 50-254 and 50-265. The date of initial reactor criticalities for Units 1 and 2 respectively were October 18, 1971 and April 26, 1972. Commercial generation of power began on February 18, 1973 for Unit 1 and March 10, 1973 for Unit 2.

This report was compiled by Dave Hannum, telephone number 309-654-2241, ext. 179.

II. SUMMARY OF OPERATING EXPERIENCE

A. Unit One

- June 1 - 8: Unit One began the reporting period operating at 792 MWe. The electrical load was held constant except for minor load reductions on June 2nd due to turbine testing and high condenser backpressure on June 6th and 7th.
- June 9 - 10: Load was reduced to 214 MWe in order to replace a thermocouple on the 1A inboard MSIV. Upon completion of the repair, load was increased at 100 MWe/hr.
- June 11 - 16: Unit One held a steady load of 800 MWe.
- June 17: Electrical load was reduced to 566 MWe in order to reverse main condenser circulating water flow.
- June 18 - 22: Unit One held a steady load of 783 MWe.
- June 23 - 24: The load was reduced to 550 MWe for main condenser flow reversal.
- June 25 - 26: Load was reduced to 684 MWe to change reactor feed pump operation due to the 1A reactor feed pump outboard bearing seal line leak. After completion of repairs, load was reduced again to return the 1A Reactor Feed Pump to operation.
- June 27 - 30: Unit One held a steady load of 791 MWe.

B. Unit Two

- June 1 - 5: Unit Two began the reporting period operating at 682 MWe. Electrical load was held constant except for a reduction to 450 MWe on June 3rd for main condenser flow reversal.
- June 6 - 10: The load fluctuated between 700 MWe and 500 MWe due to high condenser backpressure.

- June 11 - 21: Unit Two held an average load of 636 MWe during this period, which included a reduction in power to 500 MWe for main condenser flow reversal.
- June 22: At 1250 Unit Two scrammed due to a spurious false condenser low vacuum signal. The reactor was made critical at 1730 and the main generator was placed on line at 2042.
- June 23: At 0106 Unit Two scrammed due to a reactor low water level condition. The 2E feedwater regulator valve went closed for no apparent reason. The reactor was made critical at 0435 and the main generator was placed on line at 1040.
- June 24: Load was steadily increased at the rate of 10 MWe/hr to 700 MWe.
- June 25 - 27: Unit Two held an average load of 625 MWe.
- June 28: Load was reduced to 440 MWe due to high condenser backpressure.
- June 29: Unit Two held an average load of 633 MWe.
- June 30: Load was reduced to 550 MWe for main condenser flow reversal.

III. PLANT OR PROCEDURE CHANGES, TESTS,
EXPERIMENTS AND SAFETY RELATED MAINTENANCE

A. Amendments to Facility License or Technical Specification

A small portion to Amendment No. 50 was inadvertently omitted when originally added to DPR-29 in April of 1979. This addition consisted of changes to the Maximum Average Planer Heat Generation Rate Limits (MAPLHGR).

B. Facility or Procedure Changes Requiring NRC Approval

There were no Facility or procedure changes requiring NRC approval during the reporting period.

C. Tests and Experiments Requiring NRC Approval

There were no tests or experiments performed during the reporting period requiring NRC approval.

D. Other Changes, Tests, and Experiments

Speical Test 2-26: EGC - Circuitry Test

The purpose of this test was to transfer control of Unit Two to the Economic Generation Control (EGC) System. The unit was placed in both local and remote automatic recirculation flow control and several power changes were performed in each mode. The unit was then returned to master manual recirculation flow control.

Summary of Safety Evaluation:

Operation in the automatic flow control is a normal mode of operation and has been considered in the FSAR. Additional safety has been added since the EGC system has added restrictions to the range of power operation. Thus, there would be less probability of an accident or

malfunction of equipment as evaluated in the FSAR. Operation in the automatic mode of EGC was accomplished only at greater than 20% power, 65-100% core flow, and application of proper k_f factors for automatic control limitations to MCPR. Thus, there was no reduction in the margin of safety as defined in the basis for any Technical Specification.

E. Corrective Maintenance of Safety Related Equipment

The following represents a tabular summary of the safety-related maintenance performed on Unit One and Unit Two during the reporting period. The headings indicated in this summary include Work Request Numbers, LER Numbers, Components, Cause of Malfunctions, Results and Effects on Safe Operation, and Action Taken to Prevent Repetition.

UNIT ONE MAINTENANCE SUMMARY

W.R. NUMBER	LER NUMBER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS & EFFECTS ON SAFE OPERATION	ACTION TAKEN TO PREVENT REPETITION
2967-79	VIV. (AO 1-1601-60)	The air supply fitting was loose.	The valve was operable although leaking air.	The fitting was tightened and the valve was cycled 3 times.	
2477-79	RHR Hex. outlet vIvs. (1-1001-5A/B)	The position indicator was out of adjustment.	The position indicator did not agree with the light valve position indication. RHR was operable.	The position indicator was readjusted. The valves were stroked 3 times.	
2866-79	RCIC Steam Line High Flow Switch (1-1360-1B)	The micro switch was defective.	RCIC was operable.	The positive dp micro switch was replaced and calibrated.	
2868-79	'9-19/03L Drywell-Torus Vacuum Bkr, VIV (1-1601-32D)	The shaft bushing and packing were defective.	The valve had dual indication. Valve would have operated if required.	The packing and shaft bushing were replaced.	
					415 270

UNIT TWO MAINTENANCE SUMMARY

M.R. NUMBER	LER NUMBER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS & EFFECTS		ACTION TAKEN TO PREVENT REPETITION
				ON SAFE OPERATION	ON SAFE OPERATION	
2878-79		CRD 54~31 (2-300),	The rod select relay was dirty.	The rod would not settle. Scram operability was unaffected.	The relay was cleaned.	
3033-79		UBU Main Steam Rad. Monitor (2-1734-B)	The detector connector was loose.	The monitor spiked Hi-Hi. Redundant monitors were operable.	The connector was tightened. The monitor was bench tested.	
3003-79	79-10/03L	Fuel Pool Rad Monitor (2-1743-A).	The G/H tube was defective.	The 902-10 Indicator differed from the local monitor reading. B Monitor was operable.	The G/H tube was replaced and calibrated. The vent system trip was functionally tested.	
2986-79		RHR valve (2-1001-4A)	The main ckt breaker was out of adjustment.	The breaker tripped while testing valve operability. RHR was operable.	The breaker was adjusted. The valve was cycled 3 times.	
2778-79		HPC1 Steam Drain valve (AO 2-2301-31)	The operator diaphragm was cracked.	The operator was leaking air. HPC1 was operable at all times.	The diaphragm was replaced.	

271

104

UNIT TWO MAINTENANCE SUMMARY

W.R. NUMBER	LER NUMBER	COMPONENT	CAUSE OF MALFUNCTION	RESULTS & EFFECTS ON SITE OPERATION	ACTION TAKEN TO PREVENT REPETITION
2944-79	Off Gas Monitor (2-1705-13)	The monitor connectors were loose.	The "A" monitor was spiking downscale and the "g" monitor was erratic. Monitors were operable.	The monitor was reading low. Monitors were operable.	The connectors were tightened and the monitors functionally tested.
3208-79	"g" Main Steam Rad Monitor (2-1705-02B).		The monitor needed recalibrating.	The monitor was reading low. Monitors were operable.	The monitor was recalibrated.

415 272

IV. LICENSEE EVENT REPORTS

The following is a tabular summary of all license event reports for Quad-Cities Units one and two occurring during the reporting period, pursuant to the reportable occurrence reporting requirements as set forth in sections 6.6.B.1. and 6.6.B.2. of the Technical Specifications.

UNIT ONE

<u>Licensee Event Report Number</u>	<u>Date of Occurrence</u>	<u>Title of Occurrence</u>
79-22/03L	6-22-79	Unit One Diesel Generator Fuel line leak after returning to service.

UNIT TWO

<u>Licensee Event Report Number</u>	<u>Date of Occurrence</u>	<u>Title of Occurrence</u>
79-12/03L	6-22-79	Unit Two Diesel Generator Out of Service Longer than 1½ hours due to obstruction in winding.

V. DATA TABULATIONS

The following data tabulations are presented in this report.

- A. Operating Data Report
- B. Average Daily Unit Power Level
- C. Unit Shutdowns and Power Reductions

CHILLING DATA REPORT

POCKET NO. 050-254

UNIT One

DATE 6-30-79

COMPLETED BY D. Hannum

TELEPHONE (309) 654-2241,
Ext. 179

OPERATING STATUS

0000 060179

2400 063079

Gross hours in reporting period: 720

2. Currently authorized power level (MWh): 2511 Max. depend. capacity
(We-Net): 769 Design electrical rating (Mw-Net): 769

3. Power level to which restricted (if any) (We-Net): NA

4. Reasons for restriction (if any):

	This Month	Yr. to Date	Cumulative
5. Number of hours reactor operating	720	3278.8	50611.7
6. Reactor reserve shutdown hours	0	0	3329.6
7. Hours generator on line	720	3149.9	18092.8
8. Unit reserve shutdown hours.	0	19.8	909.2
9. Gross thermal energy generated (MMBtu)	1707530	6589668	95397544
10. Gross electrical energy generated (MWh)	549271	2083829	30556324
11. Net electrical Energy Generated	524045	1957138	28589711
12. Reactor service factor	100.0	75.5	80.9
13. Reactor availability factor	100.0	75.5	86.2
14. Unit service factor	100.0	72.5	76.9
15. Unit availability factor	100.0	73.0	78.3
16. Unit capacity factor (Using MDC)	94.6	58.6	59.4
17. Unit capacity factor (Using Des. MWe)	92.2	57.1	57.9
18. Unit forced outage rate	0.0	4.5	8.0
19. Shutdowns scheduled over next 6 months (Type, date, and duration of each):			

20. If shutdown at end of report period, estimated date of startup: NA

* The MDC may be lower than 769 MWe during periods of high ambient temperature due to the thermal performance of the spray canal. 415 275 631 527

OPERATING DATA REPORT

DOCKET NO. 050-265

UNIT Two

DATE 6-30-79

COMPLETED BY D. Hannum

TELEPHONE (309) 654-2241,
Ext. 179OPERATING STATUS 0000 060179
2400 063079

1. Reporting period: Gross hours in reporting period: 720

2. Currently authorized power level (Wt): 2511 Max. depend. capacity
(MWe-Net): 769 Design electrical rating (MWe-Net): 769

3. Power level to which restricted (if any) (MWe-Net): NA

4. Reasons for restriction (if any):

	This Month	Yr. to Date	Cumulative
5. Number of hours reactor was critical	711.5	4240.9	49617.3
6. Reactor reserve shutdown hours	0.0	0.0	2985.8
7. Hours generator on line	702.6	4194.7	47297.6
8. Unit reserve shutdown hours.	0.0	0.0	702.9
9. Gross thermal energy generated (MMBtu)	1422758	8791768	97533892
10. Gross electrical energy generated (MMB)	437673	2744563	31232940
11. Net electrical Energy Generated	399836	2546811	29308271
12. Reactor service factor	98.8	97.6	80.5
13. Reactor availability factor	98.8	97.6	85.3
14. Unit service factor	97.6	96.6	76.7
15. Unit availability factor	97.6	96.6	77.9
16. Unit capacity factor (Using MDC)	72.2	76.3	61.8
17. Unit capacity factor (Using Des. MWe)	70.4	74.3	60.3
18. Unit forced outage rate	2.4	0.8	9.8
19. Shutdowns scheduled over next 6 months (type, date, and duration of each):			
20. If shutdown at end of report period, estimated date of start-up:			NA

* The MDC may be lower than 769 MWe during periods of high ambient temperature due to the thermal performance of the spray cooling.

415-276

ACPIRORIN 2
AV. DAILY UNIT-LEVELRevision 4
June 1976

Docket No. 050-254

Unit One

Date 6-30-79

Completed by D. Hannum

Telephone (309) 654-2241,
Ext. 179

MONTH June 1979

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	753
2.	730
3.	757
4.	747
5.	752
6.	747
7.	734
8.	745
9.	400
10.	641
11.	762
12.	760
13.	762
14.	762
15.	757
16.	742

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	653
18.	753
19.	748
	733
	739
22.	745
23.	741
24.	690
25.	730
26.	742
27.	752
28.	751
29.	766
30.	738
31.	---

415 277

APPROVED

JUN 20 1976

INSTRUCTIONS

On this form, list the average daily unit power level in MWe-Net for each day of the reporting month. Complete to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

APPENDIX 3
AV. RACE DAILY UNIT-POWER LEVELRevision 4
June 1976

Docket No. 050-265

Unit Two

Date 6-30-79

Completed by D. Hannum

Telephone (309) 654-2241,
Ext. 179

MONTH June 1979

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

1.	636
2.	627
3.	532
4.	621
5.	615
6.	609
7.	530
8.	524
9.	533
10.	525
11.	618
12.	656
13.	638
14.	636
15.	532
16.	548

DAY AVERAGE DAILY POWER LEVEL
(MWe-Net)

17.	546
18.	588
19.	551
20.	584
21	581
22.	310
23.	181
24.	556
25.	590
26.	571
27.	567
28.	538
29.	576
30.	534
31.	---

415 278

APPROVED

JUN 20 1976

INSTRUCTIONS

On this form, list the average daily unit power level in MWe-Net for each day in the reporting month. Round off to the nearest whole megawatt.

These figures will be used to plot a graph for each reporting month. Note that when maximum dependable capacity is used for the net electrical rating of the unit, there may be occasions when the daily average power level exceeds the 100% line (or the restricted power level line). In such cases, the average daily unit power output sheet should be footnoted to explain the apparent anomaly.

DOCKET NO. 050-254APPENDIX D
UNIT SHUTDOWNS AND POWER REDUCTIONSQTP 300-S13
Revision 5
March 1978UNIT NAME Quad Cities OneCOMPLETED BY D. HannumDATE June 30, 1979REPORT MONTH June 1979 TELEPHONE (309) 654-2241,
Ext. 179

NO.	DATE	TYPE FOR S	DURATION (HOURS)	REASON	METHOD OF SHUTTING DOWN REACTOR	LICENSCER EVENT REPORT NO.	SYSTEM CODE	COMPONENT CODE	CORRECTIVE ACTIONS/COMMENTS	
4	790609	F		H	4		CC	INSTRU	Load was reduced to 214 MWe to replace a thermocouple on the inboard 1A MSIV.	

415 279

APPENDIX D
UNIT SHUTDOWNS AND POWER REDUCTIONS

QTP 300-513
 Revision 5
 March 1973

DOCKET NO. 050-265

UNIT NAME Quad Cities Two

DATE June 30, 1979

REPORT MONTH June 1979

COMPLETED BY D. Hannum

TELEPHONE (309) 654-2241,

Ext. 179

NO.	DATE	TYPE OR METHOD OF SHUTTING DOWN	REASON FOR DURATION (HOURS)	LICENSEE EVENT REPORT NO.	COMPONENT SYSTEM	COMPONENT CODE	CORRECTIVE ACTIONS/COMMENTS	
							UNIT NUMBER	ACTION/TIME
10	790622	F	7.9	A	3	IA	RELAYX	Unit Two scrammed due to a spurious false condenser low vacuum signal.
11	790623	F	9.6	A	3	CH	VALVEX	Unit Two scrammed due to reactor low water level. The 2B feedwater regulator valve went closed.

280
415

VI. UNIQUE REPORTING REQUIREMENTS

The following items are included in this report based on prior commitments to the commission.

A. Main Steam Relief Valve Operations

There were no main steam valve actuations during the reporting period.

B. Control Rod Drive Scram Timing Data for Units One and Two

There were no control rod drive scram timing exercises performed during the reporting period.

415 281

VII. REFUELING INFORMATION

The following information about future reloads at Quad Cities Station was requested in a January 26, 1978 licensing memorandum (78-24) from D.E. O'Brien to C. Reed et. al. titled "Dresden, Quad-Cities, and Zion Station - NRC request for refueling information dated January 18, 1978.

415 282

QUAD-CITIES REFUELING
INFORMATION REQUESTNNU 2200-22
Revision 1
March 1978

1. Unit: 1 Reload: 5 Cycle: 6
2. Scheduled date for next refueling shutdown: September 1, 1980 (Shaded)
3. Scheduled date for restart following refueling: Dec 15, 1980 (Startup day)
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment?
5. Scheduled date(s) for submitting proposed licensing action and supporting information: The QCI R5 licensing submittal is scheduled for Sept 1, 1980
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:

NONE

POOR CRITICALITY

7. The number of fuel assemblies.
- Number of assemblies in core: 724
 - Number of assemblies in spent fuel pool: 343
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned in number of fuel assemblies.
- Licensed storage capacity for spent fuel: 1460
 - Planned increase in licensed storage: None
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity:

APPROVED

-1-
415 283

APR 20 1973

Q. C. C. S. R.

KELLOGG LICENSING PACKAGE
PREPARATION SCHEDULE

QTP 320-525
Revision 1
March 1973

284

ACTIVITY

RESPONSIBILITY CENTER

UNIT - Q1
RECORD # 6
CYCLE 5

4/15/73

GE
NFS

NFS receives draft licensing Submittal from GE
Transmit copy of draft licensing Submittal to Station for Comments

4/29/73

NFS
GE

Transmit NFS and Site comments/questions to GE
Begin Tech, Engrg, Eval, and Coop Letter

5/30/73

GE
NFS

NFS receives final license Submittal and answers to CECO questions from GE
Complete final NFS review
Licensing Submittal and approves to FCC for publication

5/1/73

NFS

Transmit complete package to NRC off site review

5/3/73

Station

On-site review completed

5/6/73

PSA

Off-site review completed

5/11/73

NLA

Completed Licensing package received by NRC

5/12/73

-

Anticipated unit shutdown

5/19/73

-

28 days
90 day

5/29/73

-

Receipt of operating License

5/29/73

-

Anticipated Unit Startup - Assumes 56 day outage
6 weeks

5/29/73

-

NES/DRS

Prepared by:

MC

Date: 5/29/73

PRELIMINARY CHECKLIST FOR RELOAD LICENSE AMENDMENTS

UNIT: Quad-Cities 1
 RELOAD: 4
 CYCLE: 5

Item	Page	Require Changes
Screw Reactivity	4	Generalize wording and reference the submit, NEDO-XXXXX.
Safety Valve Setpoints LS55	1.2/2.2-1	None. Adequate pressure margin.
Bases	1.2/2.2-2,3	None, if the peak vessel pressure is 1325 psig, during S.V. sizing trans.
PCN Setpoints LCO	3.2/4.2-14	Change to (.65wtXX) as tested.
Bases	3.2/4.2-7 3.2/4.2-8	Change operability to XX% Change Reference 1 to NEDO-XXXXX.
Auto Flow Control LCO	3.3/4.3-5	None. Stability analysis not limiting.
Bases	3.3/4.3-11	None.
KAPLHCR LCO	Fig. 3.5.1 (shts. 1 to 3)	Revise curves to reflect new analyses.
Bases	3.5/4.5-14	Change references to reflect new analyses of NEDO-2-0461.
HCPB LCO	3.5/4.5-12	New values: #1.XX (7 x 7) 1.XX (8 x 6)
Bases	3.5/4.5-14	Generalize description of limiting transient(s).

415 285

PTB50 charges are being handled under separate cover.
 Includes additional 6.00 CPR penalty for Fuel Loading Error Accident
 and 1.00 CPR for the initial condition.

QUAD-CITIES REFUELING
INFORMATION REQUESTQTP 300-532
Revision 1
March 1978

1. Unit: 2 Reload: 4 Cycle: 5 (next outage)
2. Scheduled date for next refueling shutdown: September 30, 1979 (shutdown EOC4)
3. Scheduled date for restart following refueling: January 20, 1980 (start up DOD5)
4. Will refueling or resumption of operation thereafter require a technical specification change or other license amendment: Similar Tech. Spec. changes to Reload 3 Cycle 4, or supporting technical analysis, required information will be submitted with the license application.
5. Scheduled date(s) for submitting proposed licensing action and supporting information: Reload Submittal to be provided approximately 90 days prior to shutdown. License to extend until 1990 with two 10-year renewals. Different licensing by scenario, one with 10% GCR, one without.
6. Important licensing considerations associated with refueling, e.g., new or different fuel design or supplier, unreviewed design or performance analysis methods, significant changes in fuel design, new operating procedures:
New fuel designs: Retrofit 8 x 8 fuel (approximately 190).

POOR ORIGINAL

7. The number of fuel assemblies:
- Number of assemblies in core: 724
 - Number of assemblies in spent fuel pool: 745
8. The present licensed spent fuel pool storage capacity and the size of any increase in licensed storage capacity that has been requested or is planned in number of fuel assemblies:
- Licensed storage capacity for spent fuel: 1460
 - Planned increase in licensed storage: None
9. The projected date of the last refueling that can be discharged to the spent fuel pool assuming the present licensed capacity: Last refueling date w/ present capacity: September, 85.

UNIT OC-2
SERIAL 3
CYCLE 3

RELOAD LICENSING PACKAGE
PREPARATION SCHEDULE

GTP 300-533
Revision 1
March 1978

282

5

DATE

RESPONSIBILITY CENTER

ACTIVITY

DATE	RESPONSIBILITY CENTER	ACTIVITY	TIME
10/6/77	GE NPS	NPS receives draft Licensing Submittal from GE transmit copy of draft to Station for comments.	10/10/77
10/10/77	NPS	Transmit NPS and Site comments/greetings to GE Design Tech. Spec. changes, Safety Evaluation and Cover Letter.	10/10/77
11/3/77	GE NPS	NPS receives Final Licensing Submittal and answers to GECo questions from GE. Complete mailing vendor of licensing submittal and answers to GECo questions.	11/10/77
11/16/77	NPS	Transmit complete package for on/off site review	11/16/77
11/18/77	PSA	Onsite review completed	11/18/77
12/1/77	MLA	Completed Licensing package received by NDC	12/1/77
1/16/78	-	Anticipated unit shutdown	1/16/78
2/5/78	-	Receipt of operating license	2/5/78
3/15/78	-	Anticipated Unit Startup - Assumes _____ Day outage _____ Weeks	3/15/78

Prepared by JAS, NFS/DWR
Date 2/23/78

PRELIMINARY CHECKLIST FOR RELOAD LICENSE AMENDMENTS

UNITS Quad-Cities 2
RELOADS 3
CYCLES 4

	Item	Page	Require Changes
X	Scram Reactivity	4	Generalize wording and reference the submit, NEDO-24063.
NA	Safety Valve Setpoints LSSS	1.2/2.2-1	None. Adequate pressure margin.
X	Doses	1.2/2.2-2,3	Clarify and add bounding peak pressures.
X	RBM Setpoints LCO	3.2/4.2-14	Change to (.65±42)
X	Bases	3.2/4.2-7 3.2/5.2-8	Change operability to 30%. Change Reference 1 to NEDO-24063.
RA	Auto Flow Control LCO	3.3/4.3-5	None. Stability analysis not limiting.
NA	Bases	3.3/4.3-11	None.
X	MAPLHGR LCO	Fig. 3.5.1 (shts. 1 to 3)	Revise curves to reflect new analyses.
X	Bases	3.5/4.5-14	Change references to reflect new analyses of NEDO-24066.
X	HCPR LCO	3.5/4.5-10	New values: 1.33 (7 x 7) 1.35 (8 x 8)
	Bases	3.5/4.5-14	Generalize description of limiting transients.

415 288

a) MAPLHGR changes are being handled under separate cover.

b) Includes additional 0.2% CPR penalty for Fuel Loading Error Accident.

VIII GLOSSARY

The following abbreviation which may have been used in the Monthly Report, are defined below:

CRD	-	Control Rod Drive System
SBLC	-	Standby Liquid Control System
MSIV	-	Main Steam Isolation Valve
RHRS	-	Residual Heat Removal System
RCIC	-	Reactor Core Isolation Cooling System
HPCI	-	High Pressure Coolant Injection System
SRM	-	Source Range Monitor
IRM	-	Intermediate Range Monitor
LPRM	-	Local Power Range Monitor
APRM	-	Average Power Range Monitor
TIP	-	Traveling Incore Probe
RBCCW	-	Reactor Building Closed Cooling Water System
TBCCW	-	Turbine Building Closed Cooling Water System
RWM	-	Rod Worth Minimizer
SBGTS	-	Standby Gas Treatment System
HEPA	-	High-Efficiency Particulate Filter
RPS	-	Reactor Protection System
IPCLRT	-	Integrated Primary Containment Leak Rate Test
LPCI	-	Low Pressure Coolant Injection Mode of RHRS
RBM	-	Rod Block Monitor
BWR	-	Boiling Water Reactor
ISI	-	In-Service Inspection
MPC	-	Maximum Permissible Concentration

PCI	-	Primary Containment Isolation
SDC	-	Shutdown Cooling Mode of RHRS
LLRT	-	Local Leak Rate Testing
MAPLHGR	-	Maximum Average Planar Linear Heat Generation Rate
R.O.	-	Reportable Occurrence
DW	-	Drywell
RX	-	Reactor
EHC	-	Electro-Hydraulic Control System
MCPR	-	Minimum Critical Power Ratio
PC10MR	-	Preconditioning Interim Operating Management Recommendations
LER	-	Licenser Event Report
ANSI	-	American National Standards Institute
NIOSH	-	National Institute for Occupational Safety and Health
ACAD/CAM	-	Atmospheric Containment Atmospheric Dilution/Containment Atmospheric Monitoring