



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303
JUN 12 1979

In Reply Refer To:
RII:JJB
50-348/79-17
50-364/79-07

Alabama Power Company
ATTN: F. L. Clayton, Jr.
Senior Vice President
P. O. Box 2641
Birmingham, AL 35291

Gentlemen:

This refers to the inspection conducted by J. J. Blake of this office on April 24-26 and May 16-19, 1979, of activities authorized by NRC License No. NPF-2 and Construction Permit No. CPPR-86 for the Farley Nuclear Plant Units 1 and 2 facility, and to the discussion of our findings held with Messrs. J. A. Mooney and W. G. Hairston at the conclusion of the inspection.

Areas examined during the inspection and our findings are discussed in the enclosed inspection report. Within these areas, the inspection consisted of selective examinations of procedures and representative records, interviews with personnel, and observations by the inspectors.

Within the scope of this inspection, no items of noncompliance were disclosed.

Three new unresolved items resulted from this inspection and are discussed in the enclosed report. These items will be examined during subsequent inspections.

One inspector follow-up item was identified during this inspection to track the Plant Manager's commitment to continue the surveillance of the flow splitter integrity by conducting ultrasonic inspections during the next refueling.

In accordance with Section 2.790 of the NRC's "Rules of Practice", Part 2, Title 10, Code of Federal Regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC's Public Document Room. If this report contains any information that you (or your contractor) believe to be proprietary, it is necessary that you make a written application within 20 days to this office to withhold such information from public disclosure. Any such application must include a full statement of the reasons on the basis of which it is claimed that the information is proprietary, and should be prepared so that proprietary information identified in the application is contained in a separate part of the document. If we do not hear from you in this regard within the specified period, the report will be placed in the Public Document Room.

7907260517

413 206

~~413 205~~


JUN 1 2 1979

Alabama Power Company

-2-

Should you have any questions concerning this letter, we will be glad to discuss them with you.

Sincerely,



Charles E. Murphy, Chief
Reactor Construction and Engineering
Support Branch

Enclosure:
Inspection Report Nos. 50-348/79-17
and 50-364/79-07

cc w/encl:
A. R. Barton
Executive Vice President
P. O. Box 2641
Birmingham, AL 35291

H. O. Thrash
Manager-Nuclear Generation
P. O. Box 2641
Birmingham, AL 35291

C. Biddinger, Jr.
Manager-Corporate Quality Assurance
P. O. Box 2641
Birmingham, AL 35291

W. G. Hairston, III
Plant Manager
Drawer 470
Ashford, AL 36312

R. E. Hollands, Jr.
QA Supervisor
P. O. Box U
Ashford, AL 36312

413 2067