



ARKANSAS POWER & LIGHT COMPANY  
POST OFFICE BOX 551 LITTLE ROCK, ARKANSAS 72203 (501) 371-4000

July 27, 1979

2-079-14

Mr. K. V. Seyfrit, Director  
Office of Inspection & Enforcement  
U. S. Nuclear Regulatory Comm.  
Region IV  
611 Ryan Plaza Drive, Suite 1000  
Arlington, TX 76011

Subject: Arkansas Nuclear One-Unit 2  
Docket No. 50-368  
License No. NPF-6  
Reportable Occurrence Report  
No. 50-368/79-047  
(File: 2-0520)

Gentlemen:

In accordance with Arkansas Nuclear One - Unit 2 Technical Specification 6.9.1.9, we have attached the subject report concerning the inoperability of two Condenser Vacuum Pump Radiation Monitors for more than seven days.

Very truly yours,

David C. Trimble  
Manager, Licensing

DCT:BI:gp

Attachment

cc: Mr. Victor Stello, Jr., Director  
Office of Inspection and  
Enforcement  
U. S. Nuclear Regulatory Comm.  
Washington, DC 20555

Mr. W. D. Johnson  
U. S. Nuclear Regulatory Comm.  
P. O. Box 2090  
Washington, DC 20555

Mr. Norman M. Haller, Director  
Office of Management and  
Program Analysis  
U. S. Nuclear Regulatory Comm.  
Washington, DC 20555

437 285  
2