

STATISTICAL SAMPLING PROGRAM TO TEST CONCRETE
EXPANSION BOLTS

FULFILLING REQUIREMENTS OF NRC I.E. BULLETIN
NO. 79-02 DATED MARCH 8, 1979

FOR
ARKANSAS NUCLEAR ONE - UNIT 1
JOB 11406-276

Issued Jointly by
Civil/Structural
and Plant Design of
Bechtel Power Corporation
in San Francisco

0	5/17/79	SFPD-7902-4 Modified and Issued for Project Use	File #	CWR
Rev.	Date	Revisions	Chk. #	Approved

408 057

7908030118

TABLE OF CONTENTS

- 1.0 INTRODUCTION
- 2.0 APPROACH
- 3.0 PROCEDURE
- 4.0 DISCUSSION
- 5.0 SUMMARY

POOR ORIGINAL

TABLE 1 SEQUENTIAL SAMPLING PROGRAM BY ATTRIBUTES

TABLE 2 TYPICAL NUMBERING OF ANCHORS

TABLE 3 RANDOM NUMBERS FROM 5000 ANCHORS

FIGURE 1 ACCEPTANCE PROBABILITY VS. ACTUAL DEFECTIVES

FIGURE 2 MODIFIED SAMPLING PROGRAM

ATTACHMENT 1 SAMPLE SIZE VS. OBSERVED DEFECTS

(BASED ON 95% CONFIDENCE LEVEL AND 2% DEFECTS)

408 058

7908080 118

5/1/79

STATISTICAL SAMPLING PROGRAM TO TEST CONCRETE
EXPANSION ANCHORS

1.0 INTRODUCTION

The United States Nuclear Regulatory Commission (NRC) requires the verification of the quality of concrete expansion anchors used in the supports of Seismic Category I piping systems of each nuclear power plants (Reference 1). The quality is defined as the ability to meet the design requirement. The quality can be verified either from the existing QC (Quality Control) document or by conducting a testing program. This report discusses a sampling and testing program to determine statistically the quality of installed concrete expansion anchors in operating nuclear power plants.

2.0 APPROACH

POOR ORIGINAL

A suitable method of testing will be selected to determine the quality of installation. Experience shows that the required capacity with the prescribed safety factor is attained when the expansion anchors are properly installed. The acceptance criterion is established in Reference 2.

408 059

If the total number (N) of anchors in a plant is small (say, less than 500), the quality of anchors can be established by a screening process

in which each and every anchor would be tested.

If the total number of anchors (N) is very large, testing only a few anchors selected at random according to a sequential sampling program, as described below, would be adequate and cost effective. The sample size (n), which is the number of anchors selected at random for test, depends on the desired quality (p) and confidence level (c). The confidence level (c) is the probability that the ratio of defective anchors to the total (N) is less than or equal to p .

For example, if it is planned to demonstrate that there is less than 5% defective anchors at a confidence level of 95%, the corresponding sampling program is as shown in Table 1. Accordingly, 50 randomly selected anchors are tested first. If there is no defective anchor encountered, then no more testing is required and the anchors are of acceptable quality. However, if a defective anchor is encountered, 34 additional randomly selected anchors are tested. Thus, the total number of anchors tested becomes 92. Again, if the total number of defective anchors remains one, no more testing is required and the anchors are acceptable. On the other hand, if the total number of defective anchors have increased the testing continues as shown in Table 1 till the anchors are acceptable. The anchors will be considered unacceptable and the testing of all anchors will follow if more than 17 defective anchors were encountered while testing 505 anchors selected at random.

408 060

POOR ORIGINAL

3.0 PROCEDURE

Various items involved in the approach explained above are the following:

3.1 Numbering

All the concrete expansion anchors in the supports of Seismic Category I piping systems can be identified, for convenience, by numbering them sequentially. The numbering can be performed by any convenient manner proceeding from one building to another. A summary table similar to Table 2 could be developed. From this numbering system any particular anchor can be identified. For example, if it is required to test 1048th anchor, it can be seen from Table 2 that 1048th anchor is the third anchor in the 40th baseplate located in the fourth floor of auxiliary building. Within a baseplate all the anchors can be numbered systematically, for example, going clockwise starting from top right corner.

3.2 Sampling

The selection of anchors at random for the test (sampling) can be performed either using random numbers or by any other means. Random numbers can be obtained either from a standard table or by using a computer program. For example, 50 random numbers for a plant with 5000 anchors are shown in Table 3. These numbers were obtained using a FORTRAN subroutine, GGUB, in the UNIVAC computer system.

POOR ORIGINAL

4.0 DISCUSSION4.1 Theory

The sequential sampling by attributes is very common and easy to implement. The statistical theory involved is given briefly here. The distribution function $f(p)$ for the probability of encountering m defective anchors in a sample of n anchors selected at random from a total of N anchors is hypergeometric as follows:

$$f(p) = K_1 \frac{\binom{Np}{m} \binom{N-Np}{n-m}}{\binom{N}{n}}$$

where: p = ratio of defective anchors to the total (quality of anchors as defined in Section 2)

K_1 = normalizing constant

() = refers to combinations. For example, $\binom{n}{m}$ is the number of combinations of n anchors taken n at a time given by: $\frac{n!}{(n-m)!m!}$

POOR ORIGINAL

408 062

If the sample size (n) is much smaller than the total number of anchors (N), the hypergeometric distribution can be approximated by the following binomial distribution,

$$f(r) = K_2 \binom{n}{m} p^m (1-p)^{n-m}; \text{ if } n \leq \frac{N}{10}$$

where: K_2 = normalizing constant = $(n+1)$

The required confidence level (c) can be obtained from the following relationship:

$$c = \int_0^p f(p) dp$$

POOR ORIGINAL

$$(i.e.) c = K_2 \binom{n}{m} \int_0^p p^m (1-p)^{n-m} dp$$

From the last expression, sample sizes (n) can be calculated for various number of defectives (m) encountered to demonstrate less than p defective at a confidence level of c . For example, the sample sizes are calculated and shown in Table 1 for $p = 0.05$ $c = 0.95$ and $m = 0, 1, 2, \dots, 17$.

408 063

4.2 Acceptance Probability

It is important to study the acceptance probability while assessing the quality of anchors based on a sampling program. The curve in Figure 1 shows the probability of anchors with known amount of defectives passing the sampling program designed to establish less than 5% defectives at 95% confidence level.

The curve shows that if a lot of anchors has 5% defectives, it has only one in twenty chance of being accepted (acceptance probability of 0.05) by the sampling program. The acceptance probability increases as the actual quality of anchors increases.

A lot with only 1% defective anchors has an acceptance probability of 0.98. Increasing the sample size will increase the acceptance probability. However, a sampling program cannot change the quality of anchors.

4.3 Efficiency

POOR ORIGINAL

The sampling program is efficient in accepting anchors of very good quality as discussed above. But it is not so efficient in rejecting anchors of inferior quality. The sampling program can be modified to alleviate this by adding a rejection criterion. For illustration, a rejection criterion is developed and shown in Table 1 for the example. Accordingly, if 7 or more defectives are encountered in the first sample of 58 anchors, the anchors will be rejected and the testing of all anchors will follow. Similarly, if 12 or more defectives are encountered in a sample of 92 anchors, the anchors will be rejected and the testing of all anchors will follow. The modified sampling program for the example is also illustrated in Figure 2. The rejection criterion is based on probable anchors with 20% or more defectives.

4.4 Measured Capacity

408 064

It can be noted that the testing program does not directly evaluate the capacity of anchors but verifies the quality of installation.

If the installation is satisfactory it can be said that the ultimate capacities of the anchors will be developed.

4.5 Rejected Anchors

If the anchors in a plant are not of acceptable quality based on a sampling program, the screening process may follow to track down all the defective anchors for future strengthening.

4.6 Recommended Initial Survey

POOR ORIGINAL

For a nuclear plant with a large number (say, 5000 or more) of concrete expansion anchors in the supports of Seismic Category I piping systems, it is prudent to conduct an initial survey, as described below, to quickly assess the quality of anchors.

- o Select at random 92 anchors by walking the plant.
An attempt should be made to distribute the selected anchors more or less equally among various locations (floor, ceiling, wall, etc.) and among various types (shell type, wedge type, etc.); and in proportion to the number of anchors in various buildings.
- o Determine the number of defectives among the 92.
- o If there is none or only one defective, the plant has anchors of good quality and no more testing would be

required unless the sampling is questionable.

- o If there are 12 or more defectives, the plant has anchors of inferior quality and each and every anchor would have to be tested.

POOR ORIGINAL

- o If the number of defectives is more than one but less than 12, the plant has anchors of marginal quality. In this case, a decision has to be made based on convenience either to test anchors according to a formal sampling program as described in this report or to test each and every anchor.

5.0 SUMMARY

1. A statistical sampling program to demonstrate by testing the quality of a large number of concrete expansion anchors in a nuclear plant is presented.
2. Various items involved in and limitations of the sampling program are discussed.
3. The alternate to sampling program is screening in which each and every anchor would be tested.

4. If it is decided to conduct a sampling program, the quality (p) for demonstration and the confidence level (α) should be decided first. Also, the sampling program will require the random selection of a few sample anchors.
5. In order to assess quickly the quality of anchors in a plant, an initial survey as described in Section 4.6 is recommended.

POOR ORIGINAL

408 067

REFERENCES

1. "Pipe Support Base Plate Design Using Concrete Expansion Anchor Bolts", IE Bulletin No. 79-02, United States Nuclear Regulatory Commission, March 3, 1979.
2. "Procedure for Inspection and Testing Concrete Expansion Bolts for Pipe Supports", SFPD-7902-5.

POOR ORIGINAL

403 068

TABLE 1. SEQUENTIAL SAMPLING PROGRAM BY ATTRIBUTES

Sample size (n)	Accept if the number of defectives encountered (m) is less than or equal to	Screen (100% testing) if the number of defectives encountered (m) is larger than or equal to
58	0	7
92	1	12
123	2	17
152	3	22
180	4	27
207	5	
233	6	
259	7	
285	8	
310	9	
335	10	
360	11	
385	12	
409	13	
433	14	
457	15	
481	16	
505	17	

POOR ORIGINAL

Note: Confidence level (α) = 0.95

Accept if defectives are less than 58

Reject if defectives are greater than 70

408 069

TABLE 2. TYPICAL NUMBERING OF ANCHORS

Base Plate Number	No. of Anchors	Anchor Numbers	Location
1	4	1 - 4	Control Bldg., 1st floor.
2	6	5 - 10	Control Bldg., 2nd floor.
.	.	.	.
.	.	.	.
37	10	1028 - 1037	Aux. Bldg., 1st floor, hanger 1
38	4	1038 - 1041	Aux. Bldg., 2nd floor, hanger 1
39	4	1042 - 1045	Aux. Bldg., 2nd floor, hanger 2
40	8	1046 - 1053	Aux. Bldg., 4th floor, hanger 3
41	6	1054 - 1059	Aux. Bldg., 4th floor, hanger 4
.	.	.	.
.	.	.	.
1050	4	4997 - 5000	Turbine Bldg., 2nd floor

POOR ORIGINAL

TABLE 3. RANDOM NUMBERS FROM 5000 ANCHORS

Serial No.	Random Number	Serial No.	Random Number	Serial No.	Random Number
1	1	20	1796	39	3394
2	38	21	1826	40	3396
3	172	22	1917	41	3433
4	235	23	2079	42	3505
5	237	24	2087	43	3613
6	267	25	2182	44	3680
7	302	26	2293	45	3766
8	334	27	2388	46	3778
9	363	28	2432	47	3782
10	459	29	2597	48	3810
11	657	30	2634	49	3832
12	832	31	2640	50	4154
13	1094	32	2663	51	4230
14	1183	33	2944	52	4423
15	1236	34	3153	53	4483
16	1312	35	3163	54	4546
17	1363	36	3257	55	4551
18	1374	37	3269	56	4652
19	1641	38	3355	57	4673
				58	4912

POOR ORIGINAL

408 071

POOR ORIGINAL




FIGURE 1. ACCEPTANCE PROBABILITY VS. ACTUAL DEFECTIVES

408 072





FIGURE 2. MODIFIED SAMPLING PROGRAM

ATTACHMENT 1SPPD-7902-8
Revision 095% Confidence level
2% Defectives

408 074

PROCEDURE FOR INSPECTION AND TESTING CONCRETE
EXPANSION BOLTS FOR PIPE SUPPORTS
FULFILLING REQUIREMENTS OF NRC I.E. BULLETIN
NO. 79-02, DATED MARCH 8, 1979

FOR
ARKANSAS NUCLEAR ONE - UNIT 1
JOB 11406-276

Issued Jointly by
Construction Engineering
and Plant Design of
Bechtel Power Corporation
in San Francisco

POOR ORIGINAL

Rev.	Date	Revisions	Check'd	Approved
0	5/17/79	SFPD-7902-4 Modified and Issued for Project Use	RJS	VWR

408 075

TABLE OF CONTENTS

- 1.0 Purpose, Scope and Application
- 2.0 General Requirements
- 3.0 Procedure for Inspecting

Attachment 1	Support Surveillance Data Sheet
Attachment 1A	Support Surveillance Data Sheet - Ultasonic Test Report
Attachment 2	Torque Tables
Attachment 3	Shimming Recommendations

POOR ORIGINAL

Inspection of Concrete Fasteners

1.0 PURPOSE, SCOPE AND APPLICATION

This procedure specifies the method for performing and documenting concrete expansion bolt (CEB) inspections. The requirements of this procedure apply to CEB used in safety-related pipe hanger installations, as directed by Engineering.

2.0 GENERAL REQUIREMENTS

2.1 CEBs will consist of two types:

- o The self-drilling shell or sleeve type (such as "Phillips Snap-Off Anchor")
- o The wedge-type (such as "Wej-it" and "Phillips Wedge Anchors")

2.2 Recommended sampling programs are summarized in 11406-276-8, Paragraph 4.0.

Note: CEB are not considered as failing if the minimum required torque value can be achieved without exceeding the allowable 1/16" slip. However, if this occurs, the remaining bolts on the plate shall be torqued without recording the data (unless a failure occurs).

2.3 Data sheets will be completed for the inspections (See Attachment 1, 11406-276-5).

3.0 PROCEDURE FOR INSPECTING

3.1 Wedge-Type

The inspection of wedge-type expansion anchors shall be performed as follows:

- A. Perform torque test using a calibrated torque wrench on nut; apply torque to nut in accordance with the minimum values listed in the torque table (See Attachment 2, 11406-276-5). The test shall be considered successful if torque is achieved in two turns or less of the nut.
- B. Determine stud length by ultrasonic testing. The person performing the ultrasonic test shall sign the data sheet (Attachment 1A, 11406-276-5).
- C. Determine the stud diameter. This determination may be by slipping a washer of known size over the stud.

POOR ORIGINAL

- D. Determine stud projection. This determination is by measuring from the concrete to the end of the stud (Dimension F).
- E. Verify the nut is not bottomed out on stud threads. This verification may be accomplished by backing nut off prior to torque test and visually inspecting stud to assure that at least two threads are below the surface of the plate or, in obvious cases, by comparing manufacturer's thread length data with measured length.
- F. Check for full thread engagement. The thread engagement is considered acceptable if it has a minimum of one complete thread above the nut.
- G. Check the concrete surrounding the plate for signs of failure.
- H. Check that hanger and support plate conform to sketch.
- I. For "Wej-its", determine rods do not protrude past lugs of washer.

3.2 Shell-Type**POOR ORIGINAL**

- A. Perform torque test using a calibrated torque wrench. The appropriate torque value listed on the torque table (See Attachment 2, 11406-276-5) shall be applied to the bolt.
- B. Verify anchor length. Determine if anchor length conforms with vendor catalog data by removing bolt prior to torque test. Measure depth of anchor to its plug, compare with new anchor depth dimension of same type.
- C. Determine bolt diameter (See Paragraph 3.1.C.).
- D. Determine the shell is not in contact with hanger plate. This verification may be made by visually inspecting or measuring the gap between the plate and the expansion anchor.

Note: If clearance cannot be certified, the plate must be shimmed away from the concrete and another torque testing applied. (See Attachment 3 of 11406-276-5 for a recommended procedure.)

- E. Retorque bolt - replace bolt and retorque to the appropriate value listed on Attachment 2, 11406-276-5.
- F. Check the concrete surrounding the plate for signs of failure.
- G. Check that hanger and support plate conform to sketch.

POOR ORIGINAL

408 079

FINAL ACCESSION #/DATE

DATE BY / DATE

N/A
SHELL TOUGHNESS TEST A
SHELL - DRILLING 645 - 15
ADHESION IN PLATE & N/A
WCO-115 ONLY - 28E WASHERS
N/A

HGS. COMPACT TO STRENGTH
LVERAGE TEST N/A

TEST NOT PERFORMED

TESTS NOT PERFORMED ON 8078

(1) A0107084-A720
RHS DIA (0)

TEST NOT PERFORMED

TESTS NOT PERFORMED

TEST NOT PERFORMED

卷之三

REV. 0

卷之三

卷之三

TORQUE VALUES

ATTACHMENT 2 OF 11406 - 276 - 5 Rev.

Anchor Size (in.)	400-17 (37-143)	520-DRILLING (with tap bolt or all thd. rod) (37-142)
3/8	50	30
5/8	55	40
3/4	75	65
7/8	100	90
1	150	130
1-1/8	200	240
1-1/4	260	240
1-1/2	330	310

POOR ORIGINAL

Attachment 3

SHIMMING RECOMMENDATIONS

1. Replace all bolts with "all thread" studs one at a time and tighten nut on each stud before removal of the next bolt.
2. Move plate away from surface by backing off on all nuts evenly until 1/4" shims can be inserted behind the plate.
3. When placing shims insure they will not interfere with the insert should it pull out during the test.
4. Tighten all nuts on threaded studs enough to pinch shims.
5. Test each nut with the torque wrench and check for anchor movement.
6. Restore CEB to original condition using manufacturer's recommendations or if anchor has failed, replace it in accordance with Spec. 6600-C-2305.

POOR ORIGINAL



TECHNICAL SPECIFICATION

FOR

INSTALLATION OF CLASS I AND NON-CLASS I CONCRETE EXPANSION-TYPE

▲ SHELL OR STUD ANCHORS AND TYPE 10 GROUTED ANCHOR BOLTS

FOR THE

ARKANSAS NUCLEAR ONE - UNIT 2

ARKANSAS POWER & LIGHT COMPANY

LITTLE ROCK, ARKANSAS

PREPARED BY:

BECHTEL CORPORATION

P.O. BOX 3965

SAN FRANCISCO, CALIFORNIA 94119

POOR ORIGINAL

FOR INFORMATION ONLY

▲	11/15/71	Added Type 10 Anchor Bolts and General Revisions	CL	ESM	V	1	Q
▲	8/25/76	Revised Sec. 3.6 and Tables I & II	CL	ESM	V	1	Q
▲	11/16/75	Revised Sec. 2.1 Per ECR 2-C-249 and Minor Revisions	CL	ESM	V	1	Q
▲	4/18/75	Revised Sec. 4.1, 4.2.1.1, 5.2.1, 6.2, 6.2.1, 6.2.2, 7.2 & 7.3	CL	ESM	V	1	Q
▲	2/28/75	General Revisions	CL	ESM	V	1	Q
▲	6/28/74	Iss. for Const., Rev. Sec. 2.0, 3.0, 4.2, 5.2, 5.4, Tables I & II - 74	CL	ESM	V	1	Q
▲	4/26/74	Issued for Client approval	CL	ESM	V	1	Q
REVISIONS			BY	CHX	APPN		
ORIGINAL		INSTALLATION OF CLASS I AND NON-CLASS I CONCRETE EXPANSION-TYPE SHELL OR STUD ANCHORS ARKANSAS NUCLEAR ONE-UNIT 2	JOB NO.	6600-2			
			APPROVED	08/3	REC'D.		
				C-2305			6

TABLE OF CONTENTS

FOR

INSTALLATION OF CLASS I AND NON-CLASS I CONCRETE EXPANSION-TYPE

 SHELL OR STUD ANCHORS AND TYPE 10 GROUTED ANCHOR BOLTS

FOR THE

ARKANSAS NUCLEAR ONE - UNIT 2

ARKANSAS POWER & LIGHT COMPANY

LITTLE ROCK, ARKANSAS

SECTION	TITLE
1.0	SCOPE OF WORK
2.0	APPLICATIONS
3.0	ACCEPTABLE ANCHORS
4.0	INSTALLATION
5.0	INSPECTION AND TESTING
6.0	REPAIR OF ANCHOR FAILURES
7.0	DOCUMENTATION

POOR ORIGINAL

1.0 SCOPE OF WORK

This specification covers the installation, inspection, testing and documentation requirements of Class I and Non-Class I anchors as indicated below.

Item/Scope of Work	Class I Anchor	Non-Class I Anchor
Anchor Installation	X	X
Anchor Inspection	X	
Anchor Testing	X	
Anchor Documentation	X	
(X denotes applicability)		

2.0 APPLICATIONS

2.1 Expansion Anchors



The specification applies to expansion anchors used in the following categories installed in concrete and masonry block walls.

2.1.1 Seismic Class I Supports

The concrete expansion anchors belonging to this category shall meet the requirements of Sections 3.0, 4.0, 5.0, 6.0 and 7.0 of this specification.

This category is limited to the following, except as noted on design drawings:

2.1.1.1 Nuclear Class II and Seismic Class I Pipe Hanger Supports.

2.1.1.2 Seismic Class I Electrical Cable Tray Supports.

2.1.1.3 Seismic Class I TV Duct Supports.

2.1.1.4 Seismic Class I Equipment Foundation Supports.

2.1.1.5 Seismic Class I Concrete Block Walls.

2.1.1.6 Seismic Class I Conduit Supports.

2.1.1.7 Seismic Class I Tubing.



2.1.2 Non-Class I Supports

Concrete expansion anchors belonging to this category need to conform only to the requirements of Section 3.0 and 4.0.

POOR ORIGINAL

2.2 Type 10 Grouted Anchor Bolts

This specification applies to grouted anchor bolts used in the following categories.

2.2.1 Seismic Class I Supports

The grouted anchor bolts belonging to this category shall meet the requirements of Sections 3.0, 4.0, 5.0, 6.0 and 7.0 of this specification.

This category is limited to the following:

2.2.1.1 Type 10 anchor bolts may be substituted for expansion anchors in Section 2.1.1.

2.2.1.2 Type 10 anchors shall be as specified on Design Drawings.

2.2.2 Non-Class I Supports

Grouted anchor bolts belonging to this category need to conform only to the requirements of Section 3.0 and 4.0.

POOR ORIGINAL

3.0 ACCEPTABLE ANCHORS

This section is applicable to Class I and Non-Class I categories as defined in Section 2.0.

3.1 Expansion Anchors

Only concrete expansion-type shell or stud anchors and manufacturers as listed in this section are acceptable. No substitution of either anchor type or manufacturer shall be made without approval by the Project Engineer. When a drawing indicates a specific anchor type or manufacturer without indicating "or approved equal", there shall be no substitution of anchor type.

- a. We-Jit Stud Anchor - We-Jit Expansion Products Inc.
- b. Phillips Wedge or Stud Anchor - Phillips Drill Co.
- c. Phillips Self-Drilling Snap-off or Flush-type Shell Anchor - Phillips Drill Co.
- d. Cinch Type Expansion Anchor - National Lead Co.
- e. Kwik Bolt Stud Anchor - Hilti Fastening Systems, Inc.
- f. Molly Parabolic Stud Anchor - USM Corporation, Construction Products Division
- g. For Concrete Masonry Block Wall - see only Phillips Self-Drilling Snap-off - Phillips Drill Co.

3.2 Type 10 Grouted Anchor Bolts

Only grouted anchor bolts conforming to the details on Drawing C-2260, Sheet 5 are acceptable unless approved by the engineer.

4.0 INSTALLATION

This section is applicable to Class I and Non-Class I categories as defined in Section 2.0.

4.1 Expansion Anchor

4.1.1 General

Installation of the expansion concrete anchors shall be performed by qualified installers. The installers shall be qualified by a field procedure approved by the Project Engineer on test blocks or on production anchors.

- 4.1.1.1 Concrete anchors shall be installed after concrete has reached an adequate strength for installation of concrete expansion anchors as determined by the Project Field Engineer.
- 4.1.1.2 Unless otherwise specified on the drawings, concrete anchors shall have a minimum center to center spacings and concrete edge distances as specified in Table 1.
- 4.1.1.3 Concrete anchors shall not be installed in the vicinity of tendons in prestressed concrete members except as approved by the Project Engineer.
- 4.1.1.4 No erection stress shall be induced in the expansion anchors during the installation of supports.
- 4.1.1.5 Welding on either shell or stud anchor inserts shall not be permitted.

4.1.2 Installation Procedures

Expansion type anchors called for in this specification shall be installed according to manufacturers' instructions and recommendations.

- 4.1.2.1 Nuts and studs shall be torqued to within the range of the installation torque values given in Table 1. The torque shall be applied by a manually operated torque wrench which shall be calibrated.
- 4.1.2.2 Minimum anchor embedments shall not be less than those specified in Table 1.

4.2 Type 10 Grouted Anchor Bolts

4.2.1 Installation Procedure

Grouted anchor bolts called for in this specification shall be installed in accordance with the details shown on Drawing C-2260, Sheet 5.

POOR ORIGINAL

5.0 INSPECTION AND TESTING

 This section is applicable only to the Seismic Class I applications as defined in Section 2.1.1 for expansion anchors and Section 2.2.1 for Type 10 grouted anchor bolts.

5.1 Inspection Procedure

 Concrete anchors used for the applications defined in Sections 2.1.1 and 2.2.1 shall be visually inspected for correct installation. If inspection reveals that an anchor does not conform to Section 4.1.1 or 4.2.1, this anchor shall be either tested in accordance with the requirements of Section 5.2 below, or shall be relocated as permitted by the design, or shall be removed and another anchor installed in accordance with Section 4.0.

5.2 Testing Procedure

 The testing of concrete anchors used for the applications defined in Sections 2.1.1 and 2.2.1 may utilize either the method described in Section 5.2.1 or 5.2.2. The frequency of testing shall be in accordance with Section 5.4. Documentation shall be in accordance with Section 7.0. Shell type expansion anchors shall be tested in a manner which insures that the shell shoulder does not bear against the grout or mounting bracket during testing.

5.2.1 Torque Test Method

Testing of the installed anchors shall consist of a torque test of the installed anchors with a calibrated torque wrench. Loosen the nut about a 1/4 turn (90°) and retighten to the approximately original position. The torque reading during retightening shall be within the range of torque installation values shown in Table IA, IB or IC.

5.2.2 Tensioner Method

All acceptable anchors shall be able to take the specified tension load applied by means of a tensioner. The minimum proof loads to be used are listed in Table II A, II B or II C.

5.3 Acceptance Criteria

5.3.1 Torque Test Method

An installed anchor shall be considered acceptable if failure does not occur due to concrete breakout, anchor breakage and/or bolt rotation.

5.3.2 Tensioner Method

An installed anchor shall be considered acceptable if failure does not occur due to concrete breakout or anchor breakage and if the proof load specified in Table II A, II B or II C is attained.

POOR ORIGINAL

5.4 Testing Frequency

- 5.4.1 One out of each group of twenty anchors, installed by each installer, shall be tested in accordance with the requirements of Section 5.2. The anchors to be tested shall be chosen in such a manner so that all anchors are adequately represented. If the test anchor satisfies the acceptance criteria of Section 5.3, all anchors in that group are deemed acceptable.
- 5.4.2 Should a test anchor not satisfy the acceptance criteria of Section 5.3, the installer shall be identified and five additional anchors installed in this group by this installer shall be tested in accordance with the requirements of Section 5.2.
- 5.4.3 Should all of the five additional test anchors satisfy the acceptance criteria of Section 5.3, all remaining anchors in that group of anchors shall be deemed acceptable and testing shall proceed in accordance with the requirements of Section 5.4.1.
- 5.4.4 Should any of the additional test anchors defined in Section 5.4.2 fail, all of the remaining anchors installed in this group by this installer shall be tested in accordance with the requirements of Section 5.2. This installer shall be requalified before he can continue installation work.
- 5.4.5 In the case of Type 10 grouted anchors, the testing may be conducted on a room by room basis rather than by the installer. All other provisions concerning test frequency given in Section 5.4.1, 5.4.2, 5.4.3 and 5.4.4 shall apply.

6.0 REPAIR OF ANCHOR FAILURES

This section is applicable to Class I and Non-Class I categories as defined in Section 2.0.

Test anchor failures may be replaced in accordance with Sections 6.1 and 6.2. Anchors which cannot be replaced in accordance with the requirements of Sections 6.1 and 6.2 may be relocated as approved by the Project Engineer.

6.1 Expansion Anchors

6.1.1 Failure due to concrete breakout.

- 6.1.1.1 If failure occurred due to concrete breakout, stud anchors may be reinstalled provided that the required embedment is obtained beyond the breakout depth.

POOR ORIGINAL

6.1.1.2 If failure occurred due to concrete breakout, shell anchors may not be reinstalled. However, a stud anchor of equivalent capacity may be installed at the same location provided that the required embedment is obtained beyond the breakout depth.

6.1.1.3 The broken out concrete shall be repaired by patching in accordance with Specification 6600-C-2302 after the replacement anchor has been installed.

6.1.2 Failure due to anchor breakage.

6.1.2.1 If failure occurred due to anchor breakage, stud anchors may be removed, the hole redrilled and the next larger size anchor installed at the same location provided that the integrity of the surrounding concrete has not been disturbed.

6.1.2.2 If failure occurred due to anchor breakage, shell anchors may not be installed. However, a stud anchor of equivalent capacity may be installed provided that the required embedment is obtained beyond the breakout depth.

6.1.2.3 The concrete surface shall be repaired by patching in accordance with Specification 6600-C-2302 after the anchor bolt has been installed.



6.2 Type 10 Grooved Anchor Bolts

6.2.1 Failure due to concrete breakout.

6.2.1.1 If failure occurred due to concrete breakout, anchors may be reinstalled provided that the required embedment is obtained beyond the breakout depth.

6.2.1.2 If failure occurred due to concrete breakout and there is insufficient concrete depth beyond the breakout to obtain proper embedment, then the anchor should be relocated. Where it is not practical to relocate the anchor bolt, engineering shall be advised. Engineering will investigate the problem and issued revised details as required.

6.2.1.3 The broken out concrete shall be repaired by patching in accordance with Specification 6600-C-2302 after the replacement anchor has been installed.

POOR ORIGINAL

6.2.2 Failure due to anchor breakage.

6.1.2.1 If failure occurred due to anchor breakage, anchors may be relocated in accordance with Specification 6600-C-2316, Section 3.0.

6.2.3 Failure due to anchor twisting.

6.2.3.1 If failure occurred due to anchor not being capable of resisting installation torque values shown in Tables IA, IB or IC, anchor may be reinstalled in accordance with Section 4.2.1.

7.0 DOCUMENTATION

This section is applicable only to the Seismic Class I applications as defined in Section 2.1.

7.1 Installer qualification record

7.2 Test Inspection Report

- 7.2.1 Installer Name
- 7.2.2 General Location
- 7.2.3 Test Result
- 7.2.4 Inspectors Name
- 7.2.5 Date of Test

7.3 Failed Anchor Test Report

- 7.3.1 Installers Name
- 7.3.2 Exact Location of Tested Anchor
- 7.3.3 Repair Steps Taken
- 7.3.4 Inspectors Name
- 7.3.5 Date of Test

7.4 In the case of Type 10 grouted anchors, the installer's name will not be required.

POOR ORIGINAL

TABLE 1A EXPANSION ANCHOR INSTALLATION REQUIREMENTS IN CONCRETE

ANCHOR DIAMETER (INCHES)	TORQUE AT INSTALLATION (FT.-LBS.)	CONCRETE TYPE (D ₁ , D ₂ , C ₁ , C ₂ E ₁ , E ₂)	MINIMUM EMBEDMENT*• (INCHES)	MINIMUM CENTER TO CENTER SPACING (INCHES)	MINIMUM CONCRETE EDGE DISTANCE (INCHES)
1/4	5		5 ~ 10	1-1/2	1-3/4"
3/8	25		25 ~ 35	2	1-7/8"
1/2	45 ~ 55		55 ~ 65	2-1/2	2-1/2"
5/8	80 ~ 85		85 ~ 90	3	3-1/8"
3/4	125 ~ 150		150 ~ 175	3-1/2	3-3/4"
7/8**	200 ~ 210		210 ~ 250	4	8-3/4"
1*	250 ~ 275		275 ~ 300	4-1/2	4-3/8"
1-1/8	310 ~ 340		340 ~ 380	5-1/2	5"
1-1/4	400 ~ 450		450 ~ 500	5-1/2	5-5/8"
1-1/2	675 ~ 750		750 ~ 800	6	6-1/4"
				15"	7-1/2"

*See manufacturer's recommendations for minimum embedment for Wej-II spade type anchors.

**Minimum Embedments shall be increased by 2 anchor diameters for Molly Parabol and KWIK-bolt concrete anchors.

Minimum Embedments for Lead Ring Chinch type Anchors shall be as noted on the design drawings.
For concrete type see Specification 6600-C-2026.

Poor Original

403 093

TABLE 1B EXPANSION ANCHOR INSTALLATION REQUIREMENTS IN MASONRY BLOCK WALLS IN PILL CAVES ONLY

ANCHOR DIAMETER (INCHES)	TORQUE AT INSTALLATION (WT.-LB.)	MINIMUM IMBEDMENT (INCHES)	MINIMUM CENTER TO CENTER SPACING (INCHES)	MINIMUM CONCRETE EDGE DISTANCE (INCHES)
1/4	2 - 4	1-1/8	3	3
3/8	7 - 11	2	4	4
1/2	12 - 18	2-1/2	5	4

For Concrete Unit Masonry, see Specification 6600-A-2011.

TABLE 1C TYPE 10 GROUTED ANCHOR BOLT INSTALLATION REQUIREMENTS IN CONCRETE

ANCHOR DIAMETER (INCHES)	TORQUE AT INSTALLATION (WT.-LB.)	MINIMUM IMBEDMENT (ANCHERS)	MINIMUM CENTER TO CENTER SPACING (INCHES)	MINIMUM CONCRETE EDGE DISTANCE (INCHES)
1/2	25 - 30	3-1/2	5	6
5/8	55 - 60	4-1/2	6-1/4	6
3/4	100 - 110	5-1/4	7-1/2	6
7/8	160 - 175	6	8-3/4	6
1	240 - 265	6-3/4	10	6
1-1/4	475 - 520	8-1/2	12-1/2	6

POOR ORIGINAL

TABLE II. MINIMUM PROOF LOADS FOR EXPANSION-TYPE ANCHORS*

ANCHOR DIAMETER (INCHES)	WELL SPADÉ TYPE ANCHOR†	REDHEAD WEDGE ANCHOR**		RED HEAD SNAP-OFF TYPE SHELL ANCHOR†	
		CONCRETE Type	CONCRETE Type	CONCRETE Type	CONCRETE Type
1/4"	B ₁ ,B ₂ ,C ₁ , C ₂ ,E ₁ ,E ₂	D ₁ ,D ₂	B ₁ ,B ₂ ,C ₁ , C ₂ ,E ₁ ,E ₂	D ₁ ,D ₂	B ₁ ,B ₂ ,C ₁ , C ₂ ,E ₁ ,E ₂
3/8"	410	770	680	1010	1030
1/2"	985	1830	1150	1720	1550
5/8"	1265	2375	1660	2480	2400
3/4"	2390	4180	2200	3300	3590
7/8"	4300	8060	3230	3290	4950
1"	4750	8910	3340	4850	6820
1-1/8"	5610	10,580	4600	5000	7510
1-1/4"	8000	15,000	-	-	-
1-1/2"	8750	16,420	11,400	17,100	-
1-1/2"	12,300	23,100	-	-	-

* All values shown are in pounds.

** Minimum proof loads apply also to Molly Pan bolt and Hilti KWIK-Bolt Stud Anchors.

† Minimum proof loads apply also to Lead Ring Chinch Type Anchors.

‡ Minimum embedment length as shown on Table I.A.

For concrete types see Specification 6600-C-2026.

POOR
QUALITY

TABLE II B MINIMUM PROOF LOADS FOR EXPANSION-TYPE ANCHORS IN MASONRY BLOCK WALLS*

ANCHOR DIAMETER (INCHES)	RIVETHEAD SNAP-OFF ANCHOR
1/4	280
3/8	410
1/2	560

*All values shown are in pounds.

Minimum embedment length as shown on Table I B.
For Concrete Unit Masonry, see Specification 6600-A-2011.

TABLE II C MINIMUM PROOF LOADS FOR TYPE 10 GROUNDED ANCHOR BOLTS*

ANCHOR DIAMETER (INCHES)	TYPE 10
1/2"	1600
5/8"	2600
3/4"	3900
7/8"	5400
1"	7000
1-1/4"	11400

*All values shown are in pounds.

408 095

POOR ORIGINAL

This drawing and the design it covers are the property of BECHTEL. They are merely loaned and on the borrower's express agreement that they will be reproduced, copied, loaned, exhibited, or used except in the limited way and private use permitted by any written consent given by the lender to the borrower.

BECHTEL POWER CORPORATION


ARKANSAS NUCLEAR ONE

JOB 6600 - 2

FIELD INSTRUCTION
FOR
INSTALLATION OF CLASS I
CONCRETE EXPANSION ANCHORS
CONTROLLING SPECIFICATION 6600-C-2305

CONTROLLING DRAWING NO. RA

APPROVED BY:


PFE

3-11-75

Date


PFOCE

JULY 24

3-11-75

Date

FOR

REVISIONS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100
REVISIONS	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	16	17	18	19	20	21	22	23	24	25	26	27	28	29	30	31	32	33	34	35	36	37	38	39	40	41	42	43	44	45	46	47	48	49	50	51	52	53	54	55	56	57	58	59	60	61	62	63	64	65	66	67	68	69	70	71	72	73	74	75	76	77	78	79	80	81	82	83	84	85	86	87	88	89	90	91	92	93	94	95	96	97	98	99	100

- 5 5/20/77 Add to Sec. 2.3 - 2.3.2 & renumber
4 5/02/77 Revise and Add To Appendix "D"
 2/21/77 Revise Para. 1.1 and 7.0
 9-24-75 Deleted Section 5.4.4
 8-11-75 Revise Appendix C. Sht. 1
 7-23-75 Issued for Construction

No.	Date	REVISIONS	BY	CHK	DESIGN SUPV	ENGR	PROJ ENGR	APPR PFE
SCALE	ORIGIN	DESIGNED	DRAWN	CHIEF ENGR				
		ARKANSAS POWER & LIGHT CO. ARKANSAS NUCLEAR ONE UNIT TWO	408	JOB NO.	6600 - 2	DRAWING NO.		REV.
				02E1-129				5
				Page 1 of 7				



INDEX

- 1.0 Scope
- 2.0 Assignment of Responsibilities
- 3.0 Acceptable Anchors
- 4.0 Installation Procedures
- 5.0 Inspection, Testing, Qualification and Documentation
- 6.0 Operational Flow
- 7.0 Retro-fit Testing of Anchors

APPENDICES

- A. Organization Chart
- B. Installation Procedures
- C. Installers Qualification Procedure
- D. Retro-Fit Directive
- E. Forms
- F. Rubber Stamps
- G. Test Procedures

Poor Original

408 097

May 20, 1977

Page Three

1.0 Scope

- 1.1 This field instruction applies to all Class I anchors installed or to be installed in Unit II by Bechtel forces and HVAC subcontractor. Retro-fit testing of anchors shall be per Section 7.0.
 - 1.2 The controlling Specification is C-2305, latest revision. Refer thereto for all technical provisions.
 - 1.3 This F.I. covers all Field operations necessary to control the qualification, installation, inspection, testing, recording, repairing, logging and controls, documentation forms, review and documentation turnover to Q.C.
- 2.0 Assignment of responsibilities for implementing and monitoring this instruction are as follows:
- 2.1 The Project Field Engineer shall designate Field Engineers to implement, co-ordinate and monitor this FI.
 - 2.2 The discipline Field Engineer shall:
 - 2.2.1 Initiate requests for installer qualification as requested by superintendent.
 - 2.2.2 Initiate production installation.
 - 2.2.3 Either utilize available drawings and/or date cards or have them prepared that will indicate the installation area. Detail and description shall be sufficient

407 098

so that anchors can be identified. The drawing shall have the following data: (See rubber stamp, Appendix F)

- a. Installers name and brass no.
- b. No. of Anchors and Room No.
- c. Type and size of Anchor
- d. Embedment of Stud Anchors
- e. Field Engineers signature
- f. Work week date

2.3 The Expansion Anchor Control Engineer shall: (E. A. C. Engr.)

2.3.1 Receive the Drawing and data from the discipline Engineer.

2.3.2 Select the anchor to be tested. Anchors will be selected so that all anchors are adequately represented. The selection is made by viewing, in the field, the portion of supports which are being qualified by the test. An anchor is selected, based on judgement, so that the various combinations of installation positions and difficulty of installation are represented during the testing program.

2.3.3 Logs the anchor against the installer (Form 2FI-129-1)

2.3.4 Issues the test report (Form 2FI-129-2) to the Field Test Engineer when required to meet the test frequency.

2.3.5 Review the test report for completeness and concurrence, and initial report.


- 2.3.6 Record Test Data on Form 2FI-129-1.
 - 2.3.7 Assemble the documentation package and forward to the designated reviewing engineer.
 - 2.4 The Field Test Engineer shall:
 - 2.4.1 Arrange for a test crew.
 - 2.4.2 Determine that there is proper access to the designated anchor.
 - 2.4.3 Visually inspect the test anchor.
 - 2.4.4 Witness the anchor test.
 - 2.4.5 Complete the test report, sign it and return it to the E.A.C. Engineer.
 - 2.4.6 Should a test anchor fail, he shall initiate and complete the failed expansion anchor report (Form 2FI-129-3) covering additional tests and retests after reinstallation. He shall also prepare an NCR should it be required.
 - 2.4.7 Perform Installer Qualifications
 - 2.5 The Review Engineer shall review the documentation package for completeness. When he is satisfied that the package is complete, he shall initial it and turn the package over to Q.C.
- 3.0 Acceptable anchors used on this project shall be limited to those listed below:
- 3.1 Wej-it Stud Anchor
 - 3.2 Phillip Wedge or Stud Anchor

100
408 ~~000~~

- 3.3 Phillip Self-drilling Snap-off or Flush Type Shell Anchor.
- 3.4 Hilti Kwik-Bolts Stud Anchor.
- 4.0 Installation procedures for each of the above listed anchor types are found in Appendix B. These procedures shall be followed for all anchor installations. Should any deviation be required, prior written approval shall be obtained through the Discipline Field Engineer to the Reviewing Engineer.
- 5.0 Inspection, testing, qualification and documentation.
- 5.1 Inspection shall be by the Discipline Field Engineer per Spec. C-2305.
- 5.2 Testing, retesting and repair of anchors shall be per the requirements of the Spec. C-2305 and test procedures in Appendix G.
- 5.3 Installer Qualification Procedure is included as Appendix C utilizing Form 2FI-129-4. (Completed forms shall be kept in the Q.C. vault.)
- 5.4 Documentation - Each package shall include following forms:
- 5.4.1 Test Inspection Report (Form 2FI-129-2)
- 5.4.2 Expansion Anchor Bolt Installers Status Report (Form 2FI-129-1)
- 5.4.3 Failed Anchor Test Report - as required (Form 2FI-129-3)

- 6.0 Operational flow shall be as outlined on the Data and Document Flow Diagram (next sheet).
- 7.0 Retro-fit testing of anchors shall be by SFHO directive incorporated as Appendix D.
- 8.0 Time Schedule to put C-2305 and this FI into affect shall be as follows:
 - 8.1 Installer qualifications may begin on FI issue date.
 - 8.2 Full program initiation shall commence four weeks after FI issue date. All anchors installed prior to full program initiation shall be retro-fit.


DATA AND DOCUMENT FLOW



APPENDICES INDEX

- A. Organization Chart
- B. Installation Procedures
 - 1. Phillips Flush Type
 - 2. Phillips Self-Drilling Snap-Off Type
 - 3. Phillips Wedge Anchor
 - 4. Wej-it Stud Anchor
 - 5. Hilti's Kwik-Bolt Stud Anchor
- C. Installers Qualification Procedure
- D. Retro-Fit Directive
 - 1. E. H. Smith's Memo FM-2-1091
 - 2. E. H. Smith's Memo FM-2-1200
 - 3. E. H. Smith's Memo FM-2-2749
- E. Forms
 - 1. 2FI-129-1 Installers Status Report
 - 2. 2FI-129-2 Anchor Test Report
 - 3. 2FI-129-3 Failed Expansion Anchor Report
 - 4. 2FI-129-4 Installer Qualification Record
- F. Rubber Stamp
- G. Test Procedures
 - 1. Torque Wrench Test Procedure
 - 2. Tension Test Procedure

APPENDIX A
ORGANIZATION CHART




APPENDIX B

EXPANSION ANCHOR INSTALLATION PROCEDURE

1. Anchor Type - Phillips Flush Type
2. Anchor Dia. - 3/8" through 7/8"
3. Installation requirements (per C-2305, Table I)



Anchor Dia. Inches	Tightening Torque FT-LB	Minimum Embedment Inches	Minimum	
			C to C Spacing Inches	Edge Dist. Inches
Concrete Type	B, C, & E	D	Below	
3/8	-25	25- 35	3-3/4	1-7/8
1/2	45 - 55	55- 65	5	2-1/2
5/8	80 - 85	85- 90	6-1/4	3-1/8
3/4	125 - 150	150-175	7-1/2	3-3/4
7/8	200 - 210	210-250	8-3/4	4-3/8



(1) Drill hole with quality carbide tipped bit having 130° or greater tip angle using rotary impact hammer. Hole depth should not exceed anchor length more than 1/8".

(2) Clean all cuttings from the hole.

(3) Place red plug into anchor and insert in hole. Expand until flush or slightly below flush with hand hammer using tool provided or high-strength bolt threaded into the anchor.



408 106

100	9-11-75	17	No Change				
AS	7-23-75	Issued for Construction					
NO.	DATE	REVISIONS		BY	DESIGN CIVIL OFFICE CHIEF	PROD. ELEC. STRUCT. MATERIALS	APPR. CIVIL ELEC. STRUCT. MATERIALS
SCALE		DESIGNED	DRAWN				
ORIGIN		ARKANSAS POWER & LIGHT CO.			JOB NO. 6600 - 2		
		ARKANSAS NUCLEAR ONE			DRAWING NO.		
		UNIT TWO			2FI-129		
					REV.		
					Appen. B		

EXPANSION ANCHOR INSTALLATION PROCEDURE




1. Anchor Type - Phillips self-drilling snap-off type
2. Anchor Dia. - 3/8 through 7/8"
3. Installation requirements (per C-2305, Table I)

Anchor Dia. Inches	Tightening Torque FT-LB	D	Minimum Embedment Inches	Minimum C to C Spacing Inches	Minimum Edge Dist. Inches
			Inches	Inches	Inches
Concrete Type B,C,&E		D			
3/8	-25	25- 35		3-3/4	1-7/8
1/2	45-55	55- 65		5	2-1/2
5/8	80-85	85- 90		6-1/4	3-1/8
3/4	125-150	150-175		7-1/2	3-3/4
7/8	200-210	210-250		8-3/4	4-3/8

(1) Drill with anchor using 747 Roto Stop Hammer or Impact Hammer with appropriate chuck assembly until face of chuck is within 1/16" from surface of concrete. Withdraw anchor from hole and expel cuttings.

(2) Holes drilled with S-58 (5/8") or larger anchors may have a piece of concrete core in bottom which should be broken up with a star-drill, chisel or other tool. Clean all cuttings from the hole.

(3) Place red plug into anchor end and insert anchor in hole. Expand with impact hammer without rotation until top of anchor is approximately 1/16" below surface of concrete. If necessary, use hand driver to fully expand anchor.





ES	3-11-74-77	in charge					
DATE	7-23-75	Issued for Construction					
SCALE	DESIGNED	DRAWN	BY	CHK	DESIGN SUPERV OFFICE CHIEF	EDITE REVIEW APPRO CHIEF	
ORIGIN	ARKANSAS POWER & LIGHT CO.	ARKANSAS NUCLEAR ONE			JOB NO. 6600 - 2	DRAWING NO.	REV.
		UNIT TWO					
					2FI-129		5
					Appen. B - 2		

EXPANSION ANCHOR INSTALLATION PROCEDURE

1. Anchor Type - Phillips Wedge Anchor
2. Anchor Dia. 3/8" through 1 1/4"
3. Installation requirements (per C-2305, Table I)

Anchor Dia. Inches	Tightening Torque FT-LB	D	Minimum Embedment Inches	Minimum	
				C to C Spacing Inches	Edge Dist. Inches
Concrete Type	B, C, & E	D			
3/8	- 25	25- 35	2	3-3/4	1-7/8
1/2	45- 55	55- 65	2-1/2	5	2-1/2
5/8	80- 85	85- 90	3	6-1/4	3-1/8
3/4	125-150	150-175	3-1/2	7-1/2	3-3/4
1	250-275	275-300	4-1/2	10	5
1-1/4	400-450	450-500	5-1/2	12-1/2	6-1/4

(1) Drill hole through work (if desirable) with quality carbide-tipped bit using hammer drill (1/4" - 3/8" sizes) or rotary impact hammer (1/2" - 1-1/4" sizes). Hole should not exceed nominal diameter by more than 5% for smaller sizes to 3% for larger sizes. Hole depth should be greater than anchor embedment to accommodate cuttings or hole must be cleaned.



(2) Assemble washer and nut as shown at (A) to protect threads from damage. Drive into hole until washer bears against work. Tighten anchor to recommended torque to expand as shown at (B).

408 108

1	18-11-1974	No Change	1	1	1	1
2	7-23-75	Issue for Construction	2	2	2	2
3	DATE	REVISIONS	4	4	4	4
5	SCALE	DESIGNED	6	DRAWN	7	8
6	ORIGIN	ARMENAS POWER & LIGHT CO.	7	ORIGIN	10	11
7	APPROVED	ARMENAS NUCLEAR ONE	8	CHIEF	11	12
8	CHIEF	UNIT TWO	9	CHIEF	12	13
9	JOB NO.	6500 - 2	10	CHIEF	13	14
10	DRAWING NO.	2FI- 129	11	CHIEF	14	15
11	APPENDIX B	3	12	CHIEF	15	16

EXPANSION ANCHOR INSTALLATION PROCEDURE

1. Anchor Type - Wej-it Stud Anchor
2. Anchor Dia. - 3/8" through 1-1/2"
3. Installation requirements (per C-2305, Table I)




Anchor Dia. Inches	Tightening Torque FT-LB	D	Minimum Embedment Inches	Minimum	
				C to C Spacing Inches	Edge Dist. Inches
Concrete Type	B, C, & E	D			
3/8	- 25	25- 35	2	3-3/4	1-7/8
1/2	45- 55	55- 65	2-1/2	5	2-1/2
5/8	80- 85	85- 90	3	6-1/4	3-1/8
3/4	125-150	150-175	3-1/2	7-1/2	3-3/4
7/8	200-210	210-250	4	8-3/4	4-3/8
1	250-275	275-300	4-1/2	10	5
1-1/8	310-340	340-380	5-1/2	11-1/4	5-5/8
1-1/4	400-450	450-500	5-1/2	12-1/2	6-1/4
1-1/2	675-750	750-800	6	15	7-1/2

4. Hole Drilling - Carbide drill - same size as anchor using rotary impact hammer.
5. The hole shall be dry and blown free from all cuttings.
6. The anchor shall be free from oil and all other detrimental coatings.
7. The anchor shall be expanded per manufacturers recommendation and tightened against the fixture as required in the table above.

408 109

REF	S-1/3-75	Re-Change					
DA	7-23-75	Issued for Construction					
NS	DATE	REVISIONS	BY	CHK	DESIGN	STRUCT	APPROV
SCALE		DESIGNED	DRAWN		OFFICE		
ORIGIN		ARKANSAS POWER & LIGHT CO.			CHIEF		CHIEF
		ARKANSAS NUCLEAR ONE					
		UNIT TWO					
					JOB NO.	6600 - 2	
					DRAWING NO.		REV.
					2FI-129		5
					L-Appen. B	4	

1. Anchor Type - Hilti KWIK-Bolt Anchor
2. Anchor Dia. 3/8" thru 1-1/4"
3. Installation requirements (per C-2305, Table I)



DRILL — Simply drill a hole the same diameter as the KWIK-BOLT. Don't worry about drilling too deep — KWIK-BOLT works in a "bottomless" hole. You can drill into concrete with or without the fixture in place.

INSERT — Drive the KWIK-BOLT far enough into the hole so that at least six threads are below the top surface of the fixture.

ANCHOR — Merely tighten the nut. Resistance will increase rapidly after the third or fourth turn.

Anchor Dia. Inches	Tightening Torque FT-LB	Minimum Embedment Inches	Minimum	
			C to C Spacing Inches	Edge Dist. Inches
Concrete Type				
B, C, & E	D			
3/8"	- 25	25- 35	2-3/4	3-3/4
1/2"	45- 55	55- 65	3-1/2	5
5/8"	80- 95	85- 90	4-1/2	6-1/4
3/4"	125-150	150-175	5	7-1/2
1"	250-275	275-300	6-1/2	10
1-1/4"	400-450	450-500	8	12-1/2

4. Hole Drilling - Carbide drill - same size as anchor using rotary impact hammer.

5. The hole shall be dry and blown free from all cuttings.
6. The anchor shall be free from oil and all other detrimental coatings.
7. The anchor shall be expanded per manufacturers recommendation and tightened against the fixture as required in the table above.

<i>AS 5-15-22747 Rev. C changes</i>							<i>DR</i>
7-24-75 Issue for Construction							
DATE	REVISIONS		NY	LIVE	EXPIRED	LEAD	LEAD
7-24-75							
SCALE	DESIGNED	DRAWN					
1/2" x 1/2"							
ARKANSAS POWER & LIGHT CO.		DRAWING NO. 6600 - 2					
ARKANSAS NUCLEAR ONE		DRAWING NO.					
UNIT TWO		2FI-129				5	
		SHEET APPEND. B - 3					

APPENDIX C

CONCRETE EXPANSION ANCHOR INSTALLER QUALIFICATION
PROCEDURE

- 1.0 Procedure for qualification of installer of concrete expansion type shell or stud anchors per Specification C-2305. Installer qualification under this procedure is required for Class I and Non-Class I Anchor Installations.
- 2.0 Prior to the installation of production Concrete Expansion Anchors, the installer shall be qualified under this procedure in the presence of the Field Test Engineer. 
- 3.0 Test Anchors may be production anchors or anchors installed in a test block at the Field Test Engineer's discretion.
- 4.0 The installer shall install two (2) anchors of the type, size and position most frequently installed by applicants craft and one (1) anchor of the type, size, and position specified by the testing engineer.
- 5.0 Acceptance criteria of qualification test anchors shall be in accordance with Specification C-2305, Section 5.3.
- 6.0 Should any of the three (3) anchors in 4.0 fail acceptance, the qualification test may be repeated. The applicant will be allowed three (3) tests in any twelve (12) month period beginning on date of first test. Should an applicant fail to qualify, he will not be allowed to install any Class I or Non Class I anchors.
-  7.0 Qualification Record shall be kept on file in the Q. C. Vault. The document (Form ZFI-129-4) shall be completely filled out, dated and signed by testing engineer.  "C" Sht. 1 of 2

3.0 An installer qualified under this procedure shall be eligible to install any type of anchor for duration of project unless it has been found during production testing that two (2) anchors failed testing out of any one anchor group. An installer shall be re-qualified if his inactivity exceeds twelve (12) months.

408 112

Bechtel Power Corporation

Interoffice Memorandum

To L. E. Davis

File No. C-2305

Subject Arkansas Nuclear One - Unit 2
Job 6600-002 - Installation of
Concrete Expansion Type Anchors.

Date February 24, 1975

From E. H. Smith

~~RECORDED~~

San Francisco Division

Log: FM-2-1091

to

MAR 3 1975

at

MET 29/A19

Ex. 4418

Copies to G. Katanics
W. Ginn
K. LamBECHTEL POWER CORPORATION
6600

Reference: Refer to your IOM FME-2-883 and FME-2-888.

Your comments in IOM FME-2-883 and FME-2-888 have in general been adopted, except that on item 4.1 in both memos. We strongly feel that a qualified installer is also required to install expansion anchors on non-class I supports. As you know, workmanship is the major factor for the performance of expansion bolts. In order to avoid a similar failure as encountered on Unit One, we feel upgrading of the installation is essential.

The following directive concerning testing shall be applied to the expansion anchors already installed:

- 1.0 Specification 6600-C-2305 shall be the controlling document except as noted otherwise in the following items.
- 2.0 Application is to be per Section 2.0. (Anchors installed for section 2.1.5 and for which documentation is available need not be retested. Engineering shall be apprised of any instance where this has not been done for evaluation).
*in group 14
check 14
see 14
all test*
- 3.0 Installation is to be per Section 4.0, exception in 4.1, the installer's qualification is not required.
- 4.0 Groups of anchors shall be determined by room location and the application per Section 2.1.1 through 2.1.4.
- 5.0 Inspection and testing is to be per Section 5.0 except in 5.4, the identification of the installer related to the group of anchor is not required and test groups shall be as defined in item 4.0 above. The last sentence in 5.4.4 is not applicable.

408 113

2FI-129, Rev. 5
"D" Sht. 1 of 4

L. E. Davis
(File: C-2305)

February 24, 1975
Page 2

6.0 Documentation required.

6.1 Test Inspection Report

- 6.1.1 Inspector's Name
- 6.1.2 General Location
- 6.1.3 Test Result

6.2 Failed Anchor Test Report

- 6.2.1 Inspector's Name
- 6.2.2 Exact Location of Tested Anchor
- 6.2.3 Installer's Name → *cannot identify*
- 6.2.4 Repair Steps Taken

deleted
4-17-75
4m - 2 - 1200

E. H. Smith
E. H. Smith

KL:rg

408 114

2FI-129, Rev. 5
"D" Sht. 2 of 4

Bechtel Power Corporation

Intercifice Memorandum

To L. E. Davis *L.E.D.* *R.P.* File No. C-2305
Subject Arkansas Nuclear One - Unit 2 Date April 17, 1975
Job 6600-2-Installation of From E. H. Smith
Concrete Expansion Type Anchors
LOG: FM-2-1200 To San Francisco Division
or

Copies to W. Ginn At MET 29/A19 Ext 1846
P. Verrios
K. Lam

References: (a) FME-2-956, dated March 21, 1975.
(b) FM-2-1091, dated February 24, 1975.

The concrete expansion anchor installer qualification procedure attached with Reference (a) is approved without comment.

Revision 3 of Specification 6600-C-2305 is presently being prepared and will be issued in the very near future. This revision eliminates excessive slippage as an anchor failure mode and allows the production anchors to be utilized as the test anchor as an alternate to the use of test blocks.

We hereby delete Item 6.2.3 "Installers Name" from the directive for acceptance of existing anchors which was included with Reference (b).

E. H. Smith
E. H. Smith

KL:rg

Chris DeR *Bill*
E. H. Smith *Bill*
W. Ginn *Bill*
Kerry J. T. *Bill*

Bechtel Power Corporation

Interoffice Memorandum

To: L. E. Davis

File No. J-2-296, J-5800

Subject: Arkansas Nuclear One - Unit 2
Job 6600-2 - Anchor Bolts,
Corrective Action for Audit
Report QFR 2-42

Date April 15, 1977

From E. H. Smith

LOG: FM 2-2749

At San Francisco Division

Copies to:

AI MET-29-D 12 Ext. 1846

C. R. Davis
A. Nispeling
V. R. Uhouse
E. Y. Wong
A. Karadi
R. Redford (Field)

RECEIVED

APR 18 1977

BECHTEL POWER CORP.

JOB 6600

Installation drawings 6600-M2511 sheets J-G111-1 through J-G113-1 are revised to require installation of tray support mounting bolts in accordance with specification 6600-C-2305. Advance copies of the revised details are attached for your information.

Field is hereby directed to select at random, one in twenty of those anchor bolts already installed for testing in accordance with the C-2305 specification.

E. H. Smith

E. H. Smith

Attachment

Advanced copies
of drawings

WPB/icd

EXPANSION AND 2 BOLT
INSTALLERS STATUS REPORT C-2305

3. RECORD CONTROL
CONTROL NO. _____
FILE NO. _____

1. PROJECT NO. G600-2 2. DATE 10/10/2023

L. PAGE OF

19 L E E R S A V E

BRASS NO.:

ANALYSIS OF EDUCATION

DUG. NO.

TEST RESULTS

ANSWER _____

DATE _____

如图所示

FORM 2FI-129-1 REV-5

408 117 "E" SET 1 OF 2

EXPANSION ANCHOR TEST REPORT

C-2205

3. RECORD CONTROL
CONTROL NO. _____
FILE NO. _____

1. PROJECT NO. 6600-2 2. DATE

4. PAGE ____ OF ____

3. INSTALLER :

PRESS NO. :

ANCHOR NO. :

DUG. NO. :

ANCHOR ID. :

CRAFT :

EMBEDMENT :

PRODUCTION : YES NO

TYPE :

O.L.L.P. TEST : YES NO

ANCHOR SIZE :

5. LOCATION

SLOG. :

ROOM NO. :

FLOOR ELEV. :

6. TEST RESULTS

TORQUE VALUE :

TENSION VALUE :

SATISFACTORY: YES NO (EXPLAIN)

7. DRILL WRENCH

NO. :

RECALIBRATION DATE:

FIELD ENGINEER _____

DATE _____

REVIEW _____

FORM RFI-129-2 REV. 5

FAILED EXPANSION ANCHOR REPORT

6-2303

3. RECORD CONTROL
CONTROL NO. _____
FILE NO. _____

1. PROJECT NO. 60000-2 2. DATE

L: PAGE OF

W. H. STALLER.

BRASS 16.1

ANCHOR No.:

卷之三

AMERICAN LTD.

SIZE:

Failure Modes

ANCHOR FAILED DUE TO TEST

INSPECTION


EQUIFICATION TEST

COLLECTOR (EXH-MAKE SKETCH)

三

2001 No. 1

—.002 1.15



SECRETIVE ACTION

卷之二

RESULTS OF TESTS:

2. GROUP IDENTIFICATION
DELEGATION DATA

WEDNESDAY

25-13

FORM 2FI-129 - 5 REV 5

W.M. > W.M. —

CONCRETE EXPANSION ANCHOR
C-2305 INSTALLER QUALIFICATION RECORD

3. RECORD CONTROL
CONTROL NO. _____
FILE NO. _____

PROJECT NO. 6600-2 DATE 2/20/85

4. PAGE 1 OF 1

NAME JOHN D. HARRIS BRASS NO. 10000000000000000000

TEST ANCHOR 1 EMBEDMENT 1/2" TORQUE/TENSION 100 FT-LB

(1) 100 100 100 100

(2) 100 100 100 100

(3) 100 100 100 100

RETEST DATE 2/20/85 EMBEDMENT 1/2" RECALIBRATION DATE 2/20/85

TORQUE WRENCH NO. 100 TORQUE/TENSION 100 FT-LB

(1) 100 100 100 100

(2) 100 100 100 100

(3) 100 100 100 100

RETEST DATE 2/20/85 EMBEDMENT 1/2" RECALIBRATION DATE 2/20/85

RETEST DATE 2/20/85 EMBEDMENT 1/2" TORQUE/TENSION 100 FT-LB

(1) 100 100 100 100

(2) 100 100 100 100

(3) 100 100 100 100

RETEST DATE 2/20/85 EMBEDMENT 1/2" RECALIBRATION DATE 2/20/85

INSTALLER JOHN D. HARRIS DATE 2/20/85

THE ABOVE NAMED INSTALLER HAS BEEN TESTED AND
HAS PASSED ALL REQUIREMENTS.

TESTING SUPERVISOR JOHN D. HARRIS DATE 2/20/85

REVIEWED JOHN D. HARRIS

FORM 2F-1-129 - 4 REV. 5

408-120 "E" SHT. 4 OF 4

APPENDIX "F"

INSTALLERS NAME _____	BRASS NO. _____
NUMBER OF ANCHORS _____	ROOM NO. _____
TYPE ANCHOR _____	SIZE ANCHOR _____
EMBEDMENT OF STUD ANCHOR _____	
FIELD ENGINEERS SIGNATURE _____	
WORK COMPLETED IN WEEK OF _____	DATE _____

408 121

APPENDIX G

TEST PROCEDURES

1. Torque Wrench Test

- 1.1 Loosen the nut about 1/4 turn.
- 1.2 Retighten to approx. original position noting max. tightening torque. Record value on form 2FI-129-2. Do not exceed values shown in Table I, Spec. C-2305.
- 1.3 An installed expansion type anchor bolt shall be considered acceptable if a failure does not occur due to concrete breakout or anchor breakage.
- 1.4 Special instruction when testing Phillips flush type and self-drilling type anchors.
 - 1.4.1 Determine if anchor is "recessed" or "flush or projecting".
 - 1.4.2 Should the anchor be "flush or projecting", a 1/8" thick slotted washer shall be installed between the concrete surface and the fixture.
 - 1.4.3 Tighten bolt to the value shown in Table I Spec. C-2305. Record torque value on Form 2FI-129-2.

2. Tension Test Procedure

- 2.1 Flush and self-drilling type anchors where a bolt is required.

(Cont'd.)

403 122

- 2.1.1 Remove the bolt and determine if a slotted washer is required between concrete surface and fixture (see 1.5 above). Install a stud and nut. Torque the nut to the values shown on Table I, Specification C-2305.
- 2.1.2 Add a coupling nut to the stud, turning down a min. of 1 stud diameter. Screw in a pull rod (min. 1 dia.) and set tensioning device over pull rod. Secure pull rod by tightening wing nut against jack cylinder. Adjust the three legs to minimize bending in the anchor and pull rod.
- 2.1.3 Apply the tension load per Table II, Specification C-2305. Record value on Test Report.

2.2 Stud Type Anchors

- 2.2.1 Either add a coupling nut or remove existing nut and add a coupling nut depending on available free lead length (min. length is one bolt dia.). Washers may be used as required. Tighten nut to values shown on Table I, Specification C-2305. Proceed as outlined in 2.1.2 above.
An installed expansion type anchor bolt tension tested shall be considered acceptable if a failure does not occur due to concrete breakout or anchor breakage and if the

(Cont'd.)

408 123


May 20, 1977

proof load specified in Table 2 is attained.

2.4 The next sheet depicts a test set up.

408 124

"G" 3 of 4



EXPANSION ANCHOR
TENSION TEST OPERATION
SET UP

408 125

<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>	<input type="checkbox"/>
<input checked="" type="checkbox"/>	7-23-75	I	S	N	E	D	O	C	N	S	T
NO.	DATE	REVISIONS	BY	CHK	DESIGN SUPV.	ANCHR. ARCH.	PROJ. ENGR.	APPR.			
SCALE		DESIGNED	DRAWN		OFFICE CHIEF		TPO CHIEF				
ORIGIN		ARKANSAS POWER & LIGHT CO. ARKANSAS NUCLEAR ONE UNIT TWO			JOB NO.	6600 - 2					
					DRAWING NO.		REV.				
					ZFI 129		5				
					APPEND. G		A-54				
							ED 29 11-75				