

OFFICE OF INSPECTION AND ENFORCEMENT
B&W SITE INSPECTOR DAILY REPORT

Site Oconee 1, 2, 3

Date 4/16/79

Inspector(s) G. A. Belisle

B. T. Moon

General Plant Status: All three units operating at approximately full power.

1a. Review of Similar Transients (Item 2 of IEB 79-05A):

No change from April 12 report.

b. Review and Revision of Operating and Maintenance Procedures (Items 3, 4, 5, 7, 8, 9, 10 of IEB 79-05A):

No change from April 12 report.

c. Review and Implementation of Changes in Containment Isolation (Item 6 IEB 79-054A):

No change from April 12 report.

POOR ORIGINAL

d. Training of Plant Personnel (Items 1, 4, 11 and plant/procedures changes):

No change from April 12 report.

267 069

.907020108

2. SUMMARY OF NRC INSPECTION ACTIVITY DURING PERIOD 9:00a.m. 4/15 - 9:00a.m. 4/16
(Address items 1.a thru 2.d above, give other independent/significant effort, identify shifts on which activity was done during past 24 hours)
Conducted plant tour in plant vital areas including HPI, LPI, and feedwater system areas and confirmed that ESF system valve lineups are in proper order (locked open and closed, etc.)
Observed control room operation day/swing shift and nite/day shift.
Reviewed shift control operators logs.

3. STATUS OF INSPECTOR DISCUSSIONS WITH PLANT PERSONNEL:

No change from April 15 report.

4. DESCRIPTION OF GENERAL PLANT STATUS (i.e., operating power level, planned changes, scheduled outages, ESF out of service, major maintenance, reportable occurrences, etc.)

Unit 1, 100%
Unit 2, 99%
Unit 3, 100%

{ No ESF equipment out of service.
No major maintenance.

267 070

POOR ORIGINAL