



## JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cue (and terminating cue if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
     Procedure 3512.01 Rev: 14d  
     Procedure 3512.01F002 Rev: 3  
     Procedure 2208.01F001 Rev: 8
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

**Revision Record (Summary)**

<b>Revision</b>	<b>Date</b>	<b>Description</b>
00	3/6/18	New JPM.

**SIMULATOR SETUP INSTRUCTIONS**

1. No simulator setup is required for this JPM.

### **INITIAL CONDITIONS**

The plant is at rated power.

1B21-F021, Inboard MSIV Before Seat Warmup Drain Valve has a bad limit switch and is indicating OPEN on the Plant Process Computer display screen.

1B21-F021 is actually shut.

### **INITIATING CUE**

Prepare a request to change the CX/CZ database for the Point State parameter computer point B21DC005 to indicate NOT OPEN.

When complete, submit the request to the SM/CRS for review and approval.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

### **Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
CUE	Provide the examinee with the following items: <ul style="list-style-type: none"> <li>• CPS 3512.01 Plant Process Computer (PPC)</li> <li>• CPS 3512.01F002 CX/CZ Database Alteration Log (Marked Up)</li> </ul>				
*1	8.3.1.1 Enters point ID into the Database Alteration Log.	Examinee enters “B21DC005” in the Point ID field of CPS 3512.01F002. <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i>	—	—	—
*2	8.3.1.1 Enters desired parameter to change into the Database Alteration Log.	Examinee enters “1B21-F021 position” in the Parameter field of CPS 3512.01F002. <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i>	—	—	—
*3	8.3.1.1 Enters original condition of the parameter into the Database Alteration Log.	Examinee enters “Open and/or On” in the Original Condition field of CPS 3512.01F002. <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i>	—	—	—
*4	8.3.1.1 Enters modified condition of the parameter into the Database Alteration Log.	Examinee enters “Not Open and/or Off” in the Modified Condition field of CPS 3512.01F002. <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i>	—	—	—
*5	8.3.1.1 Enters reason for the change into the Database Alteration Log.	Examinee enters “To make PPC indicate the actual valve position” in the Reason field of CPS 3512.01F002. <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i>	—	—	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
6	8.3.1.1 Enters a duration after which removal/ restoration is required into the Database Alteration Log.	Examinee enters "Until limit switch problem is corrected" in the Necessary Duration field of CPS 3512.01F002. <i>Evaluator Cue – If asked, limit switch replacement is scoped into the next refueling outage.</i> <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i>	—	—	—
7	8.3.1.2 Makes required notifications to the SM and CRS.	Examinee enters "NA" in the notification initial blank. <i>Evaluator Note – Notification is only required if the point being altered is used in the reactor heat balance calculation.</i> <i>Evaluator Note – Any similar terminology entered by the examinee is acceptable.</i> <i>Evaluator Note – The examinee may or may not refer to CPS 2208.01F001 to determine that computer point B21DC005 is not used in the reactor heat balance calculation.</i>			
8	8.3.1.3 Obtain SM/CRS approval.	Examinee submits completed CPS 3512.01F002 CX/CZ Database Alteration Log to the examiner.			
CUE	Cue the examinee that the JPM is complete.				

 JPM Stop Time: \_\_\_\_\_
   
 .....

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_ **Emp. ID#:** \_\_\_\_\_**Job Title:**  EO  RO  SRO  FS  STA/IA  SRO CertJPM Title: Prepare A Request To Alter The CX/CZ DatabaseJPM Number: JPM423 Revision Number: 00Task Number and Title: 351201.43 Obtain Approval and Alter the PPC Database.K/A Number and Importance: 2.1.20 / RO (4.6), SRO (4.6)Suggested Testing Environment: ClassroomAlternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s):

- CPS 3512.01 Plant Processing Computer, Rev. 14d
- CPS 3512.01F002 CX/CZ Database Alteration Log, Rev. 3
- CPS 2208.01F001 Core Thermal Power Determination, Rev. 8

**Actual Testing Environment:**  Simulator  Control Room  In-Plant  Other**Testing Method:**  Simulate  PerformEstimated Time to Complete: 10 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?  Yes  NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory**Comments:** \_\_\_\_\_

---

---

---

---

---

---

---

---

---

---

**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_



CX/CZ DATABASE ALTERATION LOG

Page: \_\_\_\_\_

ALT. NO.: 0931POINT ID: B21DC005

DESCRIPTION: \_\_\_\_\_

PARAMETER: B21-F021 positionORIGINAL CONDITION: OpenMODIFIED CONDITION: Not OpenREASON: To make PPC indicate the actual valve position.NECESSARY DURATION: until limit switch problem is corrected.

c Notify both the SM and CRS if the point being altered is used in the reactor heat balance calculations.

N/A  
INITIAL

### **INITIAL CONDITIONS**

The plant is at rated power.

1B21-F021, Inboard MSIV Before Seat Warmup Drain Valve has a bad limit switch and is indicating OPEN on the Plant Process Computer display screen.

1B21-F021 is actually shut.

### **INITIATING CUE**

Prepare a request to change the CX/CZ database for the Point State parameter computer point B21DC005 to indicate NOT OPEN.

When complete, submit the request to the SM/CRS for review and approval.

---

**CX/CZ DATABASE ALTERATION LOG**

---

**SCOPE OF REVISION:**

- LAN format update. No technical changes.
- No revision marks used.

• ITR: M. HUDSON

***CONTINUOUS USE***

---

ORIGINATOR: *Thomas J. Landin*

CLASS CODE: *NNND1*

APPROVAL  
DATE:

*NOV 08 1998*

---

<i>CHANGE NO.</i>	<i>DATE</i>	<i>PAGES</i>
① _____	_____	_____
② _____	_____	_____
③ _____	_____	_____

4			
5			

CX/CZ DATABASE ALTERATION LOG

ALT. NO.: 0931

POINT ID: BZ1DC005

DESCRIPTION: \_\_\_\_\_

PARAMETER: BZ1-F0Z1 position

ORIGINAL CONDITION: Open

MODIFIED CONDITION: Not Open

REASON: To make PPC indicate the actual valve position.

NECESSARY DURATION: until limit switch problem is corrected.

c Notify both the SM and CRS if the point being altered is used in the reactor heat balance calculations.

N/A  
INITIAL

<u>INSTALLATION</u>	<u>Initial/Date</u>	<u>RESTORATION</u>	<u>Initial/Date</u>
SM/CRS:	____ / ____	RESTORED BY:	____ / ____
INSTALLED BY:	____ / ____	cINDEPENDENTLY VERIFIED BY:	____ / ____
cINDEPENDENTLY VERIFIED BY:	____ / ____	SM/CRS:	____ / ____



## JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cue (and terminating cue if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
     Procedure 9820.01 Rev: 34  
     Procedure 9820.01D001 Rev: 32e  
     Procedure WC-AA-111 Rev: 5
- \_\_\_\_\_ 10. Procedure WC-AA-111-F-01 Rev: 0
- \_\_\_\_\_ 11. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 12. Verify performance time is accurate
- \_\_\_\_\_ 13. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 14. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

**Revision Record (Summary)**

<b>Revision</b>	<b>Date</b>	<b>Description</b>
00	4/5/18	New JPM.



### **SIMULATOR SETUP INSTRUCTIONS**

1. This JPM can be performed in a classroom or other secure area with the 3D cases generated per step 2.
2. The following can be used as necessary to recreate the 3D Case printouts with out of spec MFLCPR and MFLPD:
  - a. Initialize to a full power IC.
  - b. Insert Malfunction M3D\_FLCPR\_V\_10 to a final value of 1.012 to raise MFLCPR for fuel assembly 21-18 to a value greater than 1.0.
  - c. Insert Malfunction M3D\_FLPD\_V\_2 to a final value of 1.083 to raise MFLPD for fuel assembly 23-32 to a value greater than 1.0.
  - d. Print out a 3D case.
  - e. Verify MFLCPR and MFLPD are > 1.0.
3. Freeze Simulator.

### **INITIAL CONDITIONS**

You are the 'B' RO.

The plant is at full power with RR Pumps A and B operating in fast speed.

### **INITIATING CUE**

The Control Room Supervisor directs you to perform the daily surveillance CPS 9820.01, Power Distribution Limits.

Report to the CRS after completing the task.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

#### **Information For Evaluator's Use:**

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM.

Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

.....

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
CUE	Provide the examinee with the following items: <ul style="list-style-type: none"> <li>• CPS 9820.01 Power Distribution Limits</li> <li>• CPS 9820.01D001 Power Distribution Limits Data Sheet</li> <li>• WC-AA-111 Surveillance Program Requirements Attachment 11 Initial Sheet</li> <li>• WC-AA-111-F-01 Surveillance WO Disposition (Shift Authorization to Start Work filled in)</li> <li>• Attachment 1 – 3D Case pages 1 &amp; 2.</li> </ul>				
Evaluator Note – For the following steps, refer to CPS 9820.01D001 Answer Key on JPM pages 11 and 12.					
1	Completes CPS 9820.01 Prerequisites.	Notifies SMngt. Enters start date, start time, and initials CPS 9820.01D001, Power Distribution Limits Data Sheet step 5.1.  <i>Evaluator Note – Per the initiating cue, the reactor is operating at full power.</i>  <i>Evaluator Cue – Acknowledge notification as SMngt.</i>	_____	_____	_____
		Verifies Core Thermal Power is $\geq 21.6\%$ of RTP and initials CPS 9820.01D001, Power Distribution Limits Data Sheet step 5.2.  <i>Evaluator Note – Per the initiating cue, the reactor is operating at full power.</i>	_____	_____	_____

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1 (cont.)	Completes CPS 9820.01 Prerequisites. (cont.)	Determines that the applicable entry condition is Daily Surveillance and checks the “Daily Surveillance” box on CPS 9820.01D001, Power Distribution Limits Data Sheet step 5.3.  <i>Evaluator Note – Per the initiating cue, the entry condition is “Daily Surveillance”.</i>	—	—	—
		Determines that the second character of the 3D CASE ID is 'M' and initials CPS 9820.01D001, Power Distribution Limits Data Sheet step 5.4.  <i>Evaluator Note – The case ID number appears in the upper right hand corner of the 3D case on page 1, below the date.</i>	—	—	—
		Determines “2 RR pumps are in operation and checks box on CPS 9820.01D001, Power Distribution Limits Data Sheet step 5.5.  <i>Evaluator Note – RR Pump status is provided in the initiating cue.</i>	—	—	—
		Reviews the 3D Case and checks boxes for ARTS, 2 LOOPS ON, and MANUAL FLOW on CPS 9820.01D001, Power Distribution Limits Data Sheet step 5.6.  <i>Evaluator Note – This information is located to the right of OPTION on the 3D Case.</i>	—	—	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
1 (cont.)	Completes CPS 9820.01 Prerequisites. (cont.)	<p>Determines that core flow is accurate and CPS 9820.01, Power Distribution Limits step 5.7 is "N/A".</p> <p><i>Evaluator Cue – If the examinee asks the SRO if core flow is accurate, cue him/her that core flow instrumentation is operating normally.</i></p>	—	—	—
2	Determines highest MAPRAT value.	<p>Determines the highest MAPRAT value is <math>\leq 1.0</math>. Initials CPS 9820.01D001, Power Distribution Limits Data Sheet step 8.2.</p>	—	—	—
*3	Determines the highest MFLCPR value.	<p>Determines that the highest value of MFLCPR is <math>&gt;1.0</math> and does <b>NOT</b> initial CPS 9820.01D001, Power Distribution Limits Data Sheet. Documents out of specification value in the Comments/Deficiencies section of 9820.01D001.</p> <p><i>Evaluator Cue – If examinee reports MFLCPR value is <math>&gt; 1.0</math>, acknowledge the report and then cue him/her to complete the surveillance.</i></p> <p><i>Evaluator Note – One location will have a MFLCPR value <math>&gt; 1.0</math> (21-18). May insert a note documenting what was observed.</i></p>	—	—	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*4	Determines the highest MFLPD value.	<p>Determines that the highest value of MFLPD is &gt;1.0 and does <b>NOT</b> initial CPS 9820.01D001, Power Distribution Limits Data Sheet. Documents out of specification value in the Comments/Deficiencies section of 9820.01D001.</p> <p><i>Evaluator Cue – If examinee reports MFLPD value is &gt; 1.0, acknowledge the report and then cue him/her to complete the surveillance.</i></p> <p><i>Evaluator Note – One location has MFLPD value &gt; 1.0 (23-32). May insert a note documenting what was observed.</i></p>	—	—	—
*5	Notifies SMngt of OOS conditions.	<p>Notifies Shift Management that MFLCPR and MFLPD are out of specification.</p> <p><i>Evaluator Cue – Acknowledge notification. If earlier 3D printouts are requested state the previous 3D cases are within limits.</i></p>	—	—	—
6	Notifies SMngt of surveillance completion.	<p>Notifies Shift Management of surveillance completion. Enters stop date, stop time, and initials CPS 9820.01D001, Power Distribution Limits Data Sheet.</p>	—	—	—
7	Attaches 3D Case to CPS 9820.01D001.	<p>Attaches a signed, dated, labeled copy of the 3D Case used to CPS 9820.01D001, Power Distribution Limits Data Sheet.</p>	—	—	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	<u>SAT</u>	<u>UNSAT</u>	<u>Comment Number</u>
8	Completes WC-AA-111-F-01.	Examinee records the following information in WC-AA-111-F-01: <ul style="list-style-type: none"> <li>• Work Started – enters Name, Date, and Time</li> <li>• Work Stopped – enters Name, Date, and Time</li> <li>• Surveillance Found Within Acceptance Criteria – circles NO</li> </ul>	—	—	—
9	Completes WC-AA-111 Attachment 11.	Examinee records the following information in WC-AA-111 Attachment 11: <ul style="list-style-type: none"> <li>• Procedure No. – 9820.01 or 9820.01D001</li> <li>• Enters printed Name and Initial</li> </ul>	—	—	—

<b>CUE</b>	Cue the examinee that the JPM is complete.
------------	--

JPM Stop Time: \_\_\_\_\_  
 .....

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_ **Emp. ID#:** \_\_\_\_\_**Job Title:**  EO  RO  SRO  FS  STA/IA  SRO CertJPM Title: Perform CPS 9820.01 Core Thermal LimitsJPM Number: JPM402Revision Number: 00Task Number and Title: 982001.01 / Evaluate Core Thermal Limits during Power OperationsK/A Number and Importance: 2.1.19 / RO (3.9), SRO (3.8)Suggested Testing Environment: ClassroomAlternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s):

- CPS 9820.01, Power Distribution Limits, Rev. 34
- CPS 9820.01D001, Power Distribution Limits Data Sheet, Rev. 32e
- WC-AA-111 Surveillance Program Requirements, Rev. 5
- WC-AA-111-F-01 Surveillance WO Disposition Sheet, Rev. 0

**Actual Testing Environment:**  Simulator  Control Room  In-Plant  Other**Testing Method:**  Simulate  PerformEstimated Time to Complete: 15 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?  Yes  NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_



# 9820.01D001 ANSWER KEY

**POWER DISTRIBUTION LIMITS DATA SHEET**

Initial

5.1 SMngt notification. Date xx/xx/xxxx Time xxxx

RO

5.2 Verify Core Thermal Power  $\geq$  21.6% RTP.

RO

5.3 Check the applicable entry condition:

Daily surveillance (at least once per 24 hours)

Within 12 hours after  $\geq$  21.6% RTP

Within 24 hours of entering single loop RR operations

Other (explain) \_\_\_\_\_

5.4 Verify 2nd character of 3D CASE ID is an "M".

RO

5.5  2 RR pumps in operation  
 1 RR pump in operation

5.6  ARTS  
 2 LOOPS ON  
 MANUAL FLOW  
 1 LOOP ON

Step(s)	Parameter	Admin Limit (3005.01)	Acceptable Value (ITS)	Initial
8.2	MAPRAT	$\leq 0.98$	$\leq 1.0$	RO
8.3	MFLCPR	$\leq 0.98$	$\leq 1.0$	Note 1
8.4	MFLPD	$\leq 0.98$	$\leq 1.0$	Note 2

8.6 Inform SMngt of surveillance completion

Date xxxx/xxxx Time xxxx

RO

**Corrective Action Taken**

Operability Requirements:

ITS LCOs: 3.2.1    3.2.2    3.2.3  
 ORM ORs: None    ODCM ORs: None

As applicable:

Initiated Condition Report No. \_\_\_\_\_  
 Initiated Work Document No. \_\_\_\_\_

**Comments/Deficiencies**

Note 1: MFLCPR 1.012 and greater than 1.0 (or equivalent)

Note 2: MFLPD 1.083 and greater than 1.0 (or equivalent)

**Review and Approval**

SMngt Review: \_\_\_\_\_ (Signature) \_\_\_\_\_ (Date)

## 9820.01D001 ANSWER KEY

**Attachment 1 – 3D Case (Page 1)**

FOR TRAINING USE ONLY

PAGE 1

CORE PARAMETERS			CLINTON CYCLE 18	SEQUENCE NO 10
POWER MWT	3401.		3D MONICORE	XX-XXX-2018 13:47 CALCULATED
POWER MWE	1113.		PERIODIC LOG	XX-XXX-2018 13:48 PRINTED
FLOW MLB/HR	84.228		CALC RESULTS	CASE ID FMLD1180410134733
FPAPDR	*****			RESTART FMLD1180410134733
SUBC BTU/LB	29.98		Keff	LPRM SHAPE - FULL CORE
PR PSIA	1038.0		XE WORTH %	LOAD LINE SUMMARY
CORE MWD/ST	21573.8		XE/RATED	CORE POWER
CYCLE MWD/ST	9000.0		AVE VF	CORE FLOW
MCPR	1.326		FLLLP	LOAD LINE
				97.9%
				99.7%
				98.1%

CORRECTION FACTOR: MFLCPR= 1.024 MFLPD= 0.990 MAPRAT= 0.990  
 OPTION: ARTS 2 LOOPS ON MANUAL FLOW MCPRLIM= 1.310

**MOST LIMITING LOCATIONS (NON-SYMMETRIC)**

MFLCPR	LOC	MFLPD	LOC	MAPRAT	LOC	PCMARG	LOC
1.012	21-18	1.083	23-32- 4	0.751	17-40- 2	0.100	21-18
0.831	15-40	0.876	17-40- 2	0.750	41-18- 1	0.080	15-40
0.829	41-16	0.876	15-42- 2	0.746	39-40- 2	0.065	41-16
0.825	41-40	0.875	41-18- 3	0.739	17-16- 3	0.048	41-40
0.818	15-18	0.874	15-42- 1	0.732	19-46- 2	0.033	15-18
0.810	19-46	0.873	15-40- 2	0.731	43-36- 2	0.028	19-46
0.809	45-38	0.873	17-42- 2	0.729	37-14- 3	0.020	45-38
0.807	37-12	0.872	39-18- 1	0.726	13-20- 1	0.010	37-12
0.803	11-22	0.871	39-16- 3	0.716	11-36- 1	0.000	11-22
0.793	11-36	0.870	41-16- 2	0.714	25-50- 2	-0.010	11-36

SEQ. A-2	C=MFLCPR	D=MFLPD	M=MAPRAT	P=PCRAT	*=MULTIPLE	CORE AVE	AXIAL
53		12				NOTCH REL PW	LOC
						0.417	25
49						00 0.695	24
L						02 0.787	23
45		22		16		04 0.879	22
						06 0.924	21
41						08 0.948	20
L		M				10 0.971	19
37	16			22		12 0.995	18
						14 1.008	17
33						16 1.020	16
L		D				18 1.033	15
29 12					12	20 1.035	14
						22 1.037	13
25						24 1.039	12
L						26 1.077	11
21	22			16		28 1.114	10
						30 1.152	09
17		C				32 1.209	08
L						34 1.267	07
13	16			22		36 1.325	06
						38 1.304	05
09						40 1.284	04
L						42 1.287	03
05			12			44 0.912	02
	L	L	L	L	L	46 0.281	01
	04	08	12	16	20		
			24	28	32		
				36	40		
					44		
					48		
					52		

**CORE AVERAGE RADIAL POWER DISTRIBUTION**

RING #	1	2	3	4	5	6	7
REL PW	0.932	1.128	1.202	1.090	1.192	1.089	0.596

SRRS: 3D.100; There are no retention requirements for this section

**Attachment 1 – 3D Case (Page 2)**

FOR TRAINING USE ONLY

PAGE 2

 CLINTON CYCLE 18 INSTRUMENT READINGS/STATUS  
 CALIBRATED LPRM READINGS

 SEQUENCE NO 10  
 XX-XXX-2018 13:47 CALCULATED  
 XX-XXX-2018 13:48 PRINTED  
 CASE ID FMLD1180410134733  
 LPRM SHAPE - FULL CORE

47D	29.9	43.8	46.1	41.7	17.8
C	31.3	43.3	44.3	40.9	18.1
B	31.2	40.7	45.6	44.4	18.0
A	30.7	43.4	42.4	42.9	15.9

39D	27.4	48.9	50.0	52.1	53.1	40.9
C	28.2	45.4	43.4	41.4	46.7	40.5
B	29.5	47.8	41.1	39.2	46.0	38.2
A	27.4	44.9M	34.7	30.4	41.5	41.8

31D	36.6	49.9	55.9	53.7	53.3	46.8
C	36.4	40.7	45.8	44.3	41.3	44.0
B	37.3	40.1	42.6	40.3	38.9	44.1
A	34.0	34.3	31.5D	27.6	30.5	42.1

23D	33.9	50.4	57.4	55.0	53.8	46.8
C	33.8	42.4	47.3	46.0	44.0	44.1
B	33.8	38.5	45.0	42.8	42.7	47.5
A	33.0	38.5	35.7	31.6	35.1	44.9

15D	16.5	42.4	C50.8	45.7	47.2	30.9
C	16.6	42.3	42.5	40.3	45.7	32.2
B	16.2	43.3	44.2	38.8	42.8	33.4
A	14.9	42.9	39.2	34.0	44.5	31.7

07D	16.9	34.4	35.8	26.3
C	17.1	34.8	36.1	27.0
B	17.3	36.4	36.4	26.7
A	15.1	33.8	33.7	26.4

06	14	22	30	38	46
----	----	----	----	----	----

## CORE SUMMARY

CORE POWER	97.9%	CALC SUB FLOW	97.5%	DP MEAS PSI	18.95
CORE FLOW	99.7%	OPER SUB FLOW	-2.1%	DP CALC PSI	21.59
LOAD LINE	98.1%	FLOW BASIS	MEAS	FEEDWTR FLOW MLB/HR	14.71

## APRM CALIBRATION

READING	A	B	C	D
AGAF	97.4	97.1	97.9	97.3
	1.006	1.008	1.000	1.007
APRM - %CTP	-0.6	-0.8	-0.0	-0.6

## TIP RUNS RECOMMENDED

STRINGS:	NONE
DRIVE FLOW	MLB/HR
FEEDWTR TEMP	DEG.F

 FAILED SENSORS:  
 LPRM ( 0 SIGNAL FAILED)  
 LPRM ( 0 PANACEA REJECTED)  
 OTHER SENSORS ( 0 TOTAL)  
 SUB RODS  
 NONE  
 T = TIP RUN RECOMMENDED  
 C = MFLCPR LOCATION  
 M = MAPRAT LOCATION  
 D = MFLPD LOCATION  
 P = PCRAT LOCATION  
 \* = MULTIPLE LIMIT  
 + = CTP/WT OUT OF RANGE

### **INITIAL CONDITIONS**

You are the 'B' RO.

The plant is at full power with RR Pumps A and B operating in fast speed.

### **INITIATING CUE**

The Control Room Supervisor directs you to perform the daily surveillance CPS 9820.01, Power Distribution Limits.

Report to the CRS after completing the task.



## JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cue (and terminating cue if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
     Procedure 9080.01 Rev: 55f  
     Procedure 3506.01 Rev: 37f  
     Procedure 3506.01C005 Rev: 1b  
     Procedure 3506.01F001 Rev: 8a
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

**Revision Record (Summary)**

<b>Revision</b>	<b>Date</b>	<b>Description</b>
00	3/5/18	New JPM.

**SIMULATOR SETUP INSTRUCTIONS**

1. No simulator setup is required for this JPM.



### INITIAL CONDITIONS

You are an extra RO in the MCR.

The plant is in Mode 1.

CPS 9080.01, Diesel Generator 1A Operability Manual And Quick Start Operability is in progress. This is the 51<sup>st</sup> start since the last start motor rebuild.

On start, DG 1A achieved 4200 V and 60.0 Hz within 10.2 seconds.

40 minutes into the Surveillance Run with Load  $\geq$  50% the DG 1A Output Breaker tripped open on overcurrent.

### INITIATING CUE

Complete CPS 3506.01C005 Diesel Generator Start Log.

Report to the CRS after completing the task.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

---

#### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

---

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
CUE	Provide the examinee with the following items: <ul style="list-style-type: none"> <li>• Marked up copy of CPS 3506.01C005 Diesel Generator Start Log</li> <li>• Marked up copy of CPS 3506.01F001Diesel Generator Start Log Index</li> <li>• A copy of CPS 3506.01 Diesel Generator And Support Systems (DG)</li> </ul>				
1	Maintenance Rule Evaluation Start Demand	Selects “Successful Start”.  <i>Evaluator Note – Using Attachment 1 Of CPS 3506.01C005 and conditions presented in the initial conditions, candidate determines that rated voltage and frequency were achieved.</i>	—	—	—
*2	Maintenance Rule Evaluation Load-Run Demand	Selects “Invalid Load-Run Failure (Invalid Test)”.  <i>Evaluator Note – Using Attachment 1 Of CPS 3506.01C005, exceptions to valid tests and failures listed in 3506.01 step 2.2.1.7, and conditions presented in the initial conditions, candidate determines that the Load Run was terminated by an Invalid Failure (DG 1A Output Breaker tripping on overcurrent – bypassed during a LOCA).</i>	—	—	—
3	Tech Spec Evaluation	Selects “Invalid Test”.  <i>Evaluator Note – Using Attachment 1 Of CPS 3506.01C005, exceptions to valid tests and failures listed in 3506.01 step 2.2.1.7, and conditions presented in the initial conditions, candidate determines that the Load Run was terminated by an Invalid Failure (DG 1A Output Breaker tripping on overcurrent – bypassed during a LOCA).</i>	—	—	—

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number
*4	Number Of Valid Test Failures In Last 25 Valid Tests (including this start)	Enters "1".  <i>Evaluator Note – Using the provided Diesel Generator Start Log, the candidate will determine that the current Invalid Test will leave a total of 1 valid test failure in the last 25 valid tests.</i>	—	—	—
5	Report to the CRS.	Present the completed Generator Start Log to the CRS.	—	—	—
CUE	Cue the examinee that the JPM is complete.				

 JPM Stop Time: \_\_\_\_\_
   
 .....

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_ **Emp. ID#:** \_\_\_\_\_**Job Title:**  EO  RO  SRO  FS  STA/IA  SRO CertJPM Title: Complete CPS 3506.01C005 Diesel Generator Start LogJPM Number: JPM555 Revision Number: 00Task Number and Title: 350601.23 Diesel Generator operating logs.K/A Number and Importance: 2.2.37 / RO (3.6), SRO (4.6)Suggested Testing Environment: ClassroomAlternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s):

- CPS 9080.01 Diesel Generator 1A Operability Manual And Quick Start Operability, Rev. 55f
- CPS 3506.01 Diesel Generator And Support Systems (DG), Rev. 37f
- CPS 3506.01C005 Diesel Generator Start Log, Rev 1b
- CPS 3506.01F001 Diesel Generator Start Log Index, Rev 8a

**Actual Testing Environment:**  Simulator  Control Room  In-Plant  Other**Testing Method:**  Simulate  PerformEstimated Time to Complete: 10 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?  Yes  NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

### **INITIAL CONDITIONS**

You are an extra RO in the MCR.

The plant is in Mode 1.

CPS 9080.01, Diesel Generator 1A Operability Manual And Quick Start Operability is in progress. This is the 51<sup>st</sup> start since the last start motor rebuild.

On start, DG 1A achieved 4200 V and 60.0 Hz within 10.2 seconds.

40 minutes into the Surveillance Run with Load  $\geq$  50% the DG 1A Output Breaker tripped open on overcurrent.

### **INITIATING CUE**

Complete CPS 3506.01C005 Diesel Generator Start Log.

Report to the CRS after completing the task.



## JOB PERFORMANCE MEASURE VALIDATION CHECKLIST

**NOTE:** All steps of this checklist should be performed upon initial validation.  
Prior to JPM usage, revalidate JPM using steps 9 and 13 below.

- \_\_\_\_\_ 1. Task description and number, JPM description and number are identified.
- \_\_\_\_\_ 2. Knowledge and Abilities (K/A) references are included.
- \_\_\_\_\_ 3. Performance location specified. (in-plant, control room, simulator, or other)
- \_\_\_\_\_ 4. Initial setup conditions are identified.
- \_\_\_\_\_ 5. Initiating cue (and terminating cue if required) are properly identified.
- \_\_\_\_\_ 6. Task standards identified and verified by SME review.
- \_\_\_\_\_ 7. Critical steps meet the criteria for critical steps and are identified with an asterisk (\*).
- \_\_\_\_\_ 8. If an alternate path is used, the task standard contains criteria for successful completion.
- \_\_\_\_\_ 9. Verify the procedure(s) referenced by this JPM reflects the current revision:  
     Procedure 3303.01 Rev: 36d  
     Procedure 3303.01V001 Rev: 20a  
     Procedure RP-AA-203 Rev: 5  
     Procedure \_\_\_\_\_ Rev: \_\_\_\_\_
- \_\_\_\_\_ 10. Verify cues both verbal and visual are free of conflict.
- \_\_\_\_\_ 11. Verify performance time is accurate
- \_\_\_\_\_ 12. If the JPM cannot be performed as written with proper responses, then revise the JPM.
- \_\_\_\_\_ 13. When JPM is initially validated, sign and date JPM cover page. Subsequent validations, sign and date below:

SME / Instructor	Date
SME / Instructor	Date
SME / Instructor	Date

**Revision Record (Summary)**

<b>Revision</b>	<b>Date</b>	<b>Description</b>
00	4/10/18	New JPM.



**SIMULATOR SETUP INSTRUCTIONS**

1. This is an RO admin JPM; no simulator setup is required.
2. Administer this JPM in any appropriate setting where exam security can be set and which allows the examinee access to a:
  - a. calculator.
  - b. copy of the “Selected RP Procedures for Admin JPMs” binder.

### INITIAL CONDITIONS

RWCU Recirc Pump 'B' 1G33-C001B has been secured due to a leaking seal per CPS 3303.01 Reactor Water Cleanup (RT) section 8.1.4 Removing RWCU Pump(s) From Service.

### INITIATING CUE

Determine:

- 1) the total dose required to support a pre-job brief of two Equipment Operators tasked with performing CPS 3303.01 section 8.1.4.4 to isolate and vent the 'B' RWCU Pump, and
- 2) the margin each Operator will have to the yearly admin dose limit after performing the task.

The following amplifying information is provided:

- Equipment Operator #1 has 700 mr radiation dose YTD.
- Equipment Operator #2 has 500 mr radiation dose YTD.
- Equipment Operator #1 will be performing steps 8.1.4.4.1, 8.1.4.4.2, and 8.1.4.4.3 of CPS 3303.01 Reactor Water Cleanup (RT).
- Equipment Operator #2 will be performing steps 8.1.4.4.4, 8.1.4.4.6, 8.1.4.4.7, and 8.1.4.4.8 of CPS 3303.01 Reactor Water Cleanup (RT)
- Expected total dose for each operator based on the following:
  - Equipment Operator #1: 3 minutes at 1G33-F013B, 3 minutes at 45B, and 6 minutes at 43B.
  - For Equipment Operator #2: 2 minutes performing 8.1.4.4.4 and 3 minutes performing 8.1.4.4.6, 8.1.4.4.7, and 8.1.4.4.8.
  - The 30 cm dose is the whole body dose to be received.
  - No dose will be received during the transit to and from each component.

Inform the Shift Manager when the task is complete.

Fill in the JPM Start Time when the student acknowledges the Initiating Cue.

.....

### Information For Evaluator's Use:

UNSAT requires written comments on respective step.

\* Denotes critical steps.

Number any comments in the "Comment Number" column on the following pages. Then annotate that comment in the "Comments" section. The comment section should be used to document: the reason that a step is marked as unsatisfactory, marginal performance relating to management expectations, or problems the examinee had while performing the JPM. Comments relating to procedural or equipment issues should be entered and tracked using the site's appropriate tracking system.

Some operations that are performed from outside of the control room may require multiple steps. These items may be listed as individual steps in this JPM. It is acceptable for the candidate to direct the local operator to perform groups of procedure steps instead of calling for each individual item to be performed.

The timeclock starts when the candidate acknowledges the initiating cue.

---

JPM Start Time: \_\_\_\_\_

<u>STEP</u>	<u>ELEMENT</u>	<u>STANDARD</u>	SAT	UNSAT	Comment Number																																																							
CUE	Provide the examinee with the following items: <ul style="list-style-type: none"> <li>CPS 3303.01 Reactor Water Cleanup (RT)</li> <li>CPS 3303.01V001 Reactor Water Cleanup Valve Lineup</li> <li>JPM475 Attachments 1 – 4: Survey maps RP-1137-04, RP-1126-04, RP-1136-05 and RP-1192-03</li> </ul>																																																											
*1	Examinee determines total dose for each operator.	<p><b>Examinee determines total dose for Operator #1 is 95 mrem.</b></p> <table border="1"> <thead> <tr> <th colspan="5">Operator #1</th> </tr> <tr> <th>Procedure Step</th> <th>Valve</th> <th>Dose Rate (mr/hr)</th> <th>Time (min)</th> <th>Dose (mr)</th> </tr> </thead> <tbody> <tr> <td>8.1.4.4.1</td> <td>13B</td> <td>700</td> <td>3</td> <td>35</td> </tr> <tr> <td>8.1.4.4.2</td> <td>45B</td> <td>400</td> <td>3</td> <td>20</td> </tr> <tr> <td>8.1.4.4.3</td> <td>43B</td> <td>400</td> <td>6</td> <td>40</td> </tr> <tr> <td></td> <td></td> <td></td> <td>Total Dose</td> <td>95</td> </tr> </tbody> </table> <p><b>Examinee determines total dose for Operator #2 is 25 mrem.</b></p> <table border="1"> <thead> <tr> <th colspan="5">Operator #2</th> </tr> <tr> <th>Procedure Step</th> <th>Valve</th> <th>Dose Rate (mr/hr)</th> <th>Time (min)</th> <th>Dose (mr)</th> </tr> </thead> <tbody> <tr> <td>8.1.4.4.4</td> <td>005B</td> <td>300</td> <td>2</td> <td>10</td> </tr> <tr> <td>8.1.4.4.6, 8.1.4.4.7, 8.1.4.4.8</td> <td>10B / 11B</td> <td>300</td> <td>3</td> <td>15</td> </tr> <tr> <td></td> <td></td> <td></td> <td>Total Dose</td> <td>25</td> </tr> </tbody> </table> <p><i>Examiner Cue – if asked, cue the examinee that 1G33-F005B is located at point A on Survey Map RP-1126-4, and 1G33-F010B &amp; 11B are located at point B on Survey Map RP-1126-4.</i></p>	Operator #1					Procedure Step	Valve	Dose Rate (mr/hr)	Time (min)	Dose (mr)	8.1.4.4.1	13B	700	3	35	8.1.4.4.2	45B	400	3	20	8.1.4.4.3	43B	400	6	40				Total Dose	95	Operator #2					Procedure Step	Valve	Dose Rate (mr/hr)	Time (min)	Dose (mr)	8.1.4.4.4	005B	300	2	10	8.1.4.4.6, 8.1.4.4.7, 8.1.4.4.8	10B / 11B	300	3	15				Total Dose	25	_____	_____	_____
Operator #1																																																												
Procedure Step	Valve	Dose Rate (mr/hr)	Time (min)	Dose (mr)																																																								
8.1.4.4.1	13B	700	3	35																																																								
8.1.4.4.2	45B	400	3	20																																																								
8.1.4.4.3	43B	400	6	40																																																								
			Total Dose	95																																																								
Operator #2																																																												
Procedure Step	Valve	Dose Rate (mr/hr)	Time (min)	Dose (mr)																																																								
8.1.4.4.4	005B	300	2	10																																																								
8.1.4.4.6, 8.1.4.4.7, 8.1.4.4.8	10B / 11B	300	3	15																																																								
			Total Dose	25																																																								
			_____	_____	_____																																																							

<b>*2</b>	Examinee calculates margin to the admin dose limit for both Operators.	<b>Examinee determines Operator #1 will have a margin of 1205 mrem to the annual admin dose limit after completing the task.</b> $2000 \text{ mr} - 700 \text{ mr} - 95 \text{ mr} = 1205 \text{ mr}$	—	—	—
		<b>Examinee determines Operator #2 will have a margin of 1475 mrem to the annual admin dose limit after completing the task.</b> $2000 \text{ mr} - 500 \text{ mr} - 25 \text{ mr} = 1475 \text{ mr}$			
CUE	Cue the examinee that the JPM is complete.				

JPM Stop Time: \_\_\_\_\_  
 .....

**JPM SUMMARY****Operator's Name:** \_\_\_\_\_ **Emp. ID#:** \_\_\_\_\_**Job Title:**  EO  RO  SRO  FS  STA/IA  SRO CertJPM Title: RT Pump ShutdownJPM Number: JPM475Revision Number: 00Task Number and Title: 102405.01 Apply the administrative requirements of ALARA program elements.K/A Number and Importance: 2.3.13 / RO (3.4), SRO (3.8)Suggested Testing Environment: ClassroomAlternate Path:  Yes  No SRO Only:  Yes  No Time Critical:  Yes  No

Reference(s):

- CPS 3303.01 Reactor Water Cleanup (RT) Rev. 36d
- CPS 3303.01V001 Reactor Water Cleanup Valve Lineup Rev. 20a
- Procedure RP-AA-403 Administration of the Radiation Work Permit Program Rev. 10
- Procedure RP-AA-460 Controls For High and Locked High Radiation Areas Rev. 32

**Actual Testing Environment:**  Simulator  Control Room  In-Plant  Other**Testing Method:**  Simulate  PerformEstimated Time to Complete: 10 minutes**Actual Time Used:** \_\_\_\_\_ minutes**EVALUATION SUMMARY:**Were all the Critical Elements performed satisfactorily?  Yes  NoThe operator's performance was evaluated against standards contained within this JPM and has been determined to be:  Satisfactory  Unsatisfactory**Comments:** \_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_  
\_\_\_\_\_**Evaluator's Name (Print):** \_\_\_\_\_**Evaluator's Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

## Attachment 1 – Survey Map RP-1137-04

 RP- 1137-04  
 11/28/2009

### CPS RADIOLOGICAL SURVEY SHEET

 Aux. Building – 750'EL.  
 RT Mezzanine

Survey Index No:

XX/XX/XXXX	-	21
Date		IndexNo

 Date: XX/XX/XXXX Time: XX:XX

 Type:  RWP  Other: \_\_\_\_\_

 Performed By: A. Radcontech

 Counted By: A. Nothertech

 Reviewed By: R.P. Sup Date: XX/XX/XXXX

Inst. Type

Serial #

Cal Due

Date

**RADIATION**

Telepole

334721


xx/xx/xxxx

**CONTAMINATION**

L-177

19265

xx/xx/xxxx



Smear/Location		Smear/Location	
No	dpm/100cm <sup>2</sup>	No	/
1	21K		
2	21K		
3	2K		

Remarks:

 MRRR/RWP: CL-ILT-XX-XXXXX

To support removing 'B' RWCU Pump from service.

/// Not Surveyed

 Tech Dose Received: 3.4 mR

 Notes:  Gross Massfenn (~100 ft<sup>2</sup>)

1. Gen. Area Dose Rates in mRem/hr.
2. \* # / # = Contact/30cm Dose Rates
3. Smears Taken at Circled Locations
4. X X = Radiological Boundary
5. RCA = Radiological Control Area
6. CA = Contaminated Area
7. HCA = High Contamination Area
8. RA = Radiation Area
9. HRA = High Radiation Area
10. LHRA = Locked High Radiation Area
11. T = Transfer Area
12. CAB = Clean Area Boundary

## Attachment 2 – Survey Map RP-1126-04

 RP- 1126-04  
 11/28/2009

### CPS RADIOLOGICAL SURVEY SHEET

Aux. Building – 737'EL.  
 Reactor Water Cleanup Pump 'B'

Survey Index No:

XX/XX/XXXX	-	13
Date		IndexNo

 Date: XX/XX/XXXX Time: XX:XX

 Type:  RWP  Other: \_\_\_\_\_

 Performed By: A. Radcontech

 Counted By: A. Nothertech

 Reviewed By: R.P. Sup Date: XX/XX/XXXX

Inst. Type

Serial #

Cal Due

Date

**RADIATION**

R02A

78050

xx/xx/xxxx

**CONTAMINATION**


L-177

327040

xx/xx/xxxx

By Dose 000%

Blkd 100 (cpm)



Smear/Location		Smear/Location	
No	dpm/100cm <sup>2</sup>	No	N/A
1	< 1K		
2	< 1K		
3	2K		
4	15K		
5	20K		
6	40K		
	N/A		

Remarks:

 MRRR/RWP: CL-ILT-XX-XXXX

To support removing 'B' RWCU Pump from service.

119

 Tech Dose Received: 23 mR

 Notes: Gross Masslinn (~100 ft<sup>2</sup>)

1. Gen. Area Dose Rates in mRpm/hr.
2. \* # / # = Contact/30cm Dose Rates
3. Smears Taken at Circled Locations
4. \*-\* = Radiological Boundary
5. RCA = Radiological Control Area
6. CA = Contaminated Area
7. HCA = High Contamination Area
8. RA = Radiation Area
9. HRA = High Radiation Area
10. LHRA = Locked High Radiation Area
11. T = Transfer Area
12. CAB = Clean Area Boundary

SRRS: 3D.100; There are no retention requirements for this section



### Attachment 3 – Survey Map RP-1136-05

RP- 1136-05  
11/28/2009

### CPS RADIOLOGICAL SURVEY SHEET

Aux. Building – 750'EL.  
Aux. Building Steam Tunnel

Survey Index No:	XX/XX/XXXX	-	8
Date			IndexNo

Date: XX/XX/XXXX Time: XX:XX

Type:  RWP  Other: \_\_\_\_\_

Performed By: A. Radcontech

Counted By: A. Nothertech

Reviewed By: R.P. Sup Date: XX/XX/XXXX

Inst. Type

Serial #

Cal Due


Date

RADIATION

R02A
3316
xx/xx/xxxx

CONTAMINATION


L-177
327099
xx/xx/xxxx



Smear/Location	Smear/Location
No	dpm/100cm <sup>2</sup>
1	<1K
2	<1K
3	<1K
	N/A

Remarks: MRRR/RWP CL-ILT-XX-XXXX

To support removing 'B' RWCU Pump from service.



Tech Dose Received: 6 mR

Notes: A Gross Masslinn (~100 ft)

1. Gen. Area Dose Rates in mRem/hr.
2. \*#/R = Contact/30cm Dose Rates
3. Smears Taken at Circled Locations
4. X-X = Radiological Boundary
5. RCA = Radiological Control Area
6. CA = Contaminated Area
7. HCA = High Contamination Area
8. RA = Radiation Area
9. HRA = High Radiation Area
10. LHRA = Locked High Radiation Area
11. T = Transfer Area
12. CAB = Clean Area Boundary

SRRS: 3D.100; There are no retention requirements for this section



### **INITIAL CONDITIONS**

RWCU Recirc Pump 'B' 1G33-C001B has been secured due to a leaking seal per CPS 3303.01 Reactor Water Cleanup (RT) section 8.1.4 Removing RWCU Pump(s) From Service.

### **INITIATING CUE**

Determine:

- 1) the total dose required to support a pre-job brief of two Equipment Operators tasked with performing CPS 3303.01 section 8.1.4.4 to isolate and vent the 'B' RWCU Pump, and
- 2) the margin each Operator will have to the yearly admin dose limit after performing the task.

The following amplifying information is provided:

- Equipment Operator #1 has 700 mr radiation dose YTD.
- Equipment Operator #2 has 500 mr radiation dose YTD.
- Equipment Operator #1 will be performing steps 8.1.4.4.1, 8.1.4.4.2, and 8.1.4.4.3 of CPS 3303.01 Reactor Water Cleanup (RT).
- Equipment Operator #2 will be performing steps 8.1.4.4.4, 8.1.4.4.6, 8.1.4.4.7, and 8.1.4.4.8 of CPS 3303.01 Reactor Water Cleanup (RT)
- Expected total dose for each operator based on the following:
  - Equipment Operator #1: 3 minutes at 1G33-F013B, 3 minutes at 45B, and 6 minutes at 43B.
  - For Equipment Operator #2: 2 minutes performing 8.1.4.4.4 and 3 minutes performing 8.1.4.4.6, 8.1.4.4.7, and 8.1.4.4.8.
  - The 30 cm dose is the whole body dose to be received.
  - No dose will be received during the transit to and from each component.

Inform the Shift Manager when the task is complete.