

PWROG-15109-NP, Revision 0
Project Number 99902037

August 22, 2019

OG-19-175

U.S. Nuclear Regulatory Commission
Document Control Desk
11555 Rockville Pike
Rockville, MD 20852

Subject: PWR Owners Group
PWROG Comments on the Draft Safety Evaluation for PWROG-15109-NP, Revision 0, "PWR Pressure Vessel Nozzle Appendix G Evaluation," PA-MS-1091

References:

1. Draft Safety Evaluations by the Office of Nuclear Reactor Regulation for PWROG-15109-NP, Revision 0, "PWR Pressure Vessel Nozzle Appendix G Evaluation," dated June 25, 2019 (ML19158A266)

By letter dated March 5, 2018 (Agency wide Documents and Access Management System (ADAMS) Accession No. ML18067A228), as supplemented by letter dated March 27, 2019 (ADAMS Accession No. ML19091A089), the Pressurized Water Reactor (PWR) Owners Group (PWROG) submitted to the U.S. Nuclear Regulatory Commission (NRC) topical report (TR) PWROG-15109-NP, Revision 0, "PWR Pressure Vessel Nozzle Appendix G Evaluation" (ADAMS Accession No. ML18067A229), for review and approval. The U.S. Nuclear Regulatory Commission (NRC) staff transmitted its draft safety evaluation (DSE) via a letter dated June 25, 2019 (ADAMS Accession No. ML19158A266).

Attachment 1 contains the PWROG comments on the DSE and identifies the specific changes to the DSE to address the comments. Attachment 2 contains a markup of the DSE to reflect the changes identified in Attachment 1.

The PWROG requests that the NRC provide a copy of the DSE comment resolution form for PWROG review prior to issuing the Final Safety Evaluation.

D048
NRR

Correspondence related to this transmittal should be addressed to:

Mr. W. Anthony Nowinowski, Program Manager
PWR Owners Group, Program Management Office
Westinghouse Electric Company
1000 Westinghouse Drive
Cranberry Township, PA 16066

If you have any questions, please do not hesitate to contact me at (805) 545-4328 or Mr. W. Anthony Nowinowski, Program Manager of the PWR Owners Group, Program Management Office at (412) 374-6855.

Sincerely yours,



Ken Schrader
Chief Operating Officer & Chairman
Pressurized Water Reactor Owners Group

KS:JPM:am

cc: PWROG Materials Committee (Participants of PA-MS-1091)
PWROG PMO
PWROG Steering and Management Committee
J. Drake, US NRC
J. Andrachek, Westinghouse
B. Hall, Westinghouse
B. Mays, Westinghouse
D. Love, Westinghouse

Attachments 1 and 2: Non-Proprietary list of comments

Attachment 1

Table 1 – Comments on Draft Safety Evaluation of PWROG-15109-NP					
Comment #	DSE Page No.	DSE Line No.	Comment Type	PWROG Comment	NRC Response
1	1	20	Editorial comment	Please revise the text to add: “and closure flange regions” after “(RPV)”	
2	2	47	Editorial comment	Please revise the text to add: “beltline size” after “1/4T”	
3	2	49	Editorial comment	Please revise the text to add: “and closure flange regions” after “region”	
4	3	1	Editorial comment	Please revise the text to add: “and closure flange regions” after “region”	
5	8	23	Clarification; the PWROG data and experience show that this conclusion is reasonable.	Please revise the text: “Although the staff does not find it reasonable that these forgings...” to: “Although the staff is unable to confirm that these forgings...”	
6	8	50	Revises text to reflect correct section in the DSE	Please revise the text from: “Section 2” to “Section 4.1”	
7	12	28, 38, 46	No change is being requested; this is only a comment	The value of the $\Delta T_{NDT\ Stress} = 25^{\circ}F$ has not been verified by the PWROG.	
8	13	31	Editorial comment	After “beltline region” please add “(and closure flange regions, as applicable)”.	
9	16	4	Revises text to reflect correct section in the TR	Please revise the text from: “Section 4.3” to “Section 4.4” and “Section 4.4” to “Section 4.5”.	
10	16	15	Revises text to reflect correct section in the TR	Please revise the text: “Sections 4.3 and 4.4” to “Sections 4.4 and 4.5”.	
11	20	5	Clarification; this change makes it consistent with the text on DSE page 13, lines 48-52	Please revise the text after “NRC-approved method of fluence evaluation” adding “consistent with the plant licensing basis, or another NRC-approved method of fluence evaluation”.	
12	20	9	Editorial comment	Please add the text “then” after “TR,”	
13	20	17	Editorial comment	Please add the text “(and closure flange regions, as applicable)” after “beltline region”.	

Attachment 2

DRAFT SAFETY EVALUATION

BY THE OFFICE OF NUCLEAR REACTOR REGULATION

FOR PRESSURIZED WATER REACTOR OWNERS GROUP TOPICAL REPORT

PWROG-15109-NP, REVISION 0, "PWR PRESSURE VESSEL

NOZZLE APPENDIX G EVALUATION"

EPID L-2018-TOP-0009

1.0 INTRODUCTION

By letter dated March 5, 2018 (Agencywide Documents Access and Management System (ADAMS) Accession No. ML18067A228), as supplemented by letter dated March 27, 2019 (ADAMS Accession No. ML19091A089), the Pressurized Water Reactor (PWR) Owners Group (PWROG) submitted to the U.S. Nuclear Regulatory Commission (NRC) topical report (TR) PWROG-15109-NP, Revision 0, "PWR Pressure Vessel Nozzle Appendix G Evaluation," (ADAMS Accession No. ML18067A229) for review and approval.

The TR addresses the potential for pressure-temperature (P-T) limits for inlet or outlet nozzle corners of pressurized water reactors (PWRs) to be more limiting than those of the shell (and associated welds) of the "traditional" beltline region of the reactor pressure vessel (RPV). The PWROG developed the TR to demonstrate that the RPV nozzle corner P-T limits are bounded by the NRC-approved P-T limits of the shell (and associated welds) in the RPV traditional beltline region for a 60-year license for U.S. PWRs. Specifically, the TR presented generic PWR fracture mechanics analyses of RPV inlet and outlet nozzle corners to show that P-T limits for nozzles corners, developed in accordance with the requirements of Appendix G, "Fracture Toughness Requirements," to Title 10 of the *Code of Federal Regulations* (10 CFR) Part 50, are bounded by the P-T limits of the shell (and associated welds) in the RPV traditional beltline region.

and closure flange regions

2.0 REGULATORY EVALUATION

The NRC has established requirements in 10 CFR Part 50 to protect the integrity of the reactor coolant pressure boundary in nuclear power plants. The NRC staff (the staff) evaluates the acceptability of a facility's proposed P-T limits based on the following NRC regulations and guidance:

- Section 50.60 of 10 CFR, "Acceptance criteria for fracture prevention measures for lightwater nuclear power reactors for normal operation," imposes fracture toughness and material surveillance program requirements, which are set forth in 10 CFR Part 50, Appendices G and H, "Reactor Vessel Material Surveillance Program Requirements."
- Appendix G to 10 CFR Part 50 requires that a facility's P-T limits for the RPV be at least as conservative as those obtained by following the methods of analysis and the margins of safety in Appendix G to Section XI of the American Society of Mechanical Engineers *Boiler and Pressure Vessel Code* (ASME Code).

Enclosure

1 The most recent version of Appendix G to Section XI of the ASME Code which has been
2 endorsed in 10 CFR 50.55a, and therefore by reference in 10 CFR Part 50, Appendix G, is the
3 2013 Edition of the ASME Code. Calculations of P-T limits are based, in part, on the nil-ductility
4 reference temperature (RT_{NDT}) for the material, as specified in the ASME Code, Section XI,
5 Appendix G. The RT_{NDT} is the critical parameter for determining the critical or reference stress
6 intensity factor (fracture toughness, K_{IC}) for the material. As required by 10 CFR Part 50,
7 Appendix G, RT_{NDT} values for materials in the RPV bellline region shall be adjusted to account
8 for the effects of neutron irradiation. Regulatory Guide (RG) 1.99, Revision 2, "Radiation
9 Embrittlement of Reactor Vessel Materials," contains methodologies for calculating the adjusted
10 RT_{NDT} (ART) due to neutron irradiation.

11
12 Appendix G to 10 CFR Part 50 defines the bellline or bellline region of the reactor vessel as the
13 region of the RPV (shell material including welds, heat affected zones, and plates or forgings)
14 that directly surrounds the effective height of the active core and adjacent regions of the RPV
15 that are predicted to experience sufficient neutron irradiation damage to be considered in the
16 selection of the most limiting material with regard to radiation damage.

17
18 Determination of the P-T limits for a plant in accordance with the requirements of Appendix G to
19 10 CFR Part 50 considers several factors, which include the initial properties and chemical
20 composition of the RPV materials, the accumulated neutron fluence for each material, the stress
21 levels applied to the materials resulting from heatup and cooldown transients (which include
22 internal pressure and thermal gradient loads), and structural discontinuities such as nozzles.
23 Development of P-T limits for the bellline region of the RPV considers not only the RPV shell
24 material but also other RPV materials with structural discontinuities such as nozzles.

25
26 3.0 SUMMARY OF THE TR

27
28 The TR is organized as follows:

29
30 Section 1, "Background" – provides a background of why nozzle corners must be considered in
31 evaluations of P-T limits, a summary of the NRC-approved methodologies for development of P-T
32 limits for Westinghouse Electric Company (Westinghouse), Combustion Engineering, Inc., and
33 Babcock & Wilcox Company (B&W) PWR designs, a summary of reports that inform nozzle
34 corner analyses, and a summary of low-temperature overpressure protection.

35
36 Section 2, "Flaw Size" – describes the basis for postulating a smaller than quarter-thickness
37 (1/4T) flaw and describes the small flaw size models postulated in the inlet and outlet nozzles.

38
39 Section 3, "Fracture Toughness" – provides details of the determination of generic nozzle
40 fracture toughness using the master curve approach and generic embrittlement trend curve.

41
42 Section 4, "Stress Intensity Factor Calculation" – provides details of the determining stress
43 intensity factors (SIFs) using the finite element method for the small flaw size models in
44 Section 2 of the TR.

45
46 Section 5, "Pressure-Temperature Limit Curves" – describes determination of the P-T limits for
47 nozzle corners with a small flaw (using information from Sections 3 and 4 of the TR) and 1/4T
48 flaw; compares P-T limits for nozzle corners with those from NRC-approved P-T limits for shell
49 (and associated welds) in the RPV bellline region.

50
51 Section 6, "Conclusion" – concludes that the generic P-T limits developed in
52 the TR in accordance with the requirements of Appendix G to 10 CFR Part 50 are bounded by

beltline size

and for the closure
flange regions

1 the P-T limits of the shell (and associated welds) in the RPV beltline region in the U.S. PWR
2 fleet.

3
4 4.0 TECHNICAL EVALUATION

and closure flange
regions

5
6 The staff reviewed the TR to determine whether the PWROG's evaluation to demonstrate the
7 P-T limits of shell (and associated welds) in the RPV traditional beltline region bound those of
8 inlet and outlet nozzle corners is acceptable. The staff also reviewed the TR to determine that
9 the technical bases are consistent with the requirements of 10 CFR 50.60.

10
11 The staff evaluated eleven major topics of the TR. Each topic is addressed in the subsections of
12 the safety evaluation (SE) that follow. Within each major topic, the staff summarized the
13 relevant content of a subsection of the TR or described the relevant information in the
14 subsection that falls under each major topic. Then the staff provided its findings or
15 determinations on the TR subsection or on the major topic.

16
17 4.1 Postulated Flaw Size

18
19 In Section 2 of the TR, the PWROG explained that a traditionally postulated 1/4T flaw in the
20 nozzle corner region can result in a depth of approximately 4 to 5 inches as measured at a
21 45-degree angle from the nozzle corner to the RPV outside surface since the nozzle and RPV
22 are thicker in the vicinity of nozzles per the ASME Code design requirements. Crack driving
23 forces for a postulated 1/4T flaw could lead to overly conservative P-T limits. Therefore, the
24 PWROG opted to postulate smaller flaws as allowed in the 2008 edition of the ASME Code,
25 Section XI, Appendix G, Subarticle G-2120, "Maximum Postulated Defect," which states that
26 flaws less than 1/4T may be used on an individual case basis if a smaller size of maximum
27 postulated defect can be ensured. Additionally, the 2008 edition of the ASME Code, Section XI,
28 Appendix G, Paragraph G-2223(a), "Toughness Requirements for Nozzles," states that
29 examination methods "shall be sufficiently reliable and sensitive to detect these smaller
30 defects." The PWROG created finite element models (FEMs) with a small postulated flaw in the
31 nozzle corner (the flaw penetrates 0.5 inch into the low alloy steel (LAS) from the clad-to-LAS
32 interface) to determine SIFs since closed-form SIF solutions for nozzle corners are typically for
33 1/4T flaws. Additionally, the PWROG created FEMs with a postulated flaw that penetrates
34 0.05 inch into the LAS to address the effect of the difference in coefficient of thermal expansion
35 (CTE) between the clad and the LAS.

36
37 The PWROG showed a probability of detection (POD) plot for vessels that indicates a POD of
38 100 percent for a 0.5-inch flaw into the LAS and stated that crack growth analyses have been
39 performed for postulated flaws smaller than 0.5 inch based on their high POD. Although a
40 similar POD for nozzle corners does not exist, the PWROG qualitatively concluded that the POD
41 for nozzle corners would be high because pre-service examination through ultrasonic testing
42 (UT) was performed from the inside surface and presented a conclusion by the Electric Power
43 Research Institute (EPRI) Nondestructive Examination Center that detecting flaws as small as
44 0.25 inch by UT located in RPV nozzles is excellent.

45
46 The staff reviewed the POD information for vessels in the TR, which the PWROG obtained from
47 Performance Demonstration Initiative (PDI) data from UT performed in accordance with ASME
48 Code, Section XI, Appendix VIII. The staff also reviewed the ASME Code, Section XI,
49 examination requirements for nozzle corners, which requires nozzle corners to be examined by
50 UT through PDI in accordance with ASME Code, Section XI, Appendix VIII. Accordingly, the
51 staff determined that the PWROG's qualitative evaluation of high POD for nozzle corners to be
52 reasonable. Thus, the staff determined that the postulated flaw size of 0.5 inch into the LAS

1 meets the detectability criterion of Paragraph G-2223(a) of the 2013 edition of ASME Code,
2 Section XI, which is the latest NRC-approved version of the ASME Code.

3
4 The staff noted that the ASME Code, Section XI, examination volume requirement for nozzle
5 corners specifies a maximum depth of 0.5 inch into the LAS. Thus, the staff determined that the
6 postulated flaw size of 0.5 inch into the LAS meets the required examination volume.

7
8 The staff noted that Paragraph G-2223(a) in the 2008 edition is different than in the 2013
9 edition. In addition to the detectability criterion described in Section 4.1 of this SE,
10 Paragraph G-2223(a) of the 2013 edition states that the postulated smaller flaw must
11 appropriately consider the combined effects of internal pressure, external loading, thermal
12 stresses, and flaw shape, and the postulated smaller flaw shall be no smaller than the
13 applicable inservice inspection criteria in Table IWB-3410-1 of ASME Code, Section XI. The
14 staff reviewed Section 4.7, "Loads," of the TR and determined that the PWROG applied the
15 appropriate loads and flaw shape (evaluated in Section 4.6 of this SE). The staff also reviewed
16 the flaw size requirements in Table IWB-3410-1 of the ASME Code, Section XI, and determined
17 that the flaw size of 0.5 inch into the LAS region that the PWROG postulated meets the
18 requirements of the table. Based on this and the POD information the PWROG provided, the
19 staff finds that a postulated flaw of 0.5 inch into the LAS is acceptable and meets the criteria of
20 Subarticle G-2120 and Paragraph G-2223(a) of the 2013 edition of ASME Code, Section XI.

21 22 4.2 Fracture Toughness

23 24 Generic Nozzle Forging Master Curve Reference Temperature

25
26 In Section 3.1, "Generic Nozzle Forging Master Curve Reference Temperature" of the TR, the
27 PWROG stated that the use of the lower bound plane-strain, static fracture toughness (K_{IC})
28 curve has inherent margin since RT_{NDT} is a conservative method for locating the K_{IC} curve.
29 RT_{NDT} is based on drop weight testing, which is a crack arrest transition temperature
30 measurement, and the Charpy impact test, which is a blunt notch impact test. These data are
31 conservatively bounded by the K_{IC} curve, which is a lower bound crack initiation fracture
32 toughness curve.

33
34 In contrast, the PWROG stated that the master curve method is based on an initiation transition
35 temperature true fracture toughness test technique and the master curve index temperature (T_0)
36 provides a much more accurate measure of the material fracture toughness. The PWROG
37 explained that existing master curve fracture toughness data for A-508 Class 2 type forgings
38 was gathered to establish a generic mean and standard deviation for alternate RT_{NDT} for the
39 U.S. PWR inlet and outlet nozzles. Specifically, the master curve fracture toughness data is
40 used with ASME Section XI Code Case N-629, "Use of Fracture Toughness Test Data to
41 Establish Reference Temperature for Pressure Retaining Materials, Section XI, Division 1,"
42 which is endorsed by RG 1.147 and incorporated by reference in 10 CFR 50.55a as an
43 alternative to RT_{NDT} .

44
45 The staff noted that the 2013 edition of ASME Code Section XI (i.e., the latest edition endorsed
46 by 10 CFR 50.55a) permits the use of an alternate RT_{NDT} , which is consistent with Code Case
47 N-629. Specifically, Subarticle G-2110 in the 2013 edition of ASME Code Section XI states, in
48 part, that if material-specific temperature value, T_0 , for ferritic steels in the transition range is
49 available then a reference temperature, RT_{T_0} , may be used in place of RT_{NDT} .

50
51 Since Code Case N-629 is incorporated by reference (e.g., RG 1.147) in 10 CFR 50.55a, and
52 the use of RT_{T_0} in lieu of RT_{NDT} is permitted by ASME Code Section XI, the staff finds the use of

1 a fracture-toughness-based reference temperature, RT_{T0} , acceptable and that an exemption to
2 Appendix G to 10 CFR Part 50 by the licensees is not required.

3
4 Master Curve Data Search

5
6 In Section 3.1.1, "Master Curve Data Search," of the TR, the PWROG described the approach it
7 used for searching and gathering master curve data relevant to RPV nozzle forgings in U.S.
8 PWRs. The PWROG explained that relevant data was gathered from open literature, the
9 Electric Power Research Institute (EPRI) fracture toughness database, and internal
10 Westinghouse references. Specifically, the PWROG considered thick sections of A-508 Class 2
11 or similar forgings that were used in RPV fabrication or are representative of the materials used
12 to construct U.S. PWR inlet and outlet nozzles. The purpose was to capture all available
13 transition temperature fracture toughness data to establish a generic master curve transition
14 reference temperature for A-508 Class 2 type forgings. The PWROG explained in its
15 supplement that "representative" means that the forging heats from which master curve data
16 were obtained had material specifications similar to A-508 Class 2 forgings used in U.S. PWR
17 inlet and outlet nozzles. Specifically, the staff noted that the PWROG's selection included
18 alternate forging alloys—22NiMoCr37, 20NiMoCr26, and SFVQ2A (the staff's review regarding
19 the applicability of these alternate forging alloys to U.S. PWR inlet and outlet nozzles is
20 discussed below). The PWROG also stated that the meaning of "bounding" is explained in
21 Section 3.1.2.2 of the TR. The staff noted that the master curve data is considered bounding
22 because it included irradiated materials, fracture toughness data based on K_{IC} , one material with
23 RT_{NDT} greater than 60°F, and a diversity of relevant forgings (as evidenced by the large
24 standard deviation presented in Section 3.1.2.2 of the TR), all of which conservatively impact
25 fracture toughness. Based on its review, the staff finds the scope of materials that the PWROG
26 considered and included into the master curve data is representative and reasonably bounds
27 the fracture toughness of RPV inlet and outlet nozzle forgings in U.S. PWRs.
28

29 The PWROG explained that the nozzle forgings used in U.S. PWRs are all ASME SA-508
30 Class 2 or ASTM A-508 Class 2 with the following exceptions: Prairie Island Nuclear
31 Generating Station Units 1 and 2 nozzles, which are SA-508 Class 3, Palo Verde Nuclear
32 Generating Station Units 2 and 3 nozzles (which are a combination of SA-508 Classes 2 and 3),
33 and R.E. Ginna Nuclear Power Plant nozzles (which are SA-336). The PWROG noted that the
34 Ginna nozzles meet the A-508 Class 2 specification requirements per the Ginna Certified
35 Material Test Reports (CMTRs). With regard to the nozzles forgings that are SA-508 Class 3,
36 the PWROG stated that master curve data was assessed for A-508 Class 3 and showed that
37 the fracture toughness properties were better than A-508 Class 2. Based on its review of the
38 master curve data for A-508 Class 3 materials referenced by the PWROG, the staff finds it
39 reasonable that the A-508 Class 2 generic RT_{T0} developed in this TR is conservative compared
40 to A-508 Class 3 forgings. In addition, the staff finds that the A-508 Class 2 generic RT_{T0}
41 developed in the TR is appropriate for the SA-336 forgings because plant-specific CMTRs
42 demonstrate that these forgings meet the A-508 Class 2 specification requirements.
43

44 The PWROG provided a description of the materials relevant to the U.S. PWR nozzle forgings
45 that were included in its master curve data search. Specifically, the PWROG included in its
46 supplement available master curve data, chemical composition, and mechanical properties of
47 the following materials: 22NiMoCr37, ASTM A-508-64 Class 2, SA-508 Class 2 (1971), SA-508
48 Grade 2 Class 1 (2007), 20NiMoCr26, and SFVQ2A. The staff reviewed the chemical
49 composition and mechanical properties listed for the different forgings and noted that the
50 differences in the chemical composition limits and mechanical properties between all the
51 different alloys are very minor when compared to the alloys used in U.S. PWR nozzle forgings.
52 The PWROG confirmed that each of these forgings in the master curve dataset was quenched

1 and tempered steel for pressure vessels, and that a similar heat treatment was used to produce
2 the required properties. The PWROG also confirmed that the master curve data was produced
3 from specimens taken from thick section forgings except for the 20NiMoCr26 forging, which was
4 thinner. For this particular forging that was thinner, the PWROG indicated that consideration of
5 the forging in the dataset is conservative (i.e., increases the average generic RT_{T0} in the TR).
6 Based on the impact of the 20NiMoCr26 forging to the average generic RT_{T0} determined in the
7 TR, the staff find its inclusion into the master curve dataset to be conservative.

8
9 Based on its review, the staff considers A-508 and SA-508, Class 2, 22NiMoCr37, 20NiMoCr26,
10 and SFVQ2A forgings are essentially the same alloy because of the minor differences in the
11 chemical composition and mechanical properties, and the PWROG's confirmation regarding the
12 methods used to produce these forgings. Thus, the staff finds the PWROG's inclusion of A-508
13 and SA-508, Class 2, 22NiMoCr37, 20NiMoCr26, and SFVQ2A materials in its master curve
14 dataset to be acceptable and representative of U.S. PWR nozzle forgings.

15
16 Based on its review, the staff finds the scope of materials considered by the PWROG and
17 included into the master curve data is representative and reasonably bounds the fracture
18 toughness of the RPV inlet and outlet nozzle forgings in U.S. PWRs.

19 20 Results from Master Curve Data Search

21
22 Section 3.1.2, "Results from Master Curve Data Search," of the TR states that master curve
23 data for 22 distinct forgings were identified, and in all cases the heats selected are
24 representative of the forgings used in commercial PWRs and boiling water reactors (BWRs)
25 from Japanese, Swedish, German, and U.S. RPVs. The PWROG confirmed that the references
26 were checked to ensure that all the data collected for the TR was from unique forgings.

27
28 The PWROG explained that in some cases the references only reported K_{IC} values;
29 nevertheless, the master curve reference temperature can conservatively be developed from
30 these K_{IC} values. The PWROG stated that the K_{IC} values are always the same or lower than the
31 cleavage-onset fracture toughness (K_{JC}) values from the same test; thus, the T_0 value
32 developed from these K_{IC} values would be conservative. The staff noted that where K_{IC} is used
33 instead of K_{JC} , K_{IC} is defined by ASTM E399, "Standard Test Method for Linear-Elastic Plane-
34 Strain Fracture Toughness K_{IC} of Metallic Materials," and is the applied SIF (K) where the load
35 displacement trace deviates from linearity by 5 percent. Whereas in ASTM E1921, "Standard
36 Test Method for Determination of Reference Temperature, T_0 , for Ferritic Steels in the Transition
37 Region," K_{JC} is K converted from the applied J-integral at cleavage. The staff noted that the K_{IC}
38 curve was established using only data deemed to be "valid" by linear elastic fracture mechanics
39 criteria per ASTM E399; thus, only the lower range of cleavage fracture toughness values were
40 used, whereas K_{JC} is determined from data from specimens in a temperature range where either
41 cleavage cracking or crack pop-in develops during the loading of specimens and is not limited to
42 the lower range values. Thus, the staff finds it acceptable and conservative that the PWROG
43 included relevant K_{IC} values in determining the master curve reference temperature because
44 these values only include the lower range of cleavage fracture toughness data.

45
46 Table 3-2 "All Available Master Curve Data on A-508 Class 2 Type Forgings," of the TR
47 presents the results from the master curve data search performed by the PWROG. The
48 PWROG stated that the range of RT_{NDT} values in Table 3-2 of the TR exceeds the range (i.e.,
49 more conservative) of the RT_{NDT} values generally observed in U.S. PWR nozzle forgings utilizing
50 the criteria in NB-2300 of Section III of ASME Code, which typically fall between -34°C
51 and -12°C . Additionally, the PWROG stated that the average RT_{NDT} (-11°C) of the 22 forgings in
52 Table 3-2 of the TR falls above (i.e., more conservative) this typical range of RT_{NDT} values

1 observed for U.S. PWR nozzle forgings based on measured data and ASME Code NB-2300
2 criteria. The PWROG summarized in its supplement NB-2300-compliant measured RT_{NDT}
3 values for U.S. PWR nozzle forgings developed from a review of original CMTRs. The staff
4 noted that this information is not intended to be a complete list of all U.S. PWR nozzle RT_{NDT}
5 values but contains those readily available to the PWROG, which are representative of
6 approximately half of the U.S. PWR nozzle forgings.

7
8 The staff reviewed these NB-2300-compliant RT_{NDT} values and noted an average value
9 of -10.5°F (-23.6°C). The staff noted the average value from the reported RT_{NDT} values in the
10 master curve data search (i.e., Table 3-2 in the TR) is 12.2°F (-11°C). Based on the readily
11 available data from U.S. PWR nozzle forgings and the master data search in the TR, the staff
12 finds the forgings included in the master curve data used to develop the A-508 Class 2 generic
13 RT_{T0} in the TR, on average, is not as tough as the nozzle material in U.S. PWRs and therefore
14 conservatively represents the fracture toughness of U.S. PWR nozzle forgings.

15
16 Based on the discussion above, the staff finds the PWROG demonstrated that the master curve
17 data presented in the TR is conservatively representative with respect to fracture toughness of
18 U.S. PWR nozzle forgings. Specifically, since RT_{T0} is an acceptable alternate to RT_{NDT} , the staff
19 finds the A-508 Class 2 generic RT_{T0} developed in this TR is also considered conservatively
20 representative of the U.S. PWR fleet of nozzle forgings.

21 22 Specimen Geometry Constraint Adjustment

23
24 Table 3-2 of the TR provides the details of the specimen geometry of the forgings that were
25 used to determine generic nozzle forging master curve reference temperature. Section 3.1.2.1,
26 "Specimen Geometry Constraint Adjustment," of the TR indicates that, as observed by
27 Tregoning and Joyce (Ref. 45 of the TR), there is a systematic, non-conservative bias toward
28 the Single Edge Notched Bend (SE(B)) specimen of generally 5°C to 10°C relative to the
29 compact tension (CT) specimen geometry due to its lower constraint. Thus, the PWROG
30 elected to address this by adding a 10°C bias to the SE(B) T_0 values to adjust for the lower
31 constraint SE(B) geometry, as shown in Table 3-2 of the TR.

32
33 By letter dated August 4, 2005 (ADAMS Accession No. ML052070408), the staff approved the
34 use of a 10°C bias for the lower constraint SE(B) geometry in its SE of BAW-2308, Revision 1.
35 In addition, the staff noted that recent editions of ASTM E1921 included an average difference
36 between the CT and SE(B) of 10°C .

37
38 The staff finds the PWROG's use of a 10°C bias to the SE(B) T_0 values acceptable because it is
39 consistent with (1) the data and information available on the differences between SE(B)
40 specimen and CT specimen test result, and (2) the previous approval of a 10°C bias for the
41 lower constraint SE(B) geometry.

42 43 Surface Effect

44
45 Section 3.2, "Surface Effect," of the TR describes improved toughness near the surface of a
46 forging material compared to a location deeper in the forging. The PWROG cited references
47 that illustrated the improved toughness near the surface and presented transition temperature
48 data for 24 longitudinal (LT) specimens and seven transverse (TL) specimens. The data
49 consisted of shifts in transition temperature at the surface relative to the 1/4T location and were
50 determined from Charpy V-Notch (CVN) or the master curve measurements. The PWROG
51 stated that specimens without a reported orientation were included in the LT data set.
52 Table 3-3, "Summary of Transition Temperature Shifts for LT and TL Specimens," of the TR

1 showed the average and standard deviation of the transition temperature shifts for the LT and
2 TL data sets. The PWROG selected the conservative set of average and standard deviation
3 (i.e., the LT data set) to take credit for improved fracture toughness for the small flaw models
4 described in Section 4.1 of this SE.
5

6 The staff reviewed the information in Section 3.2 of the TR and verified the average and
7 standard deviation of the transition temperature shifts in Table 3-3 of the TR. The staff noted
8 these observations in the LT measurements: five of the measurements were taken at less than
9 the assumed flaw size of 0.5 inch and two measurements had only a small difference in the
10 depths that they were taken. The staff recalculated the average and standard deviation without
11 these LT measurements and determined that they caused a negligible change. Therefore, the
12 staff finds the average and standard deviation of the temperature shifts shown in Table 3-3 of
13 the TR to be acceptable. The staff noted that the inherent scatter in CVN measurements tend
14 to increase the standard deviation in the transition temperature shifts, which is conservative;
15 thus, the staff also finds including CVN measurements to be acceptable.
16

17 The PWROG addressed in its supplement the specimens without a reported orientation being
18 included in the LT data set in two aspects. First, the PWROG confirmed that the ten B&W
19 forgings, the Westinghouse Four-Loop Inlet Nozzle, Westinghouse Four-Loop Outlet Nozzle #1,
20 and Westinghouse Four-Loop Outlet Nozzle #2 have CMTRs dated from 1969 and 1970. The
21 PWROG stated that testing of TL specimens was not required until after the issuance of the
22 Summer 1972 Addenda of the 1971 Edition of the ASME Code Section III. Although the staff
23 ~~does not find it reasonable~~ that these forgings produced prior to 1972 were tested in the LT
24 direction, the second aspect of how the PWROG addressed specimens with unknown
25 orientation is reasonable. The PWROG stated that in addition to the forgings discussed above,
26 the orientation was not reported for the BethForge forging ID, BethForge forging OD, Forging
27 M1, Forging I, and the French forging. For all of the forgings with unknown orientation identified
28 above, the PWROG ~~illustrated the breakdown~~ of the LT dataset measured transition
29 temperature su is unable to confirm se with a reported LT orientation and those with an
30 assumed LT orientation. The PWROG explained that the addition of the assumed LT
31 orientation data biases the average shift value in the conservative direction compared to the
32 dataset with only known LT orientation. Specifically, the staff noted that the "known" LT dataset
33 provides an average shift of 44.7°F; whereas, the "unknown" LT dataset in this second category
34 would only provide an average shift of 33.8°F. Thus, when the "known" and "unknown" LT
35 datasets are both included, the average shift and standard deviation values in the TR (36.5°F
36 and 28.9°F, respectively) result in a more conservative ART compared to the ART value based
37 only on known LT data.
38

39 In summary, the staff finds that the PWROG adequately addressed the forgings without a
40 reported orientation and their inclusion with the known LT data is appropriate and conservative,
41 as described above. Thus, the staff finds that the PWROG has selected a conservative dataset
42 set to determine the improved fracture toughness near the surface of a forging material and
43 finds it acceptable when addressing the small flaw models described in the TR.
44

45 Underclad Heat-Affected Zone Toughness

46

47 Section 3.3, "Underclad HAZ Toughness," of the TR states that a significant portion of the small
48 postulated flaw in this TR would be in the underclad heat-affected zone (HAZ); therefore, the
49 properties of the HAZ relative to the adjoining base metal must be considered. The staff's
50 evaluation of the small postulated flaw is documented in Section 2 of this SE.
51

4.1

1 The PWROG provided information from Oak Ridge National Laboratory (ORNL), in which ORNL
2 conducted Charpy impact testing on a stainless steel clad plate to determine the effect of
3 clad on the propagation of small surface flaws. This plate was specifically heat treated to
4 produce a high transition temperature but was not quenched and only slightly tempered. The
5 testing performed by ORNL showed that the clad HAZ had significantly better properties
6 (i.e., lower transition temperature) than the 1/4T location in the plate. The PWROG stated that
7 since the plate was not quenched, the improved HAZ transition temperature would not be due to
8 a faster cooling rate from quenching, but the tempering of the cladding operation.
9

10 The staff noted that HAZ test results from surveillance specimens have revealed the
11 inhomogeneous nature of the HAZ material, which also resulted in significant scatter of the HAZ
12 Charpy test data. As discussed in "Irradiation Embrittlement of Reactor Pressure Vessels
13 (RPVs) in Nuclear Power Plants" (Soneda, N. ed., 2015), the weld HAZ has been shown to
14 exhibit superior fracture toughness compared to the plate or forging. In addition, the staff also
15 noted that the continued need to include HAZ material in RPV material surveillance programs
16 was more recently investigated in a paper by Koichi Masaki, Jinya Katsuyama, and Kunio
17 Onizawa, "Study on the Structural Integrity of RPV Using PFM (Probabilistic Fracture
18 Mechanics) Analysis Concerning Inhomogeneity of the Heat-Affected Zone." This paper
19 investigated the features of HAZ inhomogeneity in RPV steels to determine the need for
20 surveillance test specimens of HAZ materials in Japan. The authors examined the
21 inhomogeneous distribution of fracture toughness for HAZ materials using a PFM code and
22 determined that the high-toughness coarse grain HAZ caused arrest of postulated cracks. This
23 outcome is expected metallurgically, because the HAZ is a tempered version of the plate or
24 forging and, as such, it should exhibit superior fracture toughness compared to the plate or
25 forging.
26

27 Thus, the staff finds that the PWROG has adequately addressed the properties of the HAZ
28 relative to the adjoining base metal and finds the PWROG's conclusion that underclad HAZ in
29 nozzles is as tough, or tougher than, the adjacent forging base metal to be acceptable.
30

31 4.3 Neutron Embrittlement

32

33 Section 3.4, "Neutron Embrittlement," of the TR states that the copper (Cu) content was not
34 measured for all the nozzles manufactured for the U.S. PWR fleet, however it was measured for
35 a substantial number covering nearly the full range of manufacturing dates and all major U.S.
36 RPV fabricators. Cu measurements were averaged for 178 inlet and outlet nozzles yielding an
37 average of 0.0947 percent with a standard deviation of 0.0319 percent, yielding a best-estimate
38 value, as defined by RG 1.99, Revision 2, of average plus one standard deviation of
39 0.127 percent. The PWROG explained that for nickel (Ni) content, the upper limit of the SA-508
40 Class 2 specification during the fabrication time period is used, which was 0.90 percent. The
41 PWROG stated that the Cu and Ni contents discussed above are appropriate for the U.S. PWR
42 nozzles, since the database was established from Cu measurements from PWR nozzle forgings
43 only.
44

45 The staff reviewed the information in Section 3.4 of the TR and RG 1.99, Revision 2, regarding
46 the Cu and Ni content. The staff finds the PWROG appropriately determined Cu and Ni
47 contents that are representative of U.S. PWR nozzle forgings consistent with the guidance in
48 RG 1.99, Revision 2.
49

50 Using the Cu and Ni contents discussed above and RG 1.99, Revision 2, the PWROG
51 developed an embrittlement trend curve (ETC) that shows the shift in RT_{NDT} (ΔRT_{NDT}) as a
52 function of neutron fluence, applicable to U.S. PWR nozzles. The PWROG then determined the

1 fluence value of 4.28×10^{17} n/cm² for a ΔRT_{NDT} of 25°F. The PWROG cited NRC Technical
2 Letter Report TLR-RES/DE/CIB-2013-01, "Evaluation of the Beltline Region for Nuclear Reactor
3 Pressure Vessels," Office of Nuclear Regulatory Research (RES), dated November 14, 2014
4 (ADAMS Accession No. ML14318A177), as a basis for not considering the shift due to
5 irradiation of RPV beltline materials (including nozzles) if ΔRT_{NDT} is less than 25°F. The
6 PWROG used the fluence value at ΔRT_{NDT} of 25°F as a screening threshold below which
7 embrittlement due to irradiation may be neglected in the calculation of ART (as discussed in
8 Section 4.4 of this SE). Section 3.4.5, "Future Increased Nozzle Fluence Projections," of the TR
9 indicates that as long as the nozzle fluence projections are less than the fluence screening
10 threshold, the nozzle P-T limits developed in the TR is applicable (if the new fluence is greater
11 than the threshold, a plant-specific ΔRT_{NDT} or ART shall be calculated).
12

13 The PWROG provided additional justification in its supplement that supports the
14 recommendation in TLR-RES/DE/CIB-2013-01 related to ΔRT_{NDT} of 25°F. The PWROG stated
15 that predictions of ΔRT_{NDT} have inherent scatter due to uncertainty in ΔRT_{NDT} data
16 measurement and uncertainty in ΔRT_{NDT} prediction models. The PWROG's premise is that a
17 ΔRT_{NDT} of 25 °F does not have to be considered because 25°F is a reasonable value that
18 represents the scatter in ΔRT_{NDT} due to these uncertainties. To demonstrate this, the PWROG
19 compared the standard deviation (a measure of scatter) of the ΔRT_{NDT} data in TLR-
20 RES/DE/CIB-2013-01 and from the embrittlement database used to develop the ASTM E900
21 ETC, which included data from welds, plates, and forgings from tested surveillance capsules.
22 The PWROG determined a standard deviation of ΔRT_{NDT} of 23 °F from the data in
23 TLR-RES/DE/CIB-2013-01 and a standard deviation of ΔRT_{NDT} of 18.6 °F from the ASTM E900
24 ETC data. The standard deviation from the ASTM E900 ETC data included fluence levels up to
25 4.28×10^{17} n/cm², which is the fluence corresponding to a ΔRT_{NDT} of 25 °F and the fluence
26 threshold the PWROG is proposing in the TR below which embrittlement shifts for nozzles do
27 not have to be considered. The PWROG noted that 18.6 °F is slightly less than 23°F but is
28 consistent with the standard deviation of ΔRT_{NDT} from other ETCs, which included ETCs based
29 on RG 1.99, Revision 2 and 10 CFR 50.61a.
30

31 To further demonstrate that 25°F is a reasonable value below which embrittlement shifts do not
32 have to be considered, the PWROG, using the ETC from RG 1.99, Revision 2, determined
33 ΔRT_{NDT} values of 24.5°F, 25.4°F, and 29.6°F—all comparable to 25°F—for RPV materials that
34 have hypothetically high Cu content (i.e., highly embrittled) at a fluence level of 0.99×10^{17}
35 n/cm². This fluence level is slightly less than the 1×10^{17} n/cm² threshold established in
36 Appendix H to 10 CFR Part 50 for monitoring changes in the fracture toughness properties of
37 ferritic materials in the reactor vessel beltline region. Since 0.99×10^{17} n/cm² is less than
38 1×10^{17} n/cm², these ΔRT_{NDT} values for RPV materials having hypothetically high Cu content
39 would not have been considered. Based on the discussion above, the PWROG concluded that
40 25°F is a reasonable value below which embrittlement shifts do not have to be considered.

41 The staff reviewed the PWROG's justification for using the recommendation in
42 TLR-RES/DE/CIB-2013-01 for not having to consider a ΔRT_{NDT} of 25°F. The staff noted that
43 the ΔRT_{NDT} data from the ASTM E900 embrittlement trend curve (Figure 1 in the supplement)
44 have more positive shifts than negative shifts and shifts could be up to 60°F. However, the
45 staff recognizes that the effect of embrittlement is difficult to distinguish from the data scatter for
46 shifts less than 25°F. Therefore, given the safety significance of RPV components, the staff
47 does not find the justification sufficient to demonstrate generically that embrittlement shifts less
48 than 25°F do not have to be considered. In order to determine whether the recommendation in
49 TLR-RES/DE/CIB-2013-01 of excluding 25°F embrittlement is acceptable specifically for this
50 TR, the staff evaluated the safety significance of the recommendation by identifying if there are
51 any U.S. PWRs in which the nozzles are the limiting material for P-T limits when accounting for
52 an embrittlement shift of 25°F.

1 For this independent assessment to be focused on those U.S. PWRs in which the nozzle
2 material is more limiting than the traditional beltline for P-T limits, the following criteria were
3 used to screen out U.S. PWRs as not needing any additional review:
4

- 5 • Plants that are already shutdown or not pursuing a renewed operating license
- 6 • Plant-specific license amendment requests have been reviewed and approved by the
7 NRC to address irradiation embrittlement of the nozzles
- 8 • Plant-specific Pressure-Temperature Limits Report (PTLR) demonstrates that the NRC-
9 approved P-T limit curves are limiting
- 10 • Neutron fluence at the nozzle region is less than 1×10^{17} n/cm² ($E > 1$ MeV) at the end
11 of 60-years of plant operation (neutron fluence information is publicly available in plant-
12 specific license renewal applications, license amendment requests, or PTLR)
- 13 • Reactors with traditional beltline materials with Cu ≥ 0.2 wt. % (information is publicly
14 available in Reactor Vessel Integrity Database (RVID) Version 2.0.1)

15
16 The staff determined that reactors with a neutron fluence at the nozzle region less than 1×10^{17}
17 n/cm² ($E > 1$ MeV) at the end of 60 years of plant operation are screened out consistent with the
18 threshold established in Appendix H to 10 CFR Part 50 for monitoring changes in the fracture
19 toughness properties of ferritic materials in the RPV beltline region. Furthermore, the staff
20 determined that it is reasonable that U.S. PWRs with traditional beltline materials with Cu ≥ 0.2
21 wt. % are screened out because this level of Cu content would cause a significant shift due to
22 embrittlement in the P-T limits such that it will continue being the limiting material through the
23 license renewal period (i.e., 40 to 60 years of operation).
24

25 Following this initial screening, the staff reviewed the information available in RVID 2.0.1 to
26 identify "candidate" U.S. PWRs based on the following criteria:
27

- 28 • Reactors with a traditional beltline material with low Cu content (i.e., ≤ 0.03 wt. %)
- 29 • Reactors with NRC-approved P-T limits based on a limiting material with low Cu content
- 30 • Nozzle material information (e.g., initial RT_{NDT} , Cu, Ni, and neutron fluence) is available
31 in ADAMS to generate P-T limit curves
32

33 The staff noted that reactors meeting these criteria, particularly those reactors with good beltline
34 material properties (i.e., low initial RT_{NDT}), have the highest likelihood that a shift due to
35 embrittlement of the nozzle could lead to nozzle P-T limits being more limiting than the
36 NRC-approved P-T limits based on a traditional beltline material. Since a data search was
37 being performed for nozzle material property information for the "candidate" reactors, the staff
38 opted to also include any additional reactors at the site since the information was already
39 available in the source documents (e.g., license renewal application). This resulted in a total of
40 nine U.S. PWRs that the staff further investigated by generating P-T limit curves for the limiting
41 nozzle forging using ART values based on an effective full power year (EFPY) that was
42 available from the appropriate source document or data. These nozzle P-T limit curves are
43 based on a 100°F per hour cooldown rate and a postulated inside corner flaw of depth 1/4T.
44

45 For the independent assessment, the staff determined applied SIFs for nozzles due to pressure
46 loading (K_{IP}) and thermal gradients (K_{IT}) consistent with those published in the ORNL study,
47 ORNL/TM-2010/246, "Stress and Fracture Mechanics Analyses of Boiling Water Reactor and
48 Pressurized Water Reactor Pressure Vessel Nozzles -Revision 1, June 2012." The staff noted
49 that these SIF solutions are also consistent with those in the 2013 edition of the ASME Code,
50 Section XI, Paragraph G-2223(c), which are applicable to postulated nozzle corner flaws,
51 regardless of plant design. The staff used the limiting nozzle location from ORNL/TM-2010/246

1 (i.e., the nozzle location with the highest stresses) in its independent assessment. As such, the
2 staff finds that the use of the SIF solutions in ORNL/TM-2010/246 for calculating the K_{IP} and K_{IT}
3 values for the nozzles are acceptable and appropriate for use in its independent assessment.

4
5 The nozzle P-T limit curves generated by the staff for these "candidate" U.S. PWRs were then
6 compared to their respective NRC-approved P-T limit curves, both of which were based on ART
7 values calculated at the same EFPY. Based on this comparison, the staff determined that for
8 these nine "candidate" reactors, the limiting traditional beltline NRC-approved P-T limit curves
9 were bounding compared to the nozzle P-T limit curves generated by the staff.

10
11 For the remaining U.S. PWRs, the staff noted that nozzle material information (e.g., initial
12 RT_{NDT} , Cu, Ni, and neutron fluence) was not readily available. Thus, for the staff to determine if
13 the nozzle P-T limit curve is limiting, a generic screening ART value for the nozzle was
14 calculated and then compared against the ART values from the traditional beltline. The staff
15 noted that if the ART value for the traditional beltline materials (information available in RVID
16 2.0.1) is less than this screening generic nozzle ART value, there is a potential that the nozzle
17 P-T limit curve may be more limiting. Since the plant-specific nozzle information was not
18 available, the staff used the generic mean alternate RT_{NDT} value determined in the TR for U.S.
19 PWR nozzle forgings. As discussed in Sections 4.2 and 4.4 of this document, the staff
20 determined the generic mean alternate RT_{NDT} value (i.e., RT_{TD}) in the TR is relevant and
21 conservatively representative of U.S. PWR nozzle forgings.

22
23 The generic screening nozzle ART value was determined in the following manner:

- 24
25
- Generic Nozzle $ART_{screening} = RT_{TD Initial} + \Delta RT_{NDT Stress} + \Delta RT_{NDT Embrittle} + margin_{Embrittle}$
 - $margin_{Embrittle} = 2(\sigma_i^2 + \sigma_{\Delta}^2)^{1/2}$ – Per RG 1.99, Revision 2
 - $RT_{TD Initial} = -66.4^{\circ}F$ – Per Section 3.5 of the TR
 - $\Delta RT_{NDT Stress} = 25^{\circ}F$ – Bounding shift due to stress based on review of P-T limit curves
 - $\Delta RT_{NDT Embrittle} = 25^{\circ}F$ – Maximum shift due to embrittlement
 - $\sigma_i = 54.5^{\circ}F$ – Per Section 3.5 of the TR
 - $\sigma_{\Delta} = 12.5^{\circ}F$ – Per RG 1.99, Revision 2, σ_{Δ} cannot be more than $1/2$ of $\Delta RT_{NDT Embrittle}$
 - Generic Nozzle $ART_{screening} = 95.4^{\circ}F$
- 32
33

34 As noted above, $\Delta RT_{NDT Stress}$ represents the shift of the nozzle P-T limit curve resulting from the
35 stress levels due to the structural discontinuities in the nozzle region as compared to the P-T
36 limits curve generated for the traditional beltline. Based on its observations and previous
37 reviews of License Amendment Requests for P-T limits curves, the staff noted that a value of
38 $25^{\circ}F$ is appropriate and bounding to account for the increased stress levels due to the structural
39 discontinuity in the nozzle. Based on this screening generic nozzle ART value, the staff
40 identified four U.S. PWRs that needed a detailed assessment. The staff determined that two of
41 these U.S. PWRs are governed by the P-T limit curve from the bounding unit at the site, which
42 was previously screened out because the ART value for a traditional beltline material was
43 greater than the screening generic nozzle ART value. For the remaining two PWRs, the staff
44 generated P-T limit curves for a generic nozzle ART value, consistent with the methods
45 described above, for comparison with the traditional beltline NRC-approved P-T limit curves.
46 However, to generate these nozzle P-T limit curves, $\Delta RT_{NDT Stress} = 25^{\circ}F$ was not included in the
47 ART value because $\Delta RT_{NDT Stress}$ was only for the purpose of screening in PWRs for
48 assessment. The resulting generic nozzle ART value used for generating the P-T limit curves is
49 $70.4^{\circ}F$.

1 The staff generated nozzle P-T limit curves for the two remaining PWRs using the generic ART
2 value of 70.4 °F and compared them to the NRC-approved P-T limit curves. Based on this
3 comparison for the two U.S. PWRs, the staff noted the following:

- 4
- 5 • The NRC-approved P-T limit curve was limiting for one reactor
- 6 • The NRC-approved P-T limit curve coincided with the P-T limit curve generated with the
7 generic nozzle ART value of 70.4 °F for the other reactor
- 8

9 For the case in which the two curves coincided, the staff noted that the NRC-approved P-T limit
10 curve was based on 36 EFPY (i.e., 40 years of plant operation); whereas, the generic nozzle
11 ART value is based on a neutron fluence in the nozzle region that is conservatively expected
12 after 60-years of plant operation. The staff noted that if the comparison of the NRC-approved P-
13 T limit curve and the P-T limit curve generated with the generic nozzle ART value for the subject
14 reactor was at the same EFPY, the nozzle material would not be limiting. In addition, as
15 discussed in Section 4.2 of this document, the generic nozzle ART value, which is based on RT_{T0}
16 and σ_i developed in the TR, is conservatively representative of the U.S. PWR nozzle forgings.
17 The staff noted that the generic screening nozzle ART value included the shift of 25°F due to
18 embrittlement and that the nozzle-specific shift can be less than this value. Thus, the staff noted
19 that if the plant-specific nozzle material properties for the subject reactor are used, it is
20 reasonable to expect that the nozzle would be tougher than the "generic nozzle" addressed in
21 this TR and would make the NRC-approved P-T limit curve more limiting than the nozzle P-T
22 limit curve.

23
24 In summary, based on its assessment of the PWROG's justification and the staff's independent
25 assessment, as described above, the staff finds that for a neutron fluence less than 4.28×10^{17}
26 n/cm^2 ($E > 1$ MeV) in the nozzle region, the NRC-approved P-T limit curves are limiting for
27 60 years of plant-operation when compared to the nozzle P-T limit curves. In addition, even
28 though the PWROG did not consider the shift due to irradiation of the nozzles if ΔRT_{NDT} is less
29 than 25°F, the staff demonstrated in its independent assessment that this assumption is unlikely
30 to cause the P-T limit curves for inlet or outlet nozzle corners of U.S. PWRs to be more limiting
31 than those of the shell (and associated welds) of the traditional beltline region of the RPV for a
32 neutron fluence less than $4.28 \times 10^{17} n/cm^2$ ($E > 1$ MeV) in the nozzle region.

33
34 Fluence Location Relative to the Postulated Flaw Location and F (and closure flange regions, as
35 applicable)

36 Section 3.4.1, "Calculated Fluence Location Relative to the Postulated Flaw Location," of the TR
37 states that nozzle fluence values are typically assumed to be equal to the RPV upper-shell-to-
38 nozzle forging weld fluence value or the lowest extent of the nozzle forging, and thus the nozzle
39 fluence values are conservative. The PWROG stated that since the postulated flaws in the TR
40 are at the nozzle corners, which are at a higher elevation and therefore further away from the
41 active core, the fluence value is expected to be significantly lower than the fluence at the lowest
42 extent of the nozzle forging or weld. The staff reviewed the discussion of fluence location
43 relative to the postulated flaw location in Section 3.4.1 of the TR and finds it acceptable.

44
45 Section 3.4.2, "Fluence Computational Methodology," of the TR states the use of new fluence
46 evaluation methods can more accurately determine the nozzle fluence reducing the needed
47 conservatisms. The PWROG showed a comparison of nozzle fluence values between three
48 methods of fluence evaluations. The staff reviewed the information in Section 3.4.2 of the TR
49 and noted that the fluence methods approved by the NRC staff are unique to the individual
50 licensee's current licensing basis. Thus, plant-specific fluence calculations performed by the
51 individual licensee in a manner consistent with the NRC-approved methodology will be
52 necessary to determine whether the use of the TR is applicable.

1 Neutron Streaming

2

3 Section 3.4.3, "Neutron Streaming," of the TR states that neutron streaming up the cavity to the
4 nozzle region from the beltline region is an existing phenomenon. As such, the traditional
5 fluence attenuation equation used in the beltline (i.e., in RG 1.99, Revision 2) is not appropriate
6 in the nozzle region when only considering fluence calculated at the inside surface. The
7 PWROG indicated that the fluence at the outside diameter lowest extent of the nozzles can be
8 higher than the fluence at the lowest extent of the nozzle forging at the RPV inside surface due
9 to cavity neutron streaming. The PWROG investigated the stresses at the inlet and outlet
10 nozzles due to pressure and the thermal cooldown transient. The stresses are shown in
11 Section 4.8 "Stresses at Limiting Locations" of the TR, specifically in the figures from the 3D
12 finite element analysis. The PWROG states that these figures demonstrate that the stresses at
13 the lowest extent outside diameter of the nozzles are significantly lower than at the nozzle inside
14 corner, and when pressure stress and thermal stress are considered together, the combined
15 stress is likely compressive. As is discussed in Section 4.8 of the TR, the flaw is postulated at
16 the nozzle inside surface corner at a geometric discontinuity where the highest stresses exist.
17 As a result, the nozzle inside corner is the limiting location, and this location is where the
18 fluence is considered for embrittlement.

19

20 Based on its review, the staff finds the neutron streaming effect is applicable to the 3/4T
21 postulated flaw and that the PWROG's exclusion of the 3/4T postulated flaw in the development
22 of the P-T limits in the TR for the nozzles is appropriate, as described below. Specifically, the
23 staff noted that the pressure stress decreases as a function of distance from the inside corner
24 along the through-wall nozzle corner path, as shown in Figure 24 of ORNL/TM-2010/246.
25 Therefore, the applied SIF due to pressure for a 3/4T postulated flaw at the outside corner of the
26 nozzle would be lower than that for the 1/4T flaw postulated for the inside corner region. The
27 linear elastic fracture mechanics analyses in ORNL/TM-2010/246 do not address 3/4T
28 postulated flaws for this reason. It should be noted that, based on the analysis of the 1/4T
29 location and the smaller postulated flaw from the inside corner region, the nozzle P-T limits for a
30 heatup transient would be less restrictive than those calculated for a cooldown transient
31 because the thermal stresses for a postulated inside corner flaw are compressive for heatup.
32 Therefore, the staff determined that analyses of the 1/4T location and the smaller postulated
33 flaw at the nozzle inside corner during a cooldown transient generates the most bounding P-T
34 limits for the nozzles.

35

36 4.4 Calculation of ART

37

38 In Section 3.1.2.2, "Calculation of Generic Mean Alternate RT_{NDT} ," and Section 3.5, "Adjusted
39 Reference Temperature," of the TR, the PWROG calculated ART with and without the surface
40 effect using the RT_{T0} (evaluated in Section 4.2 of this SE) as the initial reference temperature.
41 The ART value with the surface effect is to be used for the postulated small flaw and the ART
42 value without the surface effect is to be used for the traditional, postulated 1/4T flaw in the
43 nozzle P-T limits developed in Section 5.1, "Generation of Nozzle P-T Limit Curves," of the TR
44 (evaluated in Section 4.10 of this SE). Both ART calculations do not consider an embrittlement
45 shift of 25°F (which the staff evaluated in Section 4.3 of this SE) since the PWROG developed a
46 fluence threshold screening criterion of 4.28×10^{17} n/cm². The staff noted that this fluence
47 threshold screening criterion corresponds to a ΔRT_{NDT} of 25°F below which embrittlement shifts
48 may be neglected.

49

50 The staff verified the ART calculations in Sections 3.1.2.2 and 3.5 of the TR consistent with the
51 guidance in RG 1.99, Revision 2, and finds the ART values of 43°F for the 1/4T flaw and 21°F
52 for the shallow flaw are acceptable for the A-508 Class 2 generic RT_{T0} developed in this TR.

53

1 4.5 Selection of Inlet and Outlet Nozzle Model Geometry
2

3 In Section 4.1 of the TR, the PWROG considered several geometric parameters that affect the
4 stress due to pressure and thermal transient in the nozzle corner region. The PWROG stated
5 that "important characteristics that affect nozzle corner stress and SIF were assessed to ensure
6 representative or bounding models were chosen for the whole U.S. PWR fleet." The PWROG
7 considered nozzle radius-to-thickness (R/t) ratio, nozzle diameter, nozzle corner geometry, and
8 clad thickness as the important geometric parameters that affect the nozzle corner stress and
9 SIF. Table 4-1, "Model Geometry Comparison," pictorially depicted in Figure 4-3, "Diversity of
10 Nozzle Geometries Modeled," of the TR summarizes the inlet and outlet geometries that were
11 modeled.
12

13 The staff finds the PWROG's approach for selecting nozzle model geometries acceptable since
14 it is not practical to model the unique geometry of each inlet and outlet nozzle design in the U.S.
15 PWR fleet. It is reasonable to consider only the parameters that are most relevant, with respect
16 to the stress that can extend a postulated flaw in the nozzle corner. The staff considers that the
17 thickness of the nozzle section and the sharpness of the nozzle corner radius are the most
18 relevant parameters that can extend a postulated flaw in the nozzle corner. The staff finds that
19 the PWROG adequately addressed the effects of these two parameters by considering the
20 nozzle R/t ratio, nozzle diameter, nozzle corner geometry, and clad thickness. Considering the
21 nozzle R/t ratio (and nozzle diameter which accounts for the radius) addresses the section
22 thickness effect on stress. Considering the nozzle corner geometry addresses the effect of the
23 nozzle corner radius, which causes high stresses on the inside surface of the corner.
24 Considering the clad thickness addresses the effects of clad welding residual stress on the
25 small flaw models described in Section 2.
26

27 Furthermore, the staff determined that selecting a nozzle section thickness that bounds all U.S.
28 PWR fleet inlet and outlet nozzle is challenging for two reasons: (1) the effect of thickness on
29 stress due to internal pressure counterbalances the effect of thickness on stress due to thermal
30 transients: a thinner section would generate a higher stress due to internal pressure, but a
31 lower stress due to thermal transient; and (2) the time at which the maximum stress due to
32 internal pressure occurs does not occur at the same time the maximum stress due to thermal
33 transient occurs. Therefore, the staff determined that the PWROG's selection of a nozzle
34 geometry for modeling that is representative of the U.S. PWR fleet nozzle geometry is a
35 practical and reasonable approach.
36

37 Based on the discussion above, the staff finds the four nozzle geometries listed in Table 4-1 of
38 the TR acceptable for representing the inlet and outlet nozzle designs in the U.S. PWR fleet.
39

40 4.6 Finite Element Model and Analyses
41

42 Model Creation
43

44 The PWROG described the FEMs of the inlet and outlet nozzles in Section 4.2, "Model/Mesh,"
45 Section 4.3, "Flaw Modeling Methodology," and Section 4.6, "Material Properties," of the TR.
46 The three-dimensional FEMs of the inlet and outlet nozzles included flaws in the nozzle corner
47 with depths of 0.05 inch and 0.5 inch into the LAS and with length-to-depth aspect ratios of 2:1
48 and 6:1. The mesh in the vicinity of the modeled flaws included very fine elements that have
49 features for handling the sharp edges around the flaw tip. The PWROG summarized the FEM
50 cases in Table 4-2, "Flaw Case List," of the TR.
51

52 The staff reviewed the descriptions of the FEMs in Sections 4.2, 4.3, and 4.6 of the TR and finds
53 the methods (selection of element types, meshing, and definition of material properties)
54 acceptable.

1 Boundary Conditions

2
3 The PWROG described the boundary conditions applied to FEMs of the inlet and outlet nozzles
4 in Section 4.3, "Thermal Boundary Conditions," and Section 4.4, "Structural Boundary
5 Conditions," of the TR. Thermal boundary conditions included temperature coupling of the
6 coincident nodes of the modeled flaw, an assumption of infinite heat transfer coefficient on the
7 wetted surfaces, and insulated conditions on the surfaces of the FEMs where the models are
8 "cut" from the un-modeled structure. The structural boundary conditions included displacement
9 restraints, internal pressure on the wetted surface and on the crack face, end-cap pressure
10 loads on the modeled RPV shell and nozzle safe-end, and mechanical loads on the modeled
11 nozzle safe-end. Additionally, the temperature field from the thermal FEMs are applied to the
12 structural FEMs.

13
14 The staff reviewed the descriptions of the thermal and structural boundary conditions in
15 Sections 4.3 and 4.4 of the TR. One thermal boundary condition of note is the assumption
16 of infinite heat transfer coefficient on the wetted surface. The staff determined that this
17 assumption produces a large temperature gradient across the nozzle section thickness due to a
18 cooldown transient, which generates conservative tensile stresses on the inside surface of the
19 nozzle corner. The staff, therefore, finds the assumption acceptable. The staff noted that the
20 application of the temperature field from the thermal FEMs into the structural FEMs is actually a
21 structural load in the structural FEMs and is therefore acceptable.

22
23 Based on the discussion above, the staff finds that the PWROG applied the proper boundary
24 conditions to the inlet and outlet nozzle FEMs, and therefore finds the boundary conditions
25 acceptable.

26
27 Loads

28
29 The PWROG described the loads applied to FEMs of the inlet and outlet nozzles in Section 4.7,
30 "Loads," of the TR. The applied loads are the residual stress due to clad welding (clad residual
31 stress), mechanical piping loads, and cooldown transient. The internal pressure load is treated
32 as a boundary condition, which the staff evaluated in the "Boundary Conditions" section.

33
34 The staff reviewed the descriptions of the applied loads in Sections 4.7 of the TR. One applied
35 load of note is the clad residual stress. The staff reviewed the PWROG's modeling approach
36 that accounts for clad residual stress. The PWROG cited the review of the Sweden Nuclear
37 Power Inspectorate of programs that measured the effects of cladding on structural integrity of
38 cladded RPVs. Specifically, the PWROG referenced the residual stress profile measured
39 across the cladding of an RPV specimen. Then, using this residual stress profile as a reference
40 stress distribution and the FEM described in Section 4.2 of the TR, the PWROG determined,
41 through an iterative process, the average stress in the clad by adjusting the CTE reference
42 temperature of the clad material that would produce a similar effect at the flaw tip as the
43 measured clad residual stress profile. Given that the availability of residual stress
44 measurements due to clad welding is limited, the staff determined that this approach to address
45 the effect of clad residual stress is reasonable since the reference residual stress is based on
46 measured data. The staff also reviewed open literature and verified that the method of adjusting
47 the CTE reference temperature is a common approach to simulate a stress between two
48 adjacent materials. The staff, therefore finds the load due to clad residual stress acceptable.

49
50 The piping loads included those due to deadweight and thermal expansion loads at normal
51 operating conditions. The staff finds the piping loads acceptable. The cooldown transient
52 included one with composite rates (100°F/hour, then 50°F/hour, then 20°F/hour) and one with

1 100°F/hour for the limiting outlet nozzle FEM. The staff reviewed PWR systems manuals and
2 previous P-T limit curves for cooldown and determined that both cooldown transients are
3 acceptable.

4
5 Based on the discussion above, the staff finds the loads applied to the FEMs of the inlet and
6 outlet nozzle acceptable.

7
8 4.7 Stresses

9
10 The PWROG presented stresses for the inlet and outlet nozzle in Section 4.8, "Stresses at
11 Limiting Locations," of the TR. The staff reviewed the stress contour plots due to internal
12 pressure and cooldown transient for the inlet and outlet nozzle FEMs and determined that the
13 stress values are within the expected values for these nozzles.

14
15 4.8 Stress Intensity Factors

16
17 The PWROG presented SIFs for the outlet nozzle in Section 4.9, "Stress Intensity Factor
18 Results," of the TR and stated that it performed evaluations for both inlet and outlet nozzles, but
19 showed SIF results only for the outlet nozzle in the TR. The staff determined that showing SIF
20 results only for the outlet nozzle is sufficient for its review since the SIF results for the inlet
21 nozzle would show similar trends because it was subject to the same loads as the outlet nozzle.
22 The staff reviewed the SIF plots due to internal pressure and cooldown transient (which includes
23 the effect of clad residual stress) and determined that the SIF values are reasonable compared
24 to those calculated from a closed-form SIF solution for a nozzle corner crack.

25
26 4.9 Constraint and Cladding Effect

27
28 The staff reviewed the discussion of T-stress in Section 4.10.1, "Constraint," of the TR, which is
29 commonly used as a measure of constraint and is correlated to toughness. The staff
30 determined that not taking credit for the increased toughness for a nozzle corner flaw (due to
31 lower constraint compared to the constraint on an SE(B) specimen, the data from which fracture
32 toughness is determined) is acceptable.

33
34 The staff also reviewed the discussion of cracking restraint due to cladding in Section 4.10.2,
35 "Cladding," of the TR and determined that not taking credit for the ability of cladding to restrain
36 crack growth is acceptable.

37
38 4.10 Generic Nozzle P-T Limit Curves

39
40 The PWROG developed generic nozzle P-T limit curves in Section 5.1.1, "Generation of Nozzle
41 P-T Limit Curves with Postulated Small Flaw," and Section 5.1.2, "Generation of Nozzle P-T
42 Limit Curves with Postulated with 1/4T Beltline Thickness Size Flaw," of the TR based on the
43 methodology in Appendix G to Section XI of the ASME Code.

44
45 The PWROG presented the nozzle P-T limits for the postulated small flaws in Section 5.1.1 of
46 the TR with the ART determined in Section 3.5 of the TR, and the nozzle P-T limits for the
47 postulated 1/4T flaws in Section 5.1.2 of the TR with the ART determined in Section 3.1.2.2 of
48 the TR. The nozzle P-T limits for the small postulated flaws were based on SIFs developed in
49 Section 4 of the TR and included the effect of clad residual stress. The nozzle P-T limits for the
50 1/4T flaws were based on stresses determined from unflawed nozzle FEMs and SIFs from
51 ORNL/TM-2010/246 (Ref. 18 of the TR).

52

1 The staff reviewed the nozzle P-T limit curves in Sections 5.1.1 and 5.1.2 of the TR and
2 compared the limiting curves with known nozzle P-T limit curves. The staff finds the nozzle P-T
3 limit curves in the TR acceptable.

4
5 4.11 Comparison of Generic Nozzle P-T Limit Curves to RPV Shell P-T Limit Curves
6

7 In Section 5.2, "Comparison of Nozzle to Traditional NRC Approved Pressure-Temperature
8 Limit Curves," the PWROG selected the limiting nozzle P-T limit curves developed in
9 Sections 5.1.1 and 5.1.2 of the TR and compared them to the NRC-approved P-T limits of the
10 shell (and associated welds) in the RPV beltline region. The PWROG determined that eleven
11 NRC-approved P-T limits of Westinghouse plants (identified in the TR as A through K) do not
12 bound the generic limiting nozzle P-T limits developed in this TR and evaluated them separately
13 in Figures 5-10 through 5-14 of the TR. For these eleven plants, plant-specific nozzle RT_{NDT}
14 values were used instead of the generic nozzle RT_{TO} value developed in the TR, using the P-T
15 limit methodologies in Sections 4 and 5.1.2 of the TR. The staff reviewed the generic bounding
16 nozzle P-T limit curves compared to the NRC-approved P-T limit curves to determine whether
17 the PWROG adequately addressed that the NRC-approved P-T limit curves are bounding when
18 compared to bounding generic nozzle P-T limit curves. The PWROG provided additional
19 information in its supplement that aided the staff's review of the eleven plants in which the NRC-
20 approved P-T limit curves did not bound the generic bounding nozzle P-T limits developed in the
21 TR.
22

23 The staff reviewed Figure 5-15 of the TR, which provided a comparison of the bounding nozzle
24 P-T limit curves compared to NRC-approved P-T limit curves for CE and B&W PWRs. Based
25 on this comparison, the staff finds the PWROG adequately addressed that the NRC-approved
26 P-T limit curves for CE and B&W PWRs bounds the generic nozzle P-T limit curves developed
27 in this TR, as shown in Figure 5-9 of the TR. The staff reviewed Figure 5-9 of the TR, which
28 provided a comparison of the Westinghouse bounding generic nozzle P-T limit curves compared
29 to the NRC-approved P-T limit curves for Westinghouse PWRs, except for the eleven plant-
30 specific cases which are further discussed below (i.e., Plants "A" through "K"). Based on this
31 comparison, the staff finds the PWROG adequately addressed that the NRC-approved P-T limit
32 curves for Westinghouse PWRs (except for Plants "A" through "K") bound the generic
33 Westinghouse nozzle P-T limit curves developed in this TR, as shown in Figure 5-9 of the TR.
34 The staff's review of Plants "A" through "K" identified in the TR is provided below.
35

36 For Plant "A," the PWROG explained in its supplement that WCAP-18191-NP, which was
37 previously submitted to the NRC, contains a calculation of nozzle P-T limit curves using the
38 standard 1/4T nozzle corner flaw and the methods in ORNL/TM-2010/246, as well as the
39 determination of the initial RT_{NDT} values for the nozzle forgings. The staff reviewed WCAP-
40 18191-NP, Appendix B, and verified that the licensee performed confirmatory P-T limit curve
41 calculations of the RPV inlet and outlet nozzles. The staff noted that the Cu and Ni contents of
42 the nozzles were based on plant-specific CMTRs and that the unirradiated RT_{NDT} values are
43 based on drop-weight data, TL CVN test data and NUREG-0800 Branch Technical Position
44 (BTP) 5-3, "Fracture Toughness Requirements," Positions 1.1(3)(a) and (b), with the more
45 limiting unirradiated RT_{NDT} value being selected. The staff noted that the methodology in BTP
46 5-3 paragraph 1.1(3)(b) was determined to be acceptable in closure memorandum dated April
47 2017 (ADAMS Accession No. ML16364A285). The staff noted that the licensee performed
48 these nozzle calculations solely to verify that the P-T limits for the RPV "traditional" beltline is
49 bounding compared to any P-T limit curves for the RPV inlet and outlet nozzles. The staff
50 verified that the licensee used the staff-developed methodology in ORNL/TM-2010/246 to
51 generate the P-T limits of the nozzles. Based on its review of the pertinent information in
52 WCAP-18191-NP, for the purposes of this TR, the staff finds the PWROG adequately

1 addressed that the NRC-approved P-T limit curve for Plant "A" bounds the nozzle P-T limit
2 curves, as shown in Figure 5-14 of the TR.
3

4 For Plant "B," the PWROG confirmed that the NRC-approved P-T limit curves were previously
5 shown to not be impacted by the nozzle P-T limits curves using the 1/4T flaw, as documented in
6 letter dated January 22, 2015 (ADAMS Accession No. ML15029A417). The staff's review of this
7 comparison is documented in SE dated April 29, 2016 (ADAMS Accession No. ML16081A333).
8 The staff finds the PWROG has adequately addressed that the NRC-approved P-T limit curve
9 for Plant "B" is bounding.
10

11 For Plant "C" through Plant "H," the staff noted the nozzle RT_{NDT} values were measured to the
12 requirements of post-1973 ASME Subarticle NB-2300, and the uncertainty associated with an
13 RT_{NDT} estimation method does not affect these RT_{NDT} values. The staff also noted that the
14 PWROG used the FEM with postulated flaws in the TR to generate the nozzle P-T limit curves.
15 The staff's review of the FEM with postulated flaws in the TR are documented in Sections 4.5
16 through 4.9 of this SE. Based on its review, the staff finds it acceptable that the PWROG used
17 plant-specific nozzle RT_{NDT} values instead of the A-508 Class 2 generic RT_{T0} developed in this
18 TR, along with the FEM with postulated flaws in the TR to generate the nozzle P-T limit curves.
19 Thus, the staff finds the PWROG has adequately addressed that the NRC-approved P-T limit
20 curves for Plant "C" though Plant "H" bound the nozzle P-T limit curve, as shown in
21 Figures 5-10, 5-11, and 5-12 of the TR.
22

23 For Plant "I," the PWROG indicated in its supplement that the actual design dimension of the
24 cladding (5/8 inch after machining) was utilized with the postulated 0.5-inch deep LAS flaw,
25 which resulted in a flaw depth of 0.99 inch from the wetted surface. The SIFs for this 0.99-inch
26 flaw in the FEM were developed using the same methodologies that were used for the other
27 nozzle flaws in the TR. The staff's review of the FEM with postulated flaws in the TR are
28 documented in Sections 4.5 through 4.9 of this SE. For Plant "I," the staff noted the nozzle
29 RT_{NDT} values were measured to the requirements of post-1973 ASME Subarticle NB-2300, and
30 the uncertainty associated with an RT_{NDT} estimation method does not affect these RT_{NDT} values.
31 The staff finds it acceptable that the PWROG used plant-specific nozzle RT_{NDT} values instead of
32 the A-508 Class 2 generic RT_{T0} developed in this TR, to generate the nozzle P-T limit curves.
33 Based on the use of the plant-specific nozzle RT_{NDT} values and the PWROG's confirmation that
34 the flaw size for Plant "I" is based on the plant-specific design dimension of the cladding
35 thickness, the staff finds the PWROG adequately addressed that the NRC-approved P-T limits
36 curve for Plant "I" bounds the nozzle P-T limit curve, as shown in Figure 5-13 of the TR.
37

38 For Plants "J" and "K," the PWROG confirmed in its supplement the initial RT_{NDT} values for the
39 reactor vessel nozzle forging materials were determined using the methodology in BTP 5-3
40 paragraph 1.1(3)(b). The staff noted that the methodology in BTP 5-3 paragraph 1.1(3)(b) was
41 determined to be acceptable in closure memorandum dated April 2017 (ADAMS Accession No.
42 ML16364A285). Based on the PWROG's confirmation regarding the source of the initial RT_{NDT}
43 values for Plants "J" and "K," the staff finds the PWROG adequately addressed that the NRC-
44 approved P-T limits curve for Plants "J" and "K" bounds their respective nozzle P-T limit curve,
45 as shown in Figure 5-11 of the TR.
46

47 Based on the staff's review of the comparison for the NRC-approved P-T limit curves and the
48 nozzle P-T limits developed in this TR, as described above, the staff finds that the PWROG has
49 adequately demonstrated that the nozzle P-T limit curves developed in the TR are bounded by
50 the NRC-approved P-T limit curves for U.S. PWRs.
51

1 5.0 USE AND REFERENCING OF THE TR

2
3 As addressed in the TR and in this SE, the use and referencing of this TR is only applicable to
4 U.S. PWR inlet and outlet nozzles with a projected nozzle corner neutron fluence, as calculated
5 by an NRC-approved method of fluence evaluation, of less than 4.28×10^{17} n/cm² (E > 1 MeV).
6 As noted in the TR, if the nozzle fluence is greater than 4.28×10^{17} n/cm² (E > 1 MeV), the shift
7 (ΔRT_{NDT}) may be calculated for those nozzles on a plant-specific basis using an NRC-approved
8 method; as long as the shift remains below 25°F or the plant-specific ART values remain below
9 the ART determined in the TR, the analysis in the TR is applicable.

10
11 6.0 CONCLUSION

then

consistent with the plant licensing basis, or another NRC-approved method of fluence evaluation

12
13 The staff has reviewed the TR including the supplemental
14 evaluation in Section 4 of this SE, finds the TR as modified by this SE, provides an acceptable
15 means for addressing the potential for P-T limit curves for inlet or outlet nozzle corners of U.S.
16 PWRs to be more limiting than the current NRC-approved P-T limits (as of the time of issuance
17 of this SE) of the shell (and associated welds) in the traditional beltline region of the RPV. The
18 staff's independent safety assessment in Section 4.3 of this SE of the TR's use of the
19 recommendation in TLR-RES/DE/CIB-2013-01 of excluding 25°F embrittlement is specific only to
20 the TR, and as such, should not be construed as a generic safety (and closure flange regions, as
21 applications that use the recommendation in TLR-RES/DE/CIB-2 applicable)
22 justified and shall be subject to NRC review and approval on a case-by-case basis. Accordingly,
23 PWROG-15109-NP, as modified by this SE, is acceptable for referencing to satisfy the fracture
24 toughness requirements in Appendix G to 10 CFR Part 50 for U.S. PWR inlet and outlet nozzles
25 only, which provide adequate margins of safety during any condition of normal operation,
26 including anticipated operational occurrences and system hydrostatic tests, to which the
27 pressure boundary may be subjected over its service lifetime.

28
29 Principal Contributor: On Yee

30
31 Date: May 28, 2019