



**INDIANA
MICHIGAN
POWER®**

A unit of American Electric Power

Indiana Michigan Power
Cook Nuclear Plant
One Cook Place
Bridgman, MI 49106
IndianaMichiganPower.com

August 27, 2019

AEP-NRC-2019-33
10 CFR 50.90

Docket Nos.: 50-315
50-316

U. S. Nuclear Regulatory Commission
ATTN: Document Control Desk
Washington, D.C. 20555-0001

Donald C. Cook Nuclear Plant, Units 1 and 2
APPLICATION TO REVISE TECHNICAL SPECIFICATION 5.5.5, "REACTOR COOLANT PUMP
FLYWHEEL INSPECTION PROGRAM," IN ACCORDANCE WITH TSTF-421.

Pursuant to 10 CFR 50.90, Indiana Michigan Power Company (I&M), the licensee for Donald C. Cook Nuclear Plant (CNP), hereby requests an amendment to the Technical Specifications (TS) for CNP Units 1 and 2.

The proposed amendment will extend the reactor coolant pump (RCP) motor flywheel examination frequency from the currently approved 10-year inspection interval, to an interval not to exceed 20 years. The changes are consistent with Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666)." The availability of this TS improvement was announced in the Federal Register on October 22, 2003, as part of the consolidated line item improvement process.

Enclosure 1 provides an affirmation statement pertaining to the information contained herein. Enclosure 2 provides a description and the requested confirmation of applicability. Enclosures 3 and 4 provide Unit 1 and Unit 2 TS pages, respectively, marked to show the proposed changes. New clean Unit 1 and Unit 2 TS pages with proposed changes incorporated will be provided to the Nuclear Regulatory Commission (NRC) Licensing Project Manager when requested.

I&M requests NRC review and approval of the proposed changes commensurate with the NRC's normal review schedule. Once approved, the amendment shall be implemented within 60 days.

In accordance with 10 CFR 50.91, a copy of this application, with enclosures, is being provided to the designated Michigan state officials.

ADD
NRR

There are no new regulatory commitments made in this letter. Should you have any questions, please contact Mr. Michael K. Scarpello, Regulatory Affairs Director, at (269) 466-2649.

Sincerely,



Q. Shane Lies
Site Vice President
Indiana Michigan Power Company

JMT/ml

Enclosures:

1. Affirmation
2. Description and Assessment of the Technical Specification Changes
3. Donald C. Cook Nuclear Plant Unit 1 Technical Specification Pages Marked To Show Proposed Changes
4. Donald C. Cook Nuclear Plant Unit 2 Technical Specification Pages Marked To Show Proposed Changes


c: R. J. Ancona – MPSC
R. F. Kuntz – NRC, Washington, D.C.
EGLE – RMD/RPS
NRC Resident Inspector
D. J. Roberts – NRC Region III
A. J. Williamson – AEP Ft. Wayne, w/o enclosures

Enclosure 1 to AEP-NRC-2019-33

AFFIRMATION

I, Q. Shane Lies, being duly sworn, state that I am the Site Vice President of Indiana Michigan Power Company (I&M), that I am authorized to sign and file this request with the U. S. Nuclear Regulatory Commission on behalf of I&M, and that the statements made and the matters set forth herein pertaining to I&M are true and correct to the best of my knowledge, information, and belief.

Indiana Michigan Power Company



Q. Shane Lies
Site Vice President

SWORN TO AND SUBSCRIBED BEFORE ME

THIS 27 DAY OF August 2019



Notary Public

My Commission Expires 01/21/2025

Enclosure 2 to AEP-NRC-2019-33

Description and Assessment of Technical Specification Changes

1.0 DESCRIPTION

Indiana Michigan Power Company (I&M), the licensee for Donald C. Cook Nuclear Plant (CNP) Units 1 and 2, requests adoption of Technical Specifications Task Force (TSTF)-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666)," into the Technical Specifications (TS) for CNP Units 1 and 2. TSTF-421 changes TS 5.5.5, "Reactor Coolant Pump Flywheel Inspection Program." The availability of this TS improvement was announced in the Federal Register on October 22, 2003, as part of the consolidated line item improvement process (CLIIP).

2.0 DESCRIPTION OF PROPOSED AMENDMENT

Consistent with the Nuclear Regulatory Commission (NRC) -approved TSTF-421, the proposed TS change includes the following revision to TS 5.5.5:

The examination interval for the RCP flywheels is changed from approximately 10 year intervals coinciding with the Inservice Inspection schedule as required by ASME Section XI to 20 year intervals.

3.0 BACKGROUND

The background for this application is adequately addressed by the NRC Notice of Availability published on October 22, 2003, (68 FR 60422), NRC Notice for Comment published on June 24, 2003 (68 FR 37590), TSTF-421, WCAP-15666, "Extension of Reactor Coolant Pump Motor Flywheel Examination," and the related NRC safety evaluation (SE) dated May 5, 2003.

4.0 REGULATORY REQUIREMENTS AND GUIDANCE

The applicable regulatory requirements and guidance associated with this application are adequately addressed by the NRC Notice of Availability published on October 22, 2003, (68 FR 60422), NRC Notice for Comment published on June 24, 2003, (68 FR 37590), TSTF-421, WCAP-15666, and the related NRC SE.

5.0 TECHNICAL ANALYSIS

I&M has reviewed the model SE published on June 24, 2003, (68 FR 37590), and verified its applicability as part of the CLIIP. This verification included a review of the NRC staff's model SE, as well as the information provided to support TSTF-421 (including WCAP-15666 and the related SE dated May 5, 2003). I&M has concluded that the justifications presented in the TSTF proposal

and the model SE prepared by the NRC staff are applicable to CNP Units 1 and 2 and justify this amendment for the incorporation of the changes to the CNP Unit 1 and Unit 2 TS.

6.0 REGULATORY ANALYSIS

A description of this proposed change, and its relationship to applicable regulatory requirements and guidance, was provided in the NRC notices related to the CLIIP, TSTF-421, topical report WCAP-15666, and the associated SE.

7.0 NO SIGNIFICANT HAZARDS CONSIDERATION

I&M has reviewed the proposed no significant hazards consideration determination published on June 24, 2003, (68 FR 37590) as part of the CLIIP. I&M has concluded that the proposed determination presented in the notice is applicable to CNP Units 1 and 2 and the determination is hereby incorporated by reference to satisfy the requirements of 10 CFR 50.91(a).

8.0 ENVIRONMENTAL EVALUATION

I&M has reviewed the environmental evaluation included in the model SE published on June 24, 2003, (68 FR 37590) as part of the CLIIP. I&M has concluded that the staff's findings presented in that evaluation are applicable to CNP Units 1 and 2 and the evaluation is hereby incorporated by reference for this application.

9.0 PRECEDENT

This application is being made in accordance with the CLIIP. I&M is not proposing variations or deviations from the TS changes described in TSTF-421 or the NRC staff's model SE published on June 24, 2003, (68 FR 37590).

10.0 REFERENCES

1. Federal Register Notice: Notice of Availability of Model Application Concerning Technical Specification Improvement Regarding Extension of Reactor Coolant Pump Motor Flywheel Examination for Westinghouse Plants Using the Consolidated Line Item Improvement Process, published October 22, 2003 (68 FR 60422).
2. Federal Register Notice: Notice of Opportunity to Comment on Model Safety Evaluation on Technical Specification Improvement Regarding Extension of Reactor Coolant Pump Motor Flywheel Examination for Westinghouse Plants Using the Consolidated Line Item Improvement Process, published June 24, 2003 (68 FR 37590).
3. Industry/Technical Specification Task Force (TSTF) Standard Technical Specification Change Traveler, TSTF-421, "Revision to RCP Flywheel Inspection Program (WCAP-15666), "Revision 0, November 2001.
4. WCAP-15666, "Extension of Reactor Coolant Pump Motor Flywheel Examination," July 2001.

5. NRC letter dated May 5, 2003, from H. Berkow to R. Bryan (WOG) transmitting Safety Evaluation of WCAP-15666.

Enclosure 3 to AEP-NRC-2019-33

**Donald C. Cook Nuclear Plant Unit 1 Technical Specification Pages Marked to Show
Proposed Changes**

at an interval not to exceed 20 years.

5.5 Programs and Manuals

5.5.5 Reactor Coolant Pump Flywheel Inspection Program

This program shall provide for the inspection of each reactor coolant pump flywheel.

A qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle one-half of the outer radius or a surface examination (magnetic particle testing or penetrant testing, or combination of the two tests) of exposed surfaces of the removed flywheels shall be conducted ~~once every~~ 10 years.

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Reactor Coolant Pump Flywheel Inspection Program Surveillance Frequency.

5.5.6 DELETED

Enclosure 4 to AEP-NRC-2019-33

**Donald C. Cook Nuclear Plant Unit 2 Technical Specification Pages Marked to Show
Proposed Changes**

at an interval not to exceed 20 years.

5.5 Programs and Manuals

5.5.5 Reactor Coolant Pump Flywheel Inspection Program

This program shall provide for the inspection of each reactor coolant pump flywheel.

A qualified in-place UT examination over the volume from the inner bore of the flywheel to the circle one-half of the outer radius or a surface examination (magnetic particle testing or penetrant testing, or combination of the two tests) of exposed surfaces of the removed flywheels shall be conducted ~~once every 40 years.~~

The provisions of SR 3.0.2 and SR 3.0.3 are applicable to the Reactor Coolant Pump Flywheel Inspection Program Surveillance Frequency.

5.5.6 DELETED