



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

June 20, 1979

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, N. W. - Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Sir:

Grand Gulf Nuclear Station
File 0260/15521/15525
Interim Report No. 1 for PRD
79/10 As Defined in 10 CFR 50.55(e)
AECM-79/64

On May 21, 1979, Mississippi Power & Light Company notified Mr. D. S. Price of your office of a potentially reportable deficiency at the Grand Gulf Nuclear Station construction site. The deficiency concerns a problem with the gross failure output function of both the Master and Slave Trip Units of the Rosemount Model 510 DU Trip Calibration System. We have determined that this latter is reportable within the meaning of 10 CFR 50.55(e). Details of the latest findings are described in the attached interim report and we expect to submit a final report by November 16, 1979.

Yours truly,

[Handwritten signature]

L. F. Dale
Nuclear Project Manager

415 347

JRF:pa
Attachment

cc: Mr. T. B. Conner
Mr. R. B. McGehee

bcc: Dr. D. C. Gibbs
Mr. A. Zaccaria
Mr. J. N. Ward
Mr. D.M. Lake
Mr. R. L. Scott
Mr. J. P. McGaughy
Mr. W. L. Nail
Mr. T. E. Reaves
Mr. C. K. McCoy
Mr. F. W. Sly
Potential Reportable Deficiency
File

Mr. John G. Davis, Director THIS COPY FOR
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

3

7907190523

Member Middle South Utilities System

Boisill