



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
REGION IV  
611 RYAN PLAZA DRIVE, SUITE 1000  
ARLINGTON, TEXAS 76012

PDC

June 13, 1979

Docket No. 50-458  
50-459

Gulf States Utilities  
ATTN: Dr. D. G. Weigand, General Manager  
Nuclear Projects  
Post Office Box 2951  
Beaumont, Texas 77704

Gentlemen:

Enclosed is supplement AS to Preliminary Notification PNO-79-67, "Nuclear Incident at Three Mile Island," dated June 11, 1979.

Should you have any questions regarding this review, please contact this office.

Sincerely,

W. C. Seidle, Chief  
Reactor Construction and  
Engineering Support Branch

Enclosure:  
PNO-79-67AS

7907050570<sup>③</sup>

310 191

D

IMMEDIATE  
PRELIMINARY NOTIFICATION

---

June 11, 1979

PRELIMINARY NOTIFICATION OF AN EVENT OR UNUSUAL OCCURRENCE -- PNO-79-67AS

This preliminary notification provides updated information of safety or public interest significance.

Facility: Three Mile Island Unit 2  
Middletown, Pennsylvania (DN-50-320)

Subject: NUCLEAR INCIDENT AT THREE MILE ISLAND

Operational:

1. The average coolant temperature is 157 degrees F. The highest incore thermocouple temperature reading is 280 degrees F. Core cooling is being maintained by natural circulation. Pressure is about 340 psi with the pressurizer in solid operation. Steam is being admitted to the main condenser through the turbine bypass valve from the A Steam Generator.
2. Water level in the reactor building is being measured daily, and is 7.3 feet above floor level this morning.
3. Preoperational testing for the Spent Fuel Pool Tank Farm, Once-Through Steam Generator "B" Long-Term Cooling System, the modified rad waste treatment system (EPICOR), and the pressure/volume control system should be completed by June 15.

Environmental Status:

Environmental radiation levels remain consistent with natural background levels. Airborne releases have been below Technical Specification limits. From June 5 - June 10, about 37 air samples were collected by the NRC. All were less than MDA. Vegetation, soil and milk samples collected last week also showed no activity above MDA. EPA air, water and milk samples collected during the week (up to June 8) showed no detectable activity from TMI.

---

CONTINUED

**POOR ORIGINAL**

7906270031

dupe

310 192

Contact: RCPaulus, IE 227246 DThompson, IE x28487

Distribution: Transmitted H St 3:40

Chairman Hendrie	Commissioner Bradford	S. J. Chilk, SECY
Commissioner Kennedy	Commissioner Ahearne	C. C. Kammerer, CA
Commissioner Gilinsky		(For Distribution)

Transmitted: MNBB 3:45

L. V. Gossick, EDO  
H. L. Ornstein, EDO  
J. J. Fouchard, PA  
N. M. Haller, MPA  
R. G. Ryan, OSP  
H. K. Shapar, ELD

P. Bldg 3:55  
H. R. Denton, NRR  
R. C. DeYoung, NRR  
R. J. Mattson, NRR  
R. S. Boyd, NRR  
SS Bldg 4:00  
W. J. Dircks, NMSS  
S. Levine, RES

V. Stello, IE  
Region I 4:20  
Region II 4:35  
Region III 4:10  
Region IV 4:45  
Region V 4:25  
(MAIL)  
J. J. Cummings, OIA  
R. Minogue, SD

IE (TMI) Site \_\_\_\_\_ (Provide copy to STATE)  
White House Situation Room \_\_\_\_\_  
FDAA \_\_\_\_\_ (Provide copies to the Administrator and the Operations Center)  
EPA \_\_\_\_\_  
DOE/EOC \_\_\_\_\_  
PRMA \_\_\_\_\_  
BRP (State of PA) \_\_\_\_\_  
DCPA \_\_\_\_\_  
HEW \_\_\_\_\_  
Handcarry (FAA) \_\_\_\_\_

IMMEDIATE  
PRELIMINARY NOTIFICATION

POOR ORIGINAL