

TIC

**DAIRYLAND POWER COOPERATIVE**

*La Crosse, Wisconsin*

54601

June 5, 1979

In reply, please  
refer to LAC-6329

DOCKET NO. 50-409

Mr. James G. Keppler  
Director  
U. S. Nuclear Regulatory Commission  
Directorate of Regulatory Operations  
Region III  
799 Roosevelt Road  
Glen Ellyn, Illinois 60137

SUBJECT: DAIRYLAND POWER COOPERATIVE  
LA CROSSE BOILING WATER REACTOR (LACBWR)  
PROVISIONAL OPERATING LICENSE NO. DPR-45  
IE BULLETIN NO. 79-11 - FAULTY OVERCURRENT TRIP  
DEVICE IN CIRCUIT BREAKERS FOR ENGINEERED SAFETY  
SYSTEMS

Reference: NRC Letter, Keppler to Linder,  
dated May 22, 1979.

Dear Mr. Keppler:

In response to the IE Bulletin No. 79-11, we have determined the following:

- 1) Westinghouse Type DB-50 and DB-75 circuit breakers are not used in safety related or other electrical circuits at the La Crosse Boiling Water Reactor.

If there are any questions concerning this response, please contact us.

Very truly yours,

DAIRYLAND POWER COOPERATIVE

Frank Linder, General Manager

FL:WRN:af

JUN 11 1979

309 041

7907090274