

416/79004
417/79003



MISSISSIPPI POWER & LIGHT COMPANY
Helping Build Mississippi
P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

PRODUCTION DEPARTMENT

June 20, 1979

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street - Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Director

Dear Sir:

SUBJECT: Grand Gulf Nuclear Station
File 0270/15525/15526
Interim Report No. 2 For Potential
Reportable Deficiency No. 79/07
as Defined in 10 CFR 50.55(e)
AECM-79/65

On March 23, 1979, Mississippi Power & Light notified Mr. J. K. Rausch of your office of a potential reportable deficiency at the Grand Gulf Nuclear Station Construction Site. The deficiency concerns circuit separation discrepancies found in the Unit 1 and Unit 2 Power Generation Control Complexes. We are presently investigating this matter to determine reportability as defined in 10CFR50.55(e) and will submit a final report by October 20, 1979.

Yours truly,

L. F. Dale
Nuclear Project Manager

JRF/db

cc: Mr. N. L. Stampley
Mr. R. B. McGehee
Mr. T. B. Conner

Mr. John G. Davis, Director
Division of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

JUN 25 10:10

309 120
B019
S 1/0
1
2907090324
790142