



**LOUISIANA  
POWER & LIGHT**

142 DELARONDE STREET  
P. O. BOX 6008 • NEW ORLEANS, LOUISIANA 70174 • (504) 366-2345

May 4, 1979

D. L. ASWELL  
Vice President-Power Production

LPL 11021  
Q-? -A20.03.13  
J-A1.01.04

Mr. Karl V. Seyfrit, Director Region IV  
U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76012

SUBJECT: Waterford SES Unit No. 3  
Docket No. 50-382/IE Bulletin 79-03

Dear Mr. Seyfrit:

In response to the subject IE Bulletin 79-03, the Waterford 3 Project does not and will not have any ASME SA-312, type 304 or other welded (without filler metal) pipe manufactured by Youngstown in the Safety Related Systems. The Applicable Specification LOU 1564.100 for Station Piping, Hangers and Supports did not allow this material and Dravo Corporation has never requested any exceptions to this exclusion of material.

In view of the fact that no ASME SA-312, type 304 or other welded (without filler metal) pipe manufactured by Youngstown has been installed or is planned for installation in Safety Related Systems at Waterford 3 SES, the other response items of this Bulletin are not applicable.

If you have any questions or if we can be of further assistance, please advise.

Yours very truly,

D. L. Aswell

DIA·JEH:smd

cc: U. S. Nuclear Regulatory Commission  
Office of Inspection and Enforcement  
Division of Reactor Construction Inspection  
Washington, D. C. 20555

306 300

790711 0677