NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

EXHIBIT A

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | ARAN 02 (2) | 00-00000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T
01 | REPORT SOURCE L (6) | 05D 003 68 (7) | 06 07 79 (8) | 07 06 79 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 | Review revealed the surveillance test required by T.S. 3.6.1.3a
03 | was not performed within the time limit specified. The
04 | containment Personnel Hatch seal leakage measurement is
05 | required at least once per 72 hours when the air lock is
06 | being used for multiple entries. Similar to LER 50-368/
07 | 79-024. Reportable per T.S. 6.9.1.9.c.
08 |

09 | SYSTEM CODE SD (11) | CAUSE CODE A (12) | CAUSE SUBCODE C (13) | COMPONENT CODE ZZZZZZ (14) | COMP SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 79 — SEQUENTIAL REPORT NO. 041 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN E (18) | FUTURE ACTION H (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB N (24) | PRIME COMP SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 | The scheduling error was due to the irregularity of testing
11 | caused by weekends. The surveillance test schedule was
12 | revised to perform the test every Monday, Wednesday, and
13 | Friday, exceeding the requirement of T.S. 4.6.1.3a. The
14 | test was satisfactorily completed on 6/7/79.

15 | FACILITY STATUS B (28) | % POWER 05 (29) | OTHER STATUS (30) PWR Escalation Test | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) NA

16 | ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

PERSONNEL EXPOSURES
17 | NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

PERSONNEL INJURIES
18 | NUMBER 000 (40) | DESCRIPTION (41) NA

LOSS OF OR DAMAGE TO FACILITY
19 | TYPE Z (42) | DESCRIPTION NA

PUBLICITY
20 | ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER Chris Shively PHONE 501/968-2519

567 207

7907120650