

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 N C B E P 2 0 0 - 0 0 0 0 0 - 0 0 3 4 1 1 1 1 4 5
7 8 9 14 15 25 26 30 57 CAT 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE

CON'T
U 1 REPORT SOURCE L 6 0 5 0 - 0 3 2 4 7 0 6 1 3 7 9 8 0 7 1 3 7 9 9
7 8 60 61 68 69 74 75 80
DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 During normal operator surveillance of the control panel, the operator noticed an
0 3 unexplained shift in the 2-CAC-ATH-1259-2 monitor indicating drywell oxygen concentra-
0 4 tion.
0 5 (Technical Specifications 3.6.6.4,6.9.1.9b)
0 6
0 7
0 8

0 9 SYSTEM CODE S C 11 CAUSE CODE E 12 CAUSE SUBCODE A 13 COMPONENT CODE I N S T R U 14 COMP. SUBCODE S 15 VALVE SUBCODE Z 16
7 8 9 10 11 12 13 18 19 20
17 LER/RO REPORT NUMBER 7 9 21 22 23 24 25 26 27 28 29 30 31 32
ACTION TAKEN B 19 FUTURE ACTION G 19 EFFECT ON PLANT Z 20 SHUTDOWN METHOD Z 21 HOURS 0 0 0 0 22 ATTACHMENT SUBMITTED N 23 NPRD-4 FORM SUB. Y 24 PRIME COMP. SUPPLIER A 25 COMPONENT MANUFACTURER B 1 3 5 26
33 34 35 36 37 40 41 42 43 44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 An inspection found that the range switch had corroded contacts. The switch was
1 1 replaced and the instrument was calibrated and returned to service. Maintenance
1 2 Instruction 10-3A will be revised to inspect/clean this switch monthly. This is
1 3 considered an isolated event and no further action is required.
1 4

1 5 FACILITY STATUS E 28 % POWER 0 7 5 29 OTHER STATUS NA 30 METHOD OF DISCOVERY A 31 DISCOVERY DESCRIPTION Operator Surveillance 32
7 8 9 10 11 12 13 44 45 46 80
1 6 ACTIVITY CONTENT Z 33 Z 34 AMOUNT OF ACTIVITY NA 35 LOCATION OF RELEASE NA 36
7 8 9 10 11 12 13 44 45 46 80
1 7 PERSONNEL EXPOSURES 0 0 0 37 Z 38 DESCRIPTION NA 39
7 8 9 10 11 12 13 44 45 46 80
1 8 PERSONNEL INJURIES 0 0 0 40 DESCRIPTION NA 41
7 8 9 10 11 12 13 44 45 46 80
1 9 LOSS OF OR DAMAGE TO FACILITY Z 42 DESCRIPTION NA 43
7 8 9 10 11 12 13 44 45 46 80
2 0 PUBLICITY N 44 DESCRIPTION NA 45
7 8 9 10 11 12 13 44 45 46 80

7907160381

NAME OF PREPARER A. C. Tollison, Jr.

PHONE: 919-457-9521