

TENNESSEE VALLEY AUTHORITY

CHATTANOOGA, TENNESSEE 37401

400 Chestnut Street Tower II

July 10, 1979

Director of Nuclear Reactor Regulation
Attention: Mr. S. A. Varga, Chief
Light Water Reactors Branch No. 4
Division of Project Management
U.S. Nuclear Regulatory Commission
Washington, DC 20555

Dear Mr. Varga:

In the Matter of the Application of) Docket No. 50-327
Tennessee Valley Authority)

The preservice ultrasonic examination of the Sequoyah unit 1 reactor vessel closure head revealed a flaw indication exceeding the ASME Boiler and Pressure Vessel Code Section XI, Division 1, IWB-3500, acceptance criteria. This deficiency was initially reported to NRC-OIE Region II Inspector C. R. McFarland on February 16, 1979, in accordance with 10 CFR 50.55(e). It was subsequently determined that the discontinuity would be acceptable throughout the operating life of the plant, and the deficiency was classified nonreportable under the requirements of 10 CFR 50.55(e).

As required by IWB-3600 of ASME Section XI, enclosed is information demonstrating compliance with current Section XI flaw acceptance criteria.

Enclosed are copies of the "Southwest Research Institute Supplemental Report 17-5339" (Enclosure 1), a memorandum from R. H. Dunham to H. S. Fox dated February 13, 1979, (Enclosure 2); a memorandum from R. H. Dunham to H. S. Fox dated April 5, 1979, with the "Sequoyah Nuclear Plant Analytical Evaluation of a Flaw in the Unit 1 Reactor

300
SE
111

103
7907170124 A

-2-

Mr. S. A. Darga

July 10, 1979

Pressure Vessel Closure Head CEB-CQS-79-1" report attached (Enclosure 3); and a memorandum from R. M. Pierce to G. G. Stack dated February 28, 1979, with the "Division of Construction Nonconforming Condition Report" (NCR) attached (Enclosure 4).

If you have any questions concerning this matter, please get in touch with D. L. Lambert at FTS 854-2581.

Very truly yours,

TENNESSEE VALLEY AUTHORITY

L M Mills *by DSK*

L. M. Mills, Manager
Nuclear Regulation and Safety

Enclosures

461 146

ENCLOSURE 1

PRELIMINARY EVALUATION OF SEQUOYAH UNIT 1 FLAW INDICATION

SUPPLEMENTAL REPORT
SwRI Project 17-5339

February 1979

Prepared for

Tennessee Valley Authority
505 Edney Building
Chattanooga, Tennessee 37401

Prepared by:

Andrew J. Pickett, P.E.

Reviewed by:

Donald W. Denavant Jr.
Project Manager

Approved by:

Clarence E. Lautzenheiser
Clarence E. Lautzenheiser
Vice President
Quality Assurance Systems
and Engineering Division

7907170131

A

461 147

PRELIMINARY EVALUATION OF SEQUOYAH UNIT 1 FLAW INDICATION

1.0 Introduction

The preservice ultrasonic examination of Sequoyah Unit 1 reactor vessel closure head weld W09-10 revealed a flaw indication exceeding the acceptance standards of the American Society of Mechanical Engineers (ASME) Boiler and Pressure Vessel Code Section XI, Division 1, IWB-3500. Re-evaluation of the weld joint radiograph identified the indication as subject to exemption from IWB-3500 standards in accordance with Code Case N-209¹.

Code Case N-209 requires evaluation of the flaw indication by the IWB-3600 analytical procedures. This report describes a preliminary evaluation to determine the allowability of the indication and the potential effects of this flaw on operating procedures. The evaluation presented herein is based on the pressure vessel manufacturer's stress report².

~~A more detailed analysis and evaluation may be required to justify leaving this flaw indication in place. The final disposition of this indication and the justification for this disposition is to be established by others.~~

2.0 General Discussion of Potential Primary Coolant Boundary Failure at the Flaw Indication Location and the Consequences of Such Failure

The flaw location with respect to any structural discontinuities (such as a flange, nozzle, or lug) is such that the stresses at this section are about equal to the general primary membrane pressure stresses and the local thermal bending stresses (discussed as "skin effect stress" in the referenced stress report). The local surface area is not subjected to coolant injection flow cooling during postulated incidents (such as loss of coolant accidents) so that the increase in thermal stress at the flaw location, in response to emergency and faulted incident loadings, is expected to be less than the decrease in pressure stress at specific times after incident initiation. Neutron irradiation effects on material properties are negligible at this location.

The growth of a flaw through the coolant boundary at this location would result only in a steam leak (if unstable crack propagation is interdicted). This would not diminish the system capability for core submergence and cooling or safe shutdown in response to an emergency or faulted incident. System instrumentation would detect a steam leak.

¹William McGaughey and Sam Wenk, Sequoyah Unit 1 Draft Field Notes, Circumferential Weld W09-10, Southwest Research Institute, January 31, 1979.

²"Analysis of the Main Closure Including Core Support Ledge," Rotterdam Stress Report, Document No. 30616-1105 (The Rotterdam Dockyard Company, September 22, 1975).

3.0 Fracture Mechanics Analysis

ASME Section XI, Division 1, Appendix A, A-1100, summarizes the analytical procedure to be used. This procedure was followed step-by-step, as described below.

- (1) Ultrasonic and radiographic examinations evaluated by McGaughey and Wenk determined the actual flaw indication configuration. Figures 1 and 2 depict these results.
- (2) The flaw indication was resolved into elliptical shape as depicted by Figure 3, Flaw Indication Characterization.
- (3) The stresses at the flaw indication location were obtained from the manufacturer's stress report and posted in Table 1, Flaw Growth Prediction, for the various design conditions listed.
- (4) The stress intensity factors for each condition were calculated and posted in Table 1 (see Figure 4, Sample Calculation).
- (5) The necessary material properties were taken from the stress report.
- (6) The analytical procedures described in A-5000, as appropriate, were used to determine the critical flaw parameters (see Table 1 and Figure 5, IWB-3600 Analysis).
- (7) The flaw evaluation criteria of IWB-3600 were used to determine that the observed flaw indication is acceptable for continued operation provided that metal temperature exceeds the reference nil-ductility temperature (RT_{NDT}) by 120°F during the primary side hydrostatic test.

4.0 Conclusions

The fracture mechanics analyses performed using the conservative method of Section XI, Appendix A, the manufacturer's stress report, and the criteria of IWB-3600 indicate that:

- (1) If any flaw growth occurs in response to the specified operating loadings, it would be negligible.
- (2) Unstable crack propagation initiation from the defect is not credible if the metal temperature exceeds RT_{NDT} by 120°F during the primary side hydrostatic test. This is the highest stress/lowest metal temperature worst case condition postulated in the stress report.

The minimum critical flaw size (a_c) for emergency and faulted conditions has not been determined because of lack of information. There are two conditions to consider:

- (1) Large steam line break.
- (2) LOCA-ECC thermal shock.

Both of these conditions have been evaluated by Westinghouse on a generic basis and for specific reactor vessels.

For the preliminary evaluation, it can be noted that:

- (1) The large steam line break minimum fluid temperature is 212°F. This is >200°F above RT_{NDT} for the material at this location. The fracture toughness at this temperature is sufficient to permit yield strength loading of a through wall crack without unstable propagation (see Figure 4).
- (2) The flaw is located above any cold water injection location for LOCA-ECC event, and the consequent thermal shock would induce no higher stress than the large steam line break.
- (3) Figure 5 is an example of the result of an overly conservative analysis which would be more severe than either condition. As can be seen, neither condition would result in unstable crack propagation.

TABLE I

FLAW GROWTH PREDICTION

LOAD NO.	DESCRIPTION	No. of CYCLES	$\Delta \sigma_m$ KSI	$\Delta \sigma_b$ KSI	ΔK_I KSI IN.	dA/dN Inches/Cycle	ΔA Inches	REMARKS
1	Primary Side Hydrostatic Test	5	20.22	-1.98	20.33	2×10^{-6}	1×10^{-5}	3.105 psig @ 60°F
2	Primary Side Leak Test	50	16.22	-1.41	16.39	0.9×10^{-6}	4.5×10^{-5}	2.485 psig @ 400°F
3	Plant Startup & Cooldown	200	14.65	-1.08	14.90	0.63×10^{-6}	1.26×10^{-4}	Normal Full Power (2235 psig @ 547°F)
4	Small Step Load Increase	2,000	2.69	-0.27	2.70	1.08×10^{-9}	2.17×10^{-6}	
5	Small Step Load Decrease	2,000	-2.69	-0.27	2.70	1.08×10^{-9}	2.17×10^{-6}	
6	Large Step Load Decrease	200	-3.07	0.31	3.08	1.77×10^{-9}	3.54×10^{-7}	
			-1.89	-0.47	1.76	2.21×10^{-10}	4.43×10^{-8}	
7	Loss of Load	80	-6.90	0.31	7.11	3.99×10^{-8}	3.19×10^{-6}	
8	Loss of Power	40	-2.30	0.31	2.27	5.68×10^{-10}	2.27×10^{-8}	
			-0.37	-0.07	0.36	5.68×10^{-13}	2.27×10^{-11}	
9	Loss of Flow	80	-2.86	0.28	2.88	1.37×10^{-9}	1.09×10^{-7}	
			1.93	-0.20	1.94	3.12×10^{-10}	2.50×10^{-8}	
10	Reactor Trip from Full Power	400	-0.58	0.06	0.58	3.54×10^{-12}	1.42×10^{-9}	
			1.93	-0.20	1.94	3.12×10^{-10}	1.25×10^{-7}	
11	Turbine Roll Test	10	10.59	-4.83	8.83	8.95×10^{-8}	8.95×10^{-7}	0.001 > Δa in any order
12	Steady State Fluctuations	∞	11.14	10.11	1.15	4.45×10^{-11}		

$\Delta \sigma_m$ — Change in membrane stress
 $\Delta \sigma_b$ — Change in bending stress
 ΔK_I — Change in stress intensity factor
 dA/dN — Fatigue crack growth rate
 ΔA — Change in minor half diameter

POOR ORIGINAL

SAMPLE CALCULATION FLAW GROWTH INSERVICE

Loading No. 1 - Primary Side Hydrostatic Test @ 3,105 psig for 5 cycles @ 60°F.

From Stress Report

$$\sigma_{ys} = 50.07 \text{ ksi}$$

$$\sigma_m = 20.22 \text{ ksi}$$

$$\sigma_b = -1.98 \text{ ksi}$$

From Section XI, Appendix A (1977 Edition)

Fig. A-3300-1, Q = 1.9

Fig. A-3300-2 Point 1 Point 2

$$M_m = 1.035 \quad 1.025$$

Fig. A-3300-4

$$M_b = 0.47 \quad 0.27$$

$$K_I = \sigma_m M_m \sqrt{\pi} \sqrt{a/Q} + \sigma_b M_b \sqrt{\pi} \sqrt{a/Q}$$
$$= 20.22 \times 1.035 \sqrt{\pi} \sqrt{0.625/1.9} - 1.98 \times 0.47 \sqrt{\pi} \sqrt{0.625/1.9}$$

$$\Delta K = 20.33 \text{ ksi } \sqrt{\text{in}}$$

Fig. A-4300-1 (Summer 1977 Addenda)

$$da/dN = 2 \text{ micro-inches/cycle}$$

$$\Delta a, 5\% = 1 \times 10^{-5} \text{ inches}$$

IWB-3600 ANALYSIS FOR HYDROTEST

$A_f = 0.625$ inches (see flaw growth inservice)

Assume $A_c^* = 0.7$ inches

$$\sigma_m = 20.22 + 8 = 28.22 \text{ ksi} \quad (1)$$

$$\sigma_b = 1.98 \text{ ksi}$$

$$\text{Then } K_{Ia}^* = 28.22 \times 1.035 \sqrt{\pi} \sqrt{0.7/1.87} - 1.98 \times 0.47 \sqrt{\pi} \sqrt{0.7/1.87} \\ = 30.67 \text{ ksi } \sqrt{\text{in}}$$

$$K_{Ia} = 97 \text{ required}$$

Fig. A-4200-1

$$(T - RT_{NDT})^\circ F \text{ required} = 118^\circ$$

(1) Assume 8 ksi residual stress

This figure is a historical astronomical chart from 1901, featuring a coordinate system with a horizontal axis labeled 'RA' (Right Ascension) and a vertical axis labeled 'DEC' (Declination). The chart displays several sets of star catalogues and their distributions across the sky.

- Top Left:** A section of the chart shows stars from the "Carnegie Catalogue of Stars" (CC), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Top Right:** Another section shows stars from the "Hale Catalogue" (H.C.), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Bottom Left:** A section shows stars from the "Carnegie Catalogue of Stars" (CC), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Bottom Right:** A section shows stars from the "Hale Catalogue" (H.C.), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Bottom Center:** A section shows stars from the "Carnegie Catalogue of Stars" (CC), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Bottom Right:** A section shows stars from the "Hale Catalogue" (H.C.), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Bottom Left:** A section shows stars from the "Carnegie Catalogue of Stars" (CC), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".
- Bottom Right:** A section shows stars from the "Hale Catalogue" (H.C.), with labels like "270°", "270", "260", "250", "240", "230", "220", "210", "200", "190", "180", "170", "160", "150", "140", "130", "120", "110", "100", "90", "80", "70", "60", "50", "40", "30", "20", "10", and "0".

The chart also features several dashed lines representing ecliptic and other astronomical reference lines.

2HB79 *bucaneGaughey*

1




FIGURE 2

45 *A - HOW (a)
(b)*

outside surface :

$$t = 7.1"$$

$$e = 1.2375"$$

$$2a = 1.25"$$

$$l = 1.625"$$

inside surface :

0.2" clad

$$a = 0.625"$$

$$2e/t = 0.3486$$

$$2a/l = 0.3846$$

$$2a/t = 0.1761$$

0°


56°


201

FIGURE 3

POOR ORIGINAL 461156

FIGURE 12
STEAM LINE BREAK FROM NO LOAD WITH NO RETURN TO POWER





Typical Transient Thermal Stress
Calculation Result

FIGURE 5

UNITED STATES GOVERNMENT

Memorandum

TENNESSEE VALLEY AUTHORITY

TO : H. S. Fox, Director of Power Production, 716 EB-~~P~~ (2)

FROM : Roy H. Dunham, Director of Engineering Design, W11A9 C-K

DATE : 2/1/79

SUBJECT: SEQUOYAH NUCLEAR PLANT UNIT 1 - ASME SECTION XI FRACTURE MECHANICS
EVALUATION OF A FLAW INDICATION IN THE REACTOR PRESSURE VESSEL CLOSURE HEAD

Reference conversations between E. A. Merrick (EN DES-MEB) and E. F. Harwell (P PROD).

On February 1, 1979, we received data from E. F. Harwell on an indication in the unit 1 reactor pressure vessel (RPV) closure head dollar plate to flange transition forging weld. The indication had been judged unacceptable to the requirements of ASME Section XI, and a decision was made to justify it to the requirements of ASME Code Case N-209. E. F. Harwell requested we perform an analytical evaluation of the flaw.


EN DES-CEB has performed that evaluation by application of procedures from Appendix A to ASME Code Section XI. Compliance with current Section XI flaw acceptance criteria has been demonstrated.

Our evaluation predicts that the existing subsurface planar flaw will grow to an elliptical crack with 2.69- and 2.07-inch major and minor diameters after 40 years of service under specified operating conditions. Applied stress intensification factors are calculated for the final crack dimensions and compared to allowable stress intensification factors from paragraph IWB-3612 of Section XI, thereby demonstrating compliance with the flaw acceptance criteria.

The complete evaluation will be released as report CEB-CQS-79-1 on approximately February 23, 1979, after completion of our internal review.

EN DES has the necessary expertise and component information inhouse to perform work of this nature in a timely responsive manner. This would be especially important for an operating plant. Consequently, we strongly recommend that you consider using EN DES to perform future evaluations rather than having the work performed outside of TVA.

We shall forward you copies of the report upon completion of the review cycle. EN DES engineers will be available to provide support for your presentation of the information on the NRC upon request.



Roy H. Dunham

POOR ORIGINAL

DRP:EAM:MGR

cc: R. G. Domer, W9D224 C-K
MEDS, E4B37 C-K
D. R. Patterson, W10C126 C-K
H. H. Mull, E7B24 C-K

R. M. Pierce, 204 GB-K (2)
G. G. Stack, Sequoyah CONST (4)
E. F. Thomas, 550 CST2-C



167127/4 Buy U.S. Savings Bonds Regularly on the Payroll Savings Plan

UNITED STATES GOVERNMENT

Memorandum

TENNESSEE VALLEY AUTHORITY

TO : H. S. Fox, Director of Power Production, 716 EB-C (2) C O 1 790410 260

FROM : Roy H. Dunham, Director of Engineering Design, W11A9 C-K

DATE : 2/16/79

SUBJECT: SEQUOYAH NUCLEAR PLANT UNIT 1 - ASME SECTION XI FRACTURE MECHANICS
EVALUATION OF A FLAW INDICATION IN THE REACTOR PRESSURE VESSEL CLOSURE
HEAD

due in ARMS
by 5/10

CO1790220709


Reference my memorandum to you dated February 13, 1979 (MEB 790214 353). Attachment 1 is the fracture mechanics evaluation report no. CEB-CQS-79-1 promised you in the referenced memorandum.

Attachment 2 (R. G. Domer's memorandum to D. R. Patterson dated March 19, 1979, CEB 790319 011) contains comments developed by our Civil Engineering Branch on Southwest Research Institute's evaluation of the indication in the reactor vessel head.

It is our position that report no. CEB-CQS-79-1 provides adequate assurance that the flaw indication is acceptable for the full service life of the unit 1 reactor vessel and that the Southwest Research Institute report basically substantiates this conclusion. It is our position that no repair is necessary for this indication. Finally, we do not recommend further faulted condition evaluation by Southwest Research Institute.

EN DES has the necessary expertise and component design information inhouse to perform work of this nature in a timely and responsive manner. This would be especially important for an operating plant. Consequently, we strongly recommend that you consider using EN DES to perform future evaluations rather than having the work performed outside of TVA.

EN DES engineers will be available upon request to provide support for your presentation of the information to the NRC.



Roy H. Dunham

DRP:EAM:MGR

Attachments

cc: R. G. Domer, W9D224 C-K
MEDS, E4B37 C-K
H. H. Mull, E7B24 C-K
D. R. Patterson, W10C126 C-K
R. M. Pierce, 204 GB-K (2)
G. G. Stack, Sequoyah CONST (4)
E. F. Thomas, 550 CST2-C

 CHECK IF DIRECTOR'S
OFFICE REVIEW REQ'D.

350 1. for

600 ✓



XC
for
US

POOR ORIGINAL

223



TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN
CIVIL ENGINEERING BRANCH

SEQUOYAH NUCLEAR PLANT

ANALYTICAL EVALUATION OF
A FLAW INDICATION IN THE
UNIT 1 REACTOR VESSEL CLOSURE HEAD

	Revision R0	R1	R2	R3	R4	R5
Prepared	<i>J.R. Rockwell, P.E.</i>					
Reviewed	<i>R.W. Dickman</i>					
Submitted	<i>J.W.B. Wilcox, P.E.</i>					
Recommended	<i>P.C. Evans</i>					
Approved by	<i>H. Dillman</i>					

461 161

POOR ORIGINAL

Retained at 4/

TENNESSEE VALLEY AUTHORITY
DIVISION OF ENGINEERING DESIGN
CIVIL ENGINEERING BRANCH

SEQUOYAH NUCLEAR PLANT

ANALYTICAL EVALUATION OF
A FLAW INDICATION IN THE
UNIT 1 REACTOR VESSEL CLOSURE HEAD

	Revision R0	R1	R2	R3	R4	R5
Prepared	<i>J.H. Radcliffe</i>					
Reviewed	<i>P.W. Dickman</i>					
Submitted						
Recommended						
Approved						

461 162

POOR ORIGINAL

7907170140 A

SEQUOYAH NUCLEAR PLANT - ANALYTICAL
EVALUATION OF A FLAW INDICATION IN
THE UNIT 1 REACTOR VESSEL CLOSURE
HEAD

Table of Contents

	<u>Page</u>
Introduction	1
Conclusions	1
Discussion	1
Characterization of Existing Flaw	2
Acceptability	5
Analytical Evaluation - General Procedure	5
Material Properties	6
Evaluation of Existing Flaw for Hydrotest Conditions	8
Stress Cycles At $\phi = 63.2^\circ$	10
Relationship Between Stresses at $\phi = 56^\circ$ and $\phi = 63.2^\circ$	14
Stress Cycles At $\phi = 56^\circ$	17
Crack Growth for First 10 Years of Service	21
Total Crack Growth After 20 Years	37
Total Crack Growth After 30 Years	38
Total Crack Growth After 40 Years	39
Fracture Toughness Evaluation With Final Crack Size	40
References	60

SEQUOYAH NUCLEAR PLANT - ANALYTICAL
EVALUATION OF A FLAW INDICATION IN
THE UNIT 1 REACTOR VESSEL CLOSURE
HEAD

CEB-CGS-79-1

Introduction

A flaw indication has been found in the Sequoyah unit 1 reactor vessel closure head at the weld between the closure head dome (dollar plate) and ring. This flaw is of sufficient size to require analytical evaluation to satisfy section XI (reference 1) requirements for flaw acceptability.

This report documents our analytical evaluation of the flaw.

Conclusions

1. The subject subsurface planar flaw will grow from its present size (see page 2) to an elliptical crack of the dimensions shown on page 40 after 40 years of service under the specified operating conditions.
2. The applied stress intensification factors for normal, upset, and faulted conditions with the final crack size are less than allowable stress intensity factors from section XI, INB-3612 (see page 41). This proves acceptability of the flaw for continued service.

Discussion

This evaluation is based on the procedures of appendix A of section XI. Additional guidance was obtained from reference 5. Stress information was taken from the vessel stress report (reference 2).

Crack growth is predicted for 10-year intervals up to 40 years. An equal number of cycles for each specified operating condition is assumed for each interval.

The final fracture toughness evaluation is based on a 3105 psi hydrotest at 133 F as the limiting condition. Future hydrostatic tests will actually be conducted at higher temperatures. This and other conservative assumptions are noted in the body of the report.

A conservative faulted condition fracture toughness evaluation was also conducted to verify that the hydrotest at 133 F is the limiting condition.

COMPUTED MHR DATE 2-2-72
CHECKED Parikh DATE 3-8-72Characterization Of Existing Flow (Initial Condition)IWA-3320 - Ref 1Subsurface Planar Flaw


$$\text{Fig IWA-3320-1} \quad S = 1\frac{11}{16}'' = 1.6875'' \quad \left. \begin{array}{l} S > a \\ a = \frac{5}{8}'' = .625'' \end{array} \right\} (\text{Neglect Clad})$$

Orientation and Location

(See Sketch)



$$\left. \begin{array}{l} a = \frac{5}{8}'' = .625'' \\ l = 1\frac{7}{8}'' = 1.625'' \end{array} \right\} \frac{a}{l} = .3846$$

$$t = 7.1'' ; \frac{a}{t} = \frac{.625}{7.1} = 0.088 = 8.8\%$$

Flow Lies In $R-\theta$ Plane ie \perp To Meridional Str.Location Is At Weld Between Closure H.d. Domes $\frac{1}{2}$ in.

POOR ORIGINAL

10.20649L



POOR CRICKET

	W	H	I	K	N	O	C
DATE:	10/2/79	UNITS:	200/671	WINGS:	100000	SL:	10000
WING:	1	2	3	4	5	6	7
WING:	8	9	10	11	12	13	14
WING:	15	16	17	18	19	20	21
WING:	22	23	24	25	26	27	28
WING:	29	30	31	32	33	34	35
WING:	36	37	38	39	40	41	42
WING:	43	44	45	46	47	48	49
WING:	50	51	52	53	54	55	56
WING:	57	58	59	60	61	62	63
WING:	64	65	66	67	68	69	70
WING:	71	72	73	74	75	76	77
WING:	78	79	80	81	82	83	84
WING:	85	86	87	88	89	90	91
WING:	92	93	94	95	96	97	98
WING:	99	100	101	102	103	104	105
WING:	106	107	108	109	110	111	112
WING:	113	114	115	116	117	118	119
WING:	120	121	122	123	124	125	126
WING:	127	128	129	130	131	132	133
WING:	134	135	136	137	138	139	140
WING:	141	142	143	144	145	146	147
WING:	148	149	150	151	152	153	154
WING:	155	156	157	158	159	160	161
WING:	162	163	164	165	166	167	168
WING:	169	170	171	172	173	174	175
WING:	176	177	178	179	180	181	182
WING:	183	184	185	186	187	188	189
WING:	190	191	192	193	194	195	196
WING:	197	198	199	200	201	202	203

FERNINGE VOL 22 NO 1

- 1 PRINCIPES PER SPLITTE CHAIN
 - 2 VOORZIENINGEN VAN GELEGELENHEDENS (PG CO) ZIETEN 3001500000
EN VOORZIENINGEN VAN SPLITTERGATES DSSB (VIA PRF PROBLEEM)
 - 3 GLOESEN VAN LEGDE = OPLAASSEN VAN DRUKKINGSWERK
 - 4 LOSSEN VAN HULPHILF VAN CHP LIG 10
 - 5 GLEDEN EN VORMBEWERKEN VAN GATEN IN CHP LIG 10
 - 6 HOUT BEWERKING LASVRIJEN LEG 10.04 F4 19
 - 7 LAASSEN VAN ENDRAGEN 09.05 EN 09.10 AANLEGGEN HOUT
(LET OP STAND DER GATEN VAN KOGELNUTRAADSTOF)
ZUURHOUT
 - 8 VOORWERKINGHOUD SLOTS + GLASSEN (ZIE DETAILS)
 - 9 HOUT BEWERKING SLOTS, OUTGATES, CAD HOLES EN PAKK

ANSWER


W.D. BLOOM	W.D. BLOOM	W.D. BLOOM
R.T.	(DRAFT MAY 2, 1944)	R.P.
H.T.		H.T.
U.T.	-	U.T.

NOTES

DEAR HOT ANDERS & ELEVENTH FLOOR STANDING
HIGH EXCERPTS UNLTD OTHERWISE SPECIFIED -
CENTERLINE -/- IS DEFINED AS A VERTICAL LINE PASSING THROUGH
ALL CLOSURE PLATES
THE INTERSECTION OF THE KEY WAY PLATE (AS FABRICATED) TO THE
-L- IS DEFINED AS THE BASIC REFERENCE FOR THE CLOSURE PLATE
VIGOROUS ETCH VESSELLARIES WITH THEIR RELATIVE NO. 2, 300, 100, 10
DIR. SURFACE.
FOR VENT PIPE AND WELDING CAD MONKINGS SEE Dwg. 30-16-1981

<input checked="" type="checkbox"/>	72	4	KUMAR, RAMESH	6-1-64	5000
<input type="checkbox"/>	71	1	LALAN, MATE	6-1-64	5000
<input type="checkbox"/>	70	6	GOOTY, LALAN	6-1-64	5000
<input checked="" type="checkbox"/>	69	3	PRIMEST, KALYAN	6-1-64	5000

To: Ed Merrick, Woodiss Co.
From: Uncle Howell, Secretary



POOR ORIGINAL

Lucy M. Gaughan

2641179

RE HEAD DOLLAR PLATE W/ELD

HEAD
SECTIONAL

167

COMPUTED BY JHR DATE 2-2-79
CHECKED DAPT DATE 3-9-79Acceptability

IWB-3430, IWB-3510, Table I WB-3510-1 Ref 1

$$\text{P.Allowable } \%t = 4.6 + \left(\frac{3846 - .35}{.40 - .35} \right) (5.2 - 4.6) = 5.015\%$$

$$\text{Flow } \%t = \underline{8.8\%} > \text{Allowable}$$

→ Analytical Evaluation Required Per IWB-3600 (Ref 1)

Analytical Evaluation Of Indication - General Procedure

- Apply Appendix A procedures to determine α_f for Normal and Upset conditions specified by E-Spec. Determine α_f for 10 year intervals.
- At the end of specified 40 year interval evaluate fracture toughness for applied stress intensity factor as described in IWB-3612, for Normal, Upset and Faulted Conditions.

→ * A total of 10^7 cycles of steady state fluctuations to the limit ($\pm 100 \text{ psi}$) are assumed for fatigue evaluation. This assumption was also made by RDM for their code fatigue evaluation in the stress report. ←

Material Properties

- Closure Head Dome - A533 B, CL. 1

$RT_{NDT} = -17^{\circ}\text{F}$ (Insignificant Irradiation Effects)
 (See next page)

Temp ($^{\circ}\text{F}$)	100	200	300	400	500	600
σ_y (ksi)	50.	47.1	45.2	44.5	43.2	42.0

K_{IC} and $K_{Ia} \Rightarrow$ Section XII, Fig A-4200-1 * Ref 1

* Assume Upper Shelf K_{IC} and $K_{Ia} = 200$ ksi in^{-1}

$\frac{d\delta}{dN}$ Curve \Rightarrow Section XII (Fig A-4300-1)

- Closure Head Ring - A508, CL. 2

$RT_{NDT} = +5^{\circ}\text{F}$ (Insignificant Irradiation Effects)
 (See Next Page)

Other Properties Same As For Closure Head Dome

- Weld Between Closure Head Dome and Ring

Same As Ring.

1
TABLE 5.2-30
SEQNOYAH NO. 1^f REACTOR VESSEL TOUGHNESS DATA

COMPONENT	MATERIAL GRADE	Cu (%)	P (%)	IDTT (°F)	MINIMUM 50 ft-lb/35 mil temp. Long. (")		RT _{NDT} (°F)	MINIMUM IMPACT ENERGY at highest test temp. Long. Trans.	
					Trans. (")	Trans. (°F)		Long.	Trans.
Clos. Ed. Dome	A533B, Cl. 1	-	-	-40	2	43 ^a	-27	103.7 ^{**}	
Clos. Ed. Ring	A508, Cl. 2	-	-	+5	35.5	56.3 ^a	+5	125.6 ^{**}	
Ed. Flange	A503, Cl. 2	-	-	-40	-53	-28 ^a	-40	117.5 ^{**}	
Vessel Flange	A508, Cl. 2	-	-	-49	-63	-57 ^a	-49	157.0 ^{**}	
Inlet Nozzle	A508, Cl. 2	-	-	-58	25	50 ^a	-10	85.2 ^{**}	
Inlet Nozzle	A508, Cl. 2	-	-	-40	32	72.5 ^a	+12.5	92.7 ^{**}	
Inlet Nozzle	A508, Cl. 2	-	-	-22	-4	20 ^a	-22	112.9 ^{**}	
Inlet Nozzle	A508, Cl. 2	-	-	-67	8.6	63.6 ^a	+3.6	78.3 ^{**}	
Outlet Nozzle	A508, Cl. 2	-	-	-49	17.6	39 ^a	-21	85.2 ^{**}	
Outlet Nozzle	A508, Cl. 2	-	-	-58	30	60 ^a	0	75.5 ^{**}	
Outlet Nozzle	A503, Cl. 2	-	-	-58	16	22 ^a	-30	108.3 ^{**}	
Outlet Nozzle	A508, Cl. 2	-	-	-49	-4	15 ^a	-45	123.3 ^{**}	
Upper Shell	A508, Cl. 2	-	-	-40	43	70 ^a	+10	74.8 ^{**}	
Inter. Shell	A503, Cl. 2	0.15	.011	-4	10	100	+40	116	64
Lower Shell	A503, Cl. 2	0.13	.015	+5	75	133 ^a	+73	109 ^{**}	51
Trans. Ring	A503, Cl. 2	-	-	+5	26.3	44.5 ^a	+5	82.4 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-31	23	40 ^a	-12	103.7 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-31	23	40 ^a	-12	103.7 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-13	35.5	NA	<60 ^a	62.6 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-31	39	57 ^a	-3	86.4 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-49	-24	-3 ^a	-49	114 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-58	-13	+3 ^a	-57	120.4 ^{**}	
Bot. Ed. Ring	A533B, Cl. 1	-	-	-59	-67	11 ^a	-53	137.7 ^{**}	
Weld	Weld	.25	NA	-40	--	-4	-40	--	116.9 ^{\$}
HAZ	Weld HAZ	--	--	-22	--	41	-19	--	85.8 ^{\$}

^a Estimated (77 ft-lb/34 mil temp. for longitudinal data).

^{**} Percent shear was not reported. The number given in the table is the minimum impact energy value at the highest test temperature (563°F). No transverse upper shelves were estimated because the longitudinal upper shelves were not reached at the test temperatures. The longitudinal upper shelf could be estimated conservatively as 115 ft-lb based on data from Watts Bar Units 1 and 2 vessels which are also being built by the Rotterdam Dockyard Co.

^{\$} The percent shear was reported for weld and HAZ. The number shown is the true upper shelf.

^a Estimated conservatively as 60°F or less.

COMPUTED OHR DATE 2-2-75
CHECKED Curt DATE 3-8-75Evaluation of Existing Flaw For Hydrotest Conditions

$$\rightarrow P = 3105 \text{ psig}$$

$$T = 73 + 60 = 133^{\circ}\text{F}$$

$$a_f = .625"$$

$$T - RT_{NOT} = 133 - 5 = 128^{\circ}\text{F}$$

$$\sigma_y = 50 \text{ ksi}$$

$$K_{Ia} = 105 \text{ ksi}^{\sqrt{in}}, K_{Ic} = 200 \text{ ksi}^{\sqrt{in}} \quad (\text{Fig A-4200-1})$$

Stress Condition

Ref: Stress Report 30616-1105, Page B.3-14 and 15

Membrane	= 11.24 $\frac{\text{kgt}}{\text{mm}^2}$	Design Condition Stresses $p = 1.75 \frac{\text{kgt}}{\text{cm}^2}$
Bending	= -4.05 " "	
Inside	= 7.19 " "	
Outside	= 15.30 " "	

$$\text{Pressure used in Analysis} = (1.75)(1422) = 2488.5 \text{ psi}$$

$$\text{Hydrotest Stresses in ksi, Factor} = (1.422) \frac{(3105)}{2488.5}$$

$$\sigma_m = (11.24)(1.774) = +19.94 \text{ ksi}$$

$$\sigma_b = (-4.05)(1.774) = -7.18 \text{ ksi} \quad (\text{Compressive to Inside})$$

Stress Intensity Factor

Article A-3300

$$K_I = \sigma_m m_m \sqrt{\pi} \sqrt{\%_Q} + \sigma_b m_b \sqrt{\pi} \sqrt{\%_Q}$$

Fig. A-3300-1

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{19.94 - 7.18}{50.0} = .255 ; \%_Q = .385 ; Q = 1.9$$

Ref Fig A-3300.2

$$\frac{2a}{t} = \frac{(2)(.625)}{7.1} = 0.176$$

$$e = 1.2375, \quad \frac{2e}{t} = \frac{(2)(1.2375)}{7.1} = 0.349$$

$$M_m \approx \underline{1.02} @ P_{t_1} \text{ and } P_{t_2}$$

Ref Fig A-3300-7

$$M_{b_1} = .45 @ P_{t_1} \text{ (Toward Inside Of Vessel)}$$

$$M_{b_2} = .25 @ P_{t_2} \text{ (Toward Outside Of Vessel)}$$

Calculate K_I

$$K_{I_{2.2}} = (19.94)(1.02) \sqrt{\frac{.625}{7.15}} + (-7.18)(.25) \sqrt{\frac{.625}{7.15}} \\ = 20.41 - 1.82 = \underline{18.59 \text{ ksi/in}} \text{ (to outside)}$$

$$K_{I_{1.1}} = (19.94)(1.02) \sqrt{\frac{.625}{7.15}} + (-7.18)(.45) \sqrt{\frac{.625}{7.15}} \\ = 20.41 - 3.28 = \underline{17.13 \text{ ksi/in}} \text{ (to inside)}$$

Compare K_I to K_{Ia} Allowable

Ref INB-3612

$$K_{Ia}/\sqrt{t_0} = \frac{10.5}{\sqrt{10}} = \underline{33.2} > K_{I_{max}} = \underline{18.59}$$

Conclusion: Existing Flow Meets Criteria @ $T = 133^\circ F$ Minimum Hydro Test Temperature Corresponds To
 $K_{Ia} = (18.59)(\sqrt{10}) = 58.8 \text{ ksi/in}$

$$\therefore T_{min} = 70 + RT_{NDT} = 70 + 5 = \underline{75^\circ F} \text{ for present fl.}$$

COMPUTED OKR DATE 2-3-79
CHECKED West DATE 3-8-79Stress Cycles At $\phi = 63.2^\circ$ - From RDM Stress Report1. Primary Side Hydro - (2 Occurrences in 10 years + conserv.)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Zero	0	0
Preload	+1.37	-26.12
Hydrotest	+20.23	-22.42

2. Primary Side Leak Test - (13 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Zero	0	0
Preload	+1.23	-23.40
Heatup @ 12600 sec	+15.59	-24.39
Heatup @ 13080 sec	+15.59	-23.58
Heatup @ 14070 sec	+15.63	-21.50
Heatup @ 15000 sec	+15.67	-20.63
Heatup @ 18000 sec	+15.80	-19.98
Heatup @ 21000 sec	+15.88	-19.78
Leak Test @ 2485 psi	+16.23	-19.18
Cooldown @ 12600 sec	+4.11	-17.11
Cooldown @ 13080 sec	+4.11	-18.00
Cooldown @ 14070 sec	+4.07	-19.95
Cooldown @ 15000 sec	+4.01	-20.62
Cooldown @ 18000 sec	+3.85	-20.22
Cooldown @ 21000 sec	+3.75	-20.68 ?

3. Plant Heatup and Cooldown (50 Occurrences in 10 Years)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Preload	+1.23	-25.40
Heatup @ 17280 sec	+13.84	-25.16
Heatup @ 18000 sec	+13.85	-23.52
Heatup @ 19080 sec	+13.92	-21.25
Heatup @ 21600 sec	+13.92	-20.42
Heatup @ 23400 sec	+14.06	-20.19
Heatup @ 25200 sec	+14.13	-20.01
Heatup @ 28800 sec	+14.22	-19.67
Heatup @ 32400 sec	+14.31	-19.30
Normal Full Power @ 2225psi	+14.65	-19.80
Cooldown @ 17280 sec	+4.19	-15.55
Cooldown @ 18000 sec	+4.18	-17.23
Cooldown @ 19080 sec	+4.10	-19.31
Cooldown @ 21600 sec	+4.02	-19.91
Cooldown @ 23400 sec	+3.95	-20.08
Cooldown @ 25200 sec	+3.88	-20.15
Cooldown @ 28800 sec	+3.80	-20.26
Cooldown @ 32400 sec	+3.68	-19.44

4. Small Step Load Increase (500 Occurrences in 10 Years)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-18.80
First Peak	+15.25	-18.41
Second Peak	+15.46	-17.37

5. Small Step Load Decrease (500 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-18.80
First Peak	+13.89	-20.22
Second Peak	+13.76	-19.43

COMPUTED BY R DATE 2-3-79
CHECKED BY P.D. DATE 3-8-796. Large Step Load Decrease (50 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (k)
Normal Full Power	+14.65	-18.80
First T Peak	+13.87	-20.41
Pressure Peak	+12.73	-19.39
Second T Peak	+14.75	-17.70

7. Loss of Load (20 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (k)
Normal Full Power	+14.65	-18.80
First T Peak	+13.66	-22.30
Second T Peak	+10.51	-19.75

8. Loss of Power (10 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (k)
Normal Full Power	+14.65	-18.80
First T Peak	+12.61	-20.27
Pressure Peak	+14.34	-18.64
Second T Peak	+16.25	-18.36

9. Loss of Flow (20 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (k)
Normal Full Power	+14.65	-18.80
First T Peak	+12.59	-20.47
Second T Peak	+13.27	-18.04

10. Reactor Trip From Full Power (100 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (k)
Normal Full Power	+14.65	-18.80
First T Peak	+13.78	-19.20
Second T Peak	+13.24	-18.05

COMPUTED HAR DATE 2-3-79
CHECKED DR DATE 3-8-7911. Turbine Roll Test (3 Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-18.80
Test	+15.69	-11.34

12. Steady State Fluxuations (2.5x10⁶ Occurrences in 10 years)

Condition	Mean Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-18.80
First T Peak	+14.21	-18.82
Second T Peak	+14.55	-18.25

COMPUTED MHR DATE 2-4-75
CHECKED RWD DATE 3-9-75Relationship Between Stresses at $\phi = 56^\circ$ And $\phi = 63.2^\circ$ Design Condition ($P = 2485 \text{ ksi}$)(Stresses for 10 locations from $\phi = 66.8^\circ$ to $\phi = 56^\circ$ given in RDM stress report)

$$\phi = 63.2^\circ \quad \sigma_m = (11.37)(1.422) = 16.17 \text{ ksi}$$

$$\sigma_b = (-12.61)(1.422) = -17.93 \text{ ksi}$$

$$\phi = 56^\circ \quad \sigma_m = (11.24)(1.422) = 15.98 \text{ ksi}$$

$$\sigma_b = (-4.05)(1.422) = -5.76 \text{ ksi}$$

Preload For Design ($P = 0$)(Stresses at $\phi = 66.8^\circ, 65.6^\circ, 64.4^\circ$, and 63.2° given in RDM stress report)

$$\phi = 63.2^\circ \quad \sigma_m = (.86)(1.422) = +1.22 \text{ ksi}$$

$$\sigma_b = (-16.46)(1.422) = -23.41 \text{ ksi}$$

$$\phi = 56^\circ \quad \sigma_m = +1.22 \text{ ksi}$$

(estimate) $\sigma_b = (-5.76)(-1.13) = -6.51 \text{ ksi}$

$\phi (\circ)$	66.8	65.6	64.4	63.2	62.0	60.8	59.6	58.4	57.2
$(\frac{\sigma_b}{\sigma_b \text{ design}})$	1.390	1.364	1.334	1.305	1.22	1.25	1.22	1.19	1.16

From Stress Report Extrapolated

Hydrotest Condition ($P = 3105 \text{ psi}$)

$$\phi = 63.2^\circ \quad \sigma_m = (14.22)(1.422) = 20.22 \text{ ksi}$$

$$\sigma_b = (-15.77)(1.422) = -22.42 \text{ ksi}$$

$$\phi = 56^\circ \quad \sigma_m = (15.98)(\frac{3105}{2485}) = 19.97 \text{ ksi} \quad (\text{use } 20.22)$$

(estimate) $\sigma_b = (-5.76)(\frac{3105}{2485}) = -7.22 \text{ ksi}$

COMPUTED BY JHR DATE 2-4-79
 CHECKED BWHT DATE 3-8-79

Preload For Hydrotest ($P=0$)

$$\phi = 63.2^\circ \quad \sigma_m = (.96)(1.422) = +1.37 \text{ ksi}$$

$$\sigma_b = (-18.37)(1.422) = -26.12 \text{ ksi}$$

$$\phi = 56^\circ \quad \sigma_m = +1.37 \text{ ksi}$$

$$(\text{est}) \quad \sigma_b = (-6.51)\left(\frac{385}{2485}\right) = -3.13 \text{ ksi}$$

Normal Operating Full Power ($P = 2235 \text{ psi}$)

$$\phi = 63.2^\circ \quad \sigma_m = (0.30)(1.422) = 14.65 \text{ ksi}$$

$$\sigma_b = (-13.22)(1.422) = -18.80 \text{ ksi}$$

$$\phi = 56^\circ \quad \sigma_m = 14.65 \text{ ksi}$$

$$(\text{est}) \quad \sigma_b = (-6.51) + (6.51 - 5.76)\left(\frac{2235}{2485}\right) = -6.15 \text{ ksi}$$

Pressure = 385 psi

$$\phi = 63.2^\circ \quad \sigma_m = 3.75 \text{ ksi} \quad (\text{From RDM Stress Report})$$

$$(\text{est}) \quad \sigma_b = -23.41 + (23.41 - 17.93)\left(\frac{385}{2485}\right) = -22.56 \text{ ksi}$$

$$\phi = 56^\circ \quad \sigma_m = 3.75 \text{ ksi}$$

$$(\text{est}) \quad \sigma_b = -6.51 + (6.51 - 5.76)\left(\frac{385}{2485}\right) = -6.35 \text{ ksi}$$

General Relationship For Design and Operating Conditions

Membrane Stress Relationship

$$\boxed{\sigma_{m56} = \sigma_{m63.2}} \quad (\text{Conservative}).$$

Bending Stress Relationship

Pressure and Preload

$$\sigma_{F_{56}} = -6.51 + (6.51 - 5.76)\left(\frac{P}{2485}\right) = -6.51 + 0.76\left(\frac{P}{2485}\right)$$

$$\sigma_{P_{56}} = -23.41 + (23.41 - 17.93)\left(\frac{P}{2485}\right) = -23.41 + 5.48\left(\frac{P}{2485}\right)$$

Bending-Stress Relationships* (Continued)

+ 16.90 - 4.73

Thermal

$$\sigma_T)_{b_{56}} = \sigma_T)_{b_{63.2}} \quad (\text{Conservative})$$

$$(\sigma_P + \sigma_T)_{b_{56}} = (\sigma_P + \sigma_T)_{b_{63.2}} + 16.90 - 4.73 \left(\frac{P}{2485} \right) \quad (\text{General Relationship})$$

For $P = 0$ (Preload for Design and Operation)

$$\sigma_{b_{56}} = \sigma_{b_{63.2}} + 16.90 = -23.41 + 16.90 = \underline{-6.51 \text{ ksi}}$$

For $P = 2485$ (Design)

$$\sigma_{b_{56}} = \sigma_{b_{63.2}} + 16.90 - 4.73 = -17.93 + 16.90 - 4.73 = \underline{-5.76 \text{ ksi}}$$

For $P = 2235$ Normal Full Power

$$\begin{aligned} \sigma_{b_{56}} &= \sigma_{b_{63.2}} + 16.90 - 4.73 \left(\frac{P}{2485} \right) \\ &= -18.80 + 16.90 - 4.25 = \underline{-6.15 \text{ ksi}} \end{aligned}$$

For $P = 385$

$$\begin{aligned} \sigma_{b_{56}} &= \sigma_{b_{63.2}} + 16.90 - 4.73 \left(\frac{385}{2485} \right) \\ &= \underline{\sigma_{b_{63.2}} + 16.16} \end{aligned}$$

* Note: P subscript indicates pressure and preload stress.
 T subscript indicates thermal stress.

COMPUTED BY MR DATE 2-4-75
CHECKED BY J.W.F. DATE 3-3-75Stress Cycles At $\phi = 56.0^\circ$ 1. Primary Side Hydrostatic Test

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Zero	0	0
Preload	+1.37	-8.13
Hydrotest	+20.22	-7.20

2. Primary Side Leak Test

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Zero	0	0
Preload	+1.23	-6.51
Heatup @ 12600 sec	+15.59	-12.22
Heatup @ 13080 sec	+15.59	-11.41
Heatup @ 14040 sec	+15.63	-9.33
Heatup @ 15000 sec	+15.67	-8.46
Heatup @ 18000 sec	+15.80	-7.81
Heatup @ 21000 sec	+15.88	-7.61
Leak Test @ 2435 psi	+16.23	-7.01
Cooldown @ 12600 sec	+4.11	-0.95
Cooldown @ 13080 sec	+4.11	-1.84
Cooldown @ 14040 sec	+4.07	-3.79
Cooldown @ 15000 sec	+4.01	-4.40
Cooldown @ 18000 sec	+3.85	-4.66
Cooldown @ 21000 sec	+3.75	-4.52

3. Plant Heatup and Cooldown

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Preload	+1.23	≈ 6.51
Heatup @ 17280 sec	+13.84	-12.51
Heatup @ 18000 sec	+13.85	-10.87
Heatup @ 19080 sec	+13.92	-8.50
Heatup @ 21600 sec	+13.92	-7.77
Heatup @ 23400 sec	+14.06	-7.54
Heatup @ 25200 sec	+14.13	-7.36
Heatup @ 28800 sec	+14.22	-7.02
Heatup @ 32400 sec	+14.31	-6.65
Normal Full Power	+14.65	-6.15
Cooldown @ 17280 sec	+4.19	+0.61
Cooldown @ 18000 sec	+4.18	-1.07
Cooldown @ 19080 sec	+4.10	-3.15
Cooldown @ 21600 sec	+4.02	-3.75
Cooldown @ 23400 sec	+3.95	-3.92
Cooldown @ 25200 sec	+3.88	-3.99
Cooldown @ 28800 sec	+3.80	-4.10
Cooldown @ 32400 sec	+3.68	-3.28

4. Small Step Load Increase

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	≈ 6.15
First Peak p=2295	+15.25	-5.88
Second Peak p=2170	+15.46	-4.60

5. Small Step Load Decrease

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak p=2310	+13.89	-7.72
Second Peak p=2155	+13.76	-6.63

COMPUTED BY DATE 2-4-79
CHECKED BY DATE 3-8-796. Large Step Load Decrease

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak $p=2335$	+13.87	-7.95
Pressure Peak $p=1960$	+12.78	-6.22
Second Peak $p=2135$	+14.75	-4.86

7. Loss of Load

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak $p=2535$	+13.66	-10.32
Second Peak $p=1605$	+10.51	-7.77

8. Loss of Power

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak $p=2065$	+12.61	-7.30
Pressure Peak $p=2160$	+14.34	-5.85
Second Peak $p=2485$	+16.25	-6.19

9. Loss of Flow

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak $p=2110$	+12.59	-7.59
Second Peak $p=1865$	+13.27	-4.69

10. Reactor Trip From Full Power

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak $p=2335$	+13.78	-6.74
Second Peak $p=1960$	+13.24	-4.83

COMPUTED CHR DATE 2-4-72
CHECKED AWL DATE 3-8-7211. Turbine Roll Test

Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
Test $p = 1932$	+15.69	+1.88

12. Steady State Fluxuations


Condition	Membrane Stress (ksi)	Bending Stress (ksi)
Normal Full Power	+14.65	-6.15
First Peak $p = 2335$	+14.21	-6.36
Second Peak $p = 2135$	+14.55	-5.41

COMPUTED BY JR DATE 2-5-79
CHECKED DML DATE 3-9-79Crack Growth For First 10 Years Of ServiceAssumptions

1. Use $\frac{da}{dN}$ curve from Section XI, Appendix A, Fig A 4300-1

$$\frac{da}{dN} = (0.0267)(10^{-3}) \Delta K_I^{3.726}$$

2. Determine ΔK_I for each normal and upset operating condition at $\phi = 56^\circ$.
3. Use initial properties for crack size.



$$\begin{aligned}
 a &= .625" & \%_e &= 0.088 = 8.8\% & \%_t &= 0.176 \\
 l &= 1.625" & \%_l &= 0.3846 & &
 \end{aligned}$$

Primary Side Hydrostatic Test

1. Preload Condition

$$\sigma_m = +1.37 \text{ ksi}, \sigma_b = -8.13 \text{ ksi}, T = 70^\circ F, \sigma_y = 50 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{1.37 + (-8.13)}{50} = 0.19, \%, \%_L = 0.3846$$

$$Q = 1.9 \quad (\text{Fig A-3300-1})$$

$$\frac{2a}{t} = 0.176, \frac{2e}{t} = \frac{(2)(1.2375)}{7.1} = 0.3486$$

$$M_m = 1.02 @ P_t: 1 \text{ and } z \quad (\text{Fig A-3300-2})$$

$$M_{b_1} = .45, M_{b_2} = .25 \quad (\text{Fig A-3300-4})$$

$$K_I = \sigma_m M_m \sqrt{\pi} \sqrt{\frac{a}{Q}} + \sigma_b M_b \sqrt{\pi} \sqrt{\frac{a}{Q}}$$

*Sett (1.016) 2-5-79
Conservative*

$$= \sigma_m M_m \sqrt{\frac{1.2375}{1.9}} + \sigma_b M_b \sqrt{\frac{1.2375}{1.9}} = 1.033 (\sigma_m M_m + \sigma_b M_b)$$

$$K_{I_1} = (1.033) [(1.37)(1.02) + (-8.13)(.45)] = -2.34 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = (1.033) [(1.37)(1.02) + (-8.13)(.25)] = -.66 \text{ ksi} \sqrt{\text{in}}$$

2. Test Condition ($P = 3105 \text{ psi}$)

$$\sigma_m = +20.22 \text{ ksi}, \sigma_b = -7.20 \text{ ksi}, T = 113^\circ F, \sigma_y = 50 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{20.22 + (-7.20)}{50} = 0.55, \%, \%_L = 0.3846$$

$$Q = 1.9 \quad (\text{Fig A-3300-1}), M_m = 1.02, M_b = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(20.22)(1.02) + (-7.20)(.45)] = +17.96 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(20.22)(1.02) + (-7.20)(.25)] = +19.45 \text{ ksi} \sqrt{\text{in}}$$

$$3. \Delta K_r = 17.96 - (-2.34) = 20.30 \text{ ksi} \sqrt{\text{in}} = \Delta K_{eff} 185$$

4. Growth (micro-inches/cycle)

$$\frac{da}{dN} = (.0267)(10^{-3})(\Delta K_I)^{3.726}$$

$$= (.0267)(10^{-3})(20.30)^{3.726} = 1.987$$

Primary Side Leak Test

1. Preload

$$\sigma_m = +1.23 \text{ ksi}, \sigma_b = -6.51 \text{ ksi}, T = 70^\circ F, \sigma_y = 50 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{1.23 + 6.51}{50} = .19, \eta_L = 0.3846, Q = 1.9$$

$$M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(1.23)(1.02) + (-6.51)(.45)] = -1.73 \text{ ksi/in}$$

$$K_{I_2} = 1.033 [(1.23)(1.02) + (-6.51)(.25)] = -.39 \text{ ksi/in}$$

2. Heatup @ 12600 sec.

$$\sigma_m = 15.59 \text{ ksi}, \sigma_b = -12.22 \text{ ksi}, T \approx T_{fluid} - 50 = 350^\circ F, \sigma_y =$$

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{15.59 + 12.22}{50} = .62, \eta_L = 0.3846$$

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(15.59)(1.02) + (-12.22)(.45)] = +10.75 \text{ ksi/in}$$

$$K_{I_2} = 1.033 [(15.59)(1.02) + (-12.22)(.25)] = +13.27 \text{ ksi/in}$$

COMPUTED BY R.R. DATE 2-5-79
CHECKED BY P.W.H. DATE 3-8-79

3. Leak Test @ 2435 psi

$$\sigma_m = 16.23 \text{ ksi}, \sigma_b = -7.01 \text{ ksi}, T = T_{\text{fluid}} = 400^\circ F, \sigma_y = 44.5 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{16.23 + (-7.01)}{44.5} = 0.52, \% \ell = 0.3846, Q = 1.9$$

$$M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(16.23)(1.02) + (-7.01)(.45)] = +13.84 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(16.23)(1.02) + (-7.01)(.25)] = +15.29 \text{ ksi} \sqrt{\text{in}}$$

4. Cooldown @ 18000 sec.

$$\sigma_m = 3.85 \text{ ksi}, \sigma_b = -4.66 \text{ ksi}, T = T_{\text{fluid}} = 70^\circ F, \sigma_y = 50 \text{ ksi}$$

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(3.85)(1.02) + (-4.66)(.45)] = +1.89 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(3.85)(1.02) + (-4.66)(.25)] = +2.85 \text{ ksi} \sqrt{\text{in}}$$

5. Growth (micro inches/cycle)

$$\frac{da}{dN} = (.0267)(10^{-3})(\Delta K_I)^{3.726}$$

$$\Delta K_I = 15.29 - (-.39) = 15.68 \text{ ksi} \sqrt{\text{in}} = \Delta K_{I_2}$$

$$\frac{da}{dN} = (.0267)(10^{-3})(15.68)^{3.726} = .7532$$

Plant Heatup and Cooldown

1. Preload Condition

Same as for Leak Test

$$K_{I_1} = -1.73 \text{ ksi} \sqrt{\text{in}} ; K_{J_2} = -0.39 \text{ ksi} \sqrt{\text{in}}$$

2. Heatup @ 17280 sec

$$\sigma_m = 13.84 \text{ ksi}, \sigma_b = -12.51 \text{ ksi}, T = T_{\text{fluid}} - 50^\circ = 547 - 50 = 500^\circ$$

$$\sigma_y = 43.2 \text{ ksi}, \frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{13.84 + (-12.51)}{43.2} = .061$$

$$Q = 1.90, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(13.84)(1.02) + (-12.51)(.45)] = +8.77 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(13.84)(1.02) + (-12.51)(.25)] = +11.35 \text{ ksi} \sqrt{\text{in}}$$

3. Normal Full Power ($p = 2235 \text{ psi}$)

$$\sigma_m = 14.65 \text{ ksi}, \sigma_b = -6.15 \text{ ksi}, T = 547^\circ \text{F}, \sigma_y = 42.6 \text{ ksi}$$

$$\frac{\sigma_m + \sigma_b}{\sigma_y} = \frac{14.65 + (-6.15)}{42.6} = 0.49$$

$$Q = 1.90, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(14.65)(1.02) + (-6.15)(.45)] = +12.58 \text{ ksi}$$

$$K_{I_2} = 1.033 [(14.65)(1.02) + (-6.15)(.25)] = +13.35 \text{ ksi}$$

4. Cooldown @ 28800 sec

$$\sigma_m = 3.80 \text{ ksi}, \sigma_b = -4.10 \text{ ksi}, T = 70^\circ F, \sigma_y = 50 \text{ ksi}$$

$$Q = 1.9, M_m = 1.02, M_{b1} = .45, M_{b2} = .25$$

$$K_{I_1} = 1.033 [(3.80)(1.02) + (-4.10)(.45)] = +2.10 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(3.80)(1.02) + (-4.10)(.25)] = +2.95 \text{ ksi} \sqrt{\text{in}}$$

5. Growth (micro inches / cycle)

$$\frac{da}{dN} = (0.0267)(10^{-3})(\Delta K_I)^{3.726}$$

$$\Delta K_I = 12.58 - (-1.73) = 14.31 \text{ ksi} \sqrt{\text{in}} = \Delta K_I,$$

$$\frac{da}{dN} = (0.0267)(10^{-3})(14.31)^{3.726} = \underline{0.540}$$

Small Step Load Increase

1. Normal Full Power

See previous calc. $K_{I_1} = +12.58 \text{ ksi } \sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi } \sqrt{\text{in}}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_b = .45, M_{b_2} = .25, \sigma_m = 15.25 \text{ ksi}, \sigma_b = -5.83$$

$$K_{I_1} = 1.033 [(15.25)(1.02) + (-5.83)(.45)] = 13.34 \text{ ksi } \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(15.25)(1.02) + (-5.83)(.25)] = 14.55 \text{ ksi } \sqrt{\text{in}}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_b = .45, M_{b_2} = .25, \sigma_m = 15.46 \text{ ksi}, \sigma_b = -4.60$$

$$K_{I_1} = 1.033 [(15.46)(1.02) + (-4.60)(.45)] = 14.15 \text{ ksi } \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(15.46)(1.02) + (-4.60)(.25)] = 15.10 \text{ ksi } \sqrt{\text{in}}$$

4. Crack Growth (micro inches/cycle)

$$\frac{ds}{dN} = (.0267)(10^{-3}) \Delta K^3.726$$

$$\Delta K_{I_1} = 14.15 - 12.58 = 1.57, \Delta K_{I_2} = 15.10 - 13.85 = 1.25$$

$$\frac{ds}{dN} = (0.0267)(10^{-3})(1.57)^{3.726} = \underline{0.143(10^{-3})}$$

COMPUTED BY JHR DATE 2-5-79
CHECKED PWT DATE 3-8-79Small Step Load Decrease

1. Normal Full Power

See Previous Calc. $K_{I_1} = +12.58 \text{ ksi} \sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi} \sqrt{\text{in}}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_b = .45, M_{b_2} = .25, \sigma_m = 13.89, \sigma_b = -7.7$$

$$K_{I_1} = 1.033 [(13.89)(1.02) + (-7.72)(.45)] = 11.05 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(13.89)(1.02) + (-7.72)(.25)] = 12.64 \text{ ksi} \sqrt{\text{in}}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_b = .45, M_{b_2} = .25, \sigma_m = 13.76, \sigma_b = -6.$$

$$K_{I_1} = 1.033 [(13.76)(1.02) + (-6.63)(.45)] = 11.42 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(13.76)(1.02) + (-6.63)(.25)] = 12.79 \text{ ksi} \sqrt{\text{in}}$$

4. Crack Growth

$$\frac{da}{dN} = (.0267)(10^{-3})(\Delta K_I)^{3.726}$$

$$\Delta K_{I_1} = 12.58 - 11.05 = 1.53 ; \Delta K_{I_2} = 13.85 - 12.64 = 1.21$$

$$\frac{da}{dN} = (0.0267)(10^{-3})(1.53)^{3.726} = \underline{0.130(10^{-3})}$$

Large Step Load Decrease

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi} \sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi} \sqrt{\text{in}}$

2. First Peak

$$\sigma_m = 13.87 \text{ ksi}, \sigma_s = -7.95 \text{ ksi}$$

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25$$

$$K_{I_1} = 1.033 [(13.87)(1.02) + (-7.95)(.45)] = 10.92 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(13.87)(1.02) + (-7.95)(.25)] = 12.56 \text{ ksi} \sqrt{\text{in}}$$

2. Pressure Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 12.78 \text{ ksi}, \sigma_s = -6.22 \text{ ksi}$$

$$K_{I_1} = 1.033 [(12.78)(1.02) + (-6.22)(.45)] = 10.57 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(12.78)(1.02) + (-6.22)(.25)] = 11.86 \text{ ksi} \sqrt{\text{in}}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 14.75 \text{ ksi}, \sigma_s = -4.86 \text{ ksi}$$

$$K_{I_1} = 1.033 [(14.75)(1.02) + (-4.86)(.45)] = 13.22 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(14.75)(1.02) + (-4.86)(.25)] = 14.29 \text{ ksi} \sqrt{\text{in}}$$

4. Crack Growth (MicroInches/Cycle)

$$\Delta K_{I_1} = 13.22 - 10.57 = 2.71, \Delta K_{I_2} = 14.29 - 11.86 = 2.43$$

$$\frac{dg}{dN} = (.0267 \times 10^{-3}) (1/K_g)^{3.706} \approx \underline{1.096 \times 10^{-3}} \quad 461 \quad 192$$

Loss of Load

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi}\sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi}\sqrt{\text{in}}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_b = .45, M_{b_2} = .25, \sigma_m = 13.66 \text{ ksi}, \sigma_b = -10.32 \text{ ksi}$$

$$K_{I_1} = 1.033 [(13.66)(1.02) + (-10.32)(.45)] = 9.60 \text{ ksi}\sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(13.66)(1.02) + (-10.32)(.25)] = 11.73 \text{ ksi}\sqrt{\text{in}}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_b = .45, M_{b_2} = .25, \sigma_m = 10.51 \text{ ksi}, \sigma_b = -7.77 \text{ ksi}$$

$$K_{I_1} = 1.033 [(10.51)(1.02) + (-7.77)(.45)] = 7.46 \text{ ksi}\sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(10.51)(1.02) + (-7.77)(.25)] = 9.07 \text{ ksi}\sqrt{\text{in}}$$

4. Crack Growth (MicroInches/Cycle)

$$\Delta K_{I_1} = 12.58 - 7.46 = 5.12 ; \Delta K_{I_2} = 13.85 - 9.07 = 4.78$$

$$\frac{dy}{dn} = (0.0267)(10^{-3})(\Delta K_i)^{3.725} = \underline{11.73(10^{-3})}$$

Loss of Power

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi}\sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi}\sqrt{\text{in}}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 12.61 \text{ ksi}, \sigma_b = -7.30 \text{ ksi}$$

$$K_{I_1} = 1.033 [(12.61)(1.02) + (-7.30)(.45)] = 9.39 \text{ ksi}\sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(12.61)(1.02) + (-7.30)(.25)] = 11.40 \text{ ksi}\sqrt{\text{in}}$$

3. Pressure Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 14.34 \text{ ksi}, \sigma_b = -5.85$$

$$K_{I_1} = 1.033 [(14.34)(1.02) + (-5.85)(.45)] = 12.39 \text{ ksi}\sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(14.34)(1.02) + (-5.85)(.25)] = 13.60 \text{ ksi}\sqrt{\text{in}}$$

4. Second Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma = 16.25 \text{ ksi}, \sigma_b = -6.19$$

$$K_{I_1} = 1.033 [(16.25)(1.02) + (-6.19)(.45)] = 14.24 \text{ ksi}\sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(16.25)(1.02) + (-6.19)(.25)] = 15.52 \text{ ksi}\sqrt{\text{in}}$$

5. Crack Growth

$$\Delta K_{I_1} = 14.24 - 9.39 = 4.85, \Delta K_{I_2} = 15.52 - 11.40 = 4.12$$

$$\frac{da}{dN} = 0.0267 (\Delta K_I)^{3.75} = \underline{6.330(10^{-3})}$$

COMPUTED JKR DATE 2-5-74
CHECKED Dept DATE 3-8-74Loss of Flow

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi} \sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi} \sqrt{\text{in}}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 12.59 \text{ ksi}, \sigma_b = -7.59 \text{ ksi}$$

$$K_{I_1} = 1.033 [(12.59)(1.02) + (-7.59)(.45)] = 9.74 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(12.59)(1.02) + (-7.59)(.25)] = 11.31 \text{ ksi} \sqrt{\text{in}}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 13.27 \text{ ksi}, \sigma_b = -4.69$$

$$K_{I_1} = 1.033 [(13.27)(1.02) + (-4.69)(.45)] = 11.80 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(13.27)(1.02) + (-4.69)(.25)] = 12.77 \text{ ksi} \sqrt{\text{in}}$$

4. Crack Growth: (Micro-Inches/Cycle)

$$\Delta K_{I_1} = 12.58 - 9.74 = 2.84, \Delta K_{I_2} = 13.85 - 11.31 = 2.54$$

$$\frac{d^2}{dN} = 0.0267 (\Delta K_I)^{3.746} = \underline{1.305 (10^{-3})}$$

Reactor Trip From Full Power

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi} \sqrt{m}$, $K_{I_2} = 13.85 \text{ ksi} \sqrt{m}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \bar{\sigma}_m = 13.78 \text{ ksi}, \bar{\sigma}_b = -6.74 \text{ ksi}$$

$$K_{I_1} = 1.033 [(13.78)(1.02) + (-6.74)(.45)] = 11.39 \text{ ksi} \sqrt{m}$$

$$K_{I_2} = 1.033 [(13.78)(1.02) + (-6.74)(.25)] = 12.78 \text{ ksi} \sqrt{m}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \bar{\sigma}_m = 12.24 \text{ ksi}, \bar{\sigma}_b = -4.88 \text{ ksi}$$

$$K_{I_1} = 1.033 [(12.24)(1.02) + (-4.88)(.45)] = 11.68 \text{ ksi} \sqrt{m}$$

$$K_{I_2} = 1.033 [(12.24)(1.02) + (-4.88)(.25)] = 12.69 \text{ ksi} \sqrt{m}$$

4. Crack Growth (Micro Inches/cycle)

$$\Delta K_{I_1} = 12.58 - 11.39 = 1.19; \Delta K_{I_2} = 13.85 - 12.69 = 1.16 \text{ ksi} \sqrt{m}$$

$$\frac{da}{dN} = 0.0267 (\Delta K_i)^{3.756} = \underline{.0512 (10^{-3})}$$

COMPUTED DHR DATE 2-5-79
CHECKED RBF DATE 3-8-79Turbine Roll Test

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi} \sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi} \sqrt{\text{in}}$

2. Roll Test

$$Q = 1.9, M_m = 1.02, M_L = .45, M_b = .25, \sigma_m = 15.69 \text{ ksi}, \sigma_b = +1.88$$

$$K_{I_1} = 1.033 [(15.69)(1.02) + (+1.88)(.45)] = 17.41 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(15.69)(1.02) + (+1.88)(.25)] = 17.02 \text{ ksi} \sqrt{\text{in}}$$

3. Crack Growth (Micro-Inches/cycle)

$$\Delta K_{I_1} = 17.41 - 12.58 = 4.83, \Delta K_{I_2} = 17.02 - 13.85 = 3.17$$

$$\frac{da}{dN} = (0.0267)(\Delta K_I)^{3.726} = \underline{9.44(10^{-3})}$$

Steady State Fluxuations

1. Normal Full Power

From Previous Calc. $K_{I_1} = 12.58 \text{ ksi} \sqrt{\text{in}}$, $K_{I_2} = 13.85 \text{ ksi} \sqrt{\text{in}}$

2. First Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 14.21 \text{ ksi}, \sigma_b = -6.36 \text{ ksi}$$

$$K_{I_1} = 1.033 [(14.21)(1.02) + (-6.36)(.45)] = 12.02 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(14.21)(1.02) + (-6.36)(.25)] = 13.33 \text{ ksi} \sqrt{\text{in}}$$

3. Second Peak

$$Q = 1.9, M_m = 1.02, M_{b_1} = .45, M_{b_2} = .25, \sigma_m = 14.55 \text{ ksi}, \sigma_b = -5.41 \text{ ksi}$$

$$K_{I_1} = 1.033 [(14.55)(1.02) + (-5.41)(.45)] = 12.82 \text{ ksi} \sqrt{\text{in}}$$

$$K_{I_2} = 1.033 [(14.55)(1.02) + (-5.41)(.25)] = 13.93 \text{ ksi} \sqrt{\text{in}}$$

4. Crack Growth (Micro-Inches/Cycle)

$$\Delta K_{I_1} = 12.82 - 12.02 = 0.80, \Delta K_{I_2} = 13.93 - 13.33 = .60$$

$$\frac{da}{dN} = 0.0267 (\Delta K)^{3.726} = \underline{\underline{0.0116 (10^{-3})}}$$

COMPUTED JKR DATE 2-6-79
CHECKED ANTH DATE 3-8-79Total Crack Growth After 10 Years

Operational Cycle	No. of Cycles	$\frac{\text{d}a}{\text{d}N}$ microinches/cycle	da (micro)
Primary Side Hydrotest	2	.1987	.397
Primary Side Leak Test	13	.752	.9867
Plant Heatup and Cooldown	50	.540	27.000
Small Step Load Increase	500	.143(10^{-3})	.072
Small Step Load Decrease	-500	.130(10^{-3})	.065
Large Step Load Decrease	50	1.096(10^{-3})	.055
Loss of Load	20	14.73 (10^{-3})	.295
Loss of Power	10	6.390 (10^{-3})	.064
Loss of Flow	20	1.304 (10^{-3})	.026
Reactor Trip From Full Power	100	.0518 (10^{-3})	.005
Turbine Roll Test	3	9.44 (10^{-3})	.022
Steady State Fluxuations	$2.5(10)^6$	0.0116 (10^{-3})	<u>29.000</u>
			<u>70.4</u>

Conservatively multiply calculated growth by 10^3 .

$$a_f = (70.4)(10^{-3}) + (.625) = \underline{.695''}$$

$$\text{Assuming } \frac{a}{l} = 0.3846, \frac{l}{l_{f10}} = \frac{.695}{.3846} = \underline{1.803''}$$

Determine Factors For New Crack Size (a_{f10}, l_{f10})Flaw Shape Factor $\Rightarrow Q = 1.9$ (Fig A-3300-1) No ChangeMembrane Stress Correction Factor, M_m (Fig A3300-2)

$$\frac{2g}{L} = \frac{(2)(.695)}{7.1} = .196, \frac{2g}{L} = \frac{(2)(1.2375)}{7.1} = 0.3486$$

 $M_{m1} = 1.03, M_{m2} = 1.02$ Very slight change, NeglectBending Stress (Fig A 3300-4)

$$\frac{2g}{L} = 0.3486, \frac{2g}{L} = .196, M_b = .45, M_b = .25 \text{ No change}$$

$$\frac{M_{b1}}{M_{b2}} = \frac{.45}{.25} = \underline{1.8}$$

Total Crack Growth After 20 Years

$$d_{a,20} = d_{a,10} + d_{a,10} \left(\frac{1.072}{1.035} \right)^{3.726} = 70.4 + (1.148) 70.4 = 151.2$$

$$a_{f,20} = .1512 + .625 = \underline{.776} "$$

$$l_{20} = \frac{.776}{.3846} = \underline{2.01} "$$

Determine Factors For New Crack Size ($a_{f,20}$, l_{20})

Flaw Shape Factor $\Rightarrow Q = 1.9$ (Fig A-3300-1) No Change

Membrane Stress Correction Factor, M_m (Fig A-3300-2)

$$\frac{2a}{L} = \frac{(2)(.776)}{7.1} = .219, \frac{2a}{L} = 0.3486$$

$M_{m_1} = 1.04$, $M_{m_2} = 1.03 \approx 2\%$ change Neglect
Bending Stress (Fig A-3300-4)

$M_{b_1} = .45$, $M_{b_2} = .25$ No Change

$$S_{20} = 1.6875 - .1512 = 1.536 " \Rightarrow a_{f,20} = .776 "$$

$$\sqrt{\frac{a_f}{Q}} = \sqrt{\frac{(.776)}{1.9}} = \underline{1.133}$$

COMPUTED BY JHR DATE 2-6-79
CHECKED BY CNT DATE 3-8-79Total Crack Growth After 30 Years

$$d_{a_{30}} = d_{a_{20}} + \left(\frac{1.133}{1.033} \right)^{3.726} d_{a_{10}} = 151.2 + (1.411) 70.4 = 250.5$$

$$a_{f_{30}} = .2505 + .625 = \underline{.876} "$$

$$l_{30} = \frac{.876}{.3846} = \underline{2.23} "$$

Determine Factors For New Crack Size ($a_{f_{30}}$, l_{30})Flow Shape Factor $\Rightarrow Q = 1.9$ (Fig A-3300-1) No ChangeMembrane Stress Correction Factor, M_m (Fig A-3300-2)

$$\frac{2e}{t} = \frac{(2)(.876)}{7.1} = .247, \frac{2e}{t} = 0.3486$$

$M_m = 1.06, M_{m_2} = 1.04 \approx 4\% \text{ Change - Neglect}$
 Bending Stress Correction Factor (Fig A-3300-3)

$M_{b_1} = .43, M_{b_2} = .25 \approx 8\% \text{ Change - Neglect}$

$$S_{30} = 1.6875 - .2505 = 1.437 " > a_{f_{30}} = 0.876 "$$

$$\sqrt{\frac{a_{f_{30}}}{Q}} = \sqrt{\frac{0.876}{1.9}} = \underline{1.203}$$

COMPUTED 048 DATE 2-6-79
CHECKED PWB DATE 2-8-79Total Crack Growth After 40 years

$$da_{40} = da_{30} + \left(\frac{1.203}{1.033} \right)^{3726} = 250.5 + 70.4(1.764) = 374.7$$

$$a_{f40} = .375 + .625 = 1.000"$$

$$l_{40} = \frac{1.000}{.3846} = 2.60"$$

Determine Factors For New Crack Size (a_{f40} , l_{40})Flow Shape Factor $\Rightarrow Q = 1.9$ (Fig A-3300-1) No ChangeMembrane Stress Correction Factor, M_m (Fig A-3300-2)

$$\frac{2g_f}{t} = \frac{(2)(1.000)}{7.1} = .282, \quad \frac{2g_f}{t} = 0.3486$$

$$M_{m_1} = 1.07, \quad M_{m_2} = 1.05 \quad \approx 5\% \text{ change}$$

Bending Stress Correction Factor, M_b (Fig A-3300-4)

$$M_{b_1} = .50, \quad M_{b_2} = .21 \quad \approx 16\% \text{ change}$$

$$S_{40} = 1.6875 - .375 = 1.313" > a = 1.000"$$

$$\sqrt{\frac{\pi a}{Q}} = \sqrt{\frac{\pi(1.000)}{7.9}} = 1.285$$

Adjusted* Crack Growth After 40 Years


$$da_{40a} = da_{30} + da_{10} \left(\frac{1.286}{1.033} \right)^{3726} = 250.5 + (70.4)(2.26) = 409.6$$

$$a_{f40a} = .410 + .625 = \boxed{1.035"} \leftarrow$$

$$l_{40a} = \frac{1.035}{.3846} = \boxed{2.621"} \leftarrow$$

$$S_{40a} = 1.6875 - .410 = \boxed{1.279"} > a = 1.035" \quad 461 \quad 202$$

*Concludes iteration step of stress correction factor variations.

Fracture Toughness Evaluation With Final Crack Size ($a_{f_{\text{final}}}$)Geometry (The final crack size will not exceed this limit.
Growth rates have been multiplied by 1000; see page)Stress Condition

Evaluate for Hydrotest Condition: $\sigma_m = 20.22 \text{ ksi}$
 (Temperature = $73 + 60 = 133^\circ\text{F}$) $\sigma_b = -7.20 \text{ ksi}$
 $\Rightarrow (p = 3105 \text{ psi})$

Allowable Stress Intensity Factor

$$\text{Ref. IWB-3612 : } K_{I_{\text{all}}} = \frac{K_{I_a}}{\sqrt{10}}$$

$T - RT_{\text{NOT}} = 133 - 5 = 128^\circ\text{F}$ (Conservative Future Hydrotests will be conducted at higher temperatures - E.A. Nier)

From Fig (A-4200-1) : $K_{I_a} = 105 \text{ ksi} \sqrt{\text{in}}$, $K_{I_c} = 200 \text{ ksi} \sqrt{\text{in}}$

$$K_{I_{\text{all}}} = \frac{105}{\sqrt{10}} = 33.2 \text{ ksi} \sqrt{\text{in}}$$

Applied Stress Intensification FactorFlaw Shape Factor, Q

$$Q = 1.9 \quad (\text{Fig A-3300-1}) \quad \text{From Previous Calc.}$$

Membrane Stress Correction Factor, M_m (Fig A-3300-2)

$$\frac{2\%}{\epsilon} = \frac{(2)(1.025)}{7.1} = .292, \quad \frac{2\%}{\epsilon} = 0.3486$$

COMPUTED JHR DATE 2-6-79
CHECKED PWH DATE 3-8-79

$$m_{m_1} = 1.09 \quad , \quad m_{m_2} = 1.07$$

Bending Stress Correction Factor, M_b (Fig A3300-4)

$$M_{b_1} = .50 \quad , \quad M_{b_2} = .21$$

$$K_I = \sigma_m m_m \sqrt{\pi} \sqrt{\frac{g}{q}} + \sigma_b m_b \sqrt{\pi} \sqrt{\frac{g}{q}}$$

$$K_{I_1} = (20.22)(1.09) \sqrt{\frac{(\pi)(1.035)}{1.9}} + (-7.20)(.50) \sqrt{\frac{(\pi)(1.035)}{1.9}}$$

$$= 28.83 - 4.71 = \underline{24.12 \text{ ksi} \sqrt{in}} < K_{I_{all}} = \underline{33.2 \text{ ksi} \sqrt{in}}$$

$$K_{I_2} = (20.22)(1.07) \sqrt{\frac{(\pi)(1.035)}{1.9}} + (-7.20)(.21) \sqrt{\frac{(\pi)(1.035)}{1.9}}$$

$$= 28.30 - 1.98 = \underline{26.32 \text{ ksi} \sqrt{\text{in}}} \angle K_{\text{tall}} = \underline{23.2 \text{ ksi} \sqrt{\text{in}}}$$

Conclusions

1. The hydrotest condition produces the highest stress intensity factor at the evaluated crack for normal and upset conditions.
 2. The requirements of section II paragraph IW8-3612 are satisfied for a hydrotest, performed after 40 years of specified service conditions, at a test temperature of 133°F . This test temperature is based on the requirement of $T_{\text{test}} = (R_{\text{NDT}})_{\max} + 60 = 73 + 60 = 133^{\circ}\text{F}$.
 3. For all other significant* normal and upset conditions the temperature is sufficiently high ($\geq 103^{\circ}\text{F}$) to justify use of the 200 ksi $\sqrt{\text{in}}$ upper shelf values of K_{Ic} and K_{Ica} . This results in an allowable of $200/\sqrt{\text{in}} = 63.2 \text{ ksi}/\sqrt{\text{in}}$, compared to the 133°F allowable of 33.2 ksi $\sqrt{\text{in}}$. (For faulted conditions $K_{Ica}^{200/\sqrt{\text{in}}} = 141.4 \text{ ksi}/\sqrt{\text{in}}$)

Conditions with $K_1 \approx \sqrt[3]{\pi/16} = 9.5$ KSI in^{-1} are not considered significant. They are acceptable regardless of temperature (See Fig A-1200-1) 61 204.

SUBJECT FLAW INDICATION IN UNIT 1 PROJECT SEQUOIAH
REACTOR VESSEL HEAD 2-26-79 (HR) 3-7-79
DATE CHECKED BY DATE
COMPUTED BY

FRACTURE TOUGHNESS EVALUATION WITH
FINAL CRACK SIZE - FAULTED CONDITION
FOR GEOMETRY SEE SHEET 40.

STRESS CONDITION


FAULTED CONDITION FROM WESTINGHOUSE
EQUIPMENT SPEC 678777 (REF 3) PAGES
6 & 19. PAGE 19 IS INCLUDED IN THIS
REPORT AS SHEET 43.

FIND STRESS AT LOCATION OF FLAW
DUE TO TEMPERATURE TRANSIENT. SINCE
REF 6 PAGE 842 DESCRIBES THE STRESS
IN A SPHERICAL SHELL AS A FUNCTION OF
THE METAL TEMPERATURE, THE TEMPERATURE
PROFILE OF THE SHELL THICKNESS MUST
FIRST BE ESTABLISHED.

TEMPERATURE EVALUATION **POOR ORIGINAL**

SINCE THE INSIDE SURFACE OF THE
SHELL IS IMMERSSED IN WATER,

FIGURE 12
STEAM LINE BREAK FROM NO LOAD WITH NO RETURN TO POWER



SUBJECT ELAN INDICATION IN UNIT 1 PROJECT SEQUOIAH
REFLECTOR VESSEL TEST MR
2-25-79 3-7-79
COMPUTED BY DATE CHECKED BY DATE


IT WILL START TO COOL RELATIVELY SLOWLY AT $T = 4$ SECONDS, WHEN THE WATER TEMPERATURE BEGINS TO DROP. NO SIGNIFICANT HEAT IS LOST UNTIL THE PRESSURE IS BELOW THE SATURATION PRESSURE FOR THE METAL TEMPERATURE AND BOILING COMMENCES.

FROM THAT POINT ($T = 8$ SECONDS) THE ASSUMPTION WAS MADE THAT THE SHELL WOULD BE COOLED BY BOILING SUBCOOLED WATER. THE FIGURE ON SHEET 45 SHOWS THAT THE SURFACE TEMPERATURE OF THE METAL NEVER REACHES THE BOILING POINT (SATURATION TEMPERATURE) OF THE WATER FOR THE ASSUMED CONDITIONS. FIGURE 20 ON PAGE 13-24 OF REF 7 GIVES THE HEAT FLOW FOR BoILING-WATER

POOR ORIGINAL

461 207

SUBJECT FLAW INDICATION IN UNIT 1 PROJECT SEQUOYAH
RECTOR VESSFC HERO JHR DATE 3-7-79
COMPUTED BY W.H. DATE 3-7-79



TIME (SECONDS)

POOR ORIGINAL

SUBJECT	FLAW INDICATION IN UNIT PROJECT	SEQUOIAH
REACTOR VESSEL HEAD	AKR	
DATE	3-7-79	
COMPUTED BY		DATE

2-26-79

SUBCOOLED WATER AS A FUNCTION
OF TWO QUANTITIES OF THE DIFFERENCE
BETWEEN METAL SURFACE TEMPERATURE
AND SATURATION TEMPERATURE, E.O.

THE DEGREE OF SUBCOOL OF THE
WATER. ASSUMING THE CONDITIONS
AT $T = 10$ SECONDS, T_{WALL} IS ABOUT
 550°F , $T_{SAT} = 525^{\circ}\text{F}$ (REF 7 Pg 2-90
 $P = 850 \text{ PSIA}$), $T_{WATER} = 510^{\circ}\text{F}$

$$T_{WALL} - T_{SAT} = \Delta T_{ST} = 550^{\circ}\text{F} - 525^{\circ}\text{F} = 25^{\circ}\text{F}$$

$$T_{SAT} - T_{WATER} = 525^{\circ}\text{F} - 510^{\circ}\text{F} = \Delta T_{SUB} = 15^{\circ}\text{F}$$

(USE 25° IN FIG 20)

$$\delta \approx 10^5 \text{ BTU/H.R FT}^2$$

IN ORDER TO FIND THE TEMPERATURE
PROFILE FROM FIGURE 22 ON PAGES
3-39, 40 & 41 OF REF 7 AN EQUIVALENT
FLUX COEFFICIENT (λ) MUST BE

FOUND.

POOR ORIGINAL

SUBJECT FLAW INDICATION IN UNIT PROJECT SECURE/H
1 REACTOR VESSEL HEAD DATE 3-7-79
COMPUTED BY CHF CHECKED BY DATE

$$g = h (T_{WALL} - T_{WATER})$$

$$h = \frac{g}{(T_{WALL} - T_{WATER})} = \frac{10^5 \text{ BTU/HR FT}^2}{550-510 \text{ }^\circ\text{F}} = 2500 \frac{\text{BTU}}{\text{HR FT}^2 \text{ }^\circ\text{F}}$$

SINCE THE STRESS INCREASES WITH HEAT LOSS RATE & REF 8 LISTS $500 < h < 1000$ ON PAGE 4-98 & SHEET 46a SHOWS THAT THE RESULTING SURFACE TEMP. IS BELOW THE SATURATION TEMP. THIS IS A VERY CONSERVATIVE FIGURE ($2500 \frac{\text{BTU}}{\text{HR FT}^2 \text{ }^\circ\text{F}}$) TO USE.

ASSUME THE WATER TEMPERATURE DROPS INSTANTLY TO T_2 SO THAT FIGURE 3-22 (REF 7) CAN BE USED.

$$\frac{h\delta}{K} = \frac{500 (7.1)}{26.7 (12)} = 55.4 \text{ UNITLESS}$$

$$\frac{\alpha \theta}{\delta^2} = \frac{4198 / 3600}{7.1^2 / 144} \times 0 \text{ sec} = 3.33 \times 10^{-4} \text{ E}$$

SUBJECT FINAL IRRIGATION IN UNIT 1 PROJECT SEQUOYAH
REACTOR VESSEL HEAD AKR
OCT 1 2-22-79 3-7-79
COMPUTED BY DATE CHECKED BY DATE

X/5	0.3EC	10	20	30	40	50	60
	$\frac{9\pi}{2}$	3.33×10^3	6.66×10^{-3}	.01	.0133	.0166	.02
0		.81	.86	.88	.90	.92	.92
.02		.62	.72	.77	.81	.82	.84
.1		.15	.30	.42	.45	.52	.56
.4		0	0	.01	.015	.02	.05
1		0	0	0	0	0	0

461 211

SUBJECT ELAA INDICATION IN UNIT 1 PETCO2 PROJECT SEQUOIACWT 3-7-79OKR3-7-79

COMPUTED BY

DATE

CHECKED BY

DATE

<u>X/8</u>	0	70	80	90	100	110	120	150
------------	---	----	----	----	-----	-----	-----	-----

<u>9/8</u>	.0233	.0266	.0299	.0333	.0366	.04	.05
------------	-------	-------	-------	-------	-------	-----	-----

t-to/ta-to

0	.92	.93	.935	.94	.945	.95	.96
---	-----	-----	------	-----	------	-----	-----

.02	.84	.86	.87	.875	.88	.885	.90
-----	-----	-----	-----	------	-----	------	-----

.1	.58	.61	.63	.65	.67	.68	.72
----	-----	-----	-----	-----	-----	-----	-----

.4	.05	.07	.09	.10	.12	.14	.18
----	-----	-----	-----	-----	-----	-----	-----

1	0	0	0	0	0	0	.01
---	---	---	---	---	---	---	-----

TEMPERATURE

to	280	275	273	270	269	268	267
----	-----	-----	-----	-----	-----	-----	-----

0	302	294	291	287	284	282	278
---	-----	-----	-----	-----	-----	-----	-----

.02	323	313	309	305	303	300	295
-----	-----	-----	-----	-----	-----	-----	-----

.1	393	387	375	368	362	358	346
----	-----	-----	-----	-----	-----	-----	-----

.4	536	530	525	522	516	510	499
----	-----	-----	-----	-----	-----	-----	-----

1	550	550	550	550	550	550	547
---	-----	-----	-----	-----	-----	-----	-----

461 212

SUBJECT FLAW INDICATION IN UNIT 1 PEZTOP PROJECT SEQUOYAH
 VESSEL HEAD
CPW! DATE 2-22-79 CHECKED BY JKR DATE 5-7-79
 COMPUTED BY

TEMPERATURE PROFILETEMPERATURE

X/8	X	θ=10	20	30	40	50	60
		$t_{center} = 510$	425	375	340	310	300
0	0	518	442	396	361	329	320
.02	.14	525	460	415	380	353	340
.1	.71	544	512	476	455	425	410
.4	2.84	550	550	548	547	545	537
1	7.1	550	550	550	550	550	550

TIME θ

SECONDS

THICKNESS X →TEMP. t

0 1 2 3 4 5 6 7

550

500

450

400

350

300

250

0

10

20

30

40

50

60

70

80

90

100

110

120

130

140

150

160

170

180

190

200

210

220

230

240

250

260

270

280

290

300

310

320

330

340

350

360

370

380

390

400

410

420

430

440

450

460

470

480

490

500

510

520

530

540

550

560

570

580

590

600

610

620

630

640

650

660

670

680

690

700

710

720

730

740

750

760

770

780

790

800

810

820

830

840

850

860

870

880

890

900

910

920

930

940

950

960

970

980

990

1000

1010

1020

1030

1040

1050

1060

1070

1080

1090

1100

1110

1120

1130

1140

1150

1160

1170

1180

1190

1200

1210

1220

1230

1240

1250

1260

1270

1280

1290

1300

1310

1320

1330

1340

1350

1360

1370

1380

1390

1400

1410

1420

1430

1440

1450

1460

1470

1480

1490

1500

1510

1520

1530

1540

1550

1560

1570

1580

1590

1600

1610

1620

1630

1640

1650

1660

1670

1680

1690

1700

1710

1720

1730

1740

1750

1760

1770

1780

1790

1800

1810

1820

1830

1840

1850

1860

1870

1880

1890

1900

1910

1920

1930

1940

1950

1960

1970

1980

1990

2000

2010

2020

2030

2040

2050

2060

2070

2080

2090

2100

2110

2120

2130

2140

2150

2160

2170

2180

2190

2200

2210

2220

2230

2240

2250

2260

2270

2280

2290

2300

2310

2320

2330

2340

2350

2360

2370

2380

2390

2400

2410

2420

2430

2440

2450

2460

2470

2480

2490

2500

2510

2520

2530

2540

2550

2560

2570

2580

2590

2600

2610

2620

2630

2640

2650

2660

2670

2680

2690

2700

2710

2720

2730

2740

2750

2760

2770

2780

SUBJECT FLUID INDICATION IN UNIT 1 REACTOR PROJECT

VESSEL HEAD
DATE
COMPUTED BYAHR
CHECKED BY5-6-79
DAYS

FROM REF 6 PAGE 842

$$V_H = \frac{2\alpha E}{1-\alpha} \left[\frac{2r^3 + r_0^3}{2(r_0^3 - r_1^3)} \left(\frac{1}{r^3} \right) \int_{r_1}^{r_0} Tr^2 dr + \frac{1}{2r^3} \int_{r_1}^r Tr^2 dr \right]$$

$$V_H = \frac{2\alpha E}{1-\alpha} \left[\frac{r^3 - r_1^3}{r_0^3 - r_1^3} \left(\frac{1}{r^3} \right) \int_{r_1}^{r_0} Tr^2 dr - \frac{1}{r^3} \int_{r_1}^r Tr^2 dr \right]$$

$$r_1 = 88.35$$

$$r_0 = 95.45$$

② $\theta = 40$ SEC FIND V_H AT $r = 88.35 + 1.28 = 89.6$

$$\text{for } r = 89.63 + 2.07 = 91.70 \notin r = 88.35 \notin r = 95.45$$

EXPRESS T AS A FUNCTION OF R.

$$r = 88.35 \text{ TO } 88.49, T = 360 + \frac{10}{18}(r - 88.35)$$

$$r = 88.49 \text{ TO } 89.06, T = 360 + \frac{75}{57}(r - 88.49)$$

$$r = 89.06 \text{ TO } 91.19, T = 125 + \frac{92}{2.13}(r - 89.06)$$

$$r = 91.19 \text{ TO } 95.45; T = 547 + \frac{3}{4.26}(r - 91.19)$$

POOR ORIGINAL

SUBJECT FLOW INDICATION IN UNIT 1 REC'D PROJECT

VESSEL HEAD
2-23-79

OKR

3-7-79

COMPUTED BY

DATE

CHECKED BY

LAWIE

$$\begin{aligned} \bar{V}_H &= \frac{2(8.16 \times 10^{-6}) 28 \times 10^6}{-1.5} \left[\frac{2r^3 + 88.35^3}{2(95.45^2 - 88.35^2)} \right] \frac{1}{r^3} \left\{ \int_{89.06}^{83.49} \left(385 + \frac{75}{57} [r - 88.49] \right) r^2 dr + \int_{89.06}^{83.49} \left(455 + \frac{22}{2.13} (r - 89.06) \right) r^2 dr + \right. \\ &\quad \left. \int_{91.19}^{95.45} \left(543 + \frac{3}{4.26} [r - 91.19] \right) r^2 dr \right\} + \frac{1}{2r^3} \int_{83.35}^r T r^2 dr - \frac{T}{2} \end{aligned}$$

$$@ r = r_i = 88.35$$

$$\begin{aligned} \bar{V}_H &= 652.8 \left[\frac{2(88.35^3) + 88.35^3}{2(95.45^2 - 88.35^2) 88.35^2} \right] \left\{ \int_{88.49}^{88.35} (357r^2 + 131.58r^3 - 11693r^2) dr + \int_{88.35}^{91.19} (131.58r^3 - 11693r^2) dr + \int_{88.35}^{89.06} (131.58r^3 - 11693r^2) dr \right. \\ &\quad \left. + \int_{91.19}^{95.45} (57r^2 + 205r^3 - 6125r^2) dr \right\} + 0 - \frac{36P}{2} \end{aligned}$$

$$\bar{V}_H = 652.8 \left[\frac{3}{2(177781)} \right] \left\{ \left[-3075r^3 + 357r^2 \right] \Big|_{88.35}^{89.06} + \left[1257r^3 + 52.9r^2 \right] \Big|_{91.19}^{95.45} \right\}$$

POOR ORIGINAL

461

215

SUBJECT: FEAN INDICATION IN UNIT 1 REACTOR PROJECT: SEQUOIAH
 VESSEL HEAD
 DATE: 2-23-79
 COMPUTED BY: PKR
 CHECKED BY:
 DATE: 3-7-79

$$\Delta P_4 = 652.8 \left[8.334 \times 10^{-6} \left\{ -3876 (88.49^3 - 88.35^3) + 33.52 (88.49^4 - 88.35^4) + 3754 (89.06^3 - 88.49^3) + 32.9 (89.06^4 - 88.49^4) - 15.51 (91.19^3 - 89.06^3) + 10.8 (91.19^4 - 89.06^4) + 161 (95.45^3 - 91.19^3) + .176 (95.45^4 - 91.19^4) \right\} - 100.5 \right]$$

$$\Delta P_H = 652.8 \left[8.334 \times 10^{-6} \left\{ -12.73 \times 10^6 + 13.15 \times 10^6 - 52.59 \times 10^6 + 52.482 \times 10^6 - 53.70 \times 10^6 + 67.37 \times 10^6 + 17.32 \times 10^6 + 7.6 - 100.5 \right\} \right]$$

$$\Delta P_4 = 52,520 \text{ PSI}$$

③ $r = 89.63 = \text{RADIUS AT POINT } 1$

$$\Delta P_H = 652.8 \left[\frac{2(89.63^3) + 88.35^3}{2(95.45^3 - 88.35^3) 89.63^3} \left\{ 31.39 \times 10^6 \right\} + \frac{1}{2(89.63^3)} \left\{ T \right\} \right] - \frac{89.63}{88.35}$$

$$- \frac{1}{2} \left\{ \frac{3554 \times 3.32 [89.63 - 89.06]}{2} \right\}$$

$$\Delta P_H = 652.8 \left[257.9 - 232.01 + 6.997 \times 10^{-7} \left\{ \left[\frac{88.49}{89.63} + \frac{75}{57} (r - 88.49) \right] r^2 dr + \int_{88.49}^{89.06} \left[0.57 \times \frac{75}{57} (r - 88.49) r^2 dr \right] \right\} \right]$$

SUBJECT EIAN INDICATION IN UNIT 1 REACTOR PROJECT SEQUOIA 14
VEESSEL HEAD PLR 3-7-79
COMPUTED BY DATE CHECKED BY DATE

$$\bar{D}_H = 652.8 \left[18.06 + 6.944 \times 10^{-7} \left\{ -3,876 \left[88.49^3 - 88.35^3 \right] \right. \right. \\ \left. \left. + 38.92 \left[88.49^4 - 88.35^4 \right] - 3752 \left[89.06^3 - 88.49^3 \right] \right. \right. \\ \left. \left. + 32.89 \left[89.06^4 - 88.49^4 \right] - 1131 \left[89.63^3 - 89.06^3 \right] \right. \right. \\ \left. \left. + 10.80 \left[89.63^4 - 89.06^4 \right] \right\} \right]$$

$$\bar{D}_H = 13079 \text{ PSI}$$

$$\textcircled{2} \quad r = 91.70 = \text{RADIUS OF PT 2}$$

$$\bar{D}_H = 652.8 \left[\frac{2(91.7^3) + 88.35^3}{2(95.95^2 - 88.35^2) / 91.7^3} \left\{ 31.31 \times 10^6 \right\} - \frac{547 + \frac{3}{426}(91.7 - 91.19)}{2} \right]$$

$$+ \frac{1}{2(91.7^3)} \left\{ \int_{88.35}^{88.49} \left[361 + \frac{19}{14}(r - 88.35) \right] r^2 dr + \int_{91.19}^{91.70} \left[330 + \frac{75}{57}(r - 88.49) \right] r^2 dr \right. \\ \left. + \int_{67.06}^{91.19} \left[455 + \frac{92}{213}(r - 89.06) \right] r^2 dr + \int_{91.19}^{91.70} \left[547 + \frac{19}{426}(r - 91.19) \right] r^2 dr \right\}$$

$$\bar{D}_H = 652.8 \left\{ -21.92 + 6.484 \times 10^{-7} \left\{ -3876 \left[88.49^3 - 88.35^3 \right] \right. \right. \\ \left. \left. + 54.93 \left[88.49^4 - 88.35^4 \right] - 3752 \left[89.06^3 - 88.49^3 \right] + \right. \right. \\ \left. \left. + 32 \left[89.06^4 - 88.49^4 \right] - 1131 \left[89.63^3 - 89.06^3 \right] + \right. \right. \\ \left. \left. + 10.80 \left[89.63^4 - 89.06^4 \right] - 1406 \left[91.7^3 - 91.19^3 \right] + .38 \left[91.7^4 - 91.19^4 \right] \right\} \right\} \\ = -19736 \text{ PSI}$$

SUBJECT FLAW INDICATION IN UNIT 1

PROJECT SEQUOIAH

REACTOR VESSEL HEAD

ANAL 2-23-79

14R

3-7-79

COMPUTED BY

DATE

CHECKED BY

DATE

STRESS PROFILE

T = 40 SEC

 $\delta \rightarrow$ σ_H KSI

50

40

30

20

0

-10

-20

 $D_B = 45\%$

1 2 3

4 5 6 7

LINEARIZED

STRESS PROFILE AT T=100 SEC
(SEE SHEET 57)THERMAL STRESS
PROFILE, TIME =
40 SECONDSLINEARIZED
STRESS PROFILE
(REF 1 FIG
A-3200-1) TIME

COMBINED STRESS (FAULTED)

@ TIME = 40 SECONDS

 $P = 450$ PSI

$$\sigma_n = \frac{P r}{z} = \frac{450 (91)}{7.1} = 5760$$

PRELOAD (SH 14)

 σ_A
5760 D_B
0

1,220

- 6,510

TEMPERATURE
COMBINEDPOOR ORIGINAL
1760 45000
3430

461 218

SUBJECT FLAW INDICATION IN UNIT 1 REACTOR VESSEL HEAD PROJECT SEQUOIA/H
DATE 2-23-79 AKR 3-7-79
COMPUTED BY DATE CHECKED BY DATE

APPLIED STRESS INTENSIFICATION FACTOR $I = ?$

$$\frac{P_m + P_b}{P_{ys}} = \frac{-10,000 + 38490}{44,900} = .63$$

REF 1 FIG
A-3300-1

$$a/l = .38$$

$$Q = 1.8$$

STRESS CORRECTION FACTORS

$$\frac{2\%}{t_s} = 292, \frac{2e}{t} = .3486$$

MEMBRANE STRESS CORRECTION FACTOR

$$M_{m_1} = 1.09$$

FIG A 3300-2

$$M_{m_2} = 1.07$$

$$M_{b_1} = .50$$

FIG A 3300-4

$$M_{b_2} = .21$$

$$K_I = P_m M_m \sqrt{\frac{\pi a}{Q}} + P_b M_b \sqrt{\frac{\pi a}{Q}}$$

$$K_I = -1252 (1.09) \sqrt{\frac{\pi (1.035)}{1.8}} + 38.5 (.5) (1.34) = 11.23 \text{ ksin}$$

$$K_{I_2} = -12.52 (1.07) (1.34) + 38.5 (.21) (1.34) = -3.5 \text{ ksin}$$

POOR ORIGINAL

SUBJECT FLAW INDICATION IN UNIT 1 PROJECT SEQUOYAH
REACTOR VESSEL HEAD (LKR)
3-8-79 DATE 3-8-79
COMPUTED BY CWJ CHECKED BY DATE

SINCE @ $\theta = 100$ SEC THE SLOPE OF THE TEMPERATURE ACROSS THE FLAW IS AT ABOUT ITS MAXIMUM.

EXPRESS T AS $f(r)$

$$r = 88.35 \text{ TO } 88.49 \quad T = 287 + \frac{18}{14}(r - 88.35)$$

$$r = 88.49 \text{ TO } 89.06 \quad T = 305 + \frac{63}{57}(r - 88.49)$$

$$r = 89.06 \text{ TO } 91.19 \quad T = 368 + \frac{154}{213}(r - 89.06)$$

$$r = 91.19 \text{ TO } 95.45 \quad T = 522 + \frac{34}{426}(r - 91.19)$$

@ $r = 89.63$

$$\Delta H = \frac{2\alpha E}{1-\alpha} \left[\frac{2r^3 + r_i^3}{2(r_0^3 - r_i^3)} r^3 \right] \int_{r_i}^{r_0} Tr^2 dr + \frac{1}{2r^3} \left[\int_{r_i}^r Tr^2 dr - \frac{r^4}{4} \right]$$

$$= 652.8 \left[\frac{2(89.63^3) + 88.35^3}{2(95.45^3 - 88.35^3) 89.63^3} \right] \left[\begin{array}{c} 88.35 \\ 287 + \frac{18}{14}(r - 88.35) \end{array} \right] r^2 dr +$$

$$\int_{88.35}^{89.06} (305 + \frac{63}{57}[r - 88.49]) r^2 dr + \int_{88.35}^{91.19} (368 + \frac{154}{213}[r - 89.06]) r^2 dr +$$

$$\int_{91.19}^{95.45} (522 + \frac{34}{426}[r - 91.19]) r^2 dr + \frac{1}{2r^3} \left[\int_{88.35}^{89.63} Tr^2 dr - \frac{r^4}{4} \right]$$

POOR ORIGINAL

SUBJECT FLAN INDICATION IN UNIT 1 PROJECT SEQUOIA/H
REACTOR VESSEL HEAD JHR
3-7-79 3-8-79
COMPUTED BY DATE CHECKED BY DATE

$$D_H = 652.8 \left[8.217 \times 10^{-6} \left\{ \frac{[287 - 11369]}{3} r^3 + \frac{128.6}{4} r^4 \right\} \right]^{88.49} \\ + \left[-3158 r^5 + 27.63 r^4 \right]^{89.06} + \left[18.03 r^4 - 2023 r^3 \right]^{91.19} +$$

$$\left[1.995 r^4 - 68.6 r^3 \right]^{91.19} + \frac{1}{2(89.63)^3} \left\{ 32.15 r^4 - 36.1 r^3 \right\}^{88.49} \\ + \left[27.63 r^4 - 3158 r^3 \right]^{89.06} + \left[18.03 r^4 - 2023 r^3 \right]^{89.63} + \frac{363 + \frac{107}{25}}{2}$$

$$D_H = 652.8 \left[8.217 \times 10^{-6} \left\{ 32.15(88.49^4 - 88.35^4) - 3691(88.49^3 - 88.35^3) \right. \right. \\ \left. \left. + 27.63(89.06^4 - 88.49^4) - 3158(89.06^3 - 88.49^3) + 18.03(91.19^4 - 88.49^4) \right. \right. \\ \left. \left. - 2023(91.19^3 - 89.06^3) + 1.995(95.95^4 - 91.19^4) - 68.6(95.95^3 - 91.19^3) \right. \right. \\ \left. \left. + \frac{1}{2(89.63)^3} \left\{ 32.15(88.49^4 - 88.35^4) - 3691(88.49^3 - 88.35^3) \right. \right. \right. \\ \left. \left. \left. + 63(89.06^4 - 88.49^4) - 3158(89.06^3 - 88.49^3) \right. \right. \right. \\ \left. \left. \left. + 18.03(89.63^4 - 89.06^4) - 2023(89.63^3 - 89.06^3) \right\} + 205 \right]$$

POOR ORIGINAL

SUBJECT FISH MIGRATION IN UNIT 1 REFCODE PROJECT SEQUOYAH
 VESSEL HEID DATE 3-7-79 MR MKR DATE 3-8-79
 COMPUTED BY DWJ CHECKED BY

$$\begin{aligned}
 D_H &= 652.8 \left[8.217 \times 10^{-6} \left\{ 12.45 \times 10^6 - 12.12 \times 10^6 + 44.07 \times 10^6 - 42.56 \times 10^6 \right. \right. \\
 &\quad \left. \left. + 112.78 \times 10^6 - 105.00 \times 10^6 + 27.64 \times 10^6 - 7.64 \times 10^6 \right\} \right. \\
 &\quad \left. + .694 \times 10^{-6} \left\{ 12.45 \times 10^6 - 12.12 \times 10^6 + 44.07 \times 10^6 - 42.56 \times 10^6 \right. \right. \\
 &\quad \left. \left. + 29.40 \times 10^6 - 27.61 \times 10^6 \right\} - 205 \right] \\
 &= 652.8 [243.39 + 2.52 - 205] = 26703 \text{ PSI}
 \end{aligned}$$

AT $r = 91.7$

$$\begin{aligned}
 D_H &= 652.8 \left[\frac{2(91.7^3) + 88.35^3}{2(95.45^3 - 88.35^3)} \right] \left\{ 29.62 \times 10^6 \right\} - 205 \\
 &\quad + \frac{1}{2(91.7^3)} \left\{ 12.45 \times 10^6 - 12.12 \times 10^6 + 44.07 \times 10^6 - 42.56 \times 10^6 \right. \\
 &\quad \left. + 112.78 \times 10^6 - 105 \times 10^6 + 1.935(91.7^4 - 91.17^4) - 68.6(91.7^2 - 91.17^2) \right. \\
 &\quad \left. - \frac{526}{2} \right\}
 \end{aligned}$$

$$D_H = 652.8 \left[8.091 \times 10^{-6} (29.62 \times 10^6) + 1.935(91.7^4 - 91.17^4) - 213 \right]$$


$$D_H = 11190 \text{ PSI}$$

POOR ORIGINAL

461 222

SUBJECT FLAW INDICATION IN UNIT 1 PROJECT SECURITY
REACT 2 VESSEL HEAD MR 3-3-79
2-23-79 COMPUTED BY DATE CHECKED BY DATE

STRESS PROFILE @ T = 100 SEC



POOR ORIGINAL

SUBJECT ELAN INDICATION IN UNIT 1 PROJECT SEQUOYAH
 REACTOR VESSEL HEAD
DATE 2-23-79

COMPUTED BY

DATE

CHECKED BY

DATE

COMBINED STRESS (FAULTED)

② TIME = 100 SECONDS

$$P = 455 \text{ PSI}$$

$$\sigma_m$$

$$\sigma_b$$

$$\sigma_n = \frac{Pr}{t} = \frac{455(91)}{7.1} = 5832 \text{ PSI}$$

$$0$$

PRELOAD

1,220

- 6510

TEMPERATURE

- 14,000

63,000

COMBINED

- 6948

- 56440

APPLIED STRESS VITENSIFICATION FACTOR TENS.

$$\frac{\sigma_m + \sigma_b}{\sigma_{ys}} = \frac{-6948 - 56440}{44,900} = 1.1 \text{ USE } 1.0$$

CURVE DUE TO PREVIOUS CONSERVATISM

$$Q = 1.7$$

$$K_s = -10.00 (1.09)(1.58) + 56.5 (.5)(1.59) = 23.94$$

POOR ORIGINAL

SUBJECT FLAW INDICATION IN UNIT 1 PROJECT SEDOVOYAH
REACTOR 2 VESSEL HEAD JKZ
DATE 2-27-79 3-8-79
COMPUTED BY JKR CHECKED BY DATE

ALLOWABLE STRESS INTENSITY FACTOR

$$K_{IA\text{ALL}} = K_{IA} / \sqrt{2} \quad \text{FAULTED} \quad \text{REF 1 IWB-36120}$$

$$T - RT_{NOT} = 400 - 5 = 395 \quad T = 100$$

$$K_{IA} = 200$$

$$K_{IA\text{ALL}} = 200 / \sqrt{2} = 141.42$$

$$K_I = 23.94 < K_{IA\text{ALL}} = 141.42$$

CONCLUSION

FAULTED CONDITION IS NOT CRITICAL.

HEAT TRANSFER CALCULATIONS WERE BASED ON IMMERSION IN WATER AT END TEMP RATHER THAN LETTING WATER TEMP DROP WITH TIME.

AT $\theta = 100$ SEC THE STRESS AT FLAW IS NEAR ENOUGH TO MAXIMUM TO SHOW THAT THE FAULTED COND IS NOT CRITICAL.

POOR ORIGINAL

References

1. ASME Boiler and Pressure Vessel Code-Section XI, Division 1, "Rules For Inservice Inspection Of Nuclear Power Plant Components", 1977 Edition with addenda through Summer 1978.
2. TH-Rijerdam Dockyard Company (RDM) - Stress Report For Sequoyah Reactor Vessels, Document No. 30616-1105, "Analysis of The Main Closure Including Core Support Ledge".
3. Westinghouse Equipment Specifications 676413, Revision 1, and 678777, Revision 2 for the Sequoyah Unit Reactor Vessel and 2
4. ASME Boiler and Pressure Vessel Code - Section III, Division 1, "Appendices", 1977 Edition with addenda through Summer 1978.
5. EPRI NP-719-SR Special Report August 1978 - Flow Evaluation Procedures: ASME Section XI - Prepared by ASME Section XI Task Group on Flow Evaluation
6. Engineering Design - Joseph H. Fausel, John Wiley & Sons - 1961
7. Handbook of Heat Transfer - W.M. Rohsenow and J.P. Hartnett, McGraw-Hill Publishing Co., 1963.
8. Standard Handbook for Mechanical Engineers - Baumeister and Marks, 7th Edition, McGraw-Hill Publishing Co., 1966.

POOR ORIGINAL

UNITED STATES GOVERNMENT

Memorandum

CEB '790319 011
TENNESSEE VALLEY AUTHORITY

TO : D. R. Patterson, Chief, Mechanical Engineering Branch, W10C126 C-K

FROM : R. G. Domer, Chief, Civil Engineering Branch, W9D224 C-K

DATE : MAR 19 1979

SUBJECT: SEQUOYAH NUCLEAR PLANT - ANALYTICAL EVALUATION OF A FLAW INDICATION
IN THE UNIT 1 REACTOR VESSEL CLOSURE HEAD

Reference: My memorandum to you dated March 19, 1979
(CEB 790321 018).

We have reviewed the attached letter and enclosure entitled, "Preliminary Evaluation of Sequoyah 1 Flaw Indication," Supplemental Report SwRI Project 17-5339, February 1979 (attachment). We have reached the following conclusions based upon this review and our report, CEB-CQS-17-1, which was transmitted to you by the referenced memorandum.

Conclusions

1. Crack growth for the 40-year service life of the vessel will be small. Our report predicts a very conservative upper bound limit to this growth by multiplying the specified number of event cycles by 1000 and by considering 2.5 billion steady-state pressure fluxuations of 100 psi. The SwRI report predicts growth for the specified number of events and does not evaluate growth for steady-state fluxuations. The basic methodology applied and growth rates calculated in these reports are in reasonable agreement.
2. For fracture toughness, a low temperature hydrotest at 3105 psig would produce the most critical condition relative to code acceptance limits. Our report demonstrates acceptability for this condition for a minimum metal temperature of 133 F, assuming the conservative upper bound crack size after 40 years of service. The SwRI report suggests in section 3.0(7) a minimum metal temperature of $120 + 5 = 125$ F. Both reports are in substantial agreement on this conclusion.
3. SwRI did not perform a faulted condition fracture toughness evaluation, but they raised a question and suggested that more evaluation may be required. They did conclude that the specified faulted condition (large steam line break) would be the limiting case relative to the code acceptance criteria for faulted conditions. In our report, the specified faulted condition is evaluated, by a conservative thermal stress and fracture toughness approach, and it is shown to be well within acceptance limits and therefore less critical than the hydro-test condition discussed above.

MEB MASTER FILE


46R-227

D. R. Patterson

MAR 19 1979

SEQUOYAH NUCLEAR PLANT - ANALYTICAL EVALUATION OF A FLAW INDICATION
IN THE UNIT 1 REACTOR VESSEL CLOSURE HEAD

4. In summary, we feel that report CEB-CQS-79-1 provides adequate assurance that the flaw indication is acceptable for the full service life of the unit 1 reactor vessel and that the SwRI report basically substantiates this conclusion. We do not feel that any repair is necessary for this flaw. Finally, we do not recommend further faulted condition evaluation by SwRI.



R. G. Domer

WCE

HRB

RGD:JKR:DB

Attachment

cc (Attachment):

R. M. Pierce, 204 GB-K (2)
MEDS, E4B37 C-K

UNITED STATES GOVERNMENT

ENCLOSURE 4

Memorandum

MEB '79 0228 379

TENNESSEE VALLEY AUTHORITY

TO : G. G. Stack, Project Manager, Sequoyah Nuclear Plant, CONST (4)

FROM : R. M. Pierce, Sequoyah and Watts Bar Design Projects Manager, 204 GB-K

DATE : FEB 28 1979

SUBJECT: SEQUOYAH NUCLEAR PLANT UNITS 1 AND 2 - NONCONFORMANCE REPORT (NCR)
NO. 6P

We are in agreement with the recommended disposition of attached NCR
6P and that the nonconformance is classified as significant. No
drawings will be revised.

Original Signed by
R. M. Pierce

R. M. Pierce

DRP:EAM:MGR

Attachment

cc: J. M. Ballentine, Sequoyah P PROD
Roy H. Dunham, W11A9 C-K
J. P. Knight, W12B30 C-K
MEDS, E4B37 C-K, w/l
J. L. Parris, W11C126 C-K, w/l
D. R. Patterson, W10C126 C-K
H. H. Mull, E7B24 C-K



DIVISION OF CONSTRUCTION
NONCONFORMING CONDITION REPORT

1. Nuclear Project: Sequoyah		Unit <u>1</u>	NCR: <u>GP</u>
2. Area: <input type="checkbox"/> Civil <input type="checkbox"/> Electrical <input checked="" type="checkbox"/> Mechanical <input type="checkbox"/> Instrumentation <input type="checkbox"/> Welding		<input type="checkbox"/> Other	ASME Code Item <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No
3. Activity <input type="checkbox"/> Receiving <input type="checkbox"/> Storage <input type="checkbox"/> Fabricating <input type="checkbox"/> Installing <input checked="" type="checkbox"/> Testing		Contract No. _____	
4. Type: <input type="checkbox"/> Damage <input type="checkbox"/> Failure <input checked="" type="checkbox"/> Defect <input type="checkbox"/> Documentation <input type="checkbox"/> Other _____			
5. Item Description: Reactor vessel closure head seam weld W09-10			
6. Nonconformance Description: (Include Apparent Cause) See attached SwRI Customer Notification Form, Serial No. 10 dated January 31, 1979.			
Recommended Disposition: <input type="checkbox"/> Rework <input type="checkbox"/> Reject <input type="checkbox"/> Repair <input checked="" type="checkbox"/> Use-As-Is <input type="checkbox"/> Other (Check Block & Detail Below)			
Use Code Case N-209 as basis to resolve acceptance. Perform stress analysis, per IWB-3600, to determine acceptability. Disposition will be reported to NRC as soon as all information is available. Action Required to Prevent Recurrence:			
This area will be re-examined each inspection interval.			
NCR Initiator: <u>E. F. Harwell</u>		Date <u>February 13, 1979</u>	
7. Referred to Design Project Organization (DPO): <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No		DPO Coordination Contact	
Disposition: <input checked="" type="checkbox"/> As Recommended <input type="checkbox"/> Other (Describe)		Significant Condition <input checked="" type="checkbox"/> Yes <input type="checkbox"/> No	
Approved by Power Plant Supt. <u>John Bedell</u>		Date <u>2/15/79</u>	
8. DPO Disposition: <input checked="" type="checkbox"/> As Recommended		<input type="checkbox"/> Other (Describe)	
Approved By Design Project Organization: <u>P. M. Pierce</u>		Date <u>3-2-79</u>	
9. Disposition Inspection and Release from Nonconforming Status: Inspected by: _____ Date _____		<input type="checkbox"/> Yes <input type="checkbox"/> No	
10. Action Required to Prevent Recurrence Complete: Verified by Construction Engineer: _____ Date _____		<input type="checkbox"/> Yes <input type="checkbox"/> No	
Distribution: Site QA Records File Construction Engineer Site QA Unit OEDC QA Manager Design Project Organization (Items for his action only) Authorized Nuclear Inspector (Code Items only) EN DEG NEB-NLS (Significant NCR's only) MEDS		Disposition Reviewed and Accepted By: Authorized Nuclear Inspector _____ Date _____	

POTENTIAL REPORTABLE OCCURRENCE

79-7

PRO No.

TO : (1) Section Supervisor
(2) QA Staff Supervisor

FROM: E. F. Harwell *E.F.H.*

Time/Date _____
Time/Date 2/13/79 5:00 pm

Unit 1 System No. 68

Initiator

Event Description UT flaw found in closure head seam weld W09-10 during preservice examination performed by SwRI which exceeded limits of IWB-3511.1

Event Discovered Time/Date January 12, 1979

Potential LER YES NO
Potential 10 CFR 50.55(e) YES NO (If YES, attach evaluation forms)
10 CFR 21 Evaluation Required? YES NO

TO : Plant Superintendent 2/13/79
FROM: QA Staff Supervisor WJS

QA Staff Recommendation: Reportable occurrence? NO
Reportable per ASME Section XI LER
 10 CFR 50.55(c)
 10 CFR 21

Immediate Report? _____
30 day Report? _____

Description: (If not reportable, explain below.)

WJS 2/13/79
Refer to HRC NCR 6.P

John Belliveau / 2/13/79
Plant Superintendent Date

TO : QA Staff
FROM: PORC and Plant Superintendent

PORC Review Date 2/14/79

Recommendation Approved Rejected _____

John Belliveau / 2/14/79
Plant Superintendent Date

Southwest Research Institute
CUSTOMER NOTIFICATION FORM

Serial No.	10
Utility	TVA
Site	S-200-1100-1

Part I - SWRI Findings

Project No. 17-1100-1	Type of Examination	NDT Method <input checked="" type="checkbox"/> UT <input type="checkbox"/> RT	SWRI Procedure/Rev
Examination Date: 12 Jan 79 15 Feb 79	<input checked="" type="checkbox"/> PPI <input type="checkbox"/> ISI	<input type="checkbox"/> MT <input type="checkbox"/> RT <input type="checkbox"/> ET <input type="checkbox"/> VT	600-15/77

Comments:

This is to inform you of a flaw indication found in RAV closure Head Weld 390009-10, which exceeds the allowable limits as outlined in Section XI, Summer 75' Addenda, Table IWR 35-11.1.

Attached Sheets: 390018 Original Exam. Ind #5
390024 Re-look Date

Additional Resolution Data: 390024, 390025, 390023, 450012,
450013, 450014, 370062, 310034

* Indication signed off on 2/14/390024

Examination Reference:

See Attached Draft Findings dated 31 Jan 79 RT Review

Signature of SWRI Representative

F. J. P. Lemoine

Date 31 Jan 79
21 Jan 79

XIA

Part II - Customer Notification

Notification Acknowledged by

Date

Part III - Indication Disposition by Customer

Comments

Signature of Customer Representative

Date

Part IV Reexamination

Comments

Reexamination Reference


Signature

POOR ORIGINAL

Date

CNF Closed (Customer Representative Signature)

Date




TENNESSEE VALLEY AUTHORITY

SEQUOYAH
REACTOR VESSEL
CLOSURE HEAD

SCALE	NTS	ISSUED	APPROVED	REV'D
DRAWN				11-73
TRACTOR BOS				11-73
CHECKED				CH-M-235R-A

Draft Field Notes

On Jan 31, 1979 the undersigned reviewed the construction radiographs of the area of the ring-to-disk plate weld of the Sequoyah "I" RPV closure head which contains a reportable UT indication. On film 27-28, there are two ball point pen marks which would appear to indicate a previous review of that area. Close examination revealed a very faint interrupted linear indication having the appearance of tight rolled-in slag. The location and size of the indications are shown below using the film 10 as reference pts.



27 30616 CIRW09 LEG10 28

The approximate width of all three indications is $\frac{1}{32}$ " and they do not appear to be slag. The lengths and grouping are acceptable in accordance with N624.3 of Sect.

1968 Edition of the ASME Boiler and Pressure Vessel Code. It is recommended that the provisions of Code Case N209 be applied to the resolution of this indication.

S. J. Gaughan

SWRI Level III - RT


W. C. McGaughan
SWRI Level III UT

SWRI will need stress values for the closurehead -
dollar plate weld in order to perform stress analysis
to determine acceptability of the ultrasonic indication
to the criteria of IWB-3600. Please obtain these
values from Westinghouse Electric Co.

W. C. McGaughan

31 JAN 79

DOWN To FLANGE



POOR ORIGINAL

SW. R.I. PRESSURE VESSEL ULTRASONIC EXAMINATION RECORD																				
PROJECT NO.: 171329				SITE: Sunnyside Power Station, Unit 1				DATE: (DAY-MON-YR.) 13-7-78				TIME (24 HR. CLOCK)				SHEET NO.: 2000111				
EXAMINATION AREA (SYSTEM/COMPONENT) RPV				(LINE / SUBASSEMBLY) Line 1				(IDENTIFICATION) Identification				L ₀ LOCATION: Line 1				W ₀ LOCATION: External				
EXAMINER: G.M. Sweeney				SNT LEVEL: 3				PROCEDURE NO. LOC 10 REV. 31				CALIBRATION SHEET(S) 4500001		ANGLE USED	0°	45°	45°T	60°	OTHER	WELD TYPE: P-LW
EXAMINER: G.F. Weisbrod				SNT LEVEL: 3								SCANNING dB	100	NA	NA	NA	NA	NA	WELD LENGTH: 600 mm	
																			EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>	
IND. NO.	% OF DAC MAX	50 % DAC		W MAX		50 % DAC		L ₁	L	L ₂	SEARCH UNIT	SEARCH UNIT	THRU WALL DEPTH % OF T	DEPTH BELOW SURFACE % OF T	REMARKS:				INT.	
		W ₁	MP	W	MP	W ₂	MP								50 % DAC	POSITION	50% DAC	LOCATION		ANGLE
(1)	51	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(2)	52	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(3)	40	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(4)	53	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(5)	42	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(6)	43	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(7)	44	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(8)	45	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(9)	46	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(10)	47	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(11)	48	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(12)	49	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(13)	50	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(14)	51	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(15)	52	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(16)	53	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(17)	54	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(18)	55	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(19)	56	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(20)	57	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(21)	58	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(22)	59	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(23)	60	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(24)	61	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(25)	62	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(26)	63	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(27)	64	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(28)	65	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(29)	66	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(30)	67	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(31)	68	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(32)	69	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(33)	70	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(34)	71	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(35)	72	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(36)	73	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(37)	74	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(38)	75	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(39)	76	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(40)	77	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(41)	78	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(42)	79	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(43)	80	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(44)	81	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(45)	82	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(46)	83	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(47)	84	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(48)	85	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(49)	86	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(50)	87	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(51)	88	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(52)	89	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(53)	90	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(54)	91	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(55)	92	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(56)	93	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(57)	94	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(58)	95	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(59)	96	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(60)	97	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(61)	98	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(62)	99	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(63)	100	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(64)	101	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(65)	102	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(66)	103	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(67)	104	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(68)	105	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(69)	106	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(70)	107	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(71)	108	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(72)	109	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60	NA	NA	NA	NA	NA	NA	NA	
(73)	110	3/8	1/2	5/8	10	5/8	1/2	10	10	10	Up	60								

SW. R. I. PRESSURE VESSEL ULTRASONIC EXAMINATION RECORD

POOR ORIGINA⁴⁶¹ 238

S.W.R.I SONIC INSTRUMENT VESSEL CALIBRATION RECORD							
PROJECT NO: 175339		SITE: Sequoyah Power Station, Unit 1		DATE:(DAY-MON-YR) 25-JUN-77		TIME:(24 HR. CLOCK) 1440	
1.) EXAMINER: <i>J. C. McNamee</i>		SNT LEVEL <i>II</i>	PROCEDURE NO. 600-15	INSTRUMENT: SONIC MARK: <input checked="" type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/>	SERIAL NO: 750415	CALIBRATION VERIFICATION	
2.) EXAMINER: (OPERATOR) <i>J. C. McNamee</i>		SNT LEVEL <i>III</i>	REV. 37	COUPLANT: GLYCERINE <input type="checkbox"/> WATER <input checked="" type="checkbox"/> OTHER (SPECIFY)	TIME: 1001		
SEARCH UNITS		REFERENCE BLK:		CAL. BLK. TEMPERATURE 73°F			
NOMINAL ANGLE	<i>0°</i>	N/A	MEASURED ANGLE:	<i>0°</i>	N/A	CABLE TYPE	AMPLITUDE DETERMINATION FOR 5/8 NODE
MEASURED ANGLE	<i>0°</i>	1	SIGNAL AMPLITUDE	<i>6</i>	6	RG62 <input type="checkbox"/> RG174 <input checked="" type="checkbox"/>	3/8 ECHO <i>111</i> dB <i>111</i> LINES OF AMPLITUDE
BRAND	SERIAL NUMBER		(SCREEN DIVISIONS):	<i>8</i>	<i>6</i>	OTHER _____ LENGTH <i>72</i> IN.	5/8 ECHO <i>111</i> dB <i>111</i> LINES OF AMPLITUDE
<i>S.E.P.T.</i>	<i>496</i>		SIGNAL DISTANCE (IN):	<i>4</i>	<i>1</i>	JACK USED R <input type="checkbox"/> T <input checked="" type="checkbox"/>	Δ dB <i>111</i> (3/8-5/8 ECHO)
			SCREEN DIVISIONS:	<i>4</i>	<i>1</i>	MODE OF TRANS. NORM <input type="checkbox"/> THRU TRANS. <input checked="" type="checkbox"/>	REMARKS: <i>Re-take 1009-10, 60° tubes, reject reject 3002 60°</i>
SIZE:	<i>1" dia</i>		COARSE RANGE:	<i>5</i>	<i>7</i>		
NOMINAL FREQUENCY(MHZ):	<i>2.25</i>		FINE dB:	<i>7</i>	<i>5</i>		
			COARSE dB:	<i>30</i>	<i>1</i>		
INSTRUMENT SETTINGS				SCREEN DIVISIONS: <i>10</i> INCHES OF METAL			
REJECT:	<i>G</i>			LONGITUDINAL <input type="checkbox"/>	SHEAR <input type="checkbox"/>	EXAMINATION AREA(S)	
DEC:	<i>off</i>			100	90	<i>61R + 10.10 surfaces up, 6756</i>	
FINE dB:	<i>G</i>			90	80	<i>bed 1009-10 at 1238-3263</i>	
COARSE dB:	<i>70</i>			80	70	<i>674%</i>	
FREQUENCY:	<i>2</i>			70	60		
DELAY:	<i>0.03-1</i>			60	50		
MAT'L CAL:	<i>399</i>			50	40		
RANGE:	<i>5</i>			40	30		
DAMPING:	<i>min</i>			30	20		
REP RATE:	<i>1/8</i>			20	10		
FILTER:	<i>H</i>			10	0		
VIDEO:	<i>None</i>			0	10		
REVIEWED BY:	<i>J. C. McNamee</i>			0 1 2 3 4 5 6 7 8 9 10			
				BASIC CALIBRATION BLOCK NO.: <i>05</i>			
				SNT LEVEL: <i>II</i>		DATE: <i>26 JUN 77</i>	

Sw.RI SONIC INSTRUMENT VESSEL CALIBRATION RECORD						
PROJECT NO: 175339	SITE: Seawaydrill Tower Station, Unit 1	DATE: (DAY-MON-YR.) 25 Jun 79-79		TIME: (24 HR. CLOCK) 1102	SHEET NO. 10013	
1.) EXAMINER: <i>G.S. Swanson</i>	SNT LEVEL 30	PROCEDURE NO. 620-45	INSTRUMENT: SONIC MARK: <input checked="" type="checkbox"/> I <input type="checkbox"/> II <input type="checkbox"/> III <input type="checkbox"/>	SERIAL NO: <i>71573065</i>	CALIBRATION VERIFICATION	
2.) EXAMINER (OPERATOR) <i>W.M. Gauger</i>	SNT LEVEL 70	REV. 37	COUPLANT: GLYCERINE <input type="checkbox"/> WATER <input type="checkbox"/> OTHER (SPECIFY)	TIME: 1635		
SEARCH UNITS	REFERENCE BLK: 5-12-3	CAL.BL:	TEMPERATURE °F 68	INITIALS: <i>W.M.G.</i>		
NOMINAL ANGLE 60°	MEASURED ANGLE: 60°	CABLE TYPE RG62 <input type="checkbox"/> RG174 <input checked="" type="checkbox"/>	AMPLITUDE DETERMINATION FOR 5/8 NODE			
MEASURED ANGLE 60°	SIGNAL AMPLITUDE SCREEN DIVISIONS: 9	OTHER LENGTH 70 IN.	3/8 ECHO <i>10</i> dB <i>2</i> LINES OF AMPLITUDE			
BRAND Sw.RI	SERIAL NUMBER 436P	JACK USED ROT <input type="checkbox"/>	5/8 ECHO <i>10</i> dB <i>2</i> LINES OF AMPLITUDE			
SIZE: 1.0" dia	SIGNAL DISTANCE (IN): 44	MODE OF TRANS. NORM <input type="checkbox"/>	Δ dB <i>9</i> (3/8-5/8 ECHO)			
NOMINAL FREQUENCY (MHz): 3.25	SCREEN DIVISIONS: 1	THRU TRANS. <input type="checkbox"/>	REMARKS: 6143B mounted 1616 Lam. Sub. 98°F 1616 Linerper 5000 ft 3.25 MHz			
INSTRUMENT SETTINGS		SCREEN DIVISIONS: <i>10</i> INCHES OF METAL		EXAMINATION AREA(S)		
REJECT: 0	DEC: off	LONGITUDINAL <input type="checkbox"/> SHEAR <input type="checkbox"/>			1.0" dia. 436P 1.0" dia. 436P 1616 1.25" 1616	
FINE dB: 9	COARSE dB: 80					
FREQUENCY: 3.2	DELAY: 31.5-4					
MAT'L CAL: 664	RANGE: 10					
DAMPING: PAIR	REP RATE: 1K					
FILTER: 11	VIDEO: PAIR	BASIC CALIBRATION BLOCK NO: 05				
REVIEWED BY: <i>W.M. Gauger</i>	SNT LEVEL: 70			DATE: 26 JUN 79		

SSW. R. I. PRESSURE VESSEL ULTRASONIC EXAMINATION RECORD

Page 12 of 13

POOR ORIGINAL

Sw. R. I. PRESSURE VESSEL ULTRASONIC EXAMINATION RECORD

PROJECT NO.:		SITE:		DATE: (DAY-MON-YR.)		TIME (24 HR. CLOCK)		SHEET NO.:									
175339		Supernova Power Station, Unit 1		25 JAN 77		SHEET STARTED: 07:00		3000020									
EXAMINATION AREA (SYSTEM/COMPONENT)		(LINE / SUBASSEMBLY)		(IDENTIFICATION)		Lo LOCATION:		Wo LOCATION:									
RPV		Casing, weld		W001-10		Weld 10		Casing									
EXAMINER:		SNT LEVEL:		PROCEDURE		CALIBRATION SHEET(S)	ANGLE USED	0°	45°	45°T	60°	OTHER	WELD TYPE:				
H.C. Gangho.		711		NO. 400-45			SCANNING dB	17.7	N/A	N/A	N/A	N/A	WELD LENGTH: 44.50				
EXAMINER:		SNT LEVEL:		REV. 37		450214		X	N/A	N/A	N/A	N/A	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input type="checkbox"/>				
IND. NO.	% OF DAC MAX	50 % DAC		W MAX		50 % DAC		L ₁	L	L ₂	SEARCH UNIT	SEARCH UNIT	THRU WALL DEPTH % OF T	DEPTH BELOW SURFACE % OF T	REMARKS:	INT.	
		W ₁	MP	W	MP	W ₂	MP	50 % DAC	POSI- TION	50 % DAC	LOCA- TION	ANGLE	%	#			
1	9	-	-	25	52	-	-	35	-	DA	0°	N/A	N/A	X 14.8 mm thick down	DA		
SEE NOTE 1 - BACK OF PAGE														EXAMINATION AREA LIMITATION (IF NONE, SO STATE)			
SEE NOTE 2 - BACK OF PAGE														Weld at 139-32" to 260-60" W.L. 60 ft max.			
REVIEWED BY:		SNT LEVEL:		DATE:										PAGE 1 OF 1			
J. H. S.		711		30 JUN 77													

SW. R.I. PRESSURE VESSEL ULTRASONIC EXAMINATION RECORD																				
PROJECT NO.: 17-5339				SITE: Seawayde Power Station, Unit 1				DATE: (DAY-MON-YR.) 9/27/79				TIME (24 HR. CLOCK)				SHEET NO.: 3000023				
EXAMINATION AREA (SYSTEM/COMPONENT) RPV				(LINE / SUBASSEMBLY) Cladding				(IDENTIFICATION) 1004-12				Lo LOCATION: 1/2" of vessel				Wo LOCATION: 2 ft out				
EXAMINER: W.A. Heringer				SNT LEVEL: II				PROCEDURE NO. 600-5				CALIBRATION SHEET (S) 450012	ANGLE USED 0°	SCANNING dB 60/-3	45°	45°T	60°	OTHER	WELD TYPE:	
EXAMINER: N/A				SNT LEVEL: IIA				REV. 37							N/A	N/A	N/A	N/A	WELD LENGTH: 225"	
IND. NO.		% OF DAC MAX	50 % DAC		W MAX		50 % DAC		L ₁	L	L ₂	SEARCH UNIT LOCAT.	SEARCH UNIT LOCAT.	THRU WALL DEPTH % OF T *	DEPTH BELOW SURFACE % OF T *	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>				
		W ₁	MP	W	MP	W ₂	MP	50% DAC	POSITION	50% DAC	POSITION	ANGLE	ANGLE	% OF T *	% OF T *					
13		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
14		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
15		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
16		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
17		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
18		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
19		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
20		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
21		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
22		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
23		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
24		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
25		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
26		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
27		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
28		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
29		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
30		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
31		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
32		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
33		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
34		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
35		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
36		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
37		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
38		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
39		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
40		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
41		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
42		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
43		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
44		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
45		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
46		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
47		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
48		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
49		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
50		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
51		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
52		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
53		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
54		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
55		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
56		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
57		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
58		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
59		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
60		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
61		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
62		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
63		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
64		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
65		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
66		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
67		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
68		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
69		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
70		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
71		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
72		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
73		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
74		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
75		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
76		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
77		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
78		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
79		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
80		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
81		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
82		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD TYPE:		
83		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	WELD LENGTH: 225"		
84		141	5%	88	(%	92	63	96	15%	17%	45°	N/A	N/A	45°	45°T	60°	OTHER	EXAMINATION SURFACE INSIDE <input type="checkbox"/> OUTSIDE <input checked="" type="checkbox"/>		
85		141	5%	88	(%	92	63	96	15%	17										

SWRI SONIC INSTRUMENT VESSEL CALIBRATION RECORD

PROJECT NO: 175339		SITE: Sequoyah Power Station, Unit 1		DATE: (DAY-MON-YR.) 13 JULY 79		TIME: (24 HR. CLOCK) 1653		SHEET NO. 1/3012	
1.) EXAMINER (i) J. K.		SNT LEVEL 7A	PROCEDURE NO. CO. 15	INSTRUMENT: SONIC MARK: I <input type="checkbox"/> II <input type="checkbox"/> III <input checked="" type="checkbox"/>	SERIAL NO.: 730415	CALIBRATION VERIFICATION			
2.) EXAMINER: (OPERATOR) N/A		SNT LEVEL N/A	REV. 37	COUPLANT: GLYCERINE <input type="checkbox"/> WATER <input type="checkbox"/> OTHER (SPECIFY)		TIME: 1653	1653	1653	1653
SEARCH UNITS N/A		REFERENCE BLK: 15		CAL. BLK. TEMPERATURE 75 °F		INITIALS: JAK			
NOMINAL ANGLE	45°		MEASURED ANGLE:	45°	15°	AMPLITUDE DETERMINATION FOR 5/8 NODE			
MEASURED ANGLE	46°		SIGNAL AMPLITUDE	8		RG62 <input type="checkbox"/> RG174 <input checked="" type="checkbox"/>	3/8 ECHO 15 dB 3 LINES OF AMPLITUDE		
BRAND	SERIAL NUMBER		(SCREEN DIVISIONS):	8		OTHER LENGTH 7A IN.	5/8 ECHO 92 dB 3 LINES OF AMPLITUDE		
American	35133A	N/A	SIGNAL DISTANCE (IN):	4		JACK USED R <input type="checkbox"/> T <input type="checkbox"/>	Δ dB 14 (3/8-5/8 ECHO)		
			SCREEN DIVISIONS:	3		MODE OF TRANS. NORM <input type="checkbox"/>	REMARKS: 45° angle set up for calibration check surface 74° ± 5° temp 75°		
			COARSE RANGE:	10		THRU TRANS. <input type="checkbox"/>			
SIZE:	10x10		FINE dB:	6					
NOMINAL FREQUENCY(MHZ):	2.25		COARSE dB:	50					
INSTRUMENT SETTINGS			SCREEN DIVISIONS: 3 INCHES OF METAL			EXAMINATION AREA(S): 125°			
REJECT:	0	N/A	LONGITUDINAL <input type="checkbox"/>	SHEAR <input type="checkbox"/>		Re tank wall at 43° 72°			
DEC:	off		100			60° - 120°			
FINE dB:	0		90			Bottom sheet 30000			
COARSE dB:	100		80						
FREQUENCY:	0		70						
DELAY:	3333		60						
MAT'L CAL:	657		50						
RANGE:	10		40						
DAMPING:	M.W.		30						
REP RATE:	1K		20						
FILTER	1A		10						
VIDEO:	1000		0						
REVIEWED BY:	<i>J. K.</i>		SNT LEVEL:				DATE:		<i>26 JUN 79</i>

SWR INSTRUMENT LINEARITY VERIFICATION					
PROJECT NO.	SITE:	DATE TEST RUN NO.	DATE COMPLETED (4 MHZ CLOCK)	STRUCT NO.	
19-333	Site A, B, C, D	5/20/71	5/22/71	5/22/71	Z
INSTRUMENT USE 0, USE 0:	PORT 1A PORT 1B PORT 1C PORT 1D	5TH NO. PORT 1A PORT 1B PORT 1C PORT 1D	BASIC CALIBRATION BLOCK NO. 51		
MANUFACTURER:	5TH LEVEL	5TH LEVEL	5TH LEVEL	5TH LEVEL	
EXAMINED:	5TH LEVEL	5TH LEVEL	5TH LEVEL	5TH LEVEL	
TESTED BY:	John H. S.	John H. S.	John H. S.	John H. S.	
AMPLITUDE LINEARITY					
INSTRUMENT WITH FIRST IN CONTROL		AMPLITUDE CONTROL LINEARITY			
FIRST SIGNAL IN %	SECOND SIGNAL IN %	FIRST SIGNAL IN %	SECOND SIGNAL IN %	INDICATION	ACTUAL
100	100	100	100	0.0	0.0% OF FULL SCALE
90	40	-2.0	-2.0	-6.0	-5.2 TO 4.0
80	35	-2.0	-2.0	-12.0	16 TO 2.4
70	30	-2.0	-2.0	-16.0	0.4 TO 9.3
60	25	-2.0	-2.0	-20.0	7.3
50	20	-2.0	-2.0	-24.0	
40	15	-2.0	-2.0	-28.0	
30	10	-2.0	-2.0	-32.0	
20	11	-2.0	-2.0	-36.0	
REVIEWED BY		5TH LEVEL	5TH LEVEL	5TH LEVEL	

FORM NO. 3001-10-3000-6-9-11

R HEADING MUST BE $50^\circ \pm 3\%$ OF FIRST STATION ATTITUDE.

SWRI BEAM SPREAD RECORD

PROJECT NO. 17-45-5359	SITE: Engineering	DATE (DAY - MON. - YR.) 25 Jan 71	TIME COMPLETED(24HR CLOCK) 17:30	SHEET 3/5034
CALIBRATION SHEETS: 450012	dB AT 50%: 39.6 dB ref	TRANSDUCER BRAND: SWEET	TRANSDUCER SERIAL NUMBER: 43641	
	EXAMINER: W.C. McCaffrey	SHT LEVEL: II	EXAMINER: W.C. Harrington	SHT LEVEL: II
MEASUREMENTS TAKEN FROM INCIDENCE ANGLE TO SCRIBE LINE	W_1 50% DAC $2\frac{1}{2}''$	W MAX $2\frac{1}{2}''$	W_2 50% DAC $2\frac{1}{4}''$	MEASURED ANGLE OF BEAM SPREAD: $6^{\circ} 3^{\circ}$ $1-2 \quad 2-3$
$\frac{1}{4}$ T HOLE	$2\frac{1}{2}''$	$2\frac{1}{2}''$	$2\frac{1}{4}''$	
$\frac{1}{2}$ T HOLE	$5\frac{9}{16}''$	$6\frac{1}{4}''$	$6\frac{1}{4}''$	ACTUAL REFRACTED ANGLE: $62^{\circ} 59^{\circ} 61^{\circ}$ $1-2 \quad 2-3 \quad 1-3$
$\frac{3}{4}$ T HOLE	$2\frac{1}{2}''$	$2\frac{1}{2}''$	$10\frac{3}{4}''$	
REMARKS: 60° 18° FAILING				
POOR ORIGINAL				
REVIEWED BY: D. M. Schaefer	SHT LEVEL: II		DATE: 26-1-71	

POOR ORIGINAL

461 247

Sykt 436M 1.0" IP 2.25MHz March Unit

2-359
1-3 61
1-2 62

①

②

③

Basic Calibration Block 05

BEAM SPREAD SHEET 360034

SWR 1 17-5339-004
SEQUOYAH 26JAN79 JJC M Gough