POOR ORIGINAL 3

ATTENDED FORKET FILE COPY

JUN 2 0 19/9

MEMORANDUM FOR:

D. G. Eisenhut, Acting Director

Division of Operating Reactors

FROM:

V. S. Noonan, Chief, Engineering Branch

Division of Operating Reactors

THRU:

L. C. Shao, Acting Assistant Director

for Engineering Programs
Officion of Operating Reactors

SUBJECT:

CRACKS IN DECAY HEAT PIPING - THREE MILE ISLAND - T

issued a Preliminary Notification regarding this matter on June 22, 1979. have since contacted Ed Jordan of I&E and were given the following additional preliminary information:

In addition to the original leak, 11 NDT indications plus 4 areas of potential boric acid leaks have been found. The line is approximately 100 ft. long.

Joe Collins of I&E plus Al Taboada of EB are scheduled to visit the site on Thursday or Friday, June 28 or 29 to obtainffurther information.

A transfer of lead will be discussed with IZE after the site visit.

Bed Becals former

Mig pour is I kupo put

Vincent S. Noonan, Chief Engineering Branch Division of Operating Reactors

cc: W. Hazelton R. Klecker

A. Toboada E. Jordan 552004

P

7907190268

	,	OUS YELLOW FOR	17	Actiec	
OFFICE P	EB ORR	EB:DOR*	EB:DOR /	A:DIR/NOX/	
SURMANS >	RKlecker	WHaze Mon	VNoggan	L LSnao	
CATE	6/ /79	6/ //79	647/179	66.7/79	



JUN 2 6 1979

MEMORANDUM FOR: D. G. Eisenhut, Acting Director

Division of Operating Reactors

FROM:

V. S. Noonan, Chief, Engineering Branch

Division of Operating Reactors

THRU:

L. C. Shao, Acting Assistant Direct -

or Encineering Programs Division of Operating Reactors

SUBJECT:

CRICK IN DECAY HEAT PIPING - THREE MILE ISLAND - I

ILE issued a Prelimina v Notification regarding this matter on June 22, 1979. We have since contacted Ed Jordan of I&E and were given the following addittonal preliminary information:

In addition to the original leak, IT NDT indications plus 4 areas of potential borfe acid leaks have been found. The line is approximately 100 ft. long.

Joe Collins of I&E plus Al Taboada of EB are scheduled to visit the site on Thursday or Friday, June 28 or 29 to obtain further information.

A transfer of lead is being considered and will probably be implemented after the site visit.

Original signed by &

Vincent S. Noonan, Chief Engineering Branch Division of Operating Reactors

cc: W. Hazelton

R. Klecker

A. Taboada

	0.5	· M				
orrica (*	EB:90F/	CES TOOR	EB:DOR	T, V		
SDRMAPT >	RKlecker:mb	WHazelton	VNoonan	/la		
DATE	6/3/6/79	671179	6/1/29	v	 	