

TERA



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

Docket No. 50-334

JUN 14 1979

LICENSEE: Duquesne Light Company
Facility: Beaver Valley Unit No. 1
SUBJECT: MEETING SUMMARY - PIPESTRESS REANALYSIS

The licensee and Stone and Webster Engineering Corporation met with the staff on May 24, 1979 to discuss the amplified response spectra (ARS) developed with consideration of soil structure interactions. The proposed ARS is to be used in the pipestress reanalysis for the Beaver Valley, Unit No. 1. The list of attendees is shown on Enclosure 1.

Stone and Webster (S&W) presented the information on the Beaver Valley site. This information is included in the May 23, 1979 letter from Mr. C. N. Dunn to the NRC on the ARS proposed and in Enclosure II on the soil properties and location. The soil properties for the proposed ARS and the ongoing liguafaction review are reported by S&W to be the same.

Following a discussion by the NRC staff, the licensee was informed that the proposed ARS would be acceptable if calculated stresses were increased by 20% in the fundamental period range of 0.4 to 0.55 sec. This corresponds to the natural frequency range of the peak acceleration as presented in the PSAR. In further investigation by S&W, only one system is effected; the raw water system. Further delays in the reanalysis are not expected.

Dave Wigginton
Dave Wigginton, Project Manager
Operating Reactors Branch #1
Division of Operating Reactors

Enclosures:
List of Attendees
Soil Properties and Location

cc: w/enclosures
See next page

646 160

10

7907250057

Docket Files

NRC PDR
Local PDR
ORBI Reading
NRR Reading
H. Denton
E. Case
V. Stello
D. Eisenhut
B. Grimes
R. Vollmer
A. Schwencer
D. Ziemann
P. Check
G. Lainas
D. Davis
B. Grimes
T. Ippolito
R. Reid
V. Noonan
G. Knighton
D. Brinkman
Project Manager
OELD
OI&E (3)
C. Parrish
ACRS (16)
NRC Participants
J. Buchanan
TERA
Licensee

Gerald Charnoff, Esquire
Jay E. Silberg, Esquire
Shaw, Pittman, Potts and Trowbridge
1800 M Street, N.W.
Washington, D. C. 20036

Karin Carter, Esquire
Special Assistant Attorney General
Bureau of Administrative Enforcement
5th Floor, Executive House
Harrisburg, Pennsylvania 17120

Mr. J. M. Cumiskey
Stone and Webster Engineering
Corporation
P. O. Box 2325
Boston, Massachusetts 02107

Mr. James A. Werling
Plant Superintendent
Beaver Valley Power Station
P. O. Box 4
Shippingport, Pennsylvania 15077

Mr. J. D. Woodward
R & D Center
Westinghouse Electric Corporation
Building 7-303
Pittsburgh, Pennsylvania 15230

B. F. Jones Memorial Library
663 Franklin Avenue
Aliquippa, Pennsylvania 15001

Mr. Jack Carey
Technical Assistant
Duquesne Light Company
P. O. Box 4
Shippingport, Pennsylvania 15077

Mr. R. E. Martin
Duquesne Light Company
435 Sixth Avenue
Pittsburgh, Pennsylvania 15219

Marvin Fein
Utility Counsel
City of Pittsburgh
313 City-County Building
Pittsburgh, Pennsylvania 15219

BEAVER VALLEY PIPESTRESS MEETINGLIST OF ATTENDEES

<u>NAME</u>	<u>ORGANIZATION</u>
D. Wigginton	ORB#1-NRR
J. P. Knight	NRC/DSS
Steve Lewis	NRC/OELD
P. A. Wild	Stone & Webster
K. A. Condon	Stone & Webster
S. C. Rossier	Stone & Webster
J. T. Christian	Stone & Webster
A. S. Lucks	Stone & Webster
J. J. Carey	Duquesne Light Co.
G. W. Moore	Duquesne Light Co.
B. W. Churchill	Shaw, Pittman
J. Martore	NRC
J. Kane	NRC
J. M. Giannelli	NRC
F. P. Schauer	NRC
H. E. Polk	NRC/DSS/SEB
P. Chan	NRC/DSS/SEB
P. T. Kuo	NRC/DSS/SEB
J. Greeves	NRC
L. Heller	NRC





FIGURE 2.1-1
 BORING LOCATION PLAN
 CATEGORY 1 AREA
 BEAVER VALLEY POWER STATION-UNIT 1

646 163



VALUES ASSUMED FOR COMPUTING C_s

e = 0.58	e = 0.46
S = 50 %	S = 50 %
$\gamma_1 = 120$ pcf	$\gamma_1 = 125$ pcf
S = 100 %	S = 100 %
$\gamma_1 = 130$ pcf	$\gamma_1 = 135$ pcf
$G_s = 2.70$	

FIGURE 2.4-1
MEASURED AND COMPUTED VALUES
OF SHEAR WAVE VELOCITY
BEAVER VALLEY POWER STATION-UNIT 1




FIGURE 2.4-2
 FREE FIELD SOIL PROFILE
 BEAVER VALLEY POWER STATION-UNIT 1




Fig. 5.2 SHEAR MODULI OF SANDS AT RELATIVE DENSITY OF ABOUT 75%.

(From Seed and Lysmer, 1970 c)




Fig. 5.9 DAMPING RATIOS FOR SANDS.

(From Seed and Idriess, 1970c)

TABLE 1

PERCENT VARIATION FROM AVERAGE K_2 CURVE
CORRESPONDING TO \pm ONE STANDARD DEVIATION
OF ALL DATA POINTS SHOWN ON FIG. 5.2 (REF. 1)

Shear Strain Range, %	\pm Percent of Average K_2 Value in Range Corresponding to \pm One Standard Deviation, %
10^{-4} to 10^{-3}	± 14.1
10^{-3} to 6×10^{-3}	± 17.8
6×10^{-3} to 2×10^{-2}	± 30.8
2×10^{-2} to 10^{-1}	± 53.0

NOTES:

1. See Figure 1
2. Standard Deviation is Function of Variability of Data Shown on Figure 1 and Variation of Maximum Shear Moduli Values Measured at Beaver Valley Power Station 1 & 2.
3. $G = 1000 K_2 (\sigma_M')^{1/2}$, PSF
Where G = Shear Modulus At Particular Strain
 σ_M' = Mean Principal Effective Stress, PSF