

UNITED STATES NUCLEAR REGULATORY COMMISSION WASHINGTON, D. C. 20555

JUN 1 8 1979

DOCKET NOS. 50-369

AND 50-370

APPLICANT: DUKE POWER COMPANY

FACILITY: MCGUIRE NUCLEAR STATION, UNITS 1 AND 2

SUBJECT: SUMMARY OF MEETING HELD ON JUNE 8, 1979

A meeting was held with the applicant on June 8, 1979 in Bethesda, Maryland to discuss the McGuire Radiological Effluent Technical Specifications. A list of attendees is provided in the Enclosure.

The purpose of the meeting was to discuss the draft Radiological Effluent Technical Specifications (RETS) and the Offsite Dose Calculation Manual (ODCM) submitted December 18, 1978 (revised March 23, 1979) and January 25, 1979, respectively. The staff informed Duke that more information was required to identify their use of radwaste equipment, their process or program for solidification and their monitoring programs. The applicant agreed to provide:

- 1. Meteorology data background to the Hydrology/Meteorology Branch.
- 2. Details on the Condensate Cleanup System collection tank to the Effluent Treatment Systems Branch, and
- 3. Process Control Program for Solidification to the Effluent ireatment Systems Branch.

The staff provided revised Radiological Effluent Technical Specifications, (RETS) including sections that should be incorporated in the Standard Technical Specifications for McGuire. The staff (Radiological Assessment Branch) will provide additional guidance on a specification for therrolumeniscent dosimeter area monitoring around the facility. Other significant items discussed, that will require additional correspondence are as follows:

- Solidification Can the definition exclude low level radioactive wastes (wet resin and filters) in the compressed state? The Effluent Treatment Systems Branch will inform Duke.
- 2. F-32 and Fe-55 analysis Can the analysis be performed by an effective surveillance program? Duke will inform Radiological Assessment Branch.

3. Equent three quarters (Specifications 3.11.1.2, 3.11.2.2 and 3.11.2.3) - this period be changed to the remainder of the calendar? The Effluent Treatment Systems Branch will inform Duke.

The applicant will review the revised Radiological Effuent Technical Specifications and resubmit his proposal on July 6, 1979 to follow with a revised Offsite Dose Calculation Manual in mid-August. His submittal of the solidification process control program is subject to the vendor's schedule, but should be available about August 1979.

Vacques S. Boegli, Senior Nuclear Engineer Effluent Treatment Systems Branch Division of Site Safety and Environmental Analysis

Enclosure: Attendance List

ccs w/enclosure: See next pages

Mr. William O. Parker, Jr.
Vice President, Steam Production
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

cc: Mr. W. L. Porter
Duke Power Company
P. O. Box 2178
422 South Church Street
Charlotte, North Carolina 28242

Mr. R. S. Howard Power Systems Division Westinghouse Electric Corporation P. O. Box 355 Pittsburgh, Pennsylvania 15230

Mr. E. J. Keith
EDS Nuclear Incorporated
220 Montgomery Street
San Francisco, California 94104

Mr. J. E. Houghtaling NUS Corporation 2536 Countryside Boulevard Clearwater, Florida 33515

Mr. Jesse L. Riley, President The Carolina Environmental Study Group 854 Henley Place Charlotte, North Carolina 28207

J. Michael McGarry, III, Esq. Debevoise & Liberman 1200 Seventeenth Street, N. W. Washington, D. C. 20036

Shelley Blum, Esq. 418 Law Building 730 East Trade Street Charlotte, North Carolina 28202

Robert M. Lazo, Esq., Chairman Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

Dr. Emmeth A. Luebke Atomic Safety and Licensing Board U. S. Nuclear Regulatory Commission Washington, D. C. 20555

cc: Dr. Cadet H. Hand, Jr., Director Bodega Marine Lab of California P. O. Box 247 Bodega Bay, California 94923

> Ms. Brenda Best Carolina Action 1740 E. Independence Boulevard Charlotte, North Carolina 28205

Anthony Z. Roisman, Esq. Natural Resources Defense Council 917 - 15th Street, N. W. Washington, D. C. 20555

Richard P. Wilson, Esq. Assistant Attorney General State of South Carolina 2600 Bull Street Columbia, South Carolina 29201

Mr. Geoffrey Owen Little P. O. Box 2501 Davidson College Davidson, North Carolina 28036

ENCLUSURE

x - x * - x

ATTENDANCE LIST MEETING WITH DUKE POWER COMPANY JUNE 8, 1979

DUKE POWER COMPANY

T. J. Keane

T. L. McConnell G. A. Copp

M. L. Birch

NRC - STAFF

P. C. Wagner

D. S. Brinkman

W. Britz

L. Brown J. Wing

J. Boegli