



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

GEORGIA POWER COMPANY
OGLETHORPE ELECTRIC MEMBERSHIP CORPORATION
MUNICIPAL ELECTRIC ASSOCIATION OF GEORGIA
CITY OF DALTON, GEORGIA

DOCKET NO. 50-366

EDWIN I. HATCH NUCLEAR PLANT, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 8
License No. NPF-5

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Georgia Power Company, et al., (the licensee) dated May 22, 1979, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

464 243

7907270 322


2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-5 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 8, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance.

FOR THE NUCLEAR REGULATORY COMMISSION


Thomas A. Ippolito, Chief
Operating Reactors Branch #3
Division of Operating Reactors

Attachment:
Changes to the Technical
Specifications

Date of Issuance: July 3, 1979

ATTACHMENT TO LICENSE AMENDMENT NO. 8

FACILITY OPERATING LICENSE NO. NPF-5

DOCKET NO. 50-366

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages. The revised pages are identified by Amendment number and contain vertical lines indicating the area of change.

<u>Remove</u>	<u>Insert</u>
3/4 0-1	3/4 0-1
3/4 0-2*	3/4 0-2*
3/4 3-1	3/4 3-1
3/4 3-2*	3/4 3-2*
3/4 3-3*	3/4 3-3*
3/4 3-4	3/4 3-4
3/4 3-5	3/4 3-5
3/4 3-6*	3/4 3-6*
3/4 3-9	3/4 3-9
3/4 3-10	3/4 3-10
3/4 3-15	3/4 3-15
3/4 3-16*	3/4 3-16*
B 3/4 0-1	B 3/4 0-1
B 3/4 0-2*	B 3/4 0-2*

*Overleaf provided for convenience only.

3/4 LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

3/4.0 APPLICABILITY

LIMITING CONDITION FOR OPERATION

3.0.1 Limiting Conditions for Operation and ACTION requirements shall be applicable during the OPERATIONAL CONDITIONS or other states specified for each specification.

3.0.2 Adherence to the requirements of the Limiting Condition for Operation and associated ACTION within the specified time interval shall constitute compliance with the specification. In the event the Limiting Condition for Operation is restored prior to expiration of the specified time interval, completion of the ACTION statement is not required.

3.0.3 In the event a Limiting Condition for Operation and/or associated ACTION requirements cannot be satisfied because of circumstances in excess of those addressed in the specification, the facility shall be placed in at least HOT SHUT DOWN within 6 hours and in COLD SHUTDOWN within the following 30 hours unless corrective measures are completed that permit operation under the permissible ACTION statements for the specified time interval as measured from initial discovery or until the reactor is placed in an OPERATIONAL CONDITION in which the specification is not applicable. Exceptions to these requirements shall be stated in the individual specifications.

3.0.4 Entry into an OPERATIONAL CONDITION or other specified applicability state shall not be made unless the conditions of the Limiting Condition for Operation are met without reliance on provisions contained in the ACTION statements unless otherwise excepted. This provision shall not prevent passage thru OPERATIONAL CONDITIONS required to comply with ACTION requirements.

SURVEILLANCE REQUIREMENTS

4.0.1 Surveillance Requirements shall be applicable during the OPERATIONAL CONDITIONS or other states specified for individual Limiting Conditions for Operation unless otherwise stated in the individual Surveillance Requirements.

4.0.2 Each Surveillance Requirement shall be performed within the specified time interval with:

- a. A maximum allowable extension not to exceed 25% of the surveillance interval, 464 246

APPLICABILITY

SURVEILLANCE REQUIREMENTS (Continued)

- b. A total maximum combined interval time for any 3 consecutive surveillance intervals not to exceed 3.25 times the specified surveillance interval.

4.0.3 Performance of a Surveillance Requirement within the specified time interval shall constitute compliance with OPERABILITY requirements for a Limiting Condition for Operation and associated ACTION statements unless otherwise required by the specification. Surveillance requirements do not have to be performed on inoperable equipment.

4.0.4 Entry into an OPERATIONAL CONDITION or other specified applicable state shall not be made unless the Surveillance Requirement(s) associated with the Limiting Condition for Operation have been performed within the applicable surveillance interval or as otherwise specified.

4.0.5 Surveillance Requirements for inservice inspection and testing of ASME Code Class 1, 2, & 3 components shall be applicable as follows:

- a. During the time period:
 - 1. From issuance of the Facility Operating License to the start of facility commercial operation, inservice testing of ASME Code Class 1, 2, & 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code 1974 Edition, and Addenda through summer 1975, except where specific written relief has been granted by the Commission.
 - 2. Following start of facility commercial operation, inservice inspection of ASME Code Class 1, 2, and 3 components and inservice testing of ASME Code Class 1, 2, and 3 pumps and valves shall be performed in accordance with Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda as required by 10 CFR 50, Section 50.55a(g), except where specific written relief has been granted by the Commission pursuant to 10 CFR 50, Section 50.55a(g) (6) (i).
- b. Surveillance intervals specified in Section XI of the ASME Boiler and Pressure Vessel Code and applicable Addenda for the inservice inspection and testing activities required by the ASME Boiler and Pressure Vessel Code and applicable Addenda shall be applicable as follows in these Technical Specifications:

TABLE 3.3.1-1

REACTOR PROTECTION SYSTEM INSTRUMENTATION

FUNCTIONAL UNIT	APPLICABLE OPERATIONAL CONDITIONS	MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(a)	ACTION
1. Intermediate Range Monitors: (2C51-K601 A, B, C, D, E, F, G, H)			
a. Neutron Flux - High	2 ^(c) , 5 ^(b)	3	1
	3, 4	2	2
b. Inoperative	2, 5 ^(b)	3	1
	3, 4	2	2
2. Average Power Range Monitor: (2C51-K605 A, B, C, D, E, F)			
a. Neutron Flux - High, 15%	2, 5	2	1
b. Flow Biased Neutron Flux - High	1	2	3
c. Inoperative	1, 2, 5	2	4
d. Downscale	1	2	3
e. LPRM	1, 2, 5	(d)	NA
3. Reactor Vessel Steam Dome Pressure - High (2B21-N023 A, B, C, D)	1, 2 ^(e)	2 ^(j) , 2B21-N045-A, B, C, D)	5
4. Reactor Vessel Water Level - Low (2B21-N017 A, B, C, D)	1, 2	2 ^(j) , 2B21-N024-A, B and 2B21-N025-A, B)	5
5. Main Steam Line Isolation Valve Closure (NA)	1 ^(f)	4	3
6. Main Steam Line Radiation - High (2D11-K603 A, B, C, D)	1, 2 ^(e)	2	6
7. Drywell Pressure - High (2C71-N002 A, B, C, D)	1, 2 ^(g)	2	5

HATCH - UNIT 2

3/4 3-2

464

248

3/4.3 INSTRUMENTATION

3/4.3.1 REACTOR PROTECTION SYSTEM INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.1 As a minimum, the reactor protection system instrumentation channels shown in Table 3.3.1-1 shall be OPERABLE with the REACTOR PROTECTION SYSTEM RESPONSE TIME as shown in Table 3.3.1-2. Set points and interlocks are given in Table 2.2.1-1.

APPLICABILITY: As shown in Table 3.3.1-1.

ACTION:

- a. With the requirements for the minimum number of OPERABLE channels not satisfied for one trip system, place at least one inoperable channel in the tripped condition within one hour.
- b. With the requirements for the minimum number of OPERABLE channels not satisfied for both trip systems, place at least one inoperable channel in at least one trip system* in the tripped condition within one hour and take the ACTION required by Table 3.3.1-1.
- c. The provisions of Specification 3.0.3 are not applicable in OPERATIONAL CONDITION 5.

SURVEILLANCE REQUIREMENTS

4.3.1.1 Each reactor protection system instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL CHECK, CHANNEL FUNCTION TEST and CHANNEL CALIBRATION operations during the OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.1-1.

4.3.1.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months and shall include calibration of time delay relays and timers necessary for proper functioning of the trip system.

4.3.1.3 The REACTOR PROTECTION SYSTEM RESPONSE TIME of each reactor trip function of Table 3.3.1-2 shall be demonstrated to be within its limit at least once per 18 months. Each test shall include at least one logic train such that both logic trains are tested at least once per 36 months and one channel per function such that all channels are tested at least once every N times 18 months where N is the total number of redundant channels in a specific reactor trip function.

*If both channels are inoperable in one trip system, select at least one inoperable channel in that trip system to place in the tripped conditions, except when this could cause the Trip Function to occur.

HATCH - UNIT 2

TABLE 3.3.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION

<u>FUNCTIONAL UNIT</u>	<u>APPLICABLE OPERATIONAL CONDITIONS</u>	<u>MINIMUM NUMBER OPERABLE CHANNELS PER TRIP SYSTEM(a)</u>	<u>ACTION</u>
8. Scram Discharge Volume Water Level - High (2C11-N013 A, B, C, D)	1, 2, 5 ^(h)	2	4
9. Turbine Stop Valve - Closure (NA)	1 ⁽ⁱ⁾	4 ^(k)	7
10. Turbine Control Valve Fast Closure, Trip Oil Pressure - Low (2C71-N005 A, B, C, D)	1 ⁽ⁱ⁾	2 ^(k)	7
11. Reactor Mode Switch in Shutdown Position (NA)	1, 2, 3, 4, 5	1	8
12. Manual Scram (NA)	1, 2, 3, 4, 5	1	9

3/4 3-3

464
250

TABLE 3.3.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION

ACTION

- ACTION 1 - In OPERATIONAL CONDITION 2, be in at least HOT SHUTDOWN within 6 hours.
- In OPERATIONAL CONDITION 5, suspend all operations involving CORE ALTERATIONS or positive reactivity changes and fully insert all insertable control rods within one hour.
- ACTION 2 - Lock the reactor mode switch in the Shutdown position within one hour.
- ACTION 3 - Be in at least STARTUP within 2 hours.
- ACTION 4 - In OPERATIONAL CONDITION 1 or 2, be in at least HOT SHUTDOWN within 6 hours.
- In OPERATIONAL CONDITION 5, suspend all operations involving CORE ALTERATIONS or positive reactivity changes and fully insert all insertable control rods within one hour.
- ACTION 5 - Be in at least HOT SHUTDOWN within 6 hours.
- ACTION 6 - Be in STARTUP with the main steam line isolation valves closed within 2 hours or in at least HOT SHUTDOWN within 6 hours.
- ACTION 7 - Initiate a reduction in THERMAL POWER within 15 minutes and be at less than 30% of RATED THERMAL POWER within 2 hours.
- ACTION 8 - In OPERATIONAL CONDITION 1 or 2, be in at least HOT SHUTDOWN within 6 hours.
- In OPERATIONAL CONDITION 3 or 4, immediately and at least once per 12 hours verify that all control rods are fully inserted.
- In OPERATIONAL CONDITION 5, suspend all operations involving CORE ALTERATIONS or positive reactivity changes and fully insert all insertable control rods within one hour.

TABLE 3.3.1-1 (Continued)

REACTOR PROTECTION SYSTEM INSTRUMENTATION

ACTION 9 - In OPERATIONAL CONDITION 1 or 2, be in at least HOT SHUTDOWN within 6 hours.

In OPERATIONAL CONDITION 3 or 4, lock the reactor mode switch in the Shutdown position within one hour.

In OPERATIONAL CONDITION 5, suspend all operations involving CORE ALTERATIONS or positive reactivity changes and fully insert all insertable control rods within one hour.

TABLE NOTATIONS

- a. A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one OPERABLE channel in the same trip system is monitoring that parameter.
- b. The "shorting links" shall be removed from the RPS circuitry during CORE ALTERATIONS and shutdown margin demonstrations performed in accordance with Specification 3.10.3.
- c. The IRM scrams are automatically bypassed when the reactor vessel mode switch is in the Run position and all APRM channels are OPERABLE and on scale.
- d. An APRM channel is inoperable if there are less than 2 LPRM inputs per level or less than eleven LPRM inputs to an APRM channel.
- e. These functions are not required to be OPERABLE when the reactor pressure vessel head is unbolted or removed.
- f. This function is automatically bypassed when the reactor mode switch is in other than the Run position.
- g. This function is not required to be OPERABLE when PRIMARY CONTAINMENT INTEGRITY is not required.
- h. With any control rod withdrawn. Not applicable to control rods removed per Specification 3.9.11.1 or 3.9.11.2.
- i. These functions are bypassed when turbine first stage pressure is <math>< 250^* \text{ psig}</math>, equivalent to THERMAL POWER less than 30% of RATED THERMAL POWER.
- j. Also trips reactor coolant system recirculation pump MG sets.
- k. Also trips reactor coolant system recirculation pump motors.

* Initial setpoint. Final setpoint to be determined during startup testing.

464 252
~~252~~
~~252~~

HATCH - UNIT 2

3/4 3-6

TABLE 3.3.1-2

REACTOR PROTECTION SYSTEM RESPONSE TIMES

<u>FUNCTIONAL UNIT</u>	<u>RESPONSE TIME</u> (Seconds)
1. Intermediate Range Monitors:	
a. Neutron Flux - High*	NA
b. Inoperative	NA
2. Average Power Range Monitor:*	
a. Neutron Flux - High, 15%	< 0.09
b. Flow Biased Neutron Flux - High	< 0.09
c. Inoperative	NA
d. Downscale	NA
e. LPRM	NA
3. Reactor Vessel Steam Dome Pressure - High	≤ 0.55
4. Reactor Vessel Water Level - Low	≤ 1.05
5. Main Steam Line Isolation Valve - Closure	≤ 0.06
6. Main Steam Line Radiation - High	NA
7. Drywell Pressure - High	NA
8. Scram Discharge Volume Water Level - High	NA
9. Turbine Stop Valve - Closure	≤ 0.06
10. Turbine Control Valve Fast Closure, Trip Oil Pressure - Low	≤ 0.08
11. Reactor Mode Switch in Shutdown Position	NA
12. Manual Scram	NA

*Neutron detectors are exempt from response time testing. Response time shall be measured from detector output or input of first electronic component in channel.

464
253

INSTRUMENTATION

3/4.3.2 ISOLATION ACTUATION INSTRUMENTATION

LIMITING CONDITION FOR OPERATION

3.3.2 The isolation actuation instrumentation channels shown in Table 3.3.2-1 shall be OPERABLE with their trip setpoints set consistent with the values shown in the Trip Setpoint column of Table 3.3.2-2 and with ISOLATION SYSTEM RESPONSE TIME as shown in Table 3.3.2-3.

APPLICABILITY: As shown in Table 3.3.2-1.

ACTION:

- a. With an isolation actuation instrumentation channel trip setpoint less conservative than the value shown in the Allowable Values column of Table 3.3.2-2, declare the channel inoperable and place the inoperable channel in the tripped condition* until the channel is restored to OPERABLE status with its trip setpoint adjusted consistent with the Trip Setpoint value.
- b. With the requirements for the minimum number of OPERABLE channels not satisfied for one trip system, place at least one inoperable channel in the tripped condition* within one hour.
- c. With the requirements for the minimum number of OPERABLE channels not satisfied for both trip systems, place at least one inoperable channel in at least one trip system** in the tripped condition within one hour and take the ACTION required by Table 3.3.2-1.
- d. The provisions of Specification 3.0.3 are not applicable in OPERATIONAL CONDITION 5.

SURVEILLANCE REQUIREMENTS

4.3.2.1 Each isolation actuation instrumentation channel shall be demonstrated OPERABLE by the performance of the CHANNEL FUNCTIONAL TEST AND CHANNEL CALIBRATION operations during OPERATIONAL CONDITIONS and at the frequencies shown in Table 4.3.2-1.

* With a design providing only one channel per trip system, an inoperable channel need not be placed in the tripped condition where this would cause the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 2 hours or the ACTION required by Table 3.3.2-1 for that Trip Function shall be taken.

**If both channels are inoperable in one trip system, select at least one inoperable channel in that trip system to place in the tripped condition, except when that would cause the Trip Function to occur.

INSTRUMENTATION

SURVEILLANCE REQUIREMENTS (Continued)

4.3.2.2 LOGIC SYSTEM FUNCTIONAL TESTS and simulated automatic operation of all channels shall be performed at least once per 18 months and shall include calibration of time delay relays and timers necessary for proper functioning of the trip system.

4.3.2.3 The ISOLATION SYSTEM RESPONSE TIME of each isolation function shown in Table 3.3.2-3 shall be demonstrated to be within its limit at least once per 18 months. Each test shall include at least one logic train such that both logic trains are tested at least once per 36 months and one channel per function such that all channels are tested at least once every N times 18 months, where N is the total number of redundant channels in a specific isolation function.

TABLE 3.3.2-1 (Continued)

ISOLATION ACTUATION INSTRUMENTATION

ACTION

- ACTION 20 - Be in at least HOT SHUTDOWN within 6 hours and in COLD SHUTDOWN within the next 30 hours.
- ACTION 21 - Be in at least STARTUP with the main steam line isolation valves closed within 2 hours or be in at least HOT SHUTDOWN within 6 hours and in COLD SHUTDOWN within the next 30 hours.
- ACTION 22 - Be in at least STARTUP within 2 hours.
- ACTION 23 - Be in at least STARTUP with the Group 1 isolation valves closed within 2 hours or in at least HOT SHUTDOWN within 6 hours.
- ACTION 24 - Establish SECONDARY CONTAINMENT INTEGRITY with the standby gas treatment system operating within one hour.
- ACTION 25 - Isolate the reactor water cleanup system.
- ACTION 26 - Close the affected system isolation valves and declare the affected system inoperable.
- ACTION 27 - Verify power availability to the bus at least once per 12 hours or close the affected system isolation valves and declare the affected system inoperable.
- ACTION 28 - Close the shutdown cooling supply and reactor vessel head spray isolation valves unless reactor steam dome pressure \leq 135 psig.

NOTES

- # Actuates operation of the main control room environmental control system in the pressurization mode of operation.
- * Actuates the standby gas treatment system.
- ** When handling irradiated fuel in the secondary containment.
- a. See Specification 3.6.3.1, Table 3.6.3.1-1 for valves in each valve group.
- b. A channel may be placed in an inoperable status for up to 2 hours for required surveillance without placing the trip system in the tripped condition provided at least one other OPERABLE channel in the same trip system is monitoring that parameter.
- c. With a design providing only one channel per trip system, an inoperable channel need not be placed in the tripped condition where this would cause the Trip Function to occur. In these cases, the inoperable channel shall be restored to OPERABLE status within 2 hours or the ACTION required by Table 3.3.2-1 for that Trip Function shall be taken.
- d. Trips the mechanical vacuum pumps.
- e. A channel is OPERABLE if 2 of 4 instruments in that channel are OPERABLE.
- f. May be bypassed with reactor steam pressure \leq 1045 psig and all turbine stop valves closed.
- g. Closes only RWCU outlet isolation valve 2G31-F004.
- h. Alarm only.
- i. Adjustable up to 60 minutes.

TABLE 3.3.2-2

ISOLATION ACTUATION INSTRUMENTATION SETPOINTS

<u>TRIP FUNCTION</u>	<u>TRIP SETPOINT</u>	<u>ALLOWABLE VALUE</u>
<u>1. PRIMARY CONTAINMENT ISOLATION</u>		
a. Reactor Vessel Water Level		
1. Low	≥ 12.5 inches*	≥ 12.5 inches*
2. Low Low	$\geq -3^R$ inches*	≥ -38 inches*
b. Drywell Pressure - High	≤ 2 psig	≤ 2 psig
c. Main Steam Line		
1. Radiation - High	≤ 3 x full power background	≤ 3 x full power background
2. Pressure - Low	≥ 825 psig	≥ 825 psig
3. Flow - High	$\leq 140\%$ of rated flow	$\leq 140\%$ of rated flow
d. Main Steam Line Tunnel Temperature - High	$\leq 200^\circ\text{F}$	$\leq 200^\circ\text{F}$
e. Condenser Vacuum - Low	≥ 7 " Hg vacuum	≥ 7 " Hg vacuum
f. Turbine Building Area Temp.-High	$\leq 200^\circ\text{F}$	$\leq 200^\circ\text{F}$
<u>2. SECONDARY CONTAINMENT ISOLATION</u>		
a. Reactor Building Exhaust Radiation - High	≤ 60 mr/hr**	≤ 60 mr/hr**
b. Drywell Pressure - High	≤ 2 psig	≤ 2 psig
c. Reactor Vessel Water Level - Low	≥ 12.5 inches*	≥ 12.5 inches*
d. Refueling Floor Exhaust Radiation - High	≤ 20 mr/hr**	≤ 20 mr/hr**

* See Bases Figure 3/4 3-1.

** Initial setpoint. Final setpoint to be determined during startup testing.

3/4.0 APPLICABILITY

BASES

The specifications of this section provide the general requirements applicable to each of the Limiting Conditions for Operation and Surveillance Requirements within Section 3/4.

3.0.1 This specification states the applicability of each specification in terms of defined OPERATIONAL CONDITION and is provided to delineate specifically when each specification is applicable.

3.0.2 This specification defines those conditions necessary to constitute compliance with the terms of an individual Limiting Condition for Operation and associated ACTION requirement.

3.0.3 This specification delineates the ACTION to be taken for circumstances not directly provided for in the ACTION statements and whose occurrence would violate the intent of the specification. For example, Specification 3.5.1 calls for the HPCI to be OPERABLE and specifies explicit requirements if it become inoperable. Under the terms of Specification 3.0.3 if the required additional systems are not OPERABLE, the facility is to be placed in HOT SHUTDOWN within the next 6 hours and be in COLD SHUTDOWN within the following 30 hours. The unit shall be brought to HOT SHUTDOWN and COLD SHUTDOWN within the required times by promptly initiating and carrying out an orderly shutdown. It is intended that this guidance also apply whenever an ACTION statement requires a unit to be in (at least) STARTUP within 2 hours or in (at least) HOT SHUTDOWN within 6 hours.

3.0.4 This specification provides that entry into an OPERABLE CONDITION must be made with (a) the full complement of required systems, equipment or components OPERABLE and (b) all other parameters as specified in the Limiting Conditions for Operation being met without regard for allowable deviations and out of service provisions contained in the ACTION statements.

The intent of this provision is to insure that facility operation is not initiated with either required equipment or systems inoperable or other limits being exceeded.

Exceptions to this provision have been provided for a limited number of specifications when startup with inoperable equipment would not affect plant safety. These exceptions are stated in the ACTION statements of the appropriate specifications.

APPLICABILITY

BASES

4.0.1 This specification provides that surveillance activities necessary to insure the Limiting Conditions for Operation are met and will be performed during the OPERATIONAL CONDITIONS for which the Limiting Conditions for Operation are applicable. Provisions for additional surveillance activities to be performed without regard to the applicable OPERATIONAL CONDITIONS are provided in the individual Surveillance Requirements.

4.0.2 The provisions of this specification provide allowable tolerances for performing surveillance activities beyond those specified in the nominal surveillance interval. These tolerances are necessary to provide operational flexibility because of scheduling and performance considerations. The phrase "at least" associated with a surveillance frequency does not negate this allowable tolerance value and permits the performance of more frequent surveillance activities.

The tolerance values, taken either individually or consecutively over three test intervals, are sufficiently restrictive to ensure that the reliability associated with the surveillance activity is not significantly degraded beyond that obtained from the nominal specified interval.

4.0.3 The provisions of this specification set forth the criteria for determination of compliance with the OPERABILITY requirements of the Limiting Conditions for Operation. Under this criteria, equipment, systems or components are assumed to be OPERABLE if the associated surveillance activities have been satisfactorily performed within the specified time interval. Nothing in this provision is to be construed as defining equipment, systems or components OPERABLE, when such items are found or known to be inoperable although still meeting the Surveillance Requirements.

4.0.4 This specification ensures that surveillance activities associated with a Limiting Condition for Operation have been performed within the specified time interval prior to entry into an applicable CONDITION. The intent of this provision is to ensure that surveillance activities have been satisfactorily demonstrated on a current basis as required to meet the OPERABILITY requirements of the Limiting Condition for Operation.