

APPENDIX A

Portland General Electric Company  
121 S. W. Salmon Street  
Portland, Oregon 97204

License No. NPF-1  
Docket No. 50-344

Notice of Violation

Based on the results of NRC inspections conducted on April 2-30, 1979, it appears that one of your activities was not conducted in full compliance with the conditions of your NRC Facility License No. NPF-1 as indicated below. This item is an infraction.

Action step (a) for Technical Specification No. 3.8.1.1 states in part that with either an offsite circuit or diesel generator set of the required A.C. electrical power sources inoperable, demonstrate the operability of the remaining A.C. sources by performing Surveillance Requirements 4.8.1.1.1.a and 4.8.1.1.2.a.5 within one hour and at least once per eight hours thereafter;

Contrary to the above, the East Emergency Diesel Generator's operability was not demonstrated within the one-hour period following the placing of the West Emergency Diesel Generator in an inoperable status for maintenance purposes on April 11, 1979.

568 346

7907300125