



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION II
101 MARIETTA ST., N.W., SUITE 3100
ATLANTA, GEORGIA 30303

JUL 2 1979

In Reply Refer To:

RII:JPO

50-416

50-417

Mississippi Power and Light Company
ATTN: N. L. Stampley
Vice President of Production
P. O. Box 1640
Jackson, MS 39205

Gentlemen:

The enclosed Bulletin 79-14 is forwarded to you for action. Written responses are required. If you desire additional information regarding this matter, please contact this office.

Sincerely,

Mr. James P. O'Reilly
Director

Enclosure:

1. IE Bulletin No. 79-14
2. Listing of IE Bulletins Issued
In Last Twelve Months

7907310258

462 235

JUL 2 1979

Mississippi Power and
Light Company

-2-

cc w/encl:
C. K. McCoy
Plant Manager
Post Office Box 756
Port Gibson, Mississippi 39150

462 236

UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D.C. 20555

July 2, 1979

IE Bulletin No. 79-14

SEISMIC ANALYSES FOR AS-BUILT SAFETY-RELATED PIPING SYSTEMS

Description of Circumstances:

Recently two issues were identified which can cause seismic analysis of safety-related piping systems to yield nonconservative results. One issue involved algebraic summation of loads in some seismic analyses. This was addressed in show cause orders for Beaver Valley, Fitzpatrick, Maine Yankee and Surry. It was also addressed in IE Bulletin 79-07 which was sent to all power reactor licensees.

The other issue involves the accuracy of the information input for seismic analyses. In this regard, several potentially unconservative factors were discovered and subsequently addressed in IE Bulletin 79-02 (pipe supports) and 79-04 (valve weights). During resolution of these concerns, inspection by IE and by licensees of the as-built configuration of several piping systems revealed a number of nonconformances to design documents which could potentially affect the validity of seismic analyses. Nonconformances are identified in Appendix A to this bulletin. Because apparently significant nonconformances to design documents have occurred in a number of plants, this issue is generic.

The staff has determined, where design specifications and drawings are used to obtain input information for seismic analysis of safety-related piping systems, that it is essential for these documents to reflect as-built configurations. Where subsequent use, damage or modifications affect the condition or configuration of safety-related piping systems as described in documents from which seismic analysis input information was obtained, the licensee must consider the need to re-evaluate the seismic analyses to consider the as-built configuration.

Action to be taken by Licensees and Permit Holders:

All power reactor facility licensees and construction permit holders are requested to verify, unless verified to an equivalent degree within the last 12 months, that the seismic analysis applies to the actual configuration of safety-related piping systems. The safety-related piping includes Seismic Category I systems as defined by "Design Classification" Revision 1, dated the applicable FSAR. For older plants, documents did not exist at the time of license actual configuration of these safety-related systems.

DUPLICATE DOCUMENT

Entire document previously entered
into system under:

ANO 7907060295

No. of pages: 7

462 237