

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N E C P R I | 2 0 0 - 0 0 0 0 - 0 0 0 | 3 4 1 1 1 1 | 4 | 5
7 8 9 14 15 25 26 30 57 CAT 58

CON'T
0 1 | REPORT SOURCE | L | 6 0 5 0 0 0 2 9 8 | 7 0 5 3 1 7 9 | 8 0 6 2 6 7 9 | 9
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing surveillance test S.P. 6.3.5.5, RHR Pump 1A tripped during start on |
0 3 | overcurrent in phase C. RTS 3.5. No significant occurrence took place. This event |
0 4 | is not repetitive. It presented no adverse effects on public health and safety. |
0 5 | Redundant systems were available. |
0 6 | |
0 7 | |
0 8 | |

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP SUBCODE | VALVE SUBCODE
7 8 9 10 11 12 13 18 19 20
C F (11) A (12) C (13) R E L A Y X (14) D (15) Z (16)

(17) LER/RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.
21 22 23 24 26 27 28 29 30 31 32
7 9 | | 0 1 6 | | | | 0 |

ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER
33 34 35 36 37 40 41 42 43 44 47
E (18) H (19) Z (20) Z (21) 0 0 0 0 (22) N (23) | | A (25) | c b b b (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | A General Electric Model 12IAC66K8A overcurrent relay operating disc failed to return |
1 1 | to its normal position. A small particle of debris was lodged between the disc and the |
1 2 | magnet. This caused reduction in time delay for the relay contact to close. The relay |
1 3 | was cleaned, recalibrated and retested. Correct operation of RHR Pump 1A was verified. |
1 4 | |

1 5 | FACILITY STATUS | % POWER | OTHER STATUS (30) | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION (32)
7 8 9 10 12 13 44 45 46 80
E (28) 0 8 1 (29) NA | B (31) Operator Observation

1 6 | ACTIVITY CONTENT | AMOUNT OF ACTIVITY (35) | LOCATION OF RELEASE (36)
7 8 9 10 11 44 45 80
Z (33) Z (34) NA | NA

1 7 | PERSONNEL EXPOSURES | DESCRIPTION (39)
7 8 9 11 12 13 80
0 0 0 (37) Z (38) NA

1 8 | PERSONNEL INJURIES | DESCRIPTION (41)
7 8 9 11 12 80
0 0 0 (40) NA

1 9 | LOSS OF OR DAMAGE TO FACILITY | DESCRIPTION (43)
7 8 9 10 11 12 80
Z (42) NA | 462 062 7908010 557 JS

2 0 | PUBLICITY | DESCRIPTION (45) | NRC USE ONLY
7 8 9 10 11 12 58 59 80
N (44) NA

GPO 95-7-926