



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION V
1990 N. CALIFORNIA BOULEVARD
SUITE 202, WALNUT CREEK PLAZA
WALNUT CREEK, CALIFORNIA 94596

JAC
PDR

July 17, 1979

Docket Nos. 50-133
50-275
50-323

Pacific Gas and Electric Company
77 Beale Street
San Francisco, California 94106

Attention: Mr. Philip A. Crane, Jr.
Assistant General Counsel

Gentlemen:

In accordance with our letter dated April 1, 1979 transmitting Bulletin 79-05, we are enclosing Preliminary Notification 79-67AX.

Sincerely,

R. H. Engelken
Director

Enclosure
PNO-79-67AX

cc w/enclosure:
W. Barr, PG&E
W. Raymond, PG&E
E. Weeks, PG&E, Humboldt Bay
J. D. Worthington, PG&E
R. Ramsay, PG&E, Diablo Canyon

③

483 331

7908020026

Pub

IMMEDIATE
PRELIMINARY NOTIFICATION

July 17, 1979

PRELIMINARY NOTIFICATION OR EVENT OR UNUSUAL OCCURRENCE -- PNO-79-67AX

This preliminary notification provides updated information of safety or public interest significance.

Facility Three Mile Island, Unit 2
Middletown, Pennsylvania (DN 50-320)

Subject: UPDATED STATUS REPORT

Operational:

1. Average coolant temperature is 163 degrees F. The highest incore thermocouple temperature indication is 269 degrees F. Core flow is being provided by natural circulation. Core cooling is being maintained by steaming the "A" Steam Generator to the main condenser on the bypass valve.
2. Daily measurements of reactor building water level have remained at 7.0 ± 0.2 feet above floor level.
3. Functional testing of the Pressure/Volume Control system has been delayed to allow vendor review of installed nitrogen regulator valves for compatibility with system applications.

Environmental Status

Environmental radiation levels remain consistent with natural background levels. Airborne releases remain will below Technical Specification limits. During July 9 - July 15, 1979, 19 air samples, 2 milk samples, 7 vegetation samples, 2 soil samples and 7 water samples were collected by the NRC. All analytical results were less than MDA. EPA air, water and milk samples collected during the week (7/9 to July 11) showed no detectable activity from TMI.

Contact: R. C. Paulus, IE x27246 G. C. Gower, IE x27246

CONTINUED

POOR ORIGINAL

7 907240340

483 332

Distribution: Transmitted H St 9:18
Chairman Hendrie
Commissioner Kennedy
Commissioner Gilinsky
Commissioner Bradford
Commissioner Ahearne

S. J. Chilk, SECY
C. C. Kasperer, CA
(For Distribution)

Transmitted: MNBB 923
L. V. Gossick, EDO
H. L. Ornstein, EDO
J. J. Fouchard, PA
N. M. Haller, MPA
R. G. Ryan, OSP
H. K. Shapar, ELD

P. Bldg 8:47
H. R. Danton, NRR
R. C. DeYoung, NRR
R. J. Mattson, NRR
R. S. Boyd, NRR
SS Bldg 4:31
W. J. Dircks, NMSS
S. Levine, RES

V. Stallo, IE
Region I 9:34
Region II 9:38
Region III 9:43
Region IV 9:47
Region V _____
(MAIL)
J. J. Cummings, OIA
R. Minogue, SD

IE (TMI) Site _____ (Provide copy to STATE)
White House Situation Room _____
FDAA _____ (Provide copies to the Administrator and the Operations Center)
EPA _____
DDE/EOC _____
PEMA _____
BRP (State of PA) _____
DCPA _____
HEW _____
Handcarry (FAA) _____

IMMEDIATE
PRELIMINARY NOTIFICATION

Region II
11 9 44

11 - SF
11 9 26
11 9 30

POOR ORIGINAL