INTERIM REPORT

Accession	No.	

Contract Program or Project Title:

Semiscale

Subject of this Document:

"Experiment Data for Determination of Uncertainty of Two-Phase Mass Flow Rate in a Semiscale MOD-3 System Spool Piece at Karlsruhe Kernforschungzentrum"

Type of Document: .

Data Report

Author(s):

A. G. Stephens

Date of Document:

June 1979

Responsible NRC Individual and NRC Office or Division:

W. D. Lanning

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

H. P. Pearson, Supervisor Information Processing EG&G Idaho, Inc.

Prepared for U.S. Nuclear Regulatory Commission Washington, D.C. 20555

NRC Fin #A6038

INTERIM REPORT

NRC Research and Technical
Assistance Report

for U.S. Nuclear Regulatory Commission

EXPERIMENT DATA FOR DETERMINATION OF UNCERTAINTY OF TWO-PHASE MASS FLOW RATE IN A SEMISCALE MOD-3 SYSTEM SPOOL PIECE AT KARLSRUHE KERNFORSCHUNGZENTRUM

ALAN G. STEPHENS

NRC Research and Technical Assistance Report

June 1979



EGEG Idaho, Inc.



IDAHO NATIONAL ENGINEERING LABORATORY

DEPARTMENT OF ENERGY

IDAHO OPERATIONS OFFICE UNDER CONTRACT DE-AC07-76IDO1570

EXPERIMENT DATA FOR DETERMINATION OF UNCERTAINTY OF TWO-PHASE MASS FLOW RATE IN A SEMISCALE MOD-3 SYSTEM SPOOL PIECE AT KARLSRUHE KERNFORSCHUNGZENTRUM

by

A. G. Stephens

SEMISCALE PROGRAM

June 1979

Approved:

D. J. Olson, Manager Semiscale Program

Approved:

L. D. Watson, Manager

Measurement Engineering and Experimental Instrumentation Branch

NRC Research and Technical Assistance Report



INTERIM REPORT

Accession	No	
Report No	SEMI-TR-006	

Contract Program or Project Title:

Semiscale

(Rev. 12-78)

Subject of this Document: "Experiment Data for Determination of Uncertainty of Two-Phase Mass Flow Rate in a Semiscale Mod-3 System Spool Piece at Karlsruhe Kernforschungzentrum"

Type of Document:

Data Report

Author(s):

Alan G. Stephens

Date of Document:

June 1979

Responsible NRC individual and NRC Office or Division:

W. D. Lanning, NRC

This document was prepared primarily for preliminary or internal use. It has not received full review and approval. Since there may be substantive changes, this document should not be considered final.

EG&G Idaho, Inc. Idaho Falls, Idaho 83401

Prepared for the
U.S. Nuclear Regulatory Commission
and the U.S. Department of Energy
Idaho Operations Office
Under contract No. DE-AC07-76ID01570
NRC FIN No. A6038

INTERIM REPORT

ACKNOWLEDGEMENT

Our hosts were the people of the IRB division of GfK, headed by Dr. U. Müller. He and his people, particularly Dr. J. Reimann and H. John who led the experimental work and E. Wanner and L. Pawlak who operated the facility, anticipated and provided for our technical and personal needs with insight, alacrity, and graciousness.

The EG&G test operations crew for the Semiscale testing was headed by R. Meininger and consisted of V. Hansen, H. Helbert and L. Lindsay. G. Maki and J. Gilbert produced the entire software package. All these people successfully completed their work on time, and this fact serves well to remind us that the seemingly impossible can be done when determination and expertise are applied. As the complexity of the experimental work becomes more apparent, the reader will better appreciate the magnitude of their accomplishment. Special appreciation is expressed to Russ Tatley of the Information Division, Publications Branch, for the editing of this data report.

ABSTRACT

Steady state, steam-water testing of a Semiscale Mod-3 system instrumented spool piece was accomplished in the Gesellschaft fur Kernforschung (GfK) facility at Karslruhe Kernforschungzentrum, W. Germany. The testing was undertaken to determine the accuracy of spool piece, two-phase mass flow rate, inferential measurements by comparison with upstream single-phase reference measurements. Other two-phase measurements were also made to aid in understanding the flow conditions and to implement data reduction. A total of 132 single-and two-phase test points were acquired, covering pressures from 0.4 to 7.5 MPa, flow rates from 0.5 to 4.9 kg/s, and two-phase mixture qualities from 1.0 to 83% in the 66.7 mm inside diameter spool piece. The report includes a detailed description of the hardware and software and a tabulation of the data.

NOMENCLATURE

Cw	-	superficial	water	ve'	locity,	based	on	m,	Х,	PTS.	TTS
----	---	-------------	-------	-----	---------	-------	----	----	----	------	-----

DP1 - lower range steam orifice differential pressure

DP2 - lower range water orifice differential pressure

DP3 - drag screen (disk) pressure drop

DP4 - turbine meter pressure drop

DP5 - sum of drag device, turbine meter pressure drop

DP6 - upstream frictional pressure drop

DP7 - sum of frictional, drag device, turbine meter pressure drops

DP10 - fixed impedance probe pressure drop

DP11 - higher range steam orifice differential pressure

DP12 - higher range water orifice differential pressure

Hs - superheated steam enthalpy from P1, T1

H_S - subcooled water enthalpy from T2

m - sum of steam and water mass flow rates to the mixer

 \dot{m}_{S} - steam mass flow rate from DP1 (DP11), V_{S} , P1, T1

 \dot{m}_{W} - water mass flow rate from DP2 (DP12), V_{W} , T2

PTS - absolute fluid pressure upstream of the Semiscale spool piece

P_{SP} - absolute fluid pressure at spool piece (listed as P4 in Table A-III

ρu,ρL- spool piece chordal average fluid density - upper and lower beam of dual beam densitometer

 $^{\text{Pu}^2}$ - spool piece momentum flux-drag disk or full flow drag screen as noted

o - cross sectional average fluid density - scanning densitometer

NOMENCLATURE (continued)

P1 - absolute steam pressure at steam flow orifice

P3 - absolute fluid pressure at scanning densitometer

P4 - absolute fluid pressure at Semiscale spool piece

P5 - absolute fluid pressure just downstream of spool piece

T1 - temperature at steam flow orifice

T2 - temperature at water flow orifice

T3 - fluid temperature at scanning densitometer

T4 - fluid temperature at Semiscale spool piece

T6 - metal temperature at Semiscale spool piece

T9 - fluid temperature just downstream of spool piece

TTS - fluid temperature upstream of the Semiscale spool piece

T_{SP} - fluid temperature at spool piece (listed as T4 in Table A-III)

Ts4 - saturation temperature in spool piece from P4

Uw - radiotracer liquid phase velocity

U_s - radiotracer vapor phase velocity

 $V_{\rm S}$ - superheated steam specific volume from P1, T1

 V_{W} - subcooled water specific volume from T2

 V_{S4} - specific volume of saturated steam in spool piece from P4

 V_{W4} - specific volume of saturated water in spool piece from P4

	ACKNO	NU FO	SEMENT	TABLE OF CONTENTS	ii
					111
					iv
II.	FACI			WARE AND OPERATIONS	
	1.			low Facility	
	2.				
	3.				13
II.	INST			DATA ACQUISITION	16
	1.	Gene	ral Descrip	otion	16
		1.1	Common Con	mponents	24
			1.1.1	Signal Conditioners and Amplifiers	24
			1.1.2	Digital Systems	24
			1.1.3	Analog Recording System	25
		1.2	Software-		25
			1.2.1	Data Acquisition Function	25
			1.2.2	Data Validation Function	26
			1.2.3	Other Functions and Routines	28
	2.	Prin	cipal Meas	urements	29
		2.1	Single Ph	ase Flow Measurements	29
		2.2	Semiscale	Spool Piece Measurements	35
			2.2.1	Turbine Meter	35
			2.2.2	Dual Beam Densitometer	37
			2.2.3	Momentum Flux Measurement	40
			2.2.4	Spool Piece Absolute Pressure	44
		2.3	Other Pri	acipal Measurements	45

	3. Auxiliary Measurements	51
	3.1 Pressure, Temperature, Differential Pressure	51
	3.2 Storz Lens	53
IV.	TEST MATRIX	53
٧.	SUMMARY OF TEST CONDITIONS AND RESULTS	56
VI.	REFERENCES	57
	APPENDIX A TABLES OF TEST CONDITIONS, PARAMETERS, AND MEASURED DATA ABSTRACTED FROM REFERENCE 3	59
	APPENDIX B DATA REDUCTION EQUATIONS	95
	APPENDIX C DATA VALIDATION ROUTINES	107
	FIGURES	
1.	Schematic flow diagram, GfK facility	2
2.	Facility air-water, and steam-water flow capabilities	4
3.	Superficial vapor, liquid velocity envelope	5
4.	Test section arrangement, Semiscale tests	6
5.	LIT radiotracer injection ports and detectors	7
6.	GfK impedance probe and electronics	8
7.	Scanning densitometer installation	9
8.	Storz lens installation	10
9.	Semiscale instrumented spool piece	11
10.	Semiscale spool piece installation	12
11.	Instrumentation setup sheet	14
12.	Operating log sheet	17
13.	Principal data log sheet	19
14.	Instrument block diagram, Semiscale tests	21
15.	EG&G Idaho, Inc., computer processed test section transducers	22

16. Sing	le-phase IRB transducer setup	23
17. Data	acquisition printout	30
18. Drag	screen momentum flux calibration	42
19. Dens	itometer source, pipe, detector geometry	46
20. Scan	ning densitometer block diagram	49
	TABLES	
I.	GfK Sensor Check Comparisons of Measured Signals at 20%, 50%, and 100% of Full Scale	31
II.	Single Phase Spool Measurement Constants	34
III.	Turbine Meter Calibration Information	36
IV.	Dual Beam Densitometer Information	39
٧.	Momentum Flux Calibration Information	43
VI.	Pressure, Temperature Calibration Information	52
VII.	Equivalent Frictional Pasistance K-Factor	54
VIII.	Test Matrix as Performed	55
A-I.	Test Conditions as Measured by Institut fur Reaktor Bauelement	65
A-II.	Principal Measurements	70
A-III.	Pressure and Temperature Data	76
A-IV.	Differential Pressure Data	82
A-V. Misc	ellaneous On-Line-Calculated Parameters	88

viii

I. INTRODUCTION

This report presents the experimental data from the steady state, steam-water testing of an instrumented spool piece (pipe) used in the Semiscale Mod-3 test system at the Idaho National Engineering Laboratory. The testing was done in the Gesellschaft für Kernforschung (GfK) facility at Karlsruhe, West Germany. The Semiscale part of the joint EG&G Idaho, Inc., and GfK Test Program was conducted during November-December 1977. Engineers from EG&G Idaho, Inc., Instrumentation Division and two GfK divisions, the Reactor Components Institute (IRB) and the Technical Isotopes Laboratory (LIT), collaborated in performing the experiments.

The principal objective of these tests was to evaluate the capability of the three main spool piece instruments (the dual beam densitometer, full flow turbine, and drag screen) to measured steady state flow rates over the range of conditions experienced in the Semiscale Mod-3 test sistem. The purpose was to compare the total mass flow rate calculated from these three measurements with the sum of two single-phase measurements and quantify the dependence of the difference. The report contains only the experimental data and on-line-calculated single-phase parameters; two-phase flow modeling calculations and data analysis will be contained in a subsequent report.

The GfK flow ficility, test hardware, and typical test operation is described in Section II. Section III describes the instrumentation and data acquisition, including the processing hardware (signal conditioners, amplifiers, digital systems, and analog recording system), computer programs, and principal and auxiliary measurements. The test matrix is presented in Section IV, which delineates the test pressures and associated superficial water and steam velocities. Section V presents a summary of test conditions and results. References are listed in Section VI.

II. FACILITY, TEST HARDWARE AND OPERATIONS

1. GFK TWO-PHASE FLOW FACILITY

The GfK two-phase flow facility is described in detail in References 1 and 2. A simplified schematic flow diagram of the loop used for this spool piece experiment, is shown in Figure 1. Superheated steam from one boiler and subcooled water from the other boiler are directed to the mixer via separate, calibrated, single-phase flow measuring stations. The mixed flow passes through the test section and an outlet pressure control valve to the condenser. Condensate is returned to the boilers via a feed tank and pumps.

Block valves at the mixer and test section outlet (shown in Figure 1), permit the two-phase mixture to be directed either to, or around, the test section. Also shown is the dump tank used to collect the total mixture flow during radiotracer injections.




Figure 1. Schematic Flow Diagram, GfK Facility.

For air-water testing, a compressor and separate water pump supply fluids to the mixer. The air-water mixture is separated in the water storage tank.

Figure 2 shows the flow rates which can be provided at different vapor mass fractions for air-water and steam-water operation. Normal air-water operation was at 0 4 MPa or below, while the steam-water flow rates generally apply from 0.4 to 10.0 MPa. Figure 3 provides the same information for various pressures in terms of superficial water and vapor velocities in a 50 mm inside diameter test section.

2. TEST SECTION

The test section consisted of an 8-m length of piping with inlet and outlet block valves on either end, as shown in Figure 4. The 3-in. Schedule 160, Type 304 stainless steel piping (nominal 66.7 mm inside diameter, 88.9 mm outside diameter) provided by EG&G Idaho, Inc., constituted the first 6.5 m and the 50-mm inside diameter piping, provided by GfK made up the remaining 1.5 m. Eccentric reducers were used to connect the different size pipes and to maintain the bottom of the piping at the same elevation. Each spool had two rolling, vertically adjustable supports which were mounted on the test bed, and each spool was carefully leveled. Connections between spools in the 3-in. stainless steel piping were made with Grayloc fittings, while the 50 mm piping used standard GfK flanges.

The 1.36-m inlet block valve spool had a 50-mm inside diameter for Test Runs 2201 through 2247 which resulted in the flow expanding from 50 to 66.7-mm at the beginning of the test section. For Test Runs 2249 through 2340, the 50-mm spool was replaced with an 80-mm inside diameter spool so that the flow entering the test section contracted from 80-mm to 66.7-mm. The Semiscale spool piece was locted about 65 diameters downstream from the expansion/contraction point.

The LIT radiotracer injection ports were located in the first 3-in. spool piece (designated S1) with detectors mounted at various distances throughout the 6.5-m length downstream of these ports. Figure 5 shows the ports and first few detectors. Two fixed-position impedance probes were located at the same axial point in spool piece S2: one entering the flow from the top side of the pipe, the other from the bottom side. Figure 6 shows the associated electronics and upper impedance probe. The scanning densitometer (Figure 7) was mounted in spool piece RD1, at a point about 23 cm upstream from the inlet of the Semiscale spool. When used, the Storz lens was mounted in the downstream flange at the scanning densitometer, as shown in Figure 8. The Mod-3 Semiscale spool piece and instrumentation are shown in Figure 9. Figure 10 shows the maze of pressure sense lines, cooling water and control air tubing and signal cables associated with the installed spool piece instrumentation. Detailed descriptions of the radiotracer and impedance probe measurements are given in Reference 3. The scanning densitometer, Storz lens, and Semiscale instruments are discussed in detail in Sections 2.3 and 3.2.




Figure 2. Facility Air-Water, Steam-Water Flow Capabilities. 184




Figure 3. Superficial Vapor, Liquid Velocity Envelope.




Figure 4. Test Section Arrangement, Semiscale Tests.

Figure 5. LIT Radiotracer Injection Ports and Detectors.




Figure 6. GfK Impedance Probe and Electronics.




Figure 7. Scanning Densitometer Installation.




Figure 8. Storz Lens Installation.




Figure 9. Semiscale Instrumented Spool Piece.




Figure 10. Semiscale Spool Piece Installation.

3. TEST OPERATION

The daily testing consisted of the following regimen:

- 1. Establish the revised test run conditions for the day.
- 2. From these conditions, choose which boiler would provide steam, and which would provide water, and set up valving and steam and water measurement channels. Figure 11 is a copy of a typical instrumentation setup sheet, filled out each time a change was made in the hardware condition.
- 3. Set an all water point to check instruments.
- 4. Start boiler and system heatup.
- 5. Start two-phase flow tests.
- 6. At the end of the day, shutdown, set an all water point to check instruments.

For the two-phase testing, three parameters defined a matrix point: test section pressure, superficial water velocity at the test section, and superficial steam velocity. The boiler operator used the measurement of the superheated steam flow to the mixer, the subcooled water flow to the mixer, the test section pressure, and an energy balance to establish the total mass flow and quality at the test section. From these data, the superficial steam and water flows at the test section were computed. The computation was done the facility PDP-11 computer, controlled through a teletype at boiler control room. The required results are tabulated in Appendix 1. Table A-I, Test Conditions as Measured by Institut für Reaktor Bauelement. Ordinarily, 20 to 30 minutes were required to establish a new steady condition.

Once a steady condition had been established, the experimental data were acquired as follows:

- The impedance probe data were recorded on the GfK analog magnetic tape.
- The scanning densitometer was started through its traverse around the pipe.
- The EG&G Idaho, Inc., data acquisition computer (HP-21MXE) was set to acquire time-averaged values of the several test parameters.
- 4. The EG&G Idaho, Inc., analog magnetic tape recorders were turned on and after one minute were turned off.
- 5. When the computer had acquired, processed, and printed the time-averaged values, an initial quick glance at this data was performed by the computer operator.

				INST	QHM!	ENTA	TION	LOG SHEE	NW NW	50	Jati	15 Dec 77
						-	ale		AM - 10	BAR		up Ref. No. 36
SE	NSOR			CHAN			H BL	HP COE	efficien	ES		I RIGA C
10	Make		BL	TR	S	HP	Gain	ao	ā,	à ₂	a ₃	Comments Tape Chann
f.	Н	TMI	1	1-1	1	1	2	10.43	297.00			STEAM - NW 65
X	B	F/13		-	-	+	2	10.43	277.00		-	STEAM - NW CO
P3	CEC	2413	3	2-1	les l	3	1000	12.676	59,456			
P4	VIA 100	384	4	2.2	E	14	1000	2.248	8.4799			10m2 6:450 ps
15	151-	21r 11	5	2-3	1	10.		12.775	63.008	11-11		PHILL THE
) i i	H	TML	4	1-2	2	6	2	0	.45313			STEAM HI - NIV 45
),	H	T 17	7	1-6	3	7	2	0	.05664			STEAM CO-NIVES
×	18	7/12	6	-	2	-	2		12213			DIEAM HE NX OU
X	1	143	4	1-6	3	7	2		,05444		-	STEAM CO-NIX 100
)3	BLH SC	42702	8	1-3	17	8	1000	cc478	+1214		-	
Da	REH	71421	9	2-4	ļ.,,,,,,,	9	1000	00092	2427			
)5	BLH Sc"	77732	10	2-5	-01	10	1900	013	1.435			
X	H	144	71	100	*	TI	2	0	1533		-	WATER HI- NX 12
X	H	T.45	72	17-7	5	12	2	0	105664			WATER LO NX 32
)2	.D	TH	12	12	5	12	2	0	,45313	T-A		WATER - NIV'SU
Xii	H	IMA	6	10.7	Z	6	2	0	=453r3			THETHER HI - NU 32
K	+	11/2	7	1-6	3	19	2	0	. ०५ र स			THRATLE LO- NW 32
X	Б	TT	7	1-5	7	1	2	0	195313			TREATLE - NWSO
) ₆ _	BLH	39192	He	1-5	9	16	1004	-,0036	10/2/2			
) 7	BL.H	4420		2-6	-	17	1000	~.069	.7946			
	CLH ICH	43594	18	2.7		18	1000	0082	.6425			
6			19	2-8	. 199	24	yese	150 A	45.28	- 1573	CC+ 55	
4			20	2.9	-	20	1000	1.54	45.29	-1573	. 6 6 2 5 6	FOR THE STATE OF T
1	14	TÄT	21	2-15		21	520	32	70 30	5111	.52.76	STEAM-NW 45
X	13	TAZ	2+	2-15	-Manager and American	21	1700	42			10070	STEAM-NW AC
(H	143	72	2-11	-	22	Pez	-	10000			WATER-NWX2
L.	8	TAI	22	2-11	-	22	Sea	32	30 34	- 3197		WATER-NIV SC
6	FI	TA3	21	2-19	-	21	300	11	10-10	3193	1 375	THE NW 32
~	13	TAT		270	The state of the s	2.1	200	32				THE - NW SO
1				2-12	-	25		156 1	n 25	-,1573	ALAST	
9	14		25	Jed	-	25	1655	156 4	5,23	+ 1573	44.485	
			26	1 - 8	15	$2l_2$	1	Zob 24		,005		a = 10.24 after run 2292
			27	1-9		27	1	120.46	1.953			a. 11.24 apter run 2272
2 16 10 10 10 10 10 10 10 10 10 10 10 10 10			28	-	-	28	ICV .	111				
1			29	-	-	29	16.4	11.11				
1				1-10	15	31		0	-4		1000	Rong 3
6			32	-	2004	52	1810			-		X
<			33	1-11		35	5	8671.	2270			Bettom
				1-13			5	- 72.3				5 de
2				-		-	5	3007.8				Ter

Figure 11. Instrumentation Setup Sheet (Sheet 1 of 2).

FIGURE 11 INSTRUMENTATION LOG SHEET (Sheet 2 of 2, explanation of log sheet headings)

Sensor ID (Identification) column is the designation used in the EG&G Idaho, Inc., computer and in the data tables in this report. Transducer manufacturer is given if transducer is provided by EG&G Idaho, Inc., or IRB boiler designation is given (H-Henschel (small) boiler; B-Benson (large) boiler for GfK equipment).

Sensor (SN) column gives transducer serial number for EG&G Idaho, Inc., equipment or transmitter number (also GfK computer channel number) for GfK equipment (refer to Figure 16).

Channel designations are; BL - Bay Laboratories Amplifier Number; TR-Analog Magnetic tape recorder number and channel on that recorder; SC Brush Recorder Channel Number; HP - computer (ADC) channel number.

BL Gain - Bay Laboratories amplifier gain setting

HP Coefficients - coefficients of the equation relating measured voltage to engineering units

"NW 65/NW 50" - Refer to Figure 16. These are designations of GfK calibrated single-phase measurements spools and identify the source of the steam and of the water for that day. That is, NW 65/NW 50 implies steam is supplied by the small boiler, water by the large boiler. The lines crossed out represent instrument channels not used as a result of using the NW 65/NW 50 CHOICE.

- If there were no visual data problems, the LIT personnel were informed that the radiotracer injections could proceed and the test hall was evacuated. Radiotracers were not available every day.
- The radiotracer measurement was made and test personnel returned to their stations.
- 8. The scanning densitometer traverse was completed and the boiler operator was informed that he could proceed to the next point.
- The operating log sheet was completed for the run. A copy of a typical sheet is shown in Figure 12.
- 10. Principal data from the boiler operator, EG&G Idaho, Inc., computer, and the radiotracer (when available) were then collected on the daily summary sheet and reviewed by an analyst. Figure 13 is a copy of such a sheet.

The experiment data acquisition process took about 15 minutes when all went well. Frequently, computer data were taken a second time to verify that the time-averaged values were the same over these 15 minutes. It was a very unusual occurrence to find that they were significantly different.

III. INSTRUMENTATION AND DATA ACQUISITION

1. GENERAL DESCRIPTION

Figure 14 is an instrument block diagram showing all of the test instrumentation involved in the Semiscale tests. IRB engineers were responsible for the single-phase measurements (superheated steam and subcooled water going to the mixer) and the impedance probes. EG&G Idaho, Inc., personnel monitored their test section transducers and the scanning densitometer. LIT operators monitored their radiotracer measurements. The description which follows is restricted to only the EG&G Idaho, Inc., equipment and other measurements which were processed through the data acquisition computer.

Figure 15 lists the measurements on the Semiscale and reference (scanning) densitometer spool pieces processed through the EG&G Idaho, Inc., computer. Note that the drag screen, with its three transducers (F1, F2, F3), was used on tests through December 15 (Runs 2201 through 2302), whereas the drag disk (F6) was used thereafter (Runs 2303 through 2340). Also note that in addition to the impedance probe data four measurements were recorded on the IRB analog tape recorder. These are shown in Figure 14 and noted in Figure 15. In addition to the 19 measurements shown in Figure 15, a maximum of 7 more measurements from the IRB single-phase transducers were processe by the EG&G Idaho, Inc., computer. These single-phase measurements are shown in Figure 16. They constituted a backup to the IRB facility computer and also facilitated some of the EG&G Idaho, Inc., data validation calculations.

							1/2
COMMENTS	2250		Sough at 37:30				
			12 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1 1		~~	~~	
IMP. PROBE DATA			2000 Kugak	13000 Flour Parks Franks	oees oes	Š-	3
RADIO TRACER DATA		11:40 1955 12:15	7 %	13.01	3.5	13,43	14510
Scan	1.	4.883 H.30 Henge	200	R	3	Sago	3
	3448	~~	~~	~~	~~	~~	~~
Pange Range	w	~	5	2	tv.	~	pa
IRIG. END RANGE TOPE	57.20	12:10,00	54:48:01	13:00:15	13.15.9	13:34:40	
IRIG.START	349/07:56.30	12:09:30	0.32.30	12:58:45	13.14.30	13:33.00	06,10,41
SETUP REF. 10.	1 3	36	3.	2	39	2	36
TSN	2284C	4822	2225	2286	2287	2288	228

Page Date

OPERATION LOG SHEE!

Figure 12. Operating Log Sheet (Sheet 1 of 2),

FIGURE 12 OPERATION LOG SHEET (Sheet 2 of 2, explanation of log sheet data)

TSN - Experiment Run

Setup Reference Number - instrument setup defined by Figure 11.

IRIG Start/End - time code generator times for recording analog magnetic tape data for associated run.

Turbine Meter Range Position - turbine signal conditioner range implies certain engineering units coefficient (Figure 11).

Tape - assigned serial number for analog magnetic tape recording.

Scan Densitometer - scanning densitometer data taken for that run

Radiotracer Data - time of day radiotracer injection started.

Impedance Probe Data - impedance probe data taken; location on GfK tape.

*	Test Me.	W. Thirty			Measur	Peasings Vaca	uts 188								X 10 X		PENSUNED VALUES	S INE				45	Vacues 111	here
		. 1	21	J.	1 h			J = 1		× 14	The Regime	- 1	p 0	25			RHOEM Montes	4	, of 10 to 1	# ×	1, 2 × 2 × 3 × 3 × 3 × 3 × 3 × 3 × 3 × 3 ×	> 1	y	1 8
												unione												
(43%)																						111	13	
-	4827											4.42	2 138.	18.6.9	08.9	635.3	0.508		6.402	2.39/	0.897	4.4.2	3.	
1233	2205	4	9	2	Can 4076 1433		1025	43.43	3.64	5 2 2	Zw S.	3.49		150.1 3.49	91.9	30.96	180915		2.8494	84942.5744	2.4216	33	40	
1301	7322	£	0	1	4.319 159.7		1 049	4.137	3.403	0	57. 80	3.91	155.2	2 3.47	15 4	290.3	999.3		4.5282	1.256.1	0.786	try	200	
13 14	1.822	2	1.0	3	4.076 ML9		1.045	12.896	3 49 2 9	1 6 7	100	3.48		150.2 3.46	24.5	143.2	6.6692		3.1602	2.0380	7,57.7		12.9	
13.83	2228	ď	1.0	202	4.016144.9		100	20.368	340	4.7	1350	£2.53		1505346	19.3 124.3		3403.7		2.429.5	3.2705	2.3433	4.0	4,0	
19.63	2289	2	5.0	0.6	4157 146.2		0.504	41.274	1.947 14.6		120	3,62		\$8.7 1-151	35	3545	10785.6		-0.1301	£317.0	3.6935	34	A Cal	1
1423	2240	z	57	07	4 379 143.	tho:	34.0	21-202	6-945 11 201 12 349 0	2.9	- like	20	\$35 152	15281.78	5.0	15.29	2005.7		(S9.0	0 653 1.2150	2.4238	3,7	-	
	1925	z	0.5	0/	3-915 HIL	Ø	0.534 11-753 1 POF	11-753	500	4.8 17	- Ite	3,39	-	149.3 1.83	50	109.2	3.0%		2526.0	1.0938	585E1 88601 1887 0	2.3	2.3	
15 44	2292	2	2.0	ks	4.480,051	Phot	0.425	3.092	135501		Ą.	3.82	153.5	515	7.0	8.181	437.5		1-3283	1896.0	0.7523	1.9	1.9	
	2293	z	6.2	lo.	4.540 (50.	0~	0.291	4.134	D. 318 .0		27.77	3.78		147.6 1.20	2.0	200.3	517.6		1.4335	1.0629	1.0629 0.8576	1.6	#	
21/2/	2294	47	0.3	20	4.802 153.5		0.153	402 S	12 724 0 455 SI	27	19.22.09	4.215	13 755.	755.6 0457	6.80108.0		5365		0,735	100%	1.389	20	20	
1636	22.45	ū.	2.0	90	4.722 152	465	6.175	9.233	2.81 644.0	187	27.00	3.668	9.151 8	6 2.802	640 152.0		398.1		1.005	0.8444	0.7340	2.2	37	
1991	22.76	2	0.7	0,6	4.378 1487		0.219	42.16	1.04732.7	17.4	27.00	3.767	2.25\$ £	2 3.066	18.0	68.89	.4089		1.189	2.330	4.661	20	36	
1308	1397	2	0.0	20	4.318 165.	165.5	0	31.45	0.247	EHON Z		3.714	1745	5 0240	9.10	41.15	1021.		0.582	0.7720	1.382		78,3	
17.39	1298	3	00	8	4399 1724	1724	0	5899	8950	1043	1	3.887	174.9	9 0,420	6.457.05%	37.61	3338.		84.9	1:231	0.300		35	
1803	2299	pr	2.0	100	4.722	143.6	0,491	78.763	1.507	53.2 3	0.522	4.085	5 154.1	1 1385	177.7	37.42	749297		6472	3.455	1.867	100010		
1823	2300	1	2.5	100	5.448	9.64	6.497 6	1864	2.740	79.3 33	3320	4.796		158.3 2315	6291	38.55 3	35946.		6.453	4.089	2.624	Name of Street		
1835	2301	fr	10	X300	6.013	150.2	1,002	57.46	3,752	15.2 32	9550	5,376	163.1	3.572	1773	63.35	26.3%		17.23	4 505	1.819			
1855	2365	100	MAN	0.0	4.349 734	-5	1.119	0	3.815	500		3.842		13203582	3.0	2.566	519.6		0.542	7 504	10.01			
					-							-										-		
											The same of the sa	100					-					21		

Figure 13. Principal Data Log Sheet(Sheet, 1 of 2).

FIGURE 13 PRINCIPAL DATA LOG SHEET (Sheet 2 of 2, explanation of log sheet headings)

Matrix Points - desired test section pressure, superficial steam and water velocities (P, C_W, C_S) .

Measured Values IRB - actual test section pressure, temperature, superficial water and steam velocities, total mass flow, nuality and impedance probe data location on tape and inferred void fraction.

Measured Values INEL - actual Semiscale spool piece measured values for turbine meter (Q1), dual beam densitometer (RHOBAR), drag screen momentum flux (MOM FLX); scanning densitometer pressure, temperature and cross sectional average density (P3, T3, PSD); total mass flow rate calculated from turbine/densitometer, densitometer/drag body, and turbine/drag body (mTD, mD+DB, mT+DB).

Values LIT - radiotracer measured phase velocities (Vw, Vs).





Figure 14. Instrument Block Diagram, Semiscale Tests.



- D3x, + Drag device differential pressure
- D4+ Turbine meter differential pressure
- D5 Drag + turbine differential pressure
- D6+ Upstream differential pressure
- D7 Total differential pressure
- D10x Impedance probe differential pressure
- F1+ Force 1 on drag screen
- F2+ Force 2 on drag screen
- F3* Force 3 on drag screen
- F6" Force on drag disk
- P3 Absolute pressure at scanning densitometer
- P4 Absolute pressure at dual beam densitometer
- P5 Absolute pressure downstream of turbine meter
- Q1+ Turbine meter reading
- R1x,+ Dual beam densitometer upper beam reading
- R2*, + Dual beam densitometer lower beam reading
- T3 Fluid temperature at scanning densitometer
- T4 Fluid temperature at drag device
- T6 Metal temperature at densitometer
- 79 Fluid temperature downstream of turbine meter
- Measurements also routed to IRB analog tape recorder
- Measurements routed to EG&G Idaho, Inc., analog tape recorders



Measurement not processed by EG&G Idaho, Inc., computer

INEL-A-8675-1

Figure 15. EG&G Idaho, Inc., Computer Processed Test Section Transducers.




Figure 16. Single Phase IRB Transducer Setup.

Summarizing, the main body of test data came from the various types of transducers shown in Figures 15 and 16, through the EG&G Idaho, Inc., signal conditioning (equipment) to the data acquisition computer, as shown in Figure 14. Certain of these channels were also recorded on the EG&G Idaho, Inc., analog tape recorders as a means of providing backup data. Further, the recorded signals were simultaneously played back to six-channel strip chart recorders to verify that the backup data existed and were valid. Parameters thus recorded are noted in Figures 15 and 16, and were mainly the principal measurements described below.

1.1 Common Components

The hardware components common to the main body of data were the signal conditioners and amplifiers, the analog-to-digital conversion cards, the computer and teletype, the analog tape recorders, time code generator, and six-channel strip chart recorders. These are described herein.

1.1.1 Signal Conditioners and Amplifiers. This equipment consisted of 40 channels of wideband, do instrumentation amplifiers and transducer signal conditioners borrowed from the Semiscale data acquisition system. The amplifiers are Bay Laboratories, Inc., Model 5204 and the conditioners Model 7442. Some characteristics of the amplifiers are given below:

Gain: 1 to 1000 (x 2.6 vernier)
Input: differential, 100 megohm
Output: single ended, + 10 Vdc at 10 mA, dual outputs
Common mode voltage: ±500 Vdc
Wideband output cutoff: 30 kHz (-3db)
Filtered output cutoff: 50 Hz

Noise over 0.1 to 10 Hz is 1 µV referred to input, with 99.9% confidence. The signal conditioners provided a six-wire, constant 5-volt excitation system for the absolute and differential pressure transducers. For all other measurements, the signal conditioners constituted a direct connection into the amplifier input.

1.1.2 <u>Digital System.</u> The digital system consisted of a set of Hewlett-Packard equipment: a 21 MX E-Series computer, three Model 91000A 16 channel analog to digital conversion (ADC) cards, a papertape reader, and a teletype.

The three Model 91000A, ADCs, were mounted in the computer mainframe input/output slots. Each card had 16 single-ended inputs connected to the filtered outputs from the Bay Laboratories, Inc., amplifiers. Characteristics of the ADCs are

Resolution: 12 bits, including sign Input: \pm 10.0 V, full scale; 5 megohm Maximum Throughput rate: 20,000/s via DMA Overall accuracy: \pm 0.1% full scale, \pm 1/2 least significant bit

The Model 2109A, computer, was supplied with a 32 thousand word memory and incorporated both fast processor and fast memory options. System cycle time for this 16 bit memory was 560 ns. A paper tape reader, Model 2748B, and a standard teletype, Model 2752A, were supplied as the only accessories.

1.1.3 Analog Recording System. This system consisted of three analog magnetic tape recorders, three 6-channel strip chart recorders, and a time code generator translator.

The three tape recorders were Ampex Model FR-1300s, the strip chart recorders were Brush Model 260s, and the time code generator a Datum Model 9310. The wideband outputs from the Bay Laboratories amplifiers were connected to the 14-channel tape recorders. Characteristics of the tape recorders are:

Number of channels: 14
Tape speeds: 1-7/8 to 60 inches per second (ips)
Frequency response: 50 Hz to 10 KHz @ 1 7/8 ips
with signal/noise = 25 db
filtered, 18 db unfiltered
(cct Record/Reproduce
System)

The strip chart recorders, used to verify the presence and correctness of signal on the analog tapes, were 6 channel units hiving 1 to 125 mm/s chart speeds with 1 mV per division to 500 Vdc full scale measuring ranges. The time code generator was used to relate test run and position on tape of data recorded during that run. The generator time for each test run was recorded on the operating log sheet.

1.2 Software

The software was modular, consisting of several relocatable binary punched paper tapes covering the needed housekeeping, data acquisition, validation, and output functions. The simple hardware system supported only a Fortran II compiler and the Hewlett-Packard basic control system (BCS) operating environment. Because of its anticipated complexity and length, however, the program was written in Fortran IV and thus could only be compiled on a disk-based system. This made program changes more difficult, but thereby helped to reduce the number of unnecessary modifications.

1.2.1 Data Acquisition Function. The two-phase fluid conditions were expected and found to be stationary, that is, the time average values were not time-dependent. Thus, "on-line" validation of the self-consistency of various time-averaged parameters could be attempted at the expense of data acquisition sampling speed. The loosely stated criteria for speed and duration were: sampling must be done at a frequency high enough to avoid significant aliasing problems and for a duration long enough to average out the lowest frequencies. The software and hardware combined to give about 20 samples per second

on each channel and a sampling duration of about 30 s to get all of the 1000-sample average values. These conditions proved to be adequate. The number of channels involved tended to vary somewhat but generally was in the range of 40 to 50. A channel consisted of either a hardware channel (one of the possible 48 ADC inputs) or a software channel ("pseudo channel") which was an "instantaneous" variable calculated from one or more hardware channels, for example, a superheated steam specific volume calculated from a measured steam pressure and temperature. The program was set up to eliminate unsupported pseudo channels. For example, since the steam specific volume is a function of both steam pressure and temperature, the specific volume would not be calculated if either the pressure or temperature were not being measured. Further, since the mass flow of steam depends on the specific volume, if the specific volume were not calculated then the mass flow would not be calculated. For this reason the number of channels varied on occasion.

The acquisition process, incorporated in routine GDATA (Appendix A) consisted of the following:

- 1. Fetch digitized voltages (up to 48) from the ADC.
- Convert the voltages to "instantaneous" engineering units using the calibration equations.
- Calculate active pseudo channel "instantaneous" values using the pseudo channel equations (Appendix B).
- Using the "instantaneous" values, update the average value of active hardware and pseudo channels.
- 5. Repeat steps 1 through 4 until the requested number of samples in the average values have been obtained.

The rate at which the digitized voltages were generated was the 20,000/s characteristic of the ADC. But the effective sampling rate depended on the number and complexity of pseudo channel calculations, that is, the time needed to perform steps 1 through 4. The most complex pseudo channel calculation was the superheated steam mass flow, and as this calculation was always made, the effective sampling rate was essentially constant.

1.2.2 Data Validation Function. Validation of the average values obtained in GDATA was covered by three computer routines: PDATA, CDATA, and SDATA (see Appendix C). These routines were conducted while the fluid conditions were held constant, so that invalid data could be discovered and eliminated and GDATA rerun if necessary. Thus the data validation was done in an "on-line" mode as far as the fluid conditions were concerned, but off line relative to the data acquisition process. The three routines covered data validation in the following respects:

PDATA - 1. Verification that specified matrix point is reached

Zest section mass conservation
 Test section energy conservation.

CDATA - 1. Two-phase flow self-consistency checks

Single-phase flow instrument checks
 Two-phase mass flow rate calculations.

SDATA - 1. Stationary condition of steam flow, water flow, and test section pressure.

Mass and energy conservation equations (see Appendix B) were to be used in conjunction with single phase mass flow measurements at the outlet of the test section as a means of verifying the correctness of measured steam and water flow rates going to the mixer. These basic validation calculations could not be accomplished because the single phase mass flow outlet measurement spools could not be installed in the facility in time for the EG&G Idaho, Inc., testing. Allowance was made in the header for each new run to specify the superheated steam and subcooled water flow rates and test section pressure. These values were then compared with the actual measured values to verify that the facility operator had successfully reached the matrix point.

In CDATA, self consistency checks were made as follows:

Saturation:

Nearby pressure and temperature measurements were checked by calculating the saturation temperature corresponding to the measured pressure and computing the difference between it and the measured temperature. Such checks were also run on the conditions at the single phase measuring orifices to verify existence of at least minimum superheat and subcooling.

Differential Pressure:

Checks were made using redundant, differential and absolute pressures. For example, as shown in Figure 15, the difference between D5 and the sum of D3 and D4 was calculated to verify that the difference was within the expected error band of the three measurements.

Single-phase (calibration) checks were able to be made of the turbine meter, dual beam densitometer, drag device, and differential pressure measurements. The single phase mass flow rate (orifice) measurement was used as a reference to check the turbine meter signal and specific volume calculation at the test section. Likewise, the single-phase densitometer values could be checked there against the

specific volume calculated from pressure and temperature measurements. The constancy of single phase drag coefficients and pressure drop (equivalent frictional resistance, K-factor) values could also be checked through the use of mass flow rate and specific volume measurements.

The two-phase mass flow rate was calculated using simple turbine, densitometer, and drag device models, and compared with the sum of the steam and water flow rates to the mixer.

In SDATA, the number of samples in the average was reduced to 100 and the resulting average values of steam and water flows and test section pressure immediately typed on the teletype. The time to print out the numbers thus controlled the sampling rate. A later modification to the program permitted any four hardware or pseudo channels to be selected for observation.

1.2.3 Other Functions and Routines. In total, a set of seven tapes were generated:

Tape No.	Function		Routine
1.	Main	Į.	Mē 'n
2.	Housekeeping	-	List, edit, read and punch housekeeping; read, edit and punch header
3.	Acquisition	-	GDATA
4.	Validation and Printout	-	PDATA, CDATA, SDATA, ZOUT
5.	Library	_	Fortran IV
6.	Library	-	BCS relocatable floating point
7.	Miscellaneous		PSCAN, PCK, LEAD, SN, CHNG, 12313

The Housekeeping (HKP) routines provided the calibration constants and type of calibration equation, along with a listing of active hardware and pseudo channels and other standard information necessary to the computation. The Header (HDR) routines provided information on type of run, global parameters (such as number of samples in average), header information for each run, and specified matrix point data. The program accounted for five types of fluid conditions and three EG&G Idaho, Inc., program test series (LOFT, PBF, and Semiscale). The fluid conditions recognized were:

- 1) Calibration check all vapor
- 2) Calibration check all liquid
- 3) Two-phase condition achieved by throttling hot water
- 4) Two-phase condition achieved by mixing steam and water
- 5) Two-phase condition achieved by mixing air and water.

The ZOUT routine provided for data output. Options included printing or punching and metric or English units. All active hardware and pseudo channel time-averaged values from GDATA were listed. To check that the information on the punched tape was correct, the tape was read back into memory and the two versions compared. If the tape was correct, the computer responded with a "Tape Verified" output. Figure 17 is a copy of the standard GDATA printout for each run.

2. PRINCIPAL MEASUREMENTS

The principal measurements are:

- 1. Superheated steam flow to mixer , me
- 2. Subcooled water flow to mixer, mw
- 3. Semiscale spool piece absolute pressure, P4
- 4. Spool piece fluid temperature, T4
- 5. Turbine meter flow, Q
- 6. Upper and lower beam chordal average densities, $\rho_{\rm u}$, and $\rho_{\rm l}$
- 7. Drag device momentum flux, Pu2
- 8. Scanning densitometer cross sectional average density, p
- 9. Radiotracer liquid and vapor velocities, u_{S} , and u_{W}
- 10. Upper and lower impedance probe void fractions, $\alpha_{\rm U}$, $\alpha_{\rm l}$

These measurements are listed in Table A-II except that only the sum of the flows to the mixer is listed. (Separate steam and water flows are given in Table A-III). The principal measurements are discussed below in terms of Single Phase (Items 1,2), Semiscale Spool Piece (Items 3 to 7), and Other (Items 8 to 10).

2.1 Single Phase Flow Measurements

The single phase measurements were important because they constitute the reference against which to judge the accuracy of the two-phase mass flow inferential measurement combinations (turbine + densitometer, turbine + drag device, and densitometer + drag device). For this reason, backup measurements were made with the EG&G Idaho, Inc., data acquisision system, in addition to those made by the IRB facility system. The IRB pressure, temperature, and orifice differential pressure transducers shown in Figure 16 produced a 0 to 20 mA signal. A precision resistor was inserted in the current loop from each transducer to the IRB data acquisition equipment and the voltage change across this resistor was amplified and measured by the EG&G Idaho, Inc., data acquisition system. Table 1 shows the agreement achieved by the two measuring systems (average difference

```
CURRENT TSN = 2287 NEW TSN = ?
2287
TSN 2287 SEMISCALE STEAM WATER TEST. 15 DEC 77.
        OUTPUT UNITS
         565-3406 KP
P 1
P 3
         348-2294 KP
        351.6051 KP
P 4
P 5
        341 7297 KP
          38-1690 KP
D11
         31-2953 KP
D 1
            -4108 KP
D 3
D 4
           9.4304 KP
D 5
           9.8270 KP
D12
           .0000 KP
          84.9411 KP
        1102.5051 KG/M-5**2
F 2
         -2683 KP
D 6
            9.6696 KP
D-7
           1. 4526 KP
DIO
         156 7394 C
          179-0914 C
         135 4232 0
         150 - 1535 C
         149.7607 C
T 6
         145 6732 C
          9.2993 KG/CU M
          277.0684 KG/CU M
          :0215 CU-M/S
          1422-1345 KG/M-S**2
         27.0839 KG/M-S**2
 F 3
          15 - 5302 C
 TSI .
 TS3
         135 . 6905 C
         139.0275 C
 T54
US
HS
         - 3554 CU-M/KG
         2807.8125 J/G
         .0011 CU-M/KG
 UU
 1138
          569.9625 J/G
                            3.4613
          1728 KG/S
 115
           3.2885 KG/S
 1477
            *5396 CU-M/KG
 V54 .
             . ØØ11 CU-M/KG
         2639.9897 KG/M-S**2
MOM FLX
         .0161
VMS4
             +0118
 VMW4
          143-1839 KG/CU-M
RHOBAR
           6.1508 M/S
 UBAR
           3.1602 KG/S
M. D+T
           3.0780 KG/S
 M. D+DS
M. T.DS 1. 6566 KG/S
```

VERIFY TAPE: PLACE TAPE IN READER AND CHANGE SW WHEN READY

Figure 17. Data Acquisition Printout.

TABLE I

GFK SENSOR CHECK COMPARISONS OF MEASURED SIGNALS
AT 20%, 50%, and 100% OF FULL SIGNALS

		GFK	Term	20% (4	mA) Full	Scale		56% (10	mA) Full	Scale		100% (3	0 mA) Full	Scale	
NW	TM	Comp	Strip	GFK	1.6 GfK	EG&G	% Difference	GFK	1.6 GfK	EG&G	Difference	GfK	1.6 GfK	EG&G	Difference
	10	48	76/77	0.9976	1.596	1,600	0.251	2,4872	3.980	3,995	0.377	4.9780	7.965	7.990	0.314
32	4	46	82/83	0.9951	1.592	1.593	0.053	2,4872	3.980	3,980	0	4.9756	7,961	7,958	-0.038
	5	47	79/80	0.9951	1.592	1.595	0.178	2,4872	3.980	3.981	0.025	4.9780	7.965	7.960	-0.063
යු 50	3	51	61/62	0.9927	1.588	1.597	0.567	2.4847	3.976	3.991	0,377	4.9780	7.965	7,983	0.226
_	1	50	64/65	0.9951	1.592	1.595	0.178	2.4872	3,980	3,980	0	4.9780	7.965	7.954	-0.138
	11	55	85/86	0.9951	1.592	1.595	0.178	2,4872	3.980	3.992	0.302	4.9780	7.965	7.985	0.251
65	6	53	91/92	0.9951	1.592	1.595	0.178	2,4872	3.980	3.985	0.126	4.9756	7.961	7,970	0.113
	7	54	88/89	0.9976	1,596	1,591	-0.313	2_4872	3,980	3.984	0.101	4.9780	7,965	7.966	0.013
	9	59	67/68	0.9951	1,592	1.595	0.178	2.4872	3.980	3.989	0.226	4.9780	7.965	7.975	0.126
10	0 2	57	73/74	0.9951	1,592	1.595	0.178	2.4872	3.980	3,985	0.126	4.9780	7,965	7.969	0.050
	3	58	70/71	0.9927	1.588	1.595	0.441	2.4872	3.980	3.985	0.126	4.9780	7,965	7.965	0

0.18%). The 1.60 factor in the table reflects the ratio of GfK and INEL resistor values. Thus the minor differences which occasionally appear between the \dot{m} values listed in Table A-I (IRB) and Table A-II (EG&G Idaho, Inc.,) must be ascribed to data acquisition technique, software, and steam tables.

As noted earlier (Section II), the highly flexible GfK system permitted a daily decision on which boiler would provide steam to the mixer and which would provide water. Figures 16 and 11 show the details and consequences of this decision. For example, Figure 11, the log sheet for December 15 testing, indicates that measurement spools NW 65 and NW 50 were used. Figure 16 shows that this choice meant the small boiler (Henschel) would provide the steam, and the large boiler (Benson) the water. Thus, GfK transmitters 7, 6, 11, and A4 would provide the steam data and 8, A1, and 1 the water data. In turn, the EG&G Idaho, Inc., computer would list the steam data as D1, D11, P1, and T1, respectively, and the water data as T2 and D2 (water pressure was not used in determination of its density in the EG&G Idaho, Inc., program). As shown in Figure 11, this correspondence required, for example, that GfK transmitter 11 be connected to EG&G Idaho, Inc., Bay Laboratories amplifier channel 1 for measurement P1, that transmitter A4 be connected to amplifier channel 21 for T1. etc.

Thus, if on the previous day the small boiler had provided water, the wiring connections to the EG&G Idaho, Inc., amplifiers would have to be changed to the new conditions. This selection was further verified on the log sheet (Figure 11) by crossing out the unused GfK instruments.

An additional decision had to be made concerning the flow measurement, since two differential pressure transducers were connected across each orifice plate. For example, the low range steam transducer (25 kPa full scale) was designated D1, the higher 200 kPa range, D11. The EG&G Idaho, Inc., computer program selected the higher range transducer unless its reading was less than 10% of full scale, in which case the low range transducer reading was used. Both values were measured and recorded regardless of which was used in the mass flow calculation (and thus it is not unusual to find the low range transducer reading greater than its full scale value).

The orifice equations used to compute the steam and water flow rates are those recommended in Reference 4, and are:

$$\dot{m}_{s} = 1890 \quad C_{Ds} F_{s} D_{Ts}^{2} F_{as} Y_{a} \left(D1/V_{s}\right)^{1/2}, 1b/hr$$
 (1)

$$\dot{m}_{W} = 1890 \quad C_{DW} \quad F_{W} \quad D_{TW}^{2} \quad F_{aW} \quad \left(D2/V_{W} \right)^{1/2}, \quad 1b/hr$$
 (2)

where

C_{Ds}, C_{Dw} = discharge coefficients for the steam and water orifices

$$F_s$$
, $F_w = \left(1 - \beta_s^4\right) - 0.5$, $\left(1 - \beta_w^4\right) - 0.5$
 β_s , $\beta_w = D_{Ts}/D_{Ps}$, D_{Tw}/D_{Pw}

 D_{Ts} , D_{Tw} = throat diameters for steam and water orifices, in.

D_{Ps}, D_{Pw} = pipe inside diameters for steam and water orifices, in.

 F_{as} , F_{aw} = thermal expansion factors for steam and water orifice throat diameters

D1 (or D11) = steam orifice pressure drop, psia

D2 (or D12) = water orifice pressure drop, psia

 V_S , V_W = specific volume of steam or water ft³/lb (steam table algorithms are listed in Appendix B).

Values of discharge coefficients, throat and pipe diameters, thermal expansion coefficients and transducer calibration constants for the four measurement spools are given in Table II. As implied above in the software description, the quantity averaged was $\hat{\mathbf{m}}_S$ or $\hat{\mathbf{m}}_W$. That is, "instantaneous" values of P1, T1, D1, in engineering units, were used to calculate similar values of F_{as} , Y_a and V_s . Then the value of $\hat{\mathbf{m}}_S$ was calculated according to Equation (1). This value was then used to update the average $\hat{\mathbf{m}}_S$ value. Thus, while the

value was then used to update the average \dot{m}_S value. Thus, while the time-averaged values of V_S , P1, T1, and D1 are also recorded, those average values were not used to calculate the average \dot{m}_S value.

The various measurement spools and associated instruments, that is, NW 65, NW 50, etc. were earlier calibrated in W. Germany. These tests resulted in the values of discharge coefficients, transducer calibration coefficients, etc., listed in Table II. The result of the analysis of the calibration data is that, the 95% confidence level for the steam mass flow rate measurement is $\pm 2\%$ and for the water mass flow rate measurement is $\pm 1\%$. These are percentages of the reading and are considered valid down to 0.024 kg/s steam flow at 25 bar and 0.164 kg/s water flow. At lower pressures and flows, accuracy of the flow-measurements decreases.

TABLE TI
SINGLE PHASE SPOOL MEASUREMENT CONSTANTS

Spool No.	Fluid	Bay Lab Gain	Press. Coeffic a _o		Bay Lab Gain	Temperatu Coefficie a _e 11 a ₂	nts	Bay Lab Gain	Low Range & Coeff Clents	s Lab	Coeff	Range of icients ^a l	Discharge Coefficient CDs or CDW	Throat Diameter mm	Pipe Diameter mm
NW 32	Water		not u	sed	500	32,90,56,-0.	3144,0.00576	2	0, 0.05664	4 2	0,	0.45313	0.6205	15.00	32.80
NW 50	Water		not u	sed	500	32,90.56,-0.	3144,0.00576		none	2	0,	0.45313	0.6169	23.00	50.90
NW 65	Steam	2	10.43	299.06	500	32,90.55,-0.	3144,0.00576	2	0, 0.0566	4 2	0,	0.45313	0.61.7	27.90	68.10
NW 100	Steam	2	10.43	299.06	500	32,90.56,-0.	3144,0.00576	2	0, 0.05664	4 2	0,	0.45313	0.615	44.05	99.50
	Condi	tion	Usage	Summary		Test Dates	Run								
Mixing:			Steam (N Water (N			6-9,13,15 19,21 Dec	2215-2247 2249-2264 2284-2302 2303-2313A		$b_0 b_1 = (7.05)$	x 10-6)			coefficient fo		= 1 and
							Z3U3-Z313H		bo b1 = (9.66	x 10-6)	thermal	expansion	coerricient to	water	= 1 and
Mixing:			Water (N Steam (N			5,14,20 Dec	2209-2213 2265-2283 2313-2336		For spool number a_0 $a_1 = (11.6)$	ber NW 65 x 10-6)	thermal	expansion	coefficient fo	r steam	\approx 1 and
Throttling:	Both boi	lers on	Water (N	W 32, NW	50)	##.			For spool number a_0 $a_1 = (18.7)$		thermal	expansion	coefficient fo	steam	= 1 and

2.2 Semiscale Spool Piece Instrumentation

The principal measurement instruments on the spool piece were the turbine meter, dual beam densitometer, three probe drag screen or drag disk, absolute pressure transducer, and fluid temperature thermocouple.

2.2.1 Turbine Meter. The turbine meter was a standard⁶ Semiscale full flow device Model FT-48I 200-LBS, purchased from Flow Technology. The five-blade turbine rotor was mounted to a centrally located round rod axle by use of a ball bearing (see Figure 9). Both upstream and downstream of the rotor, the axial rod supported and aligned cross-shaped flow straighteners within a circular shroud. The inside diameter of the 19.7 cm long shroud, except near the rotor, was the same as that of the upstream 3-in. Schedule 160 pipe spool piece. The outer diameter of the rotor blades was 6.25 cm, with the shroud inner diameter at that location being 6.36 cm. Outer diameter of the rotor hub was 2.06 cm and the axial rod diameter was 0.635 cm.

Nominal rated range of the unit was 40 to 400 gpm. While the flow was always undirectional, both pickup probes needed to detect reverse flow were installed and connected to the signal conditioning unit, Model PRI-102FR.

The pickup probe is a detector which produces a voltage pulse as each rotor blade passes it. Thus, five pulses indicate one complete rotor revolution which in turn corresponds to a certain volume of fluid passing through the turbine meter. The calibration factor, then, is a certain number of pulses per unit volume. The signal conditioning module integrates the pulse train from the detector to produce an output analog voltage corresponding to the pulse rate or volumetric flow rate, and this in turn is further amplified by the Bay Laboratories amplifier (gain of 2).

Two turbine rotors were used in the testing; each was previously calibrated in the manufacturer's ballist: flow calibration facility. This facility uses an organic fluid of com, sition given by MIL-SPEC-7024B with a specific gravity of approximately 0.76. The turbine rotors were calibrated both with and without the EG&G Idaho, Inc., drag disk installed in its normal upstream position (the drag screen was not available for use at the time the turbine rotors were calibrated so that its effect on the turbine reading was not determined). The results of the turbine calibrations, given in Table III, indicate negligible effect of the drag disk on the turbine calibration in an all-liquid condition. On the basis of these results, the effect of the drag screen on the turbine was assumed to be neglible, since it would presumably disturb a flow less than the drag disk.

The signal conditioning module incorporated a five-position range switch, each of the first four ranges accommodating a full scale input pulse rate twice that of the preceding one. The highest range was a factor of 10 greater than the lowest range. Full scale pulse rates, volumetric flows, and (linear) engineering units conversion

TABLE III

TURBINE METER CALIBRATION INFORMATION

Co	ondition	Turbine Meter (Calibration Fac	ctor, Pulses/Gallon
Turbine	Rotor #48115A only	51.77	7	
	Rotor #48115A with Drag Disk upstream	51.6	1	
Turbine	Rotor #48115B only	51.6	?	
	e Rotor #48115B with Drag Disk upstream	51.6	3	
Range	Full Scale Pulse Rate, p/s	Full Scale Output Voltage (amp. gain = 2)	Full Scale Volu. Flow ft ³ /s	Eng. Unitsa Coefficient,a ₁ ft ³ /s, volt
1	215.4	10	0.557	0.0557
2	430.8b	10	1.114	0.1114
3	861.6	10	2.220	0.2228

4.456

5.570

10

10

1723.2

2154.0

5

0.4456

0.5570

a calibration equation for engineering units conversion is Q = + a_1 (V), Q, ft³/s = + a_1 (V, volts).

b (51.7 pulses/gal) (1.114 cu ft/s) (7.48 gal/cu ft) = 430.8 pulses/s

coefficients used in the computer are also given in Table III. An initial mistake in calculation of the values of all was subsequently discovered and all data involving values of Q in this report have been corrected. An apparent nonlinearity in the circuitry of the signal conditioning module was discovered during installation checks at Karlsruhe. (The module used in the ballistic calibration tests was not available and a second unit was taken to Karlsruhe.) The nonlinearity appeared at approximately 65% and greater of all ranges and was attributed to a circuit modification. The solution adopted was to use different ranges, as necessary, to keep the output voltage less than 60% of full scale.

A problem with the performance of the turbine meter was failure of the bearings, which led to destruction of the rotor (blades were broken off at the hub due to interference with the shroud inner diameter). The bearing failures observed were attributed to high temperature, high void fraction, and overspeed conditions. Because of the nature of the steady state testing, these adverse conditions were maintained for periods of time much longer (sixty times longer) than exist in a normal Semiscale test. As a result, though the fluid conditions in the steady Karlsruhe test and those in a normal Semiscale test were the same, the effect on the turbine meter was much more severe in the sceady state tests. Over the course of the testing, both rotors and three sets of bearings were used up.

2.2.2 <u>Dual Beam Densitometer</u>. The single source/two detector or "dual beam" densitometer Semiscale system designation GU-15 was a Model FM-3 purchased from Measurements, Inc. The densitometer consisted of a Cesium-137 source housed in a storage cask mounted on the spool piece piping, two NaI(T1) photomultiplier (PM) tube detectors in their casks, and two channels of associated electronics.

The 20 Curie Cesium-137 pellet was remotely moved from a "stored" location within the source cask to an "exposed" position by use of compressed air. In the latter position, the 662 keV gamma radiation from the pellet was able to pass through two collimating ports in the shield, the stainless steel pipe wall, contained fluid, far-side pipe wall, and through the detector collimating ports to the two NaI(Tl) crystals. The source and detector shield casks were mounted to the piping by a water cooled clamp and framework. Though the angle between detectors was fixed by collimators and detector cask mounting, the relation of the beam path to the pipe flow cross section was determined by adjusting the clamp relative to the pipe, using a flat on the clamp and a level to get the flat horizontal. Properly installed, the lower beam penetrated the pipe at the bottom of the flow cross section, while the upper beam formed an angle of 18 degrees with it, as shown in Figure 9.

Unlike the source cask which was constructed of depleted uranium, the two detector shield casks were made of lead filled steel. The detector shield casks were water cooled and contained the detectors and tube base preamplifiers. Remotely actuated (air) shim packages were mounted integrally with the detector collimating ports. Each

package contained two steel shims (Hi, Lo), separately controllable, with indicating lights on the control/amplifier. Position of the source pellet was also shown by indicator lights, and switches controlling solenoid varies which permitted application of air pressure to the source ask and shim packages were also mounted on the control/amplifier.

The Jetectors were 5.08 cm diameter by 5.08 cm high NaI(T1) scintillation crystals integrally mounted to 5.08 cm diameter PM tubes. The 1.91 cm diameter collimated gamma beam struck the crystal along a radius of the cylinder. Only four dynodes of the ten stage tubes were used (one standard method of improving detector stability). The premium grade tubes were specially selected for low, dark current. The input capacitance of the tube hase preamplifiers was such that the pulse train from the PM tube was basically integrated at that point and thus the preamplifier output was an analog voltage proportional to the pulse rate. This voltage was further amplified in the control/amplifier to produce a 10 volt full scale output. The signal was routed to a Bay Laboratories amplifier, set with a gain of 1.0. Highly stable Power Design units were supplied in the Measurements, Inc., systems to provide the two PM tube high voltages.

The detected pulse rate or output analog voltage from a detector channel is inversely proportional to the exponential of the number of mean free fluid path lengths. The number of such path lengths is itself directly proportional to the average fluid density along the chordal beam path through the fluid. Thus, two proportionality constants relate the pulse rate and chordal-average fluid density. Values for these two constants can be determined by measuring the pulse rates at each of two known fluid densities, as for example, an all-liquid condition and an all-vapor condition. This constitutes the calibration of the densitometer. The engineering units conversion equation used in the computer to calculate the chordal-average fluid density for each detector was:

$$R = A \ln \frac{B}{V - C}$$
 (3)

In this equation, A and B are the proportionality constants, V is the measured output voltage, R the chordal average fluid density, and C a small correction to take account of radiation detected (with stored source) in spite of the source and detector shielding. No correction was made either for background or for scattered radiation detected Values of the constants and other densitometer data are given in Table IV. The output voltage, V, is subject to the gain of the PM tube which in turn depends on the magnitude of the high voltage applied to it. The value of B is the output voltage, corrected by C, for the all-vapor condition, and hence is dependent on the high voltage setting for that measurement. The daily setup procedure finally adopted for the densitometer was to provide an all-liquid condition in the pipe at or near the expected operating temperature.

TABLE IV

DUAL BEAM DENSITOMETER INFORMATION

	Ca	libration Constants U	sed
Detector	A,1b/ft 3	B, volts	C, volts
R1 (upper beam)	206.24	9.986	0.005
R2 (lower beam)	120.66	9.953	0.005
	Serial Numb	ers	
Item	<u>R1</u>	R2	
Amplifier	1037	1039	
Detector	Z-879	Z-876	
Preamp	A113	A114	
Power Supply	B609013	8609012	
Source Cask	18		
Detector Cask	54	55	

Test section fluid pressure and temperature measurements provided the means to calculate liquid density from the steam table algorithms (Appendix B) and the high voltage was adjusted to give that lensity value. Use of the all-liquid condition was not as desirable as an all-vapor condition, but the all-vapor condition could not be used without damaging the turbine meter. The problem found in using the all-liquid condition to check or reset the high voltage was that the output voltage drifted sufficiently under subsequent high void fraction conditions to produce calculated, negative densities. While this few-to-several-hour drifting was a problem in the steady testing at Karlsruhe, it is not in the normal Semiscale test. In the latter case, the high voltage can be adjusted just prior to the beginning of a blowdown, while the all-liquid condition exists. Within 6 to 8 minutes, the blowdown and reflood are complete and a known all-vapor condition exists which can be used to correct any drift. But in several hours per day of steady state testing, the drift was not negligible, and all-liquid conditions could not be repeatedly run during a day without a major reduction in testing rate. The use of the shims in this respect was not tried extensively, and might have helped the situation. The approach followed was that the scanning densitometer, not being subject to the drift problem, could be used to determine correct cross sectional average densities. Part of the drift problem was finally attributed to the upper beam PM tube starting to fail, and performance did improve somewhat after the PM tube was replaced.

2.2.3 Momentum Flux Measurement. As noted earlier, momentum flux measurements were initially obtained using a three transducer, full flow drag screen setup. Later in the test series a single transducer drag disk was used. The full flow drag screen was installed for Runs 2201 to 2302, and the drag disk for Runs 2303 to 2340. The three transducer drag screen setup was the prototype of a new Semiscale measurement system developed by EG&G Idaho, Inc., and these Karlsruhe tests were the first tests in which the system was subjected to a two phase flow. The commercial drag disk system has been in use on the Semiscale facility for some time, but because of flow regime and temperature sensitivity problem is to be replaced with the newer system.

A cross section of the drag screen setup is shown in Figure 9, Section B-B. The primary components are an instrument washer, drag screen, three force transducers, and carrier amplifier signal conditioning modules. The instrument washer is mounted between the spool piece flanges with silver plated Inconel-600 O-rings used for the pressure seal. A tongue and groove arrangement provides proper alignment of washer and spool piece inside diameters. Three water-cooled transducers are mounted in the instrument washer, the tip of the force arm of each transducer engaging the drag screen. As the transducers are mounted top, bottom, and side, the vertical drag screen actually rests on the force arm of the bottom transducer and is

prevented from tipping by the side and top transducer arms. Thus, the flow-induced-drag-force on the screen is resisted by the three transducer force arms. Each arm is part of a pivoted lever which in turn causes a sing to move within an electrical coil, changing the coil or eluctance. The changed reluctance produces a phase shift of the 3-kHz carrier signal. The phase shift is detected and amplified by the carrier amplifier, and its do output is linearly related to force arm movement. Full scale movement is 1.27 mm, corresponding to a force on the arm of 31.1 newtons, and to an output voltage change of 2.00 volts. This carrier amplifier output signal was routed to the Bay Laboratories amplifiers and the remainder of the data acquisition system.

The sum of the forces on the drag screen is proportional to the momentum flux ρu^2 as can be seen in Figure 18 which shows, the momentum flux calibration of the screen. Table V lists calibration data. This calibration was done at the Semiscale air-water loop using a measured water flow only. It is to be noted that in this first system there was a non-zero offset (non-zero output signal for no applied force). In the testing at Karlsruhe, the offset values were generally checked at the beginning of the day for a non-flow condition, and these daily values were used for the remainder of that day. In several cases, offsets were checked at day's end and found to be somewhat different. The data in Table A-II reflect only the beginning values, a judgment of the validity and usefulness of attempting some correction being left to the subsequent analysis effort.

Both successes and failures were observed with the measurement. No significant temperature sensitivity was observed with these water cooled transuucers, and this constituted achievement of a significant design goal. Also, some amount of flow regime information could be gleaned from consideration of the relative magnitudes of the three transducer outputs. On the other hand, all three force arm tips broke at one time or another during the testing. Part of these failures were subsequently attributed to chloride induced stress corrosion cracking and part to alloy selection and possible inadequate heat treatments. It also became apparent that fine particles (corrosion and other foreign matter, or both) had settled and become packed around the force arm in the bottom transducer causing, finally, a loss of range and gradual loss of calibration (Subsequent designs have used side-side-top transducer orientation instead of the initial top-side-bottom one). Overall, the gains seemed to outweigh the losses and this prototype measurement system appeared to be relatively successful.

The drag disk measurement consists of a solid disk target mounted on a force arm. Disk diameter is 2.22 cm, compared to the 66.7 mm spool piece inside diameter. Because the disk is generally mounted at pipe center, it is unable to respond to stratified flow regimes with liquid levels below the bottom of the disk. In some early instances, the cross-sectional area of the force arm was significant compared to the disk area, causing calibration and interpretation problems. The




Figure 18. Drag Screen Momentum Flux Calibration.

TABLE V

MOMENTUM FLUX CALIBRATION INFORMATION

Drag Screen Transcuders

Serial Number	Washer Location	Designation	Calibration Gain,a	Constants Offset b
001	Buttom	F1	2270	V ₁ off
002	Side	F2	2270	V ₂ off
003	Тор	F3	2270	V ₃ off

Drag Disk Transducer

Serial No.	Designation	Calibration Offset a ₀	Constants Gain, a ₁
2427	F6	-66.96	1788

Drag Disk: Ramapo Model MARK V-5-PRBD

$$\rho_u^2 = a_1 \cdot a_{i=1}^3 \cdot (v_i - v_{i \circ f})$$

a. Includes Bay Laboratories amplifier gain of 5; units: 1bm/ft s^2 , volt.

b. Ckecked daily and changed as necessary - see daily instrument log sheet. Calibration equation for engineering unit conversion is:

electrical part of the transducer is simpler than the drag screen transducers, being a strain gage type measurement. It was thus handled in exactly the same manner as a pressure transducer by the software. However, although simple, this strain gage is not provided with adequate cooling or temperature compensation which impairs the measurement accuracy significantly. Calibration data for the drag disk were obtained simultaneously with the turbine calibrations and are included in Table V. The transducer worked satisfactorily and without failure within the limitations noted.

2.2.4 Spool Piece Absolute Pressure. Figures 9, 10, and 15 show the location and connection of the absolute pressure transducer, designated P4, to the Semiscale spool piece. The pressure tap was located at the horizontal centerline of the spool piece at the upstream flange of the instrument washer joint. A standard Semiscale type water cooled pressure probe was used to assure that the sense line to the transducer was continuously filled with water. The transducer was mounted below the test section on the top rail of the test stand (Figure 10). The transducer was supplied with isolation and vent valves and was connected into the redundant ΔP measurement network as shown in Figure 15.

Different transducers were used, depending on the matrix point pressures scheduled for the test day. A Baldwin Lima Hamilton (BLH) differential pressure transducer having 50 psid range was used with its low side open to the atmosphere for most of the 4 bar runs, whereas Precision Sensor absolute pressure transducers were used when test section pressures were 10 to 40 bars, and Consolated Eletrodynamics Corporation absolute units were used for 75- and 100-bar test section pressures. Constant voltage (5 volt) excitation of these various manufacturer's strain gage type transducers was used throughout the testing. As indicated earlier, the six conductor cabling and Bay Laboratories signal conditioners were common to all pressure measurements and independent of transducer ad.

The pressure transducers were all calibrated at Lake Jaho, Inc., prior to shipment to Karlsruhe. The calibration data were fitted by a least squares technique to a straight line. The resulting gain coefficient (a1) was used directly while the offset coefficient (an) was adjusted, in the case of the absolute transducers, to account for the vertical elevation (of water filled sense line) between transducer and spool piece. These coefficients, the corresponding Bay Laboratories amplifier gain, and transducer make, serial number, and ID (P-4 in this case) were then listed on the instrument log sheet, as may be seen in Figure 11. Channel numbers for the Bay Laboratories amplifier, the Ampex tape recorder, associated strip chart and Hewlett Packard ADC card were also to be used, as for example , the case for P-4 on the December 15 log shown in Figure 11. The pressure measurements were in general reliable and consistent with each other and with the temperature measurements.

2.2.5 Spool Piece Fluid Temperature. Figure 9 and 10 show the location and installation of the Semiscale spool piece fluid temperature measurement, T-4. However, in the Karlsruhe testing the resistance temperature bulb shown in Figure 9 was not used and the Chromel-Alumel thermocouple was located instead in its place, that is, in the downstream flange. As shown in both figures, the thermocouple was inserted from the top side of the spool piece flange and extended down into the flow to near the spool piece horizontal centerline. The *hermocouple junction was made in the way normally done at the emiscale facility: an exposed junction is formed and located about 1.5 cm from the sealed end of the 0.635 cm outside diameter stainless steel sheathing. Chromel-Alumel extension wire routed the signal to a 150°F reference junction. The resulting mV difference was then amplified and measured using the common front end analog and digital equipment. As with all the spool piece principal measurements, the temperature was also recorded on analog tape as a backup, as shown in Figure 11.

The thermocouple was not specifically calibrated. Instead, low tolerance thermocouple cable was purchased and used, and the Chromel-Alumel standard calibration curve was used in the computer to accomplish the engineering units conversion. The set of four coefficients used, listed in Figure 11, adequately covered the range of temperatures experienced in the testing.

2.3 Other Principal Measurements

The other principal measurements consisted of the scanning densitometer, the radiotracer measurements of phase velocities, and the impedance probe void fractions. The latter two measurements are described in detail elsewhere²; the data from all three measurements are included in Table A-2. The scanning densitometer is described herein.

The scanning densitometer was a low photon energy, moving - detector system (Figure 19) assembled and checked out at EG&G Idaho, Inc. Significant portions of the system were purchased from Westinghouse Nuclear Energy Systems where it had been used previously. In the Karlsruhe testing, a new spool piece and traversing framework were built, a new source was supplied, and these were combined with the Westinghouse detector, electronics, and traversing motor and control to form the new system.

The spool piece was a 1.48-m length of 3-in. Schedule 160, Type 304 stainless steel pipe with Grayloc hubs at both ends and a flanged joint about 23 cm from the downstream end. A beryllium ring was mounted between these flanges and the joints sealed with silver-plated Inconel-600 O-rings. The nominal beryllium ring inside diameter was 66.7 mm with an outside diameter of 101.6 mm, was 19.05 mm thick, and fabricated of Brush-Wellman alloy S-200E. The flanges were specially fabricated with an 8 bolt pattern and with taps for pressure, temperature, and Storz lens connections. Three of the flange bolts were replaced by a pair of flange clamps (Figure 8) in




Figure 19. Densitometer Source, Pipe, Detector Geometry.

order to permit the detector an unobstructed view of the entire flow cross section. The clamp bolts were at locations outside the traversing range of the detector. At the spool horizontal centerline, a 19.18 mm diameter hole was drilled in each flange at a distance of 7.620 cm from the center of the flange bore. A 19.05 mm diameter shaft (Figure 8), aligned like a flange bolt, was mounted through and between these holes, and served two functions: (1) it was the axle about which the decector rotated, and (2) it housed the radioactive source. An axial hole was drilled halfway down the shaft, and the source, mounted at the end of the source holder rod, was inserted in this hole. The wall of the tube, on the side nearest the beryllium ring, was cut away at the source location so that only air existed between the source and the beryllium ring. Thus, the source was not collimated. A roll pin was used to lock the source holder rod, axle/source tube, and the upstream flange in relative position. This assured that the source was maintained in a known, fixed position, relative to the beryllium ring, regardless of detector position.

The liquid nitrogen dewar and X-ray detector were mounted on a traversing frame constructed of rectangular aluminum tubing. At one end of the frame, vertical arms connected it to the axle/source tube. Sealed ball bearings were pressed into the arms and provided low frictional resistance between the stationary axle and rotating arms and frame. At the frame's coler end, a vertical circular arc segment was attached to the frame. A chain from the drive motor sprocket was attached to the bottom of the arc, so that pulling upward on the chain raised the detector. The chain unwrapped from the circular segment causing a detector movement linearly related to the rotation of the drive motor.

The radioactive source consisted of approximately 45 mCi of accelerator-grade Cd-109, prepared in May 1977 by New England Nuclear Company. The active material was electropiated on a silver disc which was housed in an hermetically sealed short cylinder, the ensemble noted as capsule Model LE-66A. The primary radiation is the 22.1 keV silver k_{α} X-ray with a yield of better than 95% per disintegration. k_{β} X-rays are also present at 24.9 and 25.4 keV, as is an 88 keV gamma. The electron capture decaying isotope has a half life of about 453 days.

The detector was a 1.0-cm diameter by 5-mm active depth Si (Li) crystal, cooled to near liquid nitrogen temperature in a common vacuum 5 liter dewar, Ortec Model 78916-10300. The 3.81-cm diameter evaculated cryostat snout was sealed against the atmosphere with a 0.001 in. thick beryllium window. A detector shield was mounted on the front of the cryostat. It consisted of a lead sleeve and 25.4 mm thick shield. A rectangular collimating hole was machined in the shield and had a cross section 10 mm wide by 3.17 mm high. Thus, the collimating hole length-to-height ratio was approximately 8 to 1.

With the source/detector distance of 24.58 cm, the 3.17 mm collimating slot height corresponded to an angular beam height of 0.739 degrees, and constituted 1/20 of the flow diameter. Photon

energy resolution of the detector was 274 eV full width half maximum at 15,000 of the 22.1 keV X-rays per second with a main amplifier shaping time constant of 2 μ s.

Figure 20 is a block diagram of the pulse counting system and detector traversing control. Charge pulses generated in the detector by photoelectric absorption of incident X-rays are integrated and amplified in the preamplifier. These voltage pulses are inverted, shaped, and further amplified in the main amplifier and presented to the input of the single channel analyzer (SCA) dual discriminator. The pulse height is proportional to the absorbed X-ray energy, so a pulse height or X-ray energy window can be set by adjusting the upper and lower discriminators. If the pulses are of a height to fall in the window, a slow logic pulse is sent by the SCA to the dual counter/timer where it is counted. Pulses are counted for the selected preset time (that is, 10 s) set on the dual counter/timer. At the end of the preset time, the number of pulses counted is transferred by the printout control to the teletype. Upon completion of printout, the counter is reset to zero and counting automatically reinitiated. Also at the end of the preset time, a control signal is sent from the counter/timer to the preset indexer to start the detector traverse motor and move the detector to its next azimuthal position. The traverse motor is a precise, phase switched dc stepping motor whose output shaft turns 1.8 degrees per step (or preset indexer output pulse). When the preset number of steps (200) have been accomplished, power to the motor is turned off. The speed of the stepping motor is adjusted so that the detector is moved to its next position in slightly less time than is used by the teletype for data printout, that is, slightly less than 3 s.

Thus, a traverse is started by moving the detector to its initial position. The 22.1 keV pulses are counted for 10 s. and the number counted is typed on the teletype. While the typing is proceeding, the detector is moved by the stepping motor to position 2. The counter is reset and counting reinitiated at the new position. This procedure is repeated sutomatically for the 65 azimuthal detector positions, at which time the operator stops the process and returns the detector to its initial position for the next data run.

Main amplifier gain was set at 45 so that the 22 keV photons produced pulses of about 2.6 volts; thus the accompanying 88 keV gamma rays did not saturate the amplifier. Bias voltage used was -1500 Vdc, and upper and lower discriminators were set at 2.80 and 2.40 volts, respectively. A ratemeter connected at the SCA output drove a 10-in. strip chart recorder to provide traverse plots for ease of flow regime identification. A second SCA and ratemeter, and the second pen of the recorder were used to record the 24.9 keV X-ray photon count rate as a backup with main measurement. A multichannel analyzer, Ortec Model 6240-04, was used in setup of the pulse height windows and to verify that scattering and background corrections were negligible. Dead time corrections were also found unnecessary at the counting rates encountered in these tests.




Figure 20. Scanning Densitometer Block Diagram.

As noted above, a total traverse consisted of obtaining data at 65 positions, each position separated by 200 preset indexer steps corresponding to an angular movement of 1.149 degrees. Thus, the 0.739 degree-wide interrogating window was moved the 1.149 degrees from position to position. Measurements of traverse angle were made for all 65 positions. The 1.149 degrees per 200 indexer steps represents the average angular displacement. Standard deviation of this measurement was 0.017 degrees. Data were obtained at several detector positions in the beryllium wall, outside the flow area. This was done as a means of verifying repeatable positioning of the detector, regardless of flow condition. As the total angular range covering the flow area was 54.32 degrees, two phase data were obtained at 47 positions.

Densitometer calibration was accomplished by obtaining count rate traverse data for known density, all-liquid and all-dry vapor conditions. Data were reduced using the scanning densitometer data reduction computer program, PATDP. Chordal average densities are calculated using Equation (4) and cross sectional average fluid density is calculated using Equation (5). The weighting factor used in the latter equation accounts for the angular segment beam area associated with the polar coordinate setup of source and detector.

$$\rho_{c}(\theta) = \rho_{f} - (\rho_{f} - \rho_{g}) \frac{\ln \frac{I(\theta)}{I_{f}(\theta)}}{\ln \frac{I_{g}(\theta)}{I_{f}(\theta)}}$$
(4)

$$\overline{\rho} = \frac{\int_{i=1}^{47} \left[\rho_{c}(\theta_{i}) \ 0.5 \ (D_{o} + D_{s})(\cos \theta_{i}) \ X_{f}(\theta_{i})_{\Delta \theta}\right]}{\int_{i=1}^{47} \left[0.5(D_{o} + D_{s})(\cos \theta_{i}) \ X_{f}(\theta_{i})_{\Delta \theta}\right]}$$
(5)

where

 $_{\rm f}$ = the density of the subcooled water giving rise to traverse count rates $I_{\rm f}(\theta)$

 P_g = the superheated steam density yielding count rates $I_q(\theta)$

 P_C = the cnordal average density determined from the two phase fluid count rates $I(\theta)$

Do = beryllium ring outer diameter

D_c = twice the distance from source center to nearest outer surface of beryllium ring

518 230

- θ = travers angle (Figure 19)
- X_f = fluid chordal path length = $(D_i^2 (D_0 + D_S)^2 \sin^2 \theta)^{1/2}$
- D; = beryllium ring inner diameter.

3. Auxiliary Measurements

The auxiliary measurements are the quantitative pressures, temperatures, and differential pressures listed below, and the qualitative video tape recordings obtained with the Storz lens. The measurements are:

- 1. Drag device differential pressure, D3
- 2. Turbine meter differential pressure, D4
- 3. Drag and turbine differential pressure, D5
- 4. Upstream (frictional) differential pressure, D6
- 5. Total differential pressure (Figure 15), D7
- 6. Impedance probe diffe ential pressure, D10
- 7. Absolute pressure at scanning densitometer, P3
- 8. Absolute pressure downstream of turbine meter, P5
- 9. Fluid temperature at scanning densitometer, T3
- 10. Spool piece metal temperature at dual beam densitometer, T6
- 11. Fluid temperature downstream of turbine meter, T9.

Values for these measurements are given in Tables A-III, A-IV, and A-V. Locations of the sensors are shown in Figure 15. As with all of the measurements processed by the EG&G Idaho, Inc., data acquisition computer, the calibration and other equations used in the computer are also given in the Appendicies.

3.1 Pressure, Temperature, Differential Pressure

These pressure and temperature measurements provide backup for the ones on the Semiscale spool piece and also for phase densities at the scanning densitometer. The pressure measurements were processed as described above in Section 2.2.4, likewise the fluid temperatures as in Section 2.2.5. Calibration information is given in Table VI. The metal temperature was measured with an ungrounded, 1.52 mm diameter, stainless steel sheathed Chromel-Alumel thermocouple mounted in a well in the spool piece wall.

TABLE VI

PRESSURE, TEMPERATURE CALIBRATION INFORMATION

Transducer Serial No.	Mfg. and Type	Range	Intended Application	Calibrationa EG&G Idaho, Inc.
39192 42702 71471 44296 44305 71446 77932 43544 50558 50194 50196 50197 50198 384775 391975 521 522 2611 2613 2253 2353 2353 2734 3452	BLH- ΔP CEC-P CEC-P CEC-P CEC-P	20in. H ₂ 0 50in. H ₂ 0 50in. H ₂ 0 300in. H ₂ 0 300in. H ₂ 0 300in. H ₂ 0 300in. H ₂ 0 10 PSID 10 PSID 50 PSID 50 PSID 50 PSID 50 PSID 50 PSIG 100 PSIG 100 PSIG 500 PSIG 2500 PSIG 2500 PSIG 2500 PSIG 2500 PSIG	DP-06 DP-03 DP-04 DP-07 DP-02D DP-01B DP-05 DP-10 DP-02B P-03-4bar P-04-4bar P-05-4bar 4bar BACKUP BACKUP P-01A P-03-10,40ba -05-10,75bar P-04-75bar P-04-75bar P-05-100bar P-04-100bar 100bar BACKU	r 64.241 r 63.008 59.656 156 37 151.51 155.64

Calibration equation for engineering units conversion:

$$P \text{ or } DP = a_0 + a_1 \text{ (volts)}$$

Thermocouples

Туре	Range	Application	a ₀	a_	a2	a ₃
Chrome1- Alume1	0-650°F	T-3,4,6,9	150 4	45.28	-0.1573	0.00288

Calibration equation for engineering units conversion is:

$$T = a_0 + a_1(v) + a_2(v)^2 + a_3(v)^3$$

a. Five volt excitation, English units

The separate differential pressure measurements across the impedance probe, drag device, and turbine meter were made in an effort to determine whether such measurements could be correlated with the two-phase momentum flux. The other ΔP measurements provided backup and a check of self-consistency among these and the pressure measurements. K-factors for the drag screen, turbine, etc., are listed in Table VII. These were determined from all-water flows using the GfK values for \dot{m}_W .

3.2 Storz Lens

The Storz lens is a fine rod lens optical probe with lighting provided by an integral fiber optic. As a commercial device, its primary use has been in the medical field as a borescope. As a gross check of the feasibility of using such a device for two-phase flow regime measurements, the probe was inserted in the downstream flange of the scanning densitometer spool piece. A high intensity external light source was provided and the image was monitored by a small portable black and white video camera, as shown in Figure 8. Output from the camera was displayed in real time on a monitor and recorded on a video tape recorder. Two types of probes were used: one, having a 180 degree field of view looked across the flow but did not perturb it; the second, having a 90 degree field, intruded into the flow and could adjusted to look either upstream or downstream at the circular flow cross section. Recordings of the flow pictures were obtained for eight air-water conditions and a few 4 bar steam-water conditions (21 December). Steam and water leakage and lens fogging precluded continued safe and useful operation of the commercial device under the steam-water conditions. The integral lighting was not really adequate for good resolution of the two-phase flows: however, gross features of the air-water flows are distinguishable on the vileo recordings. The unit did also play a significant role for in situ inspection of the drag screen and turbine rotor when problems were experienced with these instruments.

IV. TEST MATRIX

Initial versions of the planned test matrix were based principally on the pressure and flow rate data in spool piece No. 15 from a typical 200% break flow Semiscale Mod-1 experiment. Subsequent revisions reflected such additional considerations as upstream disturbances, short piping lengths, and blowdown times of the order of 20 s. And of course the actual test matrix reflected the limitations of the test facility, and the choice between more runs of the easily accomplished type or fewer runs of the more unstable type.

Table VIII is the finally accomplished test matrix. The converging or diverging inlet parts of the test section did have a significant effect on the flow regime, observed in spite of the 65 diameter length between the area change and the spool piece. The flow regimes seemed much more distinct and more fully developed when the 80 to 66 mm converging inlet was used than the diverging case. Even so, a few distinct differences were observed between measured flow regimes

TABLE VII

EQUIVALENT FRICTIONAL RESISTANCE K-FACTORS

Device	K factor, Dimensionless ^a
Drag Screen (D-3)	0.258
Turbine (D-4)	0.780
Screen & Turbine (Direct) (D-5)	1 014
Screen & Turbine (Sum)	1.038
Pipe Friction (D-6)	0 226
Friction+Screen+Turbine (Direct)(D-7	
Friction+Screen+Turbine (Sum)	1.264
rriction+screen+ibroine (sum)	
The state of the s	
ρ., 2	
a. ΔP , psid = K $\frac{\rho_u}{288 \text{ g}_c}$, psid	
288 9	

TABLE VIII
TEST MATRIX AS PERFORMED

Pressure, Bar	Superficial Water Velocity, m/s	Superficial Steam Velocity, m/s
4	0.2 0.5 1.0	5, 10, 20, 70 5, 10, 20, 40, 0 5, 10, 20, 44, 60
40	0.05 0.10 0.20 0.50 0.70	20 2.5, 5, 10 ² , 20 ³ b 0.5 ² , 1.0 ² , 5 ³ , 10 ³ , 20 ³ 0.5 ³ , 1.0 ⁴ , 2.5, 5 ⁴ , 10 ³ , 20 ² 20 0.5 ² , 1.0 ³ , 2.5 ⁴ , 5 ³ , 10 ³
75	0.2 0.5 0.7 1.0 1.5	1.0 ² ,5 ² ,10 ² ,15 ² 0.5,1.0 ⁵ ,2.5 ³ ,5 ³ ,10 ² ,15 ² 1.0 0.5, 1.0, 2.5, 5 0.5, 0.7, 1.0, 2.5, 5

Test Condition Summary by Run Number

Pressure = 40bar

Run	Date	Type of Crag Device	Type of Te t Section Entrance
2209-2231	5-7 Dec	Screen	Diverging (50 to 66 mm)
2249-2273	13, 14 Dec	Screen	Converging (80 to 66 mm)
2303-2319	19, 20 Dec	Disk	Converging
Pressure = 75bar			
2233-2247	9 Dec	Screen	Diverging
2274-2283	14 Dec	Screen	Converging
2320-2336	20 Dec	Disk	Converging
Pressure = 4bar			
2284-2302	15 Dec	Screen	Converging
2337-2340	21 Dec		Converging

a. Conditions at spool piece

b. Superscript indicates number of runs at that condition

and those expected on the basis of the Mandhane map. For this reason the test points have not been plotted on a map. However, in general the flow regimes observed were as indicated below.

Pressure	Flow Regimes Observed
4 bar	Slug, annular
40 bar	Elong. bubble, slug, stratified, wave, annular
75 bar	Elong. bubble, slug

V. SUMMARY OF TEST CONDITIONS AND RESULTS

Semiscale spool piece No. 15 (from the intact cold leg) was tested in the GfK steam-water facility at Karlsruhe, W. Germany. Separate, steady single phase steam and water flows were measured, mixed, and passed down an 8-m long, norizontal test section in which the instrumented spool piece was mounted. Time-averaged responses from the spool two-phase mass flow, inferential instruments (turbine, drag device, and densitometer) were measured and recorded for analysis and comparison with the single-phase measurements. Several other principal measurements of the flow were made, including the GfK radiotracer, impedance probe and few-beam densitometer, and the EG&G Idaho, Inc., cranning densitometer and Storz lens. Several auxiliary pressures, temperatures, and differential pressure measurements were also made. The appendicies contain the tabulated data for subsequent analysis work.

The entire EG&G Idaho, Inc., computerized data acquisition system hardware and software were respectively procured and generated for this test work, as were also the scanning densitometer and Storz lens. The equipment and instrumentation were shipped to Germany, installed in the facility, and initially used in testing of two LOFT spool pieces. Subsequently, testing of the Semiscale spool piece was started and during a 15 calendar day span, data on 132 single- and two-phase test runs were obtained.

The nature of steady-flow testing imposed conditions on the instrumentation not found in normal Semiscale blowdown/reflood type experiments, and both instruments and measurements suffered somewhat: turbine bearings and drag screen pickup arm tips failed and densitometer beam readings drifted significantly during the much longer term, steady state testing regimes.

Test conditions included pressures of 0.4, 4.0, and 7.5 MPa, with two-phase flow rates of 0.5-5 kg/s and flow qualities of 1-83%. All flow regimes except dispersed bubble were observed in the 66.7 mm inside diameter test section. A spool piece adapting the mixer to the test section had an effect on flow regimes observed, depending on whether the flow was forced to converge from an 80 mm inside diameter to 66.7, or diverge from 50 to 66.7 mm.

VI. REFERENCES

- J. Reimann, H. John, E. Wanner, "Gemeinsamer Versuchsstand Zum Testen und Kalibrieren Verschiedener Zweiphasen – Massenstrom-messverfahren," PNS 1. Halbajahresbericht (1975) S. 180-187, KFK 2195
- 2. H. John, U. Muller, J Reimann, "A Test Loop for Testing Measuring Methods for the Mass Flow Rate of Two-Phase Flows," GfK, IRB, paper presented at Specialists' Meeting on Transient Two-Phase Flow, OECD/Nuclear Energy Agency, Toronto, Canada, August 1976.
- D. Barschdorff, G. Class, R. Loffel, J. Reimann, "Mass Flow Measuring Techniques in Transient Two Phase Flow," paper presented at Specialists' Meeting, op. cit.
- Private communication, G. K. Maki, J. V. Gilbert, to A. G. Stephens "Real Time Data Acquisition System" (October 1977).
- Fluid Meters, Their Theory and Application, 5th Edition, 1959, The American Society of Mechanical Engineers.
- E. M. Feldman, S. A. Naff, Error Analysis for 1-1/2 Loop Semiscale System Isothermal Test Data, ANCR-1188, May 1975.
- J. M. Beeston, "Investigation of Pin Failure in Semiscale Flow Drag Transducer," EG&G Idaho, Inc., Report LR-78-3-1, March 6, 1978.
- 8. G. P. Lilly, A. G. Stephens, L. E. Hochreiter, Mixing of Emergency Core Cooling Water with Steam: 1/14th Scale Testing Phase, Electric Power Research Institute (EPRI) Report 294-2, January 1975.

APPENDIX A

TABLES OF TEST CONDITIONS, PARAMETERS, AND MEASUREMENT DATA

NOMENCLATURE

Table A-I Test Conditions as Measured by Institut für Reaktor Bauelement

Matrix Point P, $C_{\rm w}$, $C_{\rm s}$ - Nominal values of pressure, superficial water velocity, and superficial steam velocity in the test section, respectively.

Measured Run Conditions - Facility (GfK/.RB) measurements

PTS - absolute fluid pressure in the test section upstream of Semiscale spool piece

T_{TS} - fluid temperature in the test section upstream of Semiscale spool piece

m - total mass flow rate

 $_{\rm X}$ - steam mass fraction at $_{\rm TS}$, $_{\rm TS}$ - from energy balance

 C_{W} - superficial water velocity, based on \hat{m} , X, P_{TS} , T_{TS}

Cs - superficial steam velocity, based on m, X, PTS, TTS

Table A-II Principal Measurements

Semiscale Spool Piece Data - Principal EG&G Idaho, Inc., mass flow measurements on spool piece

P_{SP} - absolute fluid pressure at spool piece (listed as P4 in Table A-III)

Tsp - fluid temperature at spool piece (listed as T4 in Table A-III) 518 239

- q spool piece volumetric flow rate full flow turbine meter signal
- ou, oL spool piece chordal average fluid density upper and lower beam of dual beam densitometer
- $^{
 ho}u^{2}$ spool piece momentum flux drag disk or full flow drag screen as noted

Other data - other principal EG&G Idaho, Inc., (\dot{m}, \bar{p}) and GfK/LIT) (u_w, u_s) measurements, not on Semiscale spool piece

- m sum of steam and water mass flow rates to the mixer
- cross sectional average fluid density scanning densitometer
- uw radiotracer liquid phase volocity
- u_s radiotracer vapor phase velocity

Table A-III Pressure and Temperature Data

- P1 absolute steam pressure at steam flow orifice
- p3 absolute fluid pressure at scanning densitometer
- P4 absolute fluid pressure at Sem scale spool piece
- P5 absolute fluid pressure just townstream of spool piece
- T1 temperature at steam flow orifice
- T2 temperature at water flow orifice

- T3 fluid temperature at scanning densitometer
- .4 fl.id temperature at Semiscale spool piece
- T6 metal temperature at Semiscale spool piece
- T9 fluid temperature just downstream of spool piece

Table A-IV Differential Pressure Data

- DP1 lower range steam orifice differential pressure
- DP2 lower range water orifice differential pressure
- DP3 drag screen (disk) pressure drop
- DP4 turbine meter pressure drop
- DP5 sum of drag device, turbine meter pressure drop
- DP6 upstream frictional pressure drop
- DP7 sum of frictional, drag device, turbine meter pressure drops
- DP10 fixed impedance probe pressure drop
- DP11 higher range steam orifice differential pressure
- DP12 higher range water orifice differential pressure

Table A-V Miscellaneous Online - Calculated Parameters

Mixer Inlet -

V_s - superheated steam specific volume from P1, T1

H_s - superheated steam enthalpy from P1, T1

V_w - subcooled water specific volume from T2

 $H_{_{
m S}}$ - subcooled water enthalpy from T2

 \dot{m}_{S} - steam mass flow rate from DP1 (DP11), V_{S} , P1, T1

 $\dot{m}_{\rm W}$ - water mass flow rate from DP2 (DP12), $V_{\rm W}$, T2

Spool Piece

 v_{s4} - specific volume of saturated steam in spool piece from P4

 V_{w4} - specific volume of saturated water in spool piece from P4

TS4 - saturation temperature in spool piece from P4

UBAR - fluid velocity from turbine meter Q1

TABLE A-I

TEST CONDITIONS AS MEASURED BY INSTITUT FÜR REAKTOR BAUELLMENT

		Mat	rix Point			Me	easured R	lun Condit	ions	
Run	Date	P (MPa)	C _W	C _s	P _{TS}	T _{TS}	C _W (m/s)	C _s	mm (kg/s)	X (%)
2209 2210 2211 2212	5 DEC 5 DEC 5 DEC 5 DEC	4.0	0.05	20.0	3.88 4.05	246 251	0.08	20.64	1.62 1.75	
2213	5 DEC	1	-		4.10	225	1.11	0.00	2.89	0.
2215 2216 2217 2218 2219 2220 2221	6 DEC 6 DEC 6 DEC 6 DEC 6 DEC 6 DEC 6 DEC	4.0 4.0 4.0 4.0 4.0 4.0 4.0	1.0 1.0 1.0 1.0 1.0 0.50 0.50	0.0 10.0 5.0 2.5 1.0 0.5 1.0	4.10 4.08 4.13 4.03 4.03 3.94 4.01	250 252 250 251 251 249 250	0.98 0.97 0.95 0.94 0.51	9.38 5.12 2.83 0.99 0.50 1.28	3.32 3.05 2.84 2.69 1.47 1.52	19 12 7 2 2 5
2223 2224 2225 2226 2227A 2227B 2228 2228 2229 2230 2231	7 DEC	4.0 4.0 4.0 4.0 4.0 4.0 4.0 4.0 4.0	0.50 0.50 0.20 0.20 0.20 0.10 0.10 0.20	0.0 10.0 5.0 5.0 0.5 0.5 2.5 10.0 10.0	4.10 4.04 4.08 4.05 4.05 4.00 4.03 4.06 4.09	87 249 250 252 251 251 251 250 251 250	0.49 0.52 0.20 0.17 0.17 0.11 0.13 0.20 1.05	9.89 5.14 5.93 0.60 0.60 2.89 10.17 10.35 2.42	2.06 1.81 0.97 0.53 0.53 0.52 1.07 1.30 3.11	34 20 43 8 8 39 67 56

C

518

			Matrix Po	oint			Measure	Run Cond	ditions	
Run	Date	P (MPa)	C _w (m/s)	C _s	PTS (MPa)	T _{TS}	C _w (m/s)	C _s	m (kg/s)	X (%)
2233 2234 2235 2236 2237 2238 2239 2240 2241 2242A 2242B 2243 2744 2245 2246 2247	9 DEC	7.5 7.5 7.5 7.5 7.5 7.5 7.5 7.5 7.5 7.5	1.0 1.0 1.0 0.75 0.5 0.5 0.5 0.5 1.5 1.5 1.5	5.0 2.5 1.0 0.5 1.0 0.5 5.0 2.5 1.0 1.0 0.8 0.50 2.5 5.0	7.44 7.50 7.50 7.50 7.47 7.43 7.48 7.45 7.53 7.48 7.47 7.44 7.53 7.48	289 289 290 290 289 288 289 290 290 289 289 289 289	1.10 1.07 1.05 1.08 0.76 0.54 0.51 0.54 1.51 1.54 1.54 1.52 1.39	5.25 2.68 1.05 0.44 1.07 0.51 4.81 2.51 0.99 0.95 0.76 0.59 2.23 4.97	3.53 3.12 2.82 2.83 2.08 1.44 1.96 1.73 1.51 3.98 4.04 4.02 4.11 4.23	20.4 11.9 5.7 2.2 7.1 4.9 33.8 20.0 64.8 3.3 2.6 2.0 7.4 16.2
2249 2250 2251 2252 2253 2254 2255 2256 2257 2258 2259 2260	13 DEC 13 DEC	4.0 4.0 4.0 4.0 4.0 4.0 4.0 4.0	1.0 1.0 1.0 1.0 1.0 0.5 0.5 0.5	5.0 2.5 0.5 1.0 10.0 10.0 5.0 0.5 1.0	4.04 4.03 4.05 3.97 4.01 3.96 4.03 4.02 4.02 3.96 4.00 4.01	240 240 239 248 249 248 250 249 249 249 249 249	1.03 1.00 1.01 1.02 0.55 0.51 0.53	0.0 0.0 0.0 5.25 2.51 0.40 1.02 9.64 10.2 5.41 0.57 0.98	3.11 1.67 0.850 3.24 2.92 2.87 2.87 3.51 2.25 1.80 1.45 1.55	0.0 0.0 0.0 11.3 6.1 1.0 2.5 19.4 32.3 21.0 2.1 4.5

			Matrix Po	oint			Measured	Run Conc	litions	
Run	Date	p (MPa)	C _w	C _s	P _{TS}	T _{TS}	C _W	C _s	m̂ (kg/s)	X (%)
2261 2262 2263 2264	13 DEC 13 DEC 13 DEC 13 DEC	4.0 4.0 4.0	0.2 0.2 0.2	1.0 5.0 10.0	3.97 3.95 3.94	248 248 247	0.23 0.24 0.26	1.06 5.22 10.1	0.719 1.02 1.41	10.3 35.4 49.2
2265 2266 2267 2268 2269 2270 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282 2283	14 DEC 14 DEC	4.0 4.0 4.0 4.0 4.0 4.0 4.0 7.5 7.5 7.5 7.5 7.5 7.5 7.5 7.5	0.5 0.2 0.1 0.1 0.1 0.5 0.5 0.5 0.5 0.5 0.2 0.2 0.2	20.0 20.0 20.0 10.0 20.0 20.0 5.00 max max 10.0 5.00 1.0 2.5 10.0 5.0 1.0	4.10 3.97 3.98 4.01 3.89 3.97 4.00 4.06 4.05 7.48 7.50 7.48 7.56 7.49 7.45 7.53 7.49 7.57	209 250 249 250 249 249 250 250 289 290 290 290 290 290 290 290	0.51 0.20 0.21 0.10 0.11 0.20 0.10 0.52 0.49 0.51 0.53 0.55 0.21 0.24 0.26 0.32	19.5 20.1 19.8 9.94 19.4 20.1 5.11 0.52 15.9 10.0 5.11 1.07 3.04 10.7 4.74 1.44 15.8	2.80 1.97 1.72 0.98 1.70 1.96 0.64 3.63 3.45 2.70 2.06 1.56 1.82 2.02 1.28 0.85 3.01	49.0 71.4 80.9 71.1 82.1 71.7 56.9 60.3 63.9 51.4 34.3 9.6 23.2 72.8 51.5 23.4
2284 2285 2286 2287	15 DEC 15 DEC 15 DEC 15 DEC	0.40 0.40 0.40	1.0 1.0 1.0	max 5	0.410 0.440 0.408	143 160 147	1.03 1.05 1.03	43.4 4.14 12.9	3.64 3.40 3.40	9.1

			Matrix Po	oint		Measured Run Conditions						
Run	Date	Р	Cw	Cs	P _{TS}	T _{TS}	Cw	Cs	m	Χ		
		(MPa)	(m/s)	(m/s)	(MPa)	(°C)	(m/s)	(m/s)	(kg/s)	(%)		
2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302	15 DEC 15 DEC	0.40 0.40 0.40 0.40 0.40 0.40 0.40 0.40	1.0 0.5 0.5 0.5 0.2 0.2 0.2 0.2 0.0 0.0 0.0 0.2	20 40 20 10 5 5 20 10 40 30 60 max max max	0.408 0.416 0.446 0.392 0.448 0.456 0.472 0.432 0.432 0.440 0.472 0.548 0.602	146 150 147 152 151 154 152 149 166 172 144 148 150	1.01 0.50 0.50 0.53 0.475 0.281 0.153 0.115 0.219 0.191 0.497 1.00 1.12	20.8 41.3 21.2 11.8 3.09 4.13 18.3 9.23 42.2 31.7 59.0 78.8 65.0 57.5	3.40 1.95 1.76 1.81 1.55 0.938 0.654 0.449 1.05 0.247 0.468 1.31 2.24 3.75 3.51	4.7 16.6 9.9 4.8 1.7 3.8 25.1 18.2 32.7 104 104 93.2 29.3 15.2 2.3		
2303 2304 2305 2306 2307 2308 2309 2310A 2310B 2311 2312A 2312B 2313A	19 DEC 19 DEC	4.0 4.0 4.0 4.0 4.0 4.0 4.0 4.0 4.0 4.0	1.0 1.0 1.0 1.0 0.5 0.5 0.5 0.5 0.5	10.0 5.0 2.5 1.0 0.0 0.5 10.0 5.0 5.0 2.5 1.0 1.0	3.97 3.96 3.97 4.00 3.99 3.96 3.98 3.95 4.02	250 250 250 250 233 249 251 250 249 250	1.10 1.02 1.01 1.01 1.23 0.98 0.49 0.51	10.15 4.82 2.57 0.91 0.0 0.80 10.46 5.14 2.80 0.82	3.77 3.19 2.99 2.88 2.81 2.11 1.73 1.64 1.50	18.8 10.5 6.0 2.2 2.0 34.7 19.9		

			Matrix P	oint	1	منشنب		Measured	d Run Cond	litions	
Run	Date	р	Cw	Cs		P _{TS}	T _{TS}	Cw	Cs	m	Χ
		(MPa)	(m/s)	(m/s)		(MPa)	(°C)	(m/s)	(m/s)	(kg/s)	(%)
2313	20 DEC	4.0	max	0.0		3.99	212	1.94		4.91	10.7
2314	20 DEC	4.0	0.5	20		4.01	251	0.50	21.2	2.90	71.6
2315	20 DEC	4.0	0.2	20		4.01	251	0.20	19.0	1.90	79.6
2316	20 DEC	4.0	0.2	10		3.93	251	0.22	9.94	1.31	52.3
2317	20 DEC	4.0	0.1	20		3.97	250	0.10	19.7	1.65	83.4
2318	20 DEC	4.0	0.20	5.0		3.94	249	0.20	5.29	0.94	39.0
2319	20 DEC	4.0	0.20	1.0		3.99	253	0.21	1.00	0.66	10.7
2320	20 DEC	4.0									***
2321	20 DEC	4.0	No. 10	100			9.0				
2322	20 DEC	7.5	0.50	14.0		7.48	289	0.52	13.8	3.24	58.9
2323	20 DEC	7.5	0.50	10.0		7.43	290	0.51	10.8	2.79	52.9
2324	20 DEC	7.5	0.50	5.0		7.47	289	0.53	5.15	2.09	34.0
2325	20 DEC	7.5	0.50	2.5		7.45	290	0.55	2.24	1.7-	18.1
2326	20 DEC	7.5	0.50	1.0		7.52	289	0.56	1.11	1.59	9.7
2327	20 DEC	7.5	0.20	1.0		7.54	293	0.20	0.81	0.62	18.2
2328	20 DEC	7.5	0.20	5.0		7.48	290	0.21	4.99	1.21	56.8
2329	20 DEC	7.5	0.20	10.0		7.49	289	0.21	10.1	1.93	72.0
2330	20 DEC	7.5	0.20	15.0		7.51	291	0.21	15.0	2.61	79.4
2331	20 DEC	7.5		max		7.48	318				
2332	20 DEC	7.5		max		7.46	321		10.4	1.30	1.
2333	20 DEC	7.5		max		7.52	318		5.50	0.69	1.
2335	20 DEC	7.5	0.50	1.0		7.45	289	0,52	0.91	1.44	8.
2336	20 DEC	7.5	0.50	1.0		7.42	289	**			
2337	21 DEC	-	44.44			100 100	-	100			-
2338	21 DEC		Acc 400	16.00			100.00				
2339	21 DEC					W-17					1.5
2340	21 DEC										-

			Ť	4
		-		4
	n i	ž		ž
r	5	١,		ý
90	70	2	>	

		Semiscale	e Spool Pi	ece Data			Other	Data
Run	P _{SP} (MPa)	T _{SP}	Q (m ³ /s) X10 ⁻³	ρ _U (kg/m ³)	ρ _L (kg/m ³)	pu ² (kg/ms ²)	m (kg/s)	ρ (kg/m ³)
2209 2210 2211 2212 2213		251 253 253 252 253	34.4 33.0 60.9 62.1 60.9	0.93 1.78 7.91 2.13 19.3	52.7 54.6 51.2 48.4 62.7	88.8 305 3260 3210 6030	1.64 1.76 2.79 2.63 3.19	21. 20. 23.
2215 2216 2217 2218 2219 2220 2221		254 254 254 253 253 253 252 253	20.9 21.0 11.4 6.8 7.4 5.0 6.1	27.7 21.5 25.1 33.9 133.0 205.0 78.2	199.0 195.2 301.0 390.0 509.0 555.0 422.0	2060 2100 791 510 289 160 81	3.44 3.44 3.08 2.89 2.74 1.48 1.53	824
2223 2224 2225 2226 2227A 2227B 2228 2229 2230 2231	4.15 4.15 4.17 4.15 4.14 4.10 4.12 4.15 4.15	90 253 253 254 253 253 253 253 253 253 253	1.3 22.4 2.8 2.7 8.1 8.4 4.8	957.0 85.8 29.5 4.6	977.0 150.0 247.0 168.0 534.0 493.0 212.0 101.0 106.0 378.0	1710 2330 2330 2190 950 1780 1960 1920 1940 1850	3.30 2.08 1.82 0.988 0.581 0.536 0.523 1.09 1 31 3.19	406

		Semiscale	Spool Pie	ce Data			Other	Data
Run	P _{SP} (MPa)	T _{SP}	Q (m ³ /s) x10 ⁻³	ρ _U (kg/m ³)	ρ _L (kg/m ³)	ρ_u^2 (kg/ms ²)	mh (kg/s)	ē (kg/m ³)
2233 2234 2235 2236 2237 2238 2239 2240 2241 2242A 2242B 2242B 2243 2244 2245 2246 2247	7.44 7.64 7.64 7.61 7.56 7.60 7.65 7.58 7.58 7.56 7.61 7.60 7.65	289 292 292 292 291 291 292 291 291 291 29	30.1 10.2 6.52 1.22 5.40 3.18 14.1 7.69 4.18 7.85 7.30 6.96 11.4 17.3 22.7 4.62	-46.5 -13.2 66.7 184.0 16.5 129.0 31.8 198.0 267.0 314.0 61.6 14.3	253.0 350.0 445.0 519.0 440.0 514.0 226.0 303.0 425.0 575.0 620.0 424.0 295.0 29.6 755.0	915 610 555 420 275 913 479 334 1100 1070 1020 1690 2590 821 736	3.56 3.15 2.88 2.87 2.12 1.45 1.97 1.72 1.52 4.06 4.08 4.07 4.29 0.788 3.49	230 328 433 506 377 180 258 365 525 586 378 262 34. 753
2249 2250 2251 2252 2253 2254 2255 2256 2257 2258	4.12 4.10 4.12 4.05 4.07 4.02 4.08 4.07 4.08 4.03	241 241 240 252 252 251 252 252 252 252	0.056 0.056 0.056 15.0 9.19 5.40 6.13 26.3 27.4	833 844 840 50.1 70.1 237.0 157 28.7 0	829 821 831 309 397 575 526 238 192 255	1020 372 115 4750 2710 362 404 1830 1160 484	3.11 1.67 0.850 3.28 3.03 2.88 2.91 3.55 2.26 1.79	

		Semiscale	e Spool Pi	ece Data			Other	Data
Run	P _{SP}	T _{SP}	Q	ρ _U	ρL	p _u 2	m	õ
	(MPa)	(°C)	(m^3/s) x_{10}^{-3}	(kg/m ³)	(kg/m ³)	(kg/ms ²)	(kg/s)	(kg/m ³)
2259	4.05	251	3.62	84.6	485	178	1.48	
2260	4.07	252	4.23	67.8	443	215	1.57	-
2261	4.02	251	2.90	12.8	444	106	0.726 1.03	
2262	3.99	251	13.6		204	294 782	1.42	***
2263	3.99	251	27.7	000	157	0.00	0.00	
2264	4.10	234	0.00	822	867	0.00	0.00	
2201	4.05	208a	1.67	868	861	119	1.45	
226t	4.00	250a		Little and	82.3	4140	2.82	65.2
2267	4.01	250a			40.9	5380	2.01	36.8
2268	4.03	250a		4.82	36.5	4430	1.78	31.3
2269	4.01	250a	28.0	8.81	104	1020	1.02	53.3
2270	3.98	250a	65.4	32.4	57.1	4380	1.84	
2271	3.98	250a	64.3	44.9	60.3	5350	2.00	
2272	4.04	254ª	12.2	9.54	177	317	0.673	
2273	4.03	250a	102.0	23.1	51.9	18800	3.66	3.5
2274	7.56	289a	53.6	21.9	92.3	7920	3.49	71.2
2275	7.56	290a	30.2	26.7	155.0	2870	2.72	113
2276	7.53	290a	14.3	11.3	266	918	2.04	193
2277	7.62	287 a	4.12	53.0	469	274	1.56	368
2278	7.56	289 a	8.58	77	332	508	1.81	238
2279	7.49	289 a	33.1	10.8	129	2290	2.03	140

		Semiscale	Spool Pi	ece Data			Other	Data
Run	PSP	T _{SP}	Q	ρ _U	ρL	ρ_u^2	rft	ē
	(MPa)	(°C)	(m^3/s) x_{10}^{-3}	(kg/m ³)	(kg/m ³)	(kg/ms ²)	(kg/s)	(kg/m ³)
2280	7.60	290a	4.46	or 5	208.0	590	1.29	
2281	7.52	290a	2.45	22.1	380.0	164	0.860	
2282	7.56	290a	60.8	22.4	97.8	7370	3.35	
2283	7.62	273a	0.84	778	788	190	1.35	
2284	0.444	139	3.81	933	937	503	3.59	927
2285	0.353	150	51.2		96.0	18100	3.70	
2286	0.393	154	8.57	68.2	512	999	3.47	
2287	0.351	151	12.0	9.3	277	2640	3.46	
2288	0.356	151	10.7		280	3480	3.46	216
2289	0.365	152	20.3		60.8	11000	1.97	59.6
2290	0.386	154	5.		194	2010	1.78	137 167
2291	0.343	150	4 /1		249	961	1.83	239
2292	0.396	154	3.88	C1 A	379	437 518	1.57 1.21	194
2293	0.324	148	3.90	51.4	349	775	0.657	82.3
2294	0.424	156	3.80	40.3	176 282	398	0.801	
2295	0.371	152	3.68	21.9	98.7	6800	1.07	39.2
2296	0.379	153	10.6	23.0	59.3	1020	0.248	
2297	0.375	153 161	76.3	15.8	59.4	3340	0.472	
2298	0.408	154	96.2	14.1	60.8	26400	1.39	
2300	0.477	159	93.2	18.3	58.8	35900	2.32	13.3
2300	0.533	163	98.8	22.0	105	26400b	3.87	53.2
2302	0.387	138	0.30	990	997	520b	3.58	924

		Semiscal	e Spool Pi	ece Data			Other	Data
Run	P _{SP} (MPa)	T _{SP}	Q (m ³ /s) x10 ⁻³	ρ _U (kg/m ³)	ρ _L (kg/m ³)	ρ _u ² (kg/ms ²)	m (kg/s)	ρ̄ (kg/m ³)
2303	3.99 3.99	252 252	27.3	13.1	223 348	4220 1290	3.81	261
2305 2306 2307	4.00 4.02 4.01	252 252 252 235	9.24 6.43 4.45	58.4 111 827	447 533 829	1190 798 661	3.03 2.93 3.69	439 823
2308 2309 2310A	4.04 4.00 3.99	251 252 252	5.50 27.8 13.1	4.20 4.96	579 170 265	631 2220 373	2.81 2.12 1.78	
2310B 2311 2312A 2312B	4.01 4.01 3.98 4.06	252 252 251 252	12.8 8.13 4.11 4.23	4.65 8.45 46.2 43.9	268 346 481 476	342 63 -66 -51	1.76 1.64 1.53 1.51	369
2313A	4.00	218				0.26		
2313B 2314 2315	4.04 4.03 4.04	214 252 253	5.68 6.52 60.3	855 3.23 3.22	846 52.4 27.3	1610 11600 7080	4.99 2.93 1.92	848 51.2
2316 2317 2318	3.97 3.93 3.97	252 251 252	26.7 53.3 12.3	3.23 3.21 3.23	124 583 189	1770 5750 379	1.31 1.81 0.944	
2319 2320 2321	4.01 7.60 7.58	252 225 229	2.58 1.58 1.60	3.79 859 861	437 850 852	95.3 189 202	0.670 1.29 1.29	
2322	7.59 7.52	292 291	44.6 34.9	6.90 3.78	83.5 106	8310 5330	3.27 2.87	116

TABLE A-II (continued)

			Other	Data				
Run	P _{SP} (MPa)	T _{SP} (°C)	Q (m ³ /s) X10 ⁻³	ρ _U (kg/m ³)	ρ _L (kg/m ³)	ρ _u ² (kg/ms ²)	m (kg/s)	ρ (κg/m ³)
2324 2325 2326 2327 2328 2329 2330 2331 2332 2333 2335 2336	7.60 7.53 7.60 7.62 7.57 7.58 7.56 7.56 7.56 7.56 7.53 7.53	292 291 291 292 292 292 291 316 316 316 291 291	14.8 7.34 4.9 2.60 14.9 31.5 51.0 55.6 37.5 18.8 4.3 4.8	3.33 7.36 32.5 4.26 3.66 3.26 4.88 3.30 4.19 3.46 32.8 20.0	240 340 418 430 158 106 43.7 41.6 29.8 42.1 469	1050 374 309 -83.8 836 3260 7840 6000 2700 500 192 262	2.09 1.72 1.60 0.667 1.26 1.95 2.64 1.96 1.30 0.658 1.46 1.57	196 300 336 133 44.1 34.4
2337 2338 2339 2340	0.324 0.462 0.438 0.375	147a 158a 156a 152a	***	65.5 56.5 194 39.2	308 339 508 259	2720 3140 3080 2690	4.09 3.56 3.46 1.82	

Amplifier gain on T-4 measurement set improperly. The data acquisition mode of time-averaging the temperature in engineering units, rather than the corresponding voltage, precludes proper correction because of the non-linear relation between voltage and temperature. Best estimate of T-4, obtained by interpolation between T-3 and T-9, is given.

b. One of the pins connecting a force transducer to the drag screen failed. Momentum values listed are not correct.

TABLE A-III

PRESSURE AND TEMPERATURE DATA

		Absolute	Pressure	es.			Temp	eratures		
Run Full Sca	P1 (MPa)	P3 (MPa)	P4 (MPa)	P5 (MPa)	(°C)	T2 (°C)	(_o C)	T4 (°C)	T6 (°C)	T9 (°C)
2209 2210 2211 2212 2213	4.58 4.71 5.78 5.76 5.81	3.97 4.11 4.07 4.04 4.08		4.02 4.16 4.12 4.09 4.12	279 280 303 302 301	237 232 246 243 250	251 253 252 252 252	251 250 253 252 253	249 251 251 250 251	249 251 251 250 251
2215 2216 2217 2218 2219 2220 2221	4.51 4.51 4.31 4.13 4.09 4.00 4.06	4.13 4.12 4.13 4.06 4.06 3.99 4.04		4.16 4.14 4.16 4.09 4.10 4.03 4.08	275 275 274 272 268 264 264	226 224 225 236 240 240 238	254 253 254 253 252 249 252	254 254 254 253 253 253 252 253	252 252 252 251 251 250 250	252 252 252 251 251 248 250
2223 2224 2225 2226 2227A 2227B 2228 2229 2230 2231	4.14 4.41 4.20 4.22 4.10 4.09 4.07 4.33 4.39 4.17	3.93 3.89 3.88 3.90 3.89 3.88 3.83 3.85 3.89 3.89	4.15 4.15 4.17 4.15 4.14 4.10 4.12 4.15 4.15	4.09 4.04 4.07 4.06 4.05 4.00 4.01 4.05 4.05	57 290 291 299 280 275 288 303 305 296	102 227 230 233 234 232 230 233 235 238	90 253 253 253 251 252 252 252 252 253 253	90 253 253 254 253 253 253 253 253 253	90 251 251 251 251 251 250 251 251 251	90 251 251 251 248 248 250 251 251

0:

5 00

		Absolute	Pressure	S			Temp	eratures		
Run	P1 (MPa)	P3 (MPa)	P4 (MPa)	P5 (MPa)	(°C)	T2 (°C)	T3 (°C)	T4 (°C)	T6 (°C)	T9 (°C)
ull Scal	e									
2233 2234 2235 2236 2237 2238 2239 2240 2241 2242A 2242B 2243 2244 2245 2246 2247	7.75 7.67 7.61 7.59 7.56 7.49 7.68 7.62 7.61 7.57 7.56 7.53 7.65 7.72 7.66 7.27	7.43 7.48 7.47 7.47 7.44 7.39 7.44 7.50 7.42 7.11 7.39 7.44 7.43 7.39 7.48	7.60 7.64 7.64 7.61 7.61 7.65 7.67 7.58 7.58 7.56 7.61 7.60 7.56 7.65	7.55 7.60 7.60 7.57 7.52 7.57 7.61 7.55 7.54 7.52 7.57 7.56 7.53 7.62	352 345 336 337 344 333 339 330 325 327 330 326 327 326 323 289	268 267 266 266 266 267 267 267 265 265 265 265 268 278 281	290 290 289 290 287 290 290 290 290 289 289 290 290 315 279	291 292 292 292 292 291 292 291 291 291	289 289 289 289 289 289 289 289 289 289	289 289 289 289 288 285 289 289 288 287 289 289 311
2249 2250 2251 2252 2253 2254 2255 2256 2257 2258	4.02 4.00 4.03 5.84 4.60 4.09 4.24 4.30 4.30 4.06	4.04 4.03 4.05 3.99 4.02 3.96 4.02 4.01 4.02 3.97	4.12 4.10 4.12 4.05 4.07 4.02 4.08 4.07 4.08 4.03	4.10 4.09 4.10 4.05 4.08 4.03 4.09 4.07 4.08 4.04	213 217 216 311 307 289 290 289 289 274	243 244 243 237 238 237 238 237 236 235	240 240 239 250 251 247 250 251 251 250	241 240 252 252 251 252 252 252 252 252	239 238 237 249 250 248 250 250 250 249	239 239 238 249 243 246 250 250 249

		Absolute	Pressure	25			Temp	peratures		
Run	P1	Р3	P4	P5	71	T2	T3	T4	T6	T9
	(MPa)	(MPa)	(MPa)	(MPa)	(°C)	(°C)	(00)	(°C)	(oc)	(°C)
Full Sca	le .									
2259	4.15	3.99	4.05	4.05	256	231	249	251	249	242
2260	4.25	4.01	4.07	4.08	263	231	250	252	250	244
2261	4.09	3.96	4.02	4.03	258	230	249	251	249	244
2262	4.64	3.94	3.99	4.00	267	230	250	251	249	249
2263	6.79	3.93	3.99	3.99	287	232	249	251	249	249
2264	4.02	4.04	4.10	4.11	251	235	229	234	227	227
2265	3.96	4.05	4.05	4.05	182	213	209	208 a	207	208
2266	4.61	4.00	4.00	3.99	295	217	251	250a	250	250
2267	4.59	4.01	4.01	4.00	295	215	251	250a	250	250
2268	4.58	4.03	4.03	4.02	296	214	251	250a	250	250
2269	4.11	4.01	4.01	4.00	294	218	251	2503	250	250
2270	4.53	3.99	3.98	3.97	297	217	250	250a		250
2271	4.55	3.98	3.98	3.97	295	219	250	250a		249
2272	4.01	4.04	4.0-	4.04	292	218	259	254a	. 60.00	250
2273	5.38	4.04	4.03	4.01	295	221	251	250 a		250
2274	8.21	7.58	7.56	7.54	331	273	290	289 a		289
2275	7.76	7.45	7.56	7.49	330	272	290	290a	200,000	289
2276	7.49	7.43	7.53	7.47	327	278	290	290a		289

		Absciute	Pressure	S			Temp	eratures		
Run	P1 (MPa)	P3 (MPa)	P4 (MPa)	P5 (MPa)	T1 (°C)	T2	T3 (°C)	T4 (°C)	T6 (°C)	T9 (°C)
ull Scale										
2277 2278 2279 2280 2281 2282 2283	7.48 7.46 7.71 7.54 7.39 8.18 7.46	7.51 7.45 7.39 7.50 7.42 7.46 7.51	7.62 7.56 7.49 7.60 7.52 7.56 7.62	7.56 7.50 7.44 7.54 7.46 7.47 7.56	322 322 332 328 321 332 314	276 277 275 276 276 279 278	290 290 290 290 292 292 290 274	287 a 289 a 289 a 290 a 290 a 290 a 273 a	288 289 289 289 288 289 271	284 288 288 289 288 289 273
2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298	0.503 0.917 0.547 0.565 0.660 0.875 0.631 0.483 0.494 0.419 0.612 0.486 0.854 0.680 1.090	0.443 0.350 0.391 0.348 0.353 0.362 0.384 0.339 0.392 0.219 0.421 0.367 0.377 0.371 0.388	0.444 0.353 0.393 0.352 0.356 0.365 0.343 0.396 0.324 0.424 0.371 0.379 0.375 0.391	0.447 0.295 0.392 0.342 0.338 0.336 0.379 0.339 0.397 0.322 0.424 0.371 0.360 0.372 0.376	134 260 197 179 190 194 191 177 173 164 179 180 205 191 203	140 139 136 135 134 136 139 135 136 137 138 139 140 130 122	139 150 153 150 150 151 153 149 153 148 156 152 152 170 177	139 150 154 151 151 152 154 150 154 148 156 152 153 153 161	138 150 153 150 150 151 153 149 153 147 155 152 152 157 165	138 145 152 148 148 152 148 151 146 155 151 150

		Absolute	Pressure	S			Tem	peratures		
Run	P1 (MPa)	P3 (MPa)	P4 (MPa)	P5 (MPa)	T1 (°C)	T2 (°C)	T3 (°C)	T4 (°C)	T6 (°C)	T9 (°C)
Full Scal		(Mr a)	(rir a)	(Inr a)	(0)	1.07	7.01	101	1.07	1
2299 2300 2301 2302	1.79 1.81 1.83 0.701	0.408 0.480 0.538 0.386	0.408 0.477 0.533 0.387	0.298 0.348 0.390 0.390	219 210 210 169	138 139 139 139	154 159 163 137	154 159 163 138	154 159 163 136	144 149 152 136
2303 2304 2305 2306 2307 2308 2309 2310A 2310B 2311 2312A 2312B 2313A	4.68 4.56 4.66 4.31 4.02 4.18 5.67 4.44 4.46 4.71 4.15 4.24	3.99 4.00 4.01 4.03 4.02 4.04 4.01 3.99 4.02 4.02 3.98 4.06 4.01	3.99 3.99 4.00 4.02 4.01 4.04 4.00 3.99 4.01 4.01 3.98 4.06 4.00	3.99 4.01 4.01 4.04 4.03 4.05 4.01 4.00 4.03 4.03 4.00 4.08 4.02	321 310 308 301 244 297 335 319 314 312 302 298	235 231 233 234 237 238 237 236 236 237 235 236	251 251 251 250 234 249 251 251 251 249 251 249 251	252 252 252 252 235 251 252 252 252 252 251 252 251 252 218	250 250 250 250 233 250 250 250 250 250 249 250 216	250 250 249 247 233 245 250 250 251 250 244 246 217
2313B 2314 2315 2316 2317	4.78 4.59 4.10 4.39	4.05 4.04 4.04 3.98 3.94	4.04 4.03 4.04 3.97 3.93	4.06 4.04 4.05 3.99 3.95	217 ^b 300 300 297 296	213 228 232 238 234	214 251 251 251 251 250	214 252 253 252 251	213 251 251 250 250	213 251 251 250 249

		Absolute	Pressure	5			Temp	eratures		
Run Full Scal	P1 e (MPa)	P3 (MPa)	P4 (MPa)	P5 (MPa)	T1 (°C)	(₀ C)	T3 (°C)	T4 (°C)	(°C)	T9 (°C)
2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330 2331 2332 2333 2335 2336	3.98 4.13 7.46 7.44 8.17 7.85 7.60 7.45 7.49 7.51 7.55 7.80 8.12 8.12 7.69 7.56 7.49 7.56	3.98 4.01 7.49 7.46 7.48 7.41 7.48 7.42 7.48 7.51 7.46 7.45 7.45 7.45 7.45 7.47 7.47	3.97 4.01 7.60 7.58 7.59 7.52 7.60 7.53 7.60 7.62 7.57 7.58 7.56 7.56 7.56 7.59 7.53 7.53	3.99 4.03 7.56 7.54 7.54 7.56 7.56 7.56 7.58 7.54 7.53 7.51 7.52 7.44 7.55 7.49 7.49	292 281 235 227 333 332 330 329 325 321 330 334 334 332 331 330 323 323	230 220 228 232 246 262 263 260 259 254 257 266 271 286 273 265 271 270	251 251 223 228 290 290 290 290 290 290 290 290 316 316 316 316 316 289 289	252 252 225 229 292 291 291 291 292 292 292 292 291 316 316 316 316 291 291	250 250 221 225 289 289 289 289 289 289 289 315 314 308 288 288	250 243 222 226 290 289 290 288 283 281 289 289 316 316 316 316 283 284
2337 2338 2339 2340	0.486 ^b 0.629 0.534 0.554	0.336 0.478 0.453 0.389	0.324 0.462 0.438 0.375	0.348 0.493 0.471 0.404	152b 205 188 203	150 149 152 151		147a 158a 156a 152a	147 159 157 152	147 158 156 152

Amplifier gain on T-4 measurement set improperly. The data acquisition mode of time-averaging the temperature, in engineering units, rather than the corresponding voltage, precludes proper correction because of the non-linear relation between voltage, and temperature. Best estimate of T-4, obtained by interpolation between T-3 and T-9, is given.

b. Two-phase condition in test section for this run achieved by mixing and throttling two water streams, not mixing steam and water streams. P-1, T-1, DP-1, DP-11, V_S , H_S , \dot{m}_S are second water stream measurements to mixing chamber.

TABLE A-IV

DIFFERENTIAL PRESSURE DATA

Run		DP1 (kPa)	DP2 (kPa)	DP3 (kPa)	DP4 (kPa)	DP5 (kPa)	DP6 (kPa)	DP7 (kPa)	DP10 (kPa)	DP11 (kPa)	DP12 (kPa)
Ful	1 Scale										
2209 2210 2211 2212 2213		31.6 31.6 31.7 31.7	3.38 6.23 8.28 2.70 31.1	1.33 1.43 3.63 3.14 5.04	4.34 4.71 11.5 10.1 14.3	5.94 6.40 15.5 13.6 19.7	0.59 0.59 2.02 1.93 2.21	5.44 5.85 15.5 13.7 19.7	1.54 1.51 4.04 3.74 4.45	48.2 48.0 118.0 120.0 119.0	1.92 4.81 6.89 1.25 30.2
2215 2216 2217 2218 2219 2220 2221		31.1 31.1 31.2 18.2 4.7 1.12 3.95	58.3 58.1 55.9 58.8 59.6 17.5 17.1	0.74 0.75 0.13 0.04 -0.08 -0.13	16.9 16.8 9.82 6.69 3.60 1.06 1.47	19.7 19.7 9.95 6.70 3.48 0.91 1.32	0.17 0.18 0.07 0.01 -0.10 -0.10	18.2 18.2 9.00 5.91 2.79 0.36 0.76	0.12 0.11 -0.13 -0.25 -0.27 -0.21	120.0 121.0 51.9 17.1 3.48 0.00 2.73	0.0 0.0 0.0 0.0 0.0 0.0
2223 2225 2225 2227 2227 2227 2228 2228 2230 2231	7A 7B 3	3.87 31.1 31.2 31.2 0.66 0.88 8.49 31.3 31.3	83.3 15.4 17.1 2 8 4.41 1.92 0.86 1.41 3.17 73.9	0.00 0.25 0.09 0.02 -0.11 -0.10 0.27 0.31 0.04	4.25 11.8 5.26 3.45 0.28 0.26 0.82 7.60 8.72 7.19	4.35 12.3 5.56 3.67 0.39 0.36 0.92 3.04 9.19 7.40	0.24 0.10 -0.10 -0.14 -0.18 -0.20 -0.09 -0.07 -0.06	3.82 11.0 4.48 2.65 -0.47 -0.50 -0.004 6.76 7.86 6.19	0.15 0.16 -0.02 0.05 -0.04 -0.04 -0.04 0.13 0.12 -0.23	2.68 101.0 33.7 34.7 0.00 0.00 7.68 89.6 94.4 17.6	0.0 0.0 0.0 0.0 0.0 0.0 0.0

Run	DP1 (kPa)	DP2 (kPa)	DP3 (kPa)	DP4 (kPa)	DP5 (kPa)	OP6 (kPa)	CP7 (kPa)	DP10 (kPa)	DP11 (kPa)	DP12 (kPa)
Full Scale 2233 2234 2235 2236 2237 2238 2239 2240 2241 2242A 2242B 2243 2244 2245 2246 2247	31.1 31.2 12.8 8.74 9.07 2.88 31.3 17.9 5.69 17.7 17.5 15.2 31.4 31.4 31.4	70.9 64.3 59.8 62.8 31.4 15.4 15.4 15.9 15.4 125.0 126.0 126.0 126.0 118.0 0.0 118.0	0.39 0.14 0.02 -0.04 -0.08 0.12 -0.06 -0.10 0.02 0.02 0.02 0.02 0.16 0.40 -0.01	3.52 1.79 0.82 3.26 0.52 0.16 1.75 0.73 0.24 1.32 1.14 1.02 2.47 4.24 0.37 0.31	3.85 1.81 0.67 3.02 0.24 -0.14 1.62 0.39 -0.16 0.96 0.78 0.66 2.25 4.26 -0.02 -0.11	-0.08 -0.13 -0.19 -0.20 -0.19 -0.19 -0.13 -0.17 -0.19 -0.14 -0.15 -0.15 -0.02 0.01 -0.37 -0.11	3.23 1.28 0.19 2.40 -0.18 -0.51 1.20 0.04 -0.48 0.66 0.49 0.38 2.00 3.93 -0.42 -0.25	0.09 -0.19 -0.27 0.27 -0.25 -0.23 -0.08 -0.19 -0.31 -0.32 -0.32 -0.19 0.10 -0.60 -0.11	72.9 30.4 11.8 7.72 8.07 1.92 49.8 17.1 4.75 16.9 16.6 14.4 38.3 61.6 61.5 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
2249 2250 2251 2252 2253 2254 2255 2256 2257 2258	0.0 0.0 0.0 28.7 13.2 3.21 5.45 31.3 31.4	86.9 75.0 6.50 71.0 67.8 67.6 66.7 69.4 20.3 16.6	0.05 -0.02 -0.05 0.34 0.07 -0.04 -0.03 0.94 0.54 0.09	2.41 0.67 0.19 3.61 1.64 0.63 0.80 7.58 5.14 2.05	2.38 0.58 0.06 3.75 1.48 0.31 0.46 8.17 5.34 1.81	-0.08 0.14 0.15 0.06 0.01 -0.06 -0.03 0.37 0.18 -0.06	1.84 0.14 0.40 3.32 1.15 0.01 0.19 7.79 4.97 1.43	0.03 -0.05 0.10 0.45 0.07 0.01 -0.01 1.14 0.76 0.15	0.0 0.0 0.0 27.8 12.1 2.06 4.30 104.0 103.0 32.5	0.0 0.0 0.0 0.0 0.0 0.0 0.0

Run		DP1 (kPa)	DP2 (kPa)	DP3 (kPa)	DP4 (kPa)	DP5 (kPa)	DP6 (kPa)	DP7 (kPa)	DP10 (kPa)	DPII (kPa)	DP12 (kPa)
Full	Scale										
2259 2260 2261 2262 2263 2264		2.54 3.75 2.04 24.4 31.4 0.0	16.3 17.7 3.34 3.55 4.04 116.0	-0.14 -0.19 -0.10 0.25 -0.18	0.24 0.32 0.13 1.14 3.06	-0.23 -0.17 -0.42 0.66 2.92 -0.60	-0.11 -0.13 -0.12 0.02 -0.14	-0.55 -0.47 -0.71 0.33 2.57 -0.89	-0.13 -0.07 -0.16 -0.02 0.42 -0.19	1.61 2.83 1.14 23.9 54.7 0.0	0.0 0.0 0.0 0.0 0.0
2265 2266 267 68 69 70 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282 2283		0.0 31.6 31.7 31.8 13.4 31.8 31.8 3.56 31.8 7.61 0.66 3.21 28.7 6.63 0.72 31.8 0.0	31.0 31.1 18.2 8.30 5.73 7.62 18.5 5.18 31.5 31.5 31.5 31.5 31.5 31.5 31.5 31.5	-0.03 2.05 1.50 1.26 0.21 1.23 1.47 -0.04 5.72 2.06 0.713 0.10 -0.12 -0.05 0.47 -0.01 -0.13 1.96 -0.10	0.05 9.75 6.00 4.84 1.87 4.75 5.97 0.57 16.0 7.70 4.60 1.92 0.37 1.01 3.23 3.81 0.69 17.1 0.45	-0.04 11.7 7.36 5.95 1.90 5.76 7.21 0.28 21.5 9.39 4.92 1.62 -0.15 0.56 3.31 3.40 0.18 40.3 -0.06	-0.11 0.66 0.59 0.53 -0.12 0.54 0.59 -0.21 1.81 0.65 0.122 -0.08 -0.15 -0.13 0.10 -0.17 -0.19 0.59 -0.18	-0.48 11.2 7.11 5.74 1.35 5.59 7.00 -0.23 21.5 9.10 4.44 1.16 0.56 0.12 2.92 2.74 -0.29 37.9 -0.49	-0.08 1.82 1.75 1.62 0.30 1.61 1.73 -0.05 4.14 2.24 1.11 0.54 0.26 0.35 1.00 0.41 0.23 2.19 0.25	0.48 53.5 51.4 49.2 13.9 49.1 50.7 4.06 109.0 66.6 29.0 8.43 1.50 4.03 29.9 7.44 1.53 64.4 0.80	97.7 92.4 17.0 7.02 4.49 6.37 17.3 3.90 97.3 95.3 95.2 96.3 96.1 96.6 22.5 21.8 21.9 83.1 95.3

Run	DP1 (kPa)	DP2 (kPa)	DP3 (kPa)	DP4 (kPa)	DP5 (kPa)	DP6 (kPa)	DP7 (kPa)	DP10 (kPa)	DP11 (kPa)	DP12 (kPa)
Full Scale										
2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302	0.0 31.2 21.8 31.3 31.4 31.4 20.8 7.45 6.65 31.3 12.8 31.4 31.4 31.4 31.4	102 88.5 88.0 84.9 81.7 20.6 19.6 22.9 17.6 10.2 1.82 4.05 4.12 0.0 0.0 3.14 19.1 75.7	0.08 4.03 0.03 0.41 1.05 2.48 0.62 0.14 -0.09 -0.05 0.16 -0.03 1.66 0.04 0.74 7.85 10.5 11.4 0.10	0.46 17.1 3.92 9.43 15.4 17.1 9.34 4.08 1.28 1.53 3.57 1.65 17.1 4.65 16.4 17.1 20.1 20.2 2.24	0.25 56.3 3.23 9.83 17.6 29.8 9.31 3.67 0.645 0.96 3.18 1.10 21.3 4.04 16.4 105 118 118 -0.73	0.03 1.03 -0.02 0.27 0.72 0.67 0.35 0.18 0.02 0.04 0.02 0.02 0.72 -0.09 0.32 2.48 2.54 3.24 0.05	0.15 51.9 3.25 9.67 17.3 28.6 9.19 3.70 0.71 1.02 3.08 1.13 20.8 3.85 15.8 52.1 95.6 95.8 1.76	0.06 1.88 0.07 1.45 0.91 1.28 0.57 0.34 -0.03 0.08 0.23 0.03 1.37 0.04 -0.46 4.36 5.64 6.73 0.03	0.00 118 21.7 38.2 62.8 109 48.3 20.6 7.02 6.21 36.1 12.4 109.0 68.5 160.0 246.0 246.0 246.0 0.0	0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0 0.0
2303 2304 2305 2306 2307 2308 2309	31.0 31.0 15.5 7.38 0.0 3.55 31.1	81.9 67. 66.0 66.1 121.0 63.8 17.6	1.44 0.43 0.44 0.25 0.05 0.15 0.62	7.92 3.27 1.60 0.65 0.44 0.45 4.81	10.56 4.87 3.18 2.01 1.57 1.64 6.41	0.37 0.09 0.00 -0.02 -0.04 -0.05 0.15	8.69 3.13 1.49 0.41 0.00 0.09 4.77	1.14 0.24 -0.01 -0.13 -0.11 -0.14 0.53	109.0 37.8 14.9 6.80 0.0 2.97 76.4	0.0 0.0 0.0 0.0 0.0

Run	DP1 (kPa)	DP2 (kPa)	DP3 (kPa)	DP4 (kPa)	DP5 (kPa)	DP6 (kPa)	DP7 (kPa)	DP10 (kPa)	DP11 (kPa)	DP12 (kPa)
Full Scale										
2310A 2310B 2311 2312A 2312B 2313A	26.6 26.2 11.1 2.89 3.12 0.01	17.6 17.1 17.2 17.5 17.1	-0.02 -0.05 -0.13 -0.13 -0.12 -0.20	1.88 1.81 0.93 0.26 0.28 -0.01	2.83 2.74 1.76 1.06 1.07 0.71	-0.05 -0.05 -0.06 -0.12 -0.14 -0.03	1.25 1.16 0.25 -0.45 -0.43 -0.69	-0.05 -0.07 -0.19 -0.30 -0.28 -0.27	26.3 25.8 10.5 2.25 2.47 0.03	0.0 0.0 0.0 0.0
2313B 2314 2315 2316 2317 2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330 2331 2332	31.5 31.6 13.0 28.8 3.75 0.38 0.0 0.0 31.6 31.6 9.23 2.85 1.27 0.43 7.79 26.4 31.7 31.7 25.7	30.8 31.0 20.5 22.5 23.4 17.0 14.5 31.2 31.2 31.2 31.2 31.2 31.2 31.2 31.2	0.37 4.15 2.17 0.40 -0.03 -0.14 -0.34 -0.06 2.63 1.75 0.33 0.10 0.10 -0.04 0.189 0.854 2.40 1.53 0.62	0.85 8.73 4.70 2.62 4.42 0.86 0.09 0.07 0.03 5.62 4.65 1.88 0.68 0.26 0.06 1.00 2.73 3.98 2.60 1.17	1.18 12.7 6.71 2.85 5.96 0.64 -0.26 0.56 -0.08 8.14 6.21 2.00 0.53 0.10 -0.25 0.91 3.31 6.10 3.84 1.49	0.06 0.88 0.51 -0.03 0.39 -0.15 -0.13 0.07 -0.05 0.67 0.26 -0.03 -0.07 -0.12 -0.14 -0.12 0.20 0.54 0.18 -0.23	0.94 12.6 6.60 2.49 5.81 0.31 -0.49 -0.62 -0.46 7.95 5.81 1.58 0.19 -0.25 -0.61 0.50 3.04 5.99 3.52 0.93	0.17 2.08 1.46 0.34 1.17 -0.08 -0.20 0.23 -0.13 1.35 0.84 0.13 -0.14 -0.17 -0.23 -0.04 0.46 1.35 0.19 -0.50	0.0a 57.6 44.7 13.5 37.1 4.25 0.96 0.63 0.63 56.2 36.5 9.91 3.52 1.96 1.13 8.47 27.4 56.4 56.6 26.7	96.8 98.6 19.1 21.1 22.0 15.7 13.1 80.4 80.1 86.1 89.9 89.8 87.9 88.5 10.3 14.3 20.3 25.0 0.0 0.0

									-	
Run	DP1	DP2	DP3	DP4	DP5	DP6	DP7	DP10	DP11	DP12
	(kPa)									
Full Scale										
2333	6.97	0.0	0.08	0.25	0.01	-0.43	-0.63	-0.88	7.68	0.0
2335	0.74	31.4	0.06	0.21	-0.03	-0.12	-0.39	-0.25	1.49	79.4
2336	0.93	31.4	0.09	0.26	0.04	-0.12	0.32	-0.23	1.69	91.2
2337	20.5ª	93.0	1.07	2.35	3.19	1.03	3.69	-0.17	21.3ª	=======================================
2338	23.5	92.8	0.73	1.55	2.01	0.39	2.02	-0.17	24.0	
2339	3.05	93.1	0.66	-0.16	0.21	0.06	0.04	-0.18	3.22	
2340	28.2	22.4	0.52	1.01	1.23	0.30	1.23	-0.18	28.5	

a. Two-phase condition in test section for this run achieved by mixing and throttling two water streams, not mixing steam and water streams. P-1, T-1, DP-1, DP-11, V_S , H_S , \dot{m}_S are second water stream measurements to mixing chamber.

TABLE A-V

MISCELLANEC IN-LINE-CALCULATED PARAMETERS

	Mixer Inlet						Spool Piece				
	V _s	H _s	V _w	H _W	m _s	m _w	V _{s4}	v_{w4}	T _{s4}	UBAR	
Run	$\frac{(m^3/kq)}{x10^{-3}}$	(J/g) X10 ³	$\frac{(m^3/kg)}{x10^{-3}}$	(J/g) X10 ³	(kg/s)	(kg/s)	$\frac{(m^3/kg)}{x10^{-3}}$	$\frac{(m^3/kg)}{x10^{-3}}$	(°C)	(m/s)	
2209 2210 2211 2212 2213	47.0 45.5 38.3 38.3 37.8	2.88 2.87 2.90 2.90 2.90	1.22 1.21 1.24 1.24 1.25	1.03 1.00 1.07 1.05 1.09	1.38 1.40 2.38 2.40 2.41	0.264 0.360 0.411 0.235 0.781		1.25 1.26 1.26 1.26 1.26	=======================================	9.85 9.47 17.4 17.8 17.5	
2215 2216 2217 2218 2219 2220 2221	47.2 47.3 49.8 51.9 51.9 52.5 51.4	2.86 2.87 2.87 2.86 2.85 2.85	1.20 1.20 1.20 1.22 1.23 1.23	0.973 0.965 0.966 1.02 1.04 1.04	0.854 0.856 0.549 0.315 0.162 0.0783 0.149	2.58 2.58 2.53 2.57 2.58 1.40 1.38		1.26 1.26 1.26 1.26 1.26 1.26 1.26		6.00 6.02 3.27 2.12 2.12 1.44 1.75	
2223 2224 2225 2226 2227A 2227B 2228 2229 2230 2231	51.0 54.3 55.3 53.8 53.1 55.7 54.1 53.7 55.6	2.92 2.93 2.95 2.90 2.88 2.92 2.96 2.96 2.95	1.04 1.20 1.21 1.21 1.22 1.21 1.21 1.21 1.21	0.427 0.979 0.991 1.01 0.999 0.992 1.00 1.01 1.03	0.00 0.756 0.425 0.427 0.0597 0.0693 0.211 0.691 0.712 0.307	3.30 1.33 1.39 0.560 0.522 0.466 0.313 0.399 0.598 2.88	48.0 48.1 47.9 48.0 48.2 48.7 48.5 48.0 48.0	1.04 1.26 1.26 1.26 1.26 1.26 1.26 1.26 1.26	253 253 252 253 253 252 252 252 253 253	0 36 6.43 0.80 0.77 2.33 2.41 1.39	

	Mixer Inlet						Spool Piece			
	V _s	H _s	V _w	H _w	₼ _s	mw	V _{s4}	v_{w4}	T _{s4}	UBAR
Run	(m^3/kg)	(J/q)	(m^3/kg)	(J/g)	(kg/s)	(kg/s)	(m^3/kg)	(m^3/kg)	(°C)_	(m/s)
	x10-3	X103	x10-3	X103			X10-3	X10-3		
2233	31.4	3.00	1.30	1.18	0.822	2.74	24.9	1.37	291	4.80
234	31.1	2.98	1.29	1.17	0.534	2.62	24.8	1.37	292	2.93
235	30.5	2.96	1.29	1.17	0.351	2.52	24.8	1.37	292	1.86
236	30.7	2.96	1.29	1.16	0.289	2.59	24.8	1.37	292	0.35
2237	31.5	2.98	1.29	1.16	0.290	1.83	24.9	1.37	291	1.54
2238	30.8	2.95	1.29	1.17	0.165	1.28	25.1	1.37	29	0.91
2239	30.5	2.96	1.29	1.17	0.690	1.28	24.9	1.37	29)	4.06
240	29.7	2.93	1.29	1.17	0.419	1.30	24.8	1.37	292	2.20
2241	29.2	2.91	1.29	1.17	0.238	1.28	24.7	1.37	292	1.19
242A	29.7	2.92	1.29	1.17	0.417	3.64	25.0	1.37	291	2.24
2242B	30.1	2.94	1.29	1.16	0.412	3.67	25.0	1.37	291	2.09
2243	29.8	2.92	1.29	1.16	0.336	3.68	25.1	1.37	291	1.99
2244	29.2	2.92	1.29	1.16	0.617	3.67	24.9	1.37	291	3.25
2245	28.8	2.91	1.33	1.23	0.789	3.50	24.9	1.37	291	4.97
2246	28.8	2.90			0.788	0.00	25.2	4 00	291	6.51
2247			1.34	1.24	0.0	3.49	**	1.33	292	1.32
2249			1.24	1.06	0.0	3.11		1.23	252	0.02
2250			1.24	1.06	0.0	1.67		1.23	252	0.02
2251			1.24	1.05	0.0	0.850		1.23	252	0.02
2252	38.8	2.93	1.22	1.02	0.457	2.82	49.3	1.25	251	4.31
2253	51.0	2.96	1.23	1.03	0.275	2.76	48.9	1.26	251	2.64
2254	55.6	2.93	1.22	1.02	0.130	2.76	49.5	1.25	251	1.54
2255	53.5	2.93	1.22	1.03	0.172	2.74	48.8	1.26	251	1.76
2256	52.4	2.92	1.22	1.02	0.755	2.79	49.0	1.26	251	7.54
2257	52.3	2.92	1.22	1.02	0.753	1.51	48.9	1.26	251	7.85 3.99
2258	53.3	2.88	1.22	1.01	0.420	1.37	19.6	1.25	251	3.9:

UT

	Mixer Inlet							Spool Piece			
	V _s	H _s	V _W	H _w	ħ_	₼ _W	V _{s4}	V _{w4}	T _{s4}	UBAR	
Run	$\frac{(m^3/kg)}{x10-3}$	(J/g) X10 ³	$\frac{(m^3/kg)}{x_{10}-3}$	(J/g) X10 ³	(kg/s)	(kg/s)	$\frac{(m^3/kg)}{x_{10}-3}$	$\frac{(m^3/kg)}{x_10-3}$	_(°C)_	(m/s)	
2259 2260 2261 2262 2263 2264	48.6 48.5 49.9 44.1 28.7 49.5	2.81 2.83 2.82 2.83 2.79 2.80	1.21 1.21 1.21 1.21 1.21 1.21	0.996 0.996 0.990 0.990 1.000 1.01	0.123 0.150 0.109 0.397 0.744	1.36 1.42 0.617 0.635 0.676	49.2 49.0 49.6 50.0 50.1 44.4	1.25 1.25 1.25 1.25 1.25 1.25	251 251 251 250 250 252	1.04 1.20 0.83 3.91 7.94 0.0	
2265 2266 2267 2268 2269 2270 2271 2272 2273 2274 2275 2276 2277 2278 2279 2280 2281 2282	49.2 49.5 49.7 56.1 50.4 50.0 57.3 40.8 27.2 29.0 30.1 29.6 29.7 29.6 29.9 30.0 27.3	2.93 2.93 2.93 2.94 2.93 2.94 2.90 2.92 2.93 2.91 2.91 2.94 2.93 2.91 2.94 2.93	1.18 1.18 1.18 1.18 1.19 1.19 1.19 1.31 1.31 1.32 1.32 1.32 1.32 1.32	0.913 0.929 0.921 0.915 0.936 0.932 0.938 0.935 0.948 1.20 1.20 1.23 1.22 1.22 1.22 1.22	0.0 1.42 1.39 1.36 0.667 1.34 1.37 0.340 2.22 2.14 1.37 0.687 0.202 0.446 1.37 0.644 0.212 2.09	1.45 1.40 0.624 0.422 0.350 0.493 0.628 0.332 1.44 1.36 1.36 1.36 1.36 0.659 0.646 0.648 1.26	50.0a 50.0a 50.0a 50.0a 50.0a 50.0a 46.7a 50.0a 26.0 25.5 25.5 26.8 26.0 25.5 25.5 25.5 25.5 25.5	1.17a 1.25a 1.25a 1.25a 1.25a 1.25a 1.25a 1.25a 1.25a 1.26a 1.25a 1.36 1.36 1.36 1.36 1.36 1.36 1.36 1.36	251 250 251 251 250 250 250 251 251 291 291 291 292 291 290 291 291	8.02 18.7 18.4 3.49 29.2 15.4 8.64 4.08 1.18 2.46 9.48 1.20 0.70 17.4	

		Mixer Inlet						Spool Piece			
		V _s	H _s	V _W	H _w	m _s	₩.	V _{s4}	V _{w4}	T _{s4}	UBAR
	Run	$\frac{(m^3/kg)}{X10^{-3}}$	(J/g) X10 ³	$\frac{(m^3/kg)}{x_{10}-3}$	(J/g) X10 ³	(kg/s)	(kg/s)	$\frac{(m^3/kg)}{x10-3}$	$\frac{(m^3/kg)}{x10^{-3}}$	_(°c)_	(m/s)
	2284 2285 2286 2287 2288 2289 2290 2291 2292 2293 2294 2295 2296 2297 2298 2299 2300 2301 2302	261 385 355 311 234 327 416 402 465 327 417 247 302 190 115 111 110 276	2.97 2.85 2.81 2.83 2.82 2.83 2.61 2.80 2.78 2.80 2.81 2.95 2.83 2.83 2.83 2.83 2.80 2.78	1.08 1.08 1.08 1.08 1.07 1.08 1.08 1.08 1.08 1.08 1.08 1.08 1.08	5.89 0.587 0.570 0.570 0.563 0.572 0.587 0.580 0.572 0.574 0.580 0.585 0.585 0.586 0.546 0.512 0.582 0.582 0.584 0.584	0.0 0.348 0.126 0.173 0.235 0.353 0.202 0.118 0.073 0.064 0.176 0.094 0.343 0.248 0.472 0.754 0.769 0.772	3.59 3.35 3.29 3.23 1.62 1.58 1.71 1.50 1.14 0.481 0.708 0.723 G.0 0.0 0.631 1.56 3.10 3.58	409 537 485 540 533 521 494 552 482 584 451 513 501 508 497 467 402 362 470	1.08 1.09 1.10 1.09 1.09 1.09 1.09 1.10 1.09 1.10 1.10	147 139 143 139 139 140 142 138 143 136 146 141 142 141 143 144 150 154 142	1.09 14.7 2.45 3.43 3.08 5.81 1.67 1.35 1.11 1.12 1.09 1.05 2.88 1.46 21.8 27.6 26.7 28.3 0.09
518 249	2303 2304 2305 2306 2307 2308	52.1 52.1 50.5 54.1 48.0 55.5	3.0 2.97 2.96 2.96 2.77 2.95	1.22 1.22 1.21 1.22 1.22 1.23	1.01 0.995 1.01 1.01 1.02 1.03	0.76 0.459 0.299 0.200 0.0 0.137	3.04 2.76 2.73 2.73 3.69 2.67	50.3 50.2 50.2 49.7 46.0 49.4	1.26 1.26 1.26 1.26 1.22 1.22	250 250 250 251 251 251	7.81 4.02 2.65 1.84 1.27 1.58

			Mixer Inlet				Spool Piece			
	V _s	H _s	V _w	H _w	m _s	m _w	V _{s4}	V _{w4}	T _{s4}	UBAR
Run	$\frac{(m^3/kg)}{x_{10}-3}$	(J/g) X10 ³	$\frac{(m^3/kg)}{x10^{-3}}$	(J/g) X10 ³	(kg/s)	(kg/s)	$\frac{(m^3/kg)}{x10^{-3}}$	$\frac{(m^3/kg)}{x_{10}-3}$	(°C)	(m/s)
2309 2310A 2310B 2311 2312A 2312B 2313A	43.4 55.0 54.1 50.5 56.7 54.9	3.01 3.00 2.99 2.97 2.96 2.95 2.90	1.22 1.22 1.22 1.22 1.22 1.22	1.02 1.02 1.02 1.02 1.01 1.02	0.715 0.373 0.373 0.254 0.122 0.129	1.41 1.41 1.39 1.39 1.40 1.39	50.1 50.3 49.9 50.0 50.3 49.3 40.7	1.26 1.26 1.26 1.26 1.26 1.26 1.26	250 250 251 251 250 251 250	7.97 3.77 3.66 2.33 1.18 1.22
2313B 2314 2315 2316 2317 2318 2319 2320 2321 2322 2323 2324 2325 2326 2327 2328 2329 2330	1.19b 47.8 50.2 56.7 52.7 57.9 53.6 27.5 28.9 29.8 30.5 29.9 29.4 30.1 29.3 27.8	0.931b 2.93 2.94 2.95 2.94 2.99 2.93 2.93 2.93 2.93 2.93 2.92 2.90 2.94 2.94 2.93	1.18 1.21 1.23 1.23 1.21 1.19 1.20 1.24 1.28 1.28 1.27 1.27 1.26 1.27	0.910 0.983 1.00 1.03 1.01 0.993 0.946 0.981 1.00 1.07 1.14 1.15 1.13 1.13 1.11 1.12 1.16 1.19	3.55b 1.49 1.29 0.654 1.14 0.347 0.115 0.000 0.000 1.95 1.54 0.760 0.418 0.276 0.165 0.695 1.32 1.94	1.44 1.44 0.634 0.660 0.675 0.597 0.555 1.29 1.32 1.33 1.33 1.31 1.33 0.502 0.567 0.632 0.697	38.0 49.7 49.7 50.5 51.1 50.5 50.0 25.3 25.0 25.2 24.9 24.9 24.9 25.1 25.1	1.18 1.26 1.26 1.26 1.26 1.26 1.20 1.37 1.37 1.37 1.37 1.37	251 251 251 250 249 250 250 291 291 291 291 291 291 291 291 291 291	1.63 18.7 17.3 7.65 15.3 3.51 0.74 0.45 0.45 12.8 10.0 4.24 2.10 1.34 0.74 4.27 9.01 14.6

UT

a. Amplifier gain on T-4 measurement set improperly. The data acquisition mode of time-averaging the temperature, in engineering units, rather than corresponding voltage, precludes proper correction because of the non-linear relation between voltage and temperature. Best estimate of T-4, obtained by interpolation between T-3 and T-9, is given.

b. Two-phase condition in test section for this run achieved by mixing and throttling two water streams, not mixing steam and water streams. P-1, T-1, DP-1, DP-11, V_S , H_S , \dot{m}_S are second water stream measurements to mixing chamber.

APPENDIX B

DATA REDUCTION EQUATIONS

APPENDIX B

GDATA

The essential function of GDATA is to fetch a digital signal from the ADC, convert to proper set of English units, and execute a series of FSEUDO (P-channel) calculations. The first option executed in GDATA is the number of ADC (channels are 16 per card) that are being utilized. A maximum of 48 channels (3 cards) are utilized in GDATA; 1 to 3 cards can be active at any one time. The system operates faster if a minimum number of cards are activated, since fewer subroutine calls to fetch the digital words have to be executed. The equations used in GDATA are found in this Appendix. GDATA inputs all ADC channels, but only those that are activated are converted to proper units, and only those P-channels that are activated are exectued. The output data from GDATA is in proper English units. Material in this appendix is abstracted from Reference 4.

APPENDIX B

EQUATIONS USED TO GENERATE PSEUDO CHANNELS

Equation number	Parameter	Equation
1.	Specific Volume	See enclosed Steam Table Algorithms
2.	Mass Flow Rate Steam	$MS = 1890*CDS*F*DT^2*FA*YA*SQRT(D1/VS)$
		CDS = Steam Orifice Discharge Coefficient
		VS = Specific Volume Steam
		P1 = Sterm Orifice Input Pressure
		D1 = Steam Orifice Pressure Drop
		YA = 0.684615 - 0.269238 ⁴ + D1/P1
		B = DTS/DPS
		DTS = Throat Diameter Steam (Orifice)
		DPS = Pipe Internal Diameter, Steam
		FA = ^^ + A1*T1
		$F = 1/SQRT (1 - B^4)$
3.	Mass low	MW (or MO) = $1390 \times CD \times DT^2 \times F \times FA \times SQRT$ (D@/VW)

Rate Water D@ = D2 for water

D@ = D20 for output

CD = CDW for water - Orifice Discharge Coefficient

CD = CDO for output

FA = BO + B1*T1 for water

FA = CO : C1*T1 for output

DT = DTW for water Throat Diameter (Orifice)

DT = DTO for output

DP = DPW water internal Diameter

= DPO output internal Diameter

EQUATIONS USED TO GENERATE PSEUDO CHANNELS (Continued)

Equation number	Parameter	Equation
		B = DT/DF
		$F = 1/SQRT (1 - B^4)$
		VW = VW specific volume water
		= VO specific volume output
4.	MOM FLX	MOM FLX = F1 + F2 + F3
5.	VMS4	$VMS = VS4*MS^2$
6.	VMW4	$VMW4 = VW4*MW^2$
7.	RHOBAR	RHOBAR = CS1*R1 + CS2*R2
		CS1, CS2 Flow Regime Constants.

Equation number	Parameter	Equation
8.	UBAR	UBAR = 01/A; A = Area of Test Section = π *DTEST ² /4*144
9.	M.D+T	M.D+T = RHOBAR*Q1
10.	M.D+DS	M.D+DS = A*SQRT (RHOBAF*MOM FLX); A = Area of T/S
11.	M.D+DD	M.D+DD = A*SQRT (RHOBAR*F6)
12.	M.T+DS	M.T+DS = A*MOM FLX/UBAR
13.	M.T+DD	M.T+DD = A*F6/UBAR
14.a	r. obar	RHOBAR = C11*R4+C12*R5+CL3*R6
		C11, C12, C13 Flow Regime Constants (two sets)
15.	URAR	UBAR = Q4/A; A = Area of Test Section
18.	M.D+T	M.D+T = RHOBAR*4
17.	M.D+DD	M.D+DD = A*SORT (RHOBAR*F5)
18.	M.T+DD	M.T+DD = A*F5/UBAR
19.	VMS	VMS = VST/S*MS ²
20.	VMW	VMW = VWT/S*MW2

a. Equations 14 through 20 refer to the LOFT Test Program.

OUTPUT CONVERSION METHOD

P-(Channel	Parameter	To Convert from	to	Multinly By
	1.	Pressure	PSI	KP	6.894757
	2.	Force	Lb _m /ft-sec ²	kg/m-sec ²	1.488156
	3.	Volume flow	ft ³ /s	m^3/s	0.028316
	4.	Temperature	F	C	5/9 (F-32)
	5	Density	$\mathrm{Lb_{m}/ft^{3}}$	kg/m ³	16.01346
	6.	Volts	volts	volts	1
Р	CHANNEL				
	49-52	TSAT	F	C	5/9 (F-32)
	53	VS	ft ³ /1b _m	m ³ /kg	x/16.01846
	54	HS	Btu/1b m	J/gm	2 326
	55	VW	ft ³ /1bm	m^3/kg	16.01846
	56	HW	Btu/1b m	J/gm	2 326
	57	VU	same as 53		
	58	H0	same as 54		
	59	MS	lb _m /hr	kg/s	0.0001259979
	60	MW	same as 59		
	61	MO	same as 59		
	62	VS4	same as 53		
	63	HS4	same as 54		
	64	MOM FLX	1b _m /ft-sec ²	kg/m-sec ²	1.488156
0	65	VMS4	lb _m ft ³ /hr ²	m ³ kg/sec ²	9.9107718E-1
	66	VMW4	same as 65		
	67	RHOBAR	1b _m /ft ³	kg/m ³	16.01846
	68	UBAR	ft/s	m/s 518	0.3048
			101		200

OUTPUT CONVERSION METHOD (Continued)

P CHANNEL	Parameter	To Convert from	to	Multiply By
69	M.D+T	1b _m /s	kg/s	0.4535924
70	MD.+DS	same as 69		
71	M.D+DD	same as 69		
72	M.T+DS	same as 69		
73	M.T+DD	same as 69		
74a	T10Sat	F	С	5/9 (F-32)
75	RHOBAR	same as 67		
76	UBAR	same as 68		
77	M.D+T	1b _m /s	kg/s	0.4535924
78	M.D+DD	same as 77		
79	M. T+DD	same as 77		
80	VST/S	same as 53		
81	VWT/S	same as 54		
82	VMS	same as 65		
83	VMW	same as 66		

a. Channels 74 through 83 refer to LOFT Test Program

STEAM TABLE ALGORITHMS

Subroutine Prop (TW, PW, TS, PS VW, HW, VS, HS)

If (PS-PW) 2, 1, 2

1 X = ALOG (PW)

TW = 69.372 + 82.3946*X - 28.72115*X**2 + 10.81333*X**3 - 2.130566*X**4 + 0.252783*X**5 - 0.0159195*X**6 + 0.00042256*X**7

TS = TW

2 Y = TW/100.0

VW = 0.001*(16.1844 - 0.717679*Y + 0.99268*Y**2 - 0.443779*Y**3 + 0.122204* **4 - 0.01712667*Y**5 + 0.001000533*Y**6)

HW = 32.4756 + 101.8866*Y - 2.19336*Y**2 + 0.972783*Y**3 - 0.172796*Y**4 + 0.016753*Y**5

P = PS/14.696

TAU = 1.0/(TS-32.0)*5.0/9.0 + 273.16)

ALPHA = 2641.62*10.0**(80870.0*TAU**2)

BETA = 2.3025809*\$0870.0*TAU**2

BØ = 1.89 - TAU*ALPHA

GAMMA = ALPHA*(1.0+2.0*BETA)

DELTA = 82.546 - 162460.0*TAU

EPSIL = 0.21828 - 126970.0 TAU**2

RHO = 0.0003635 - 6.768E-8*(1000.0*TAU)**24

A1UM1 = P**2*((BØ*TAU)**2*(4.0*DELTA-82.546) - 2.0*DELTA*TAU**3*BØ*GAMMA)/2.0

A2UM2 = (TAU*P)**4*(BØ**4*(3.0*EPSIL - 0.21828)/TAU - 2.0*EPSIL*BØ**3*GAMMA)/2.0

A3UM3 = (TAU*P)**13*(Bp**13*(27.0*RHO-0.008724)/TAU - 13.0*RHO*Bp**12*GAMMA)/13.0

VS = 0.0160185*(4.55504/(TAU*P) + BØ + BØ**2*TAU**2*P*DELTA + BØ**4* (TAU*P)**3*EPSIL - BØ**13*(TAU*P)**12*RHO)

HS - 0.43*(0.101325*/P*(1.69-2.0*TAU*ALPHA*(1.0+BETA)) + A1UM1 + A2UM2 - A3UM3) + (1.472/TAU + 0.00037783/TAU**2 - 47.836*ALOG (TAU) + 1803.7))

GDATA CALCULATIONS

FUNCTION	EQUATION	UNITS
1.	P of D = A + BX, X = Input	Pressure psi
2.	F = A + BX	Lbm/ft-s ²
3.	Q = A + BX	ft ³ /s
4.	$T = A + BX + CX^2 + DX^3$	or
5.	$T5 = 50 + 5000/A - SQRT((50+5000/A)^2 - ((1000/(A*B))*(X/(C*D) -1)))$	oF
6.	$R = A \star LN(B/(X - C)$	Lb _m /ft ³
7.	Z = X	volts

CHANNEL	FTN STMT	NAME		EQ#	INPUT
49	10	TISAT	Saturation Temperature T1	1	P1
50	10	TZSAT	Saturation Temperature T2	1	P2
51	10	T3SAT	Saturation Temperature T3	1	Р3
52	10	T4SAT	Saturation Temperature T4	1	P4
53	11	VS	Specific Volume Steam		T1,P1
54	11	HS	Enthalpy Steam	1	T2,P1
55	12	VW	Specific Volume Water	1	TZ
56	12	HW	Enthalpy Steam	1	T2
57	12	VO	Specific Volume Output	1	T20
58	12	НО	Enthalpy Steam	1	T20
59	13	MS	Mass Flow Rate Steam	2	D1,P1,T1,VS
60	14	MW	Mass Flow Rate Water	2	D2,T2,VW
61	18	МО	Mass Flow Rate Output	2	D20,T20,VW

CHANNEL	FTN STMT	NAME	EQ#	INPUT
62	15	VS4 Specific Volume T/S Steam	1	T4,P4
63	16	VW4 Specific Volume T/S Water	1	T4
64	17	MOMFLX Momentum Flux	3	F1,F2,F3
65	19	VMS4	4	VS4, 4S
66	20	VMW4	5	VW4,MW
67	21	RHOBAR Density	6	R1,R2
68	22	UBAR Velocity	7	Q1
69	23	M.D+T Mass Flow Rate Densitometer + Turbine Meter	8	RHOBAR,Q1
70	24	M.D+DS Mass Flow Rate Densitometer + Drag Screen	9	RHOBAR, MOM
71	25	M.D+DD Mass Flow Rate Densitometer + Drag Disk	10	RHOBAR,F6
72	26	M.T+DS Mass Flow Rate Turbine Meter + Drag Screen	11	UBAR, MOM FLX
73	27	M.T+DD Mass Flow Rate Drag Disk + Turbine Meter	12	F6,UBAR
74ª	10	T10SAT T10 Temperature Saturation	1	P7

CHANNEL	FTN STMT	NAME	EQ#	INPUT
75	28	RHOBAR Density	13	P4,R5,R6
76	29	UBAR Velocity	14	Q4
77	30	M.D+DD Mass Flow Rate Densitometer + Turbine Meter	15	RHOBAR,Q1
78	31	M.D+DD Mass Flow Rate Densitometer + Drag Disk	16	RHOBAR,F5
79	32	M.T+DD Mass Flow Rate Turbine + Drag Disk	17	R5,UBAR
80	33	VST/S Specific Volume T/S Steam	1	T10,P7
81	34	VWT/S Specific Volume T/S Water	1	T10
82	35	VMS	18	VST/S,MS
83	36	VMW	19	VWT/S,MW

a. Equations 74 through 83 refer to the LOFT Program Test Channels.

APPENDIX C
DATA VALIDATION ROUTINES

PDATA

Following are the calculations that PDATA performs: $^{\rm a}$

- I. Mass Flow Rates:
 - If a mixing run is occurring, then the actual steam mass flow rate, MS, is subtracted from the specified mass flow rate steam (SMFRS) and printed out first;

SMFRS-ACTUAL = ____.

- 2. All run types perform the difference between specified mass flow rate water SMFRW and actual mass flow rate water MW, SMFRW-ACTUAL = _____.
- II. Pressure and Temperature Checks:
 - 1. Difference between specified pressure 4 SP4 and actual P4 for all run types SP4 PC =
 - 2. If the run type is Throttling, Cal Water, or Cal Steam then:
 - a. Difference between specified ressure 3 SP3 and actual P3; SP3 P3 =
 - b. Difference between specified temperature 3 ST3 and actual; T3 ST3 T3 = _____.
- III. Mass Balance Check:
 - 1. If no* a mixing run:
 Mass Water Mass out = _____ (MASS IN MASS OUT)

518 284

a. Material in this appendix is abstracted from Reference 4.

PDATA (Continued)

- 2. If mixing run then:
 Mass Steam + Mass Water Mass out = _____.
- IV. Energy Calance Checks:
 - 1. If mixing run, then Energy In = Energy Steam + Energy Water.
 - 2. If non-mixing run, then Energy In = Energy Water.
 Energy In Energy Out = _____.

CDATA

The following calculations are made in CDATA.

I. Saturation Checks:

 For Semiscale, saturation temperatures for P1, P3, P4, and P5 are determined. Each saturation temperature is determined from steam table calculations using Pi.

Each saturation temperature is compared to actual temperature: TiSAT - Ti = ____.

T1 should always be greater than T1SAT.

T2 should always be lower than T2SAT.

For LOF1 saturation temperatures T1, T2, and T10 are calculated.

II. Pressure Checks:

This is done only for Semiscale. Essentially these checks should be close to zero as they are independent checks on the pressure gauges, both absolute and differential.

III. Drag Body Constants:

These checks are made only during a water or steam calibration run. Each drag body constant is determined from the following equation:

$$K = A*32.16*F/(V_{T/S}M^2)$$

A = Area of Test section

F = MOM F1X if Drag Screen . present

= F6 if drag disk of Semi_cale is present

= F5 if drag disk of LOFT is present

 $V_{T/S}$ = Specific volume at test section of LOFT or Semiscale

CDATA (Continued)

- = VW specific volume water for Cal water
- = VS specific volume steam for Cal steam
- M = MS mass flow rate steam if Cal steam
 - = MW mass flow rate water if Cal water

IV. Mass Flow Rate Checks

Three independent mass flow rates are determined and compared to the sum of mass flow rates of water and steam (input quantities).

The three checks are:

- Mass flow rate using densitometer plus drag disk (or screen)
 M.D+DD (M.D+DS).
- Mass flow rate using turbine meter plus drag disk (or screen) M.i+DD (M.T+DS).
- 3. Itass flow rate using densitometer plus turbine meter M.D+T. See Appendix B for each calculation of these mass flow rates. In each case these mass flow rates are subtracted from the sum of the mass flow rate water and steam. This difference is printed.

V. Turbine Checks

Each turbine meter is checked with the following calculation:

M = Q*3600/VT/S = ...

M1 = MW mass flow rate water; = MS mass flow rate steam.

 $Q = flow rate, ft^3/s$

= Q1 Semiscale

= 04 LOFT

CDATA (Continued)

VT/S = Specific volume water or steam at the test section.

- = Specific volume water if cal water.
- = Specific volume steam if cal steam.

VI. Densitometer Checks

The densitometers are checked by the following:

1/V - R =

- V = Specific volume at test section, water if Cal water, steam if Cal steam.
- R = Densitometer reading.
 For Semiscale, two values of R are used, R1 and R2; for LOFT, three R readings are used, R4, R5, R6.

VII. Differential Pressure Checks

Each differential pressure gauge is checked with the following:

 $D*3.5708E6*DTEST^4/V_{T/S}M^2 = ____.$

D = Differential Pressure Guage, all values except D1, D2, and D20 DTEST = Diameter of test section

V_{T/S} = Specific volume at test section; steam for Cal steam, water for Cal water.

M = Mass flow rate; MS for Cal steam, MW for Cal water.

The above equation should be constant.

SDATA

The function of this subroutine is to print out the current values of P3, mass flow rate steam MS, and mass flow rate water MW. SDATA continues to print out these values until the switch register SW is changed (in any bit position). Upon changing SW, SDATA returns to the main program. At this point the operator can obtain more data, through calling GDATA, print out current values, of all channels, or call other subroutires.

SDATA changes the number of samples to 100 and the delay to zero. Upon returning to the main program, the number of samples and delay are restored to the original value as determined by the header HDR. When SDATA fetches data from GDATA, it obtains new values for $\underline{\text{all}}$ active channels, including P-channels.