NRC FORM 366 (7-77)

LICENSEE EVENT REPORT

(PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

CONTROL BLOCK: (1)

01 | CTMNS2 (2) | 00-000-000 (3) | 4 LICENSE TYPE | CAT (5)

LICENSEE CODE — LICENSE NUMBER

CON'T 01 | REPORT SOURCE L (6) | 05000377 (7) DOCKET NUMBER | 062779 EVENT DATE (8) | 072799 REPORT DATE (9)

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 At the completion of a surveillance test per T.S. 4.8.1.1.2.a.2, the output breaker
03 for the 12U Emergency Diesel Generator could not be opened remotely from the Control
04 Room; the breaker was manually tripped from the local station at the switchgear. Per
05 T.S. 3.8.1.1 action statement a, D/G 12U was declared inoperable and the remaining
06 AC sources were verified operable. The breaker is a G.E. Magna-blast, Model AM-4.16-
07 250-8 with a ML-13 Mechanism.
08

09 SYSTEM CODE EE (11) | CAUSE CODE E (12) | CAUSE SUBCODE A (13) | COMPONENT CODE CKTBRK (14) | COMP. SUBCODE A (15) | VALVE SUBCODE Z (16)

LER/RO REPORT NUMBER (17): EVENT YEAR 79 | SEQUENTIAL REPORT NO. 019 | OCCURRENCE CODE 03 | REPORT TYPE L | REVISION NO. 0

ACTION TAKEN B (18) | FUTURE ACTION Z (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER A (25) | COMPONENT MANUFACTURER G080 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 A loose wire connection was found in series with the trip coil of the breaker. The
11 termination was tightened and the breaker was functionally tested satisfactorily. The
12 engine was started and its operability verified. The diesel was out of service
13 approximately 4 hours.
14

15 FACILITY STATUS E (28) | % POWER 100 (29) | OTHER STATUS (30) N/A | METHOD OF DISCOVERY B (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) N/A | LOCATION OF RELEASE (36) N/A

PERSONNEL EXPOSURES: NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) N/A

17

PERSONNEL INJURIES: NUMBER 000 (40) | DESCRIPTION (41) N/A

18

LOSS OF OR DAMAGE TO FACILITY (43): TYPE Z (42) | DESCRIPTION N/A

19

PUBLICITY: ISSUED N (44) | DESCRIPTION (45) N/A

20

NRC USE ONLY

7908030300 4

POOR ORIGINAL

481 201

203-447-1791