

TRANSCRIPT OF PROCEEDINGS

PRESIDENT'S COMMISSION ON THE ACCIDENT AT THREE MILE ISLAND

PUBLIC HEARING

WEDNESDAY,  
JULY 18, 1979

Additional copies of this report are available from:  
OMEGA T.M.I.  
5119 Lee Highway  
Arlington, Va. 22207  
703-241-0850

486 047

7908030392

1 PRESIDENT'S COMMISSION ON THE ACCIDENT AT THREE MILE ISLAND

2  
3 PUBLIC HEARING

4 Wednesday,  
5 July 13, 1979

6 Hall of Nations  
7 Edmund Walsh Building  
8 Georgetown University  
9 36th Street, N.W.  
10 Washington, D.C.

11 The hearing was convened pursuant to notice at 10:05 a.m.  
12 John G. Kemeny, Chairman, presiding.

13 PARTICIPANTS:

14 John G. Kemeny  
15 President of Dartmouth College

16 Bruce Babbitt  
17 Governor of Arizona

18 Patrick E. Haggerty  
19 Retired President of Texas Instruments

20 Carolyn Lewis  
21 Associate Professor of Journalism  
22 Graduate School of Journalism,  
23 Columbia University

24 Paul E. Marks  
25 Vice President for Health Sciences  
Columbia University

Cora B. Marrett  
Associate Professor of Sociology  
University of Wisconsin

Lloyd McBride  
President of United Steelworkers of America



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

PARTICIPANTS: (continued)

Harry McPherson  
Attorney

Russell Peterson  
President of Audubon Society

Thomas Pigford  
Professor and Chairman  
Department of Nuclear Engineering  
University of California at Berkeley

Theodore Taylor  
Professor of Aerospace and Mechanical Science  
Princeton University

Anne Trunk  
Resident of Middletown, Pennsylvania

STAFF:

Stanley Gorinson  
Kevin Kane  
Win Rockwell  
Barbara Jorgenson

Bowers Reporting Company

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

I N D E X

Page

Opening Statement by: John G. Kemeny	1
Witness - Joseph John Kelly, Jr.	2
Exhibit No. 1 (Customer Guidance on High Pressure Injection Operation)	13
Exhibit No. 2 (Letter from J. F. Walters to J.J. Kelly)	19
Witness - Bert Merit Dunn	53
Exhibit No. 3 (Memo from Bert Dunn to Jim Taylor)	61
Exhibit No. 4 (Memo from Bert Dunn to Jim Taylor)	71
Exhibit No. 5 (Memo from D.F. Hallman to B. A. Karrasch)	75
Exhibit No. 6 & 7 (Notifications by Babcock & Wilcox)	80
Exhibit No. 8 (J. T. Willse, Licensing to the distribution)	83
Exhibit No. 9 (Michelson Story Comments)	90
Witness - James M. Walters	145

Bowers Reporting Company

DO  
TMI  
7-18-79

P R O C E E D I N G S

CHAIRMAN KEMENY: Will the meeting please come to order.

I am happy to see that all members of the Presidential Commission are present and this is the opening of the fourth set of public hearings by the Presidential Commission. A fifth and sixth sets of hearings will occur in August and the dates of those have already been announced.

What we will be trying to do in these three sets of hearings is to present the connected pieces of evidence on various subjects and, therefore, have fairly homogenous groupings. We will try at each hearing to have one, two or three major topics brought out that relate to groups of individuals.

The order of the three hearings is somewhat accidental and it is an accident that we happen to have witnesses from a single company at this particular hearing.

This week, the three half days of hearings will deal with the witnesses from the Babcock and Wilcox Company.

As you will recall at our last open hearings, we had a number of witnesses from the managing utility. Babcock and Wilcox are the vendors of the nuclear steam system for TMI-2 and they played a role in the training of operators.

We expect to hear witnesses today, tomorrow and the day after tomorrow roughly from 10 to 2:00 A. M. Unlike our -- sorry. I guess I am thinking of some previous hearings of

Bowers Reporting Company

1 this commission. We are planning it from 10 to 2:00 P. M., but  
2 if we go as we did at one previous hearing, maybe 10 to 2:00  
3 A. M. is a better prediction.

4 Unlike our previous hearings, all the witnesses  
5 have been deposed by our legal staff and we will turn to our  
6 legal staff in each case to bring out the highlights of those  
7 depositions.

8 Will chief counsel please swear in the first witness?

9 MR. GORINSON: Mr. Kelly, will you raise your right  
10 arm, please?

11 Do you solemnly swear that the testimony that you  
12 are about to give is the truth, the whole truth and nothing  
13 but the truth, so help you God?

14 MR. KELLY: I do.

15 CHAIRMAN KEMENY: Will you please state for the  
16 record your full name and your position within the company?

17 MR. KELLY: My name is Joseph John Kelly, Jr. I am  
18 in the Plant Integration Unit of Babcock and Wilcox Company.

19 CHAIRMAN KEMENY: Thank you.

20 Chief counsel.

21 MR. GORINSON: Thank you, Mr. Chairman.

22 Mr. Kelly, the Plant Integration Unit is part of  
23 the Design Section. Is that correct?

24 MR. KELLY: That is correct.

25 MR. GORINSON: And that Design Section is also part

1 of the Engineering Department at Babcock and Wilcox.

2 MR. KELLY: Correct.

3 MR. GORINSON: Could you please explain for the  
4 Commission what the responsibilities of the Plant Integration  
5 Unit are?

6 MR. KELLY: We are given various assignments to make  
7 sure that the interfaces between various disciplines and set  
8 portions of the design -- we integrate the interfaces to make  
9 sure that when the pieces are put together that they will fit.

10 MR. GORINSON: So, that is where it all comes to-  
11 gether, in the Plant Integration Unit. Is that correct?

12 MR. KELLY: Yes.

13 MR. GORINSON: Could you explain your responsibilities  
14 as principal engineer, sir?

15 MR. KELLY: I am in a subgroup of the Plant Integra-  
16 tion Unit, the Nuclear Steam Supply Systems Design Group. As  
17 a member of that group, I take assignments as issued by my  
18 supervisor.

19 MR. GORINSON: And who is your supervisor, sir?

20 MR. KELLY: Mr. Eric Swanson.

21 MR. GORINSON: Did you become aware during 1977 of  
22 the transient that took place at the Davis-Besse plant on  
23 September 24, 1977?

24 MR. KELLY: Yes.

25 MR. GORINSON: And when did you become aware of that?

1 MR. KELLY: I believe it was the day of the transient  
2 on the 24th.

3 MR. GORINSON: Could you briefly describe that tran-  
4 sient for us?

5 MR. KELLY: Davis-Besse was at a low power level.  
6 The reactor was critical. They were dumping steam to the main  
7 condenser. The turbine was not on the line. They were about  
8 7, 9 percent reactor power. When their steam and feedwater  
9 rupture control system apparently sent an erroneous signal to  
10 the starter feedwater valve, the valve went shut. When the  
11 valve went shut, the one generator lost feedwater. The level  
12 started to boil down. When the level got low enough, it  
13 triggered, again, their steam and rupture control system to  
14 shut the main steam isolation valves and main feedwater isola-  
15 tion valves and that resulted in a complete loss of feedwater.  
16 Pressure escalated and went up in the reactor coolant system.  
17 Pressure on the level went up in the reactor coolant system.  
18 Before they reached the high pressure trip point, the operator  
19 manually tripped the reactor.

20 They did, during that pressure increase, lift the  
21 electromatic relief valve that reached a set point. After the  
22 reactor trip, pressure started downward. The electromatic  
23 relief valve did not seat due to some -- or stuck open some-  
24 where along the line and the pressure continued to decrease.  
25 They got down to the actuation set point of their safety

1 engineering system. It actuated and started high pressure  
2 injection. Pressurizer levels started to go up. Primary pres-  
3 sure was still going down. The operator throttled back on  
4 high pressure injection when the pressurizer level was going  
5 up.

6 In a period of about twenty minutes from when the  
7 reactor tripped, the incident started, they recognized that  
8 the electromatic relief valve had stuck open. They shut the  
9 electromatic relief valve, block valve, and stopped that loss  
10 of inventory from the reactor coolant system.

11 After another period of time, I believe, it must  
12 have been thirty minutes, pressurizer levels started to go  
13 down again.

14 As a result of my investigation of that incident,  
15 I saw that during that period the pressure had gone down to  
16 saturation and you had boiling in your reactor coolant loops  
17 and that had caused the pressure increase. And what I was  
18 seeing now, after thirty minutes of the valve having shut the  
19 electromatic relief valve, the level was collapsing again in  
20 the reactor coolant system and it had a decrease in pressurizer  
21 level.

22 The operator restarted high pressure injection pumps  
23 and recovered pressurizer level again and he had a solid in-  
24 ventory in the loops. His reactor coolant pumps were running.  
25 Pressurizer level was going up and primary plant pressure was

1 going up. At that point, he again throttled back the high  
2 pressure injection, brought the transient under control.

3 MR. GORINSON: So, in the Davis-Besse transient on  
4 September 24, 1977, there was a loss of feedwater. Is that  
5 correct?

6 MR. KELLY: It was initiated by a loss of feedwater.

7 MR. GORINSON: Private operator relief valve stuck  
8 open? Or electromatic relief valve?

9 MR. KELLY: That was another event in that.

10 MR. GORINSON: Right. But it stuck open during the  
11 transient?

12 MR. KELLY: Yes, it did.

13 MR. GORINSON: The pressurizer level was increasing  
14 at a time during that transient while pressure was decreasing.  
15 Is that correct?

16 MR. KELLY: That is correct.

17 MR. GORINSON: And the operator's relying on that  
18 increasing pressurizer level shut off the HPI?

19 MR. KELLY: I don't remember whether they shut it  
20 off or just throttled it back.

21 MR. GORINSON: They just throttled it back but they  
22 were relying on the increasing pressurizer level.

23 MR. KELLY: Yeah.

24 MR. GORINSON: And you just said that you were sent  
25 to Davis-Besse to investigate that event. Is that correct?



1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25

MR. KELLY: Yes. That is correct.

MR. GORINSON: Is it standard operating procedure at Babcock and Wilcox to go out and investigate a transient?

MR. KELLY: Joe Kelly, you mean?

MR. GORINSON: Joe Kelly.

MR. KELLY: I have investigated two.

MR. GORINSON: What two were those, sir?

MR. KELLY: Davis-Besse and the one we were referring to and I was also sent on March 28, 1979 to investigate the Three Mile Island Unit 2 incident.

MR. GORINSON: Would it be fair to say that you were sent out to investigate these two because they were unusual?

MR. KELLY: Yes.

MR. GORINSON: What made the Davis-Besse transient unusual?

MR. KELLY: It was unusual in that it was complicated. It was not a simple reactor trip, not a simple loss of feedwater. By the time I heard about it, they had known that the electromagnetic relief valve had stuck open for some reason. They had depressurized, had a partial cooldown of the plant. Because it was complicated, it was not a simple transient. That is why I was sent to investigate it.

MR. GORINSON: How long did you stay at Davis-Besse, Mr. Kelly?

MR. KELLY: Two days.

Bowers Reporting Company

1 MR. GORINSON: And when you returned to Lynchburg,  
2 did you make a presentation to Babcock and Wilcox personnel  
3 on what had happened at Davis-Besse?

4 MR. KELLY: Yes, I did.

5 MR. GORINSON: To how many people did you make that  
6 presentation?

7 MR. KELLY: The room was fairly crowded and I have  
8 estimated about thirty.

9 MR. GORINSON: Was that a larger group than would  
10 usually be present for a presentation on a transient?

11 MR. KELLY: I have nothing to compare it with. It  
12 was the only one I have made.

13 MR. GORINSON: Have you ever been in a group that  
14 received a presentation of a transient?

15 MR. KELLY: No.

16 MR. GORINSON: Okay.

17 Could you tell us to the best of your recollection  
18 who was there at that meeting?

19 MR. KELLY: Don Montgomery was there. Joe Lauer  
20 was there. Bert Dunn, Bob Jones. Fred Weiss was making the  
21 presentation with myself. Mr. MacMillan was there for a por-  
22 tion of the time. My unit manager, Bruce Karrasch, was there.

23 MR. GORINSON: And at that meeting you gave a factual  
24 presentation of what had happened at Davis-Besse?

25 MR. KELLY: My assignment was to try and determine

Bowers Reporting Company

1 the sequence of events going to transient and that is what I  
2 presented; the results of my investigation.

3 MR. GORINSON: So, you told them at that meeting  
4 that there had been a loss of feedwater and you told them that  
5 a pilot operated relief valve stuck open.

6 MR. KELLY: Yes.

7 MR. GORINSON: And you told them that pressurizer  
8 level had increased while pressure was decreasing.

9 MR. KELLY: Yes.

10 MR. GORINSON: And you also told them that the oper-  
11 ators had terminated the high pressure injection.

12 MR. KELLY: O maybe --

13 MR. GORINSON: Or throttled it back.

14 MR. KELLY: Yes.

15 MR. GORINSON: At that meeting did you give them  
16 your opinion as to whether operator termination or throttling  
17 back of the high pressure injection was appropriate during the  
18 Davis-Besse transient?

19 MR. KELLY: I don't remember giving an opinion like  
20 that, no.

21 MR. GORINSON: Did anyone ask for your opinion during  
22 that meeting?

23 MR. KELLY: Not that I remember; not during the meet-  
24 ing.

25 MR. GORINSON: After the meeting, did you get into

1 a discussion with Bert Dunn?

2 MR. KELLY: Yes, I did.

3 MR. GORINSON: And who is Bert Dunn, sir?

4 MR. KELLY: Bert Dunn is the Unit Manager of ECCS,  
5 Emergency Core Coolant System.

6 MR. GORINSON: Emergency Core Coolant System.

7 CHAIRMAN KEMENY: Just for clarification, may I ask  
8 that is the unit that provides high pressure injection. Is  
9 that correct?

10 MR. KELLY: High pressure injection is one of the  
11 emergency core cooling systems, yes.

12 CHAIRMAN KEMENY: I just wanted to connect this.

13 MR. GORINSON: What was the substance of that dis-  
14 cussion, sir?

15 MR. KELLY: Mr. Dunn expressed a concern after the  
16 meeting with me that the operators had terminated or throttled  
17 -- I don't remember which -- during that transient. And he  
18 said that he could give me scenarios that would have led to  
19 possible core damage if they had done that under different  
20 circumstances.

21 MR. GORINSON: Was that the first time you had  
22 heard a concern about premature operator termination or throt-  
23 tling back of high pressure injection?

24 MR. KELLY: Yes.

25 MR. GORINSON: Was there another transient involving

1 high pressure injection at Davis-Besse on October 23, 1977?

2 MR. KELLY: Yes.

3 MR. GORINSON: Could you describe that transient to  
4 us?

5 MR. KELLY: No, I cannot describe it any detail. I  
6 was not assigned to investigate that transient.

7 MR. GORINSON: And could you briefly tell us what is  
8 the purpose of the high pressure injection system?

9 MR. KELLY: High pressure injection is to maintain  
10 a core cooling during a loss of coolant accident.

11 MR. GORINSON: After talking to Mr. Dunn and having  
12 done your investigation at Davis-Besse, is it fair to say that  
13 you had concerns about operator understanding of when to term-  
14 inate or to throttle back with high pressure injection?

15 MR. KELLY: Yes, it is.

16 MR. GORINSON: Did you talk to the training depart-  
17 ment at Babcock and Wilcox about operator understanding of  
18 high pressure injection?

19 MR. KELLY: Have I ever talked to them?

20 MR. GORINSON: Did you after your concerns became --

21 MR. KELLY: After the incident of the 23rd of October,  
22 I talked to the training department.

23 MR. GORINSON: And who in that department did you  
24 talk to?

25 MR. KELLY: I went down and talked to simulator

1 instructors that I had known from work at Crystal River Unit  
2 3. I talked to John Lind, Harry Helmyer. There were other  
3 simulator instructors present during that conversation.

4 MR. GORINSON: And what did Mr. Lind and these other  
5 individuals tell you about the subject of high pressure injec-  
6 tion?

7 MR. KELLY: I had told them about the incident of  
8 the 24th and about what I had heard about the incident of  
9 October 23rd and was down there -- I told them I was asking  
10 them to tell me how they approached this discussion or whether  
11 they thought the operators' training was sufficient to preclude  
12 this. And John Lind, Harry, both told me -- and the other  
13 operators agreed with them -- that, yes, that the operators --  
14 I mean, yes, the plant operators are instructed to look at  
15 pressurizer level and primary plant pressure and reactor cool-  
16 ant average temperature and make sure that they are all under  
17 control before they could terminate high pressure injection.  
18 That is the way they are taught. They told me -- well, that  
19 was the substance of that conversation. And when I got their  
20 concurrence that they were teaching the operators when to  
21 secure high pressure injection and I was in agreement with  
22 what they had said, then I told Mr. Lind and the others that  
23 I was going to write a letter to Nuclear Service to make sure  
24 that the written words we were putting out were in accordance  
25 with what we were teaching.

1 MR. GORINSON: What is Nuclear Service, sir?

2 MR. KELLY: That is another department of NPGD,  
3 Nuclear Power Generation Division.

4 MR. GORINSON: That has now been renamed, hasn't it?  
5 The Customer Service Department?

6 MR. KELLY: At that time it was Nuclear Service;  
7 now it is Customer Service.

8 MR. GORINSON: Did you or Mr. Lind ever address the  
9 question during your discussion of why the operators of Davis-  
10 Besse had interrupted the high pressure injection if they were  
11 being trained correctly?

12 MR. KELLY: Yes. Well, we talked about that and  
13 none of the instructors could understand why they had inter-  
14 rupted.

15 MR. GORINSON: So, it is fair to say, though, that  
16 when you walked away from your meeting with Mr. Lind that you  
17 had been reassured on the subject?

18 MR. KELLY: Oh, yes.

19 MR. GORINSON: Mr. Kelly, let me put in front of you  
20 a document that has been marked as Hearing Exhibit 1 and just  
21 to make it clear for the record, this is a document dated  
22 November 1, 1977, and it is from J. J. Kelly, Plant Integration  
23 to Distribution. And the subject is Customer Guidance on High  
24 Pressure Injection Operation. Do you have that in front of  
25 you, sir?



1 MR. KELLY: Yes, I do.

2 MR. GORINSON: And this is a memorandum which you  
3 wrote?

4 MR. KELLY: Yes.

5 MR. GORINSON: In the first sentence you state --  
6 well, let me go back one second. Before writing this memoran-  
7 dum, did you have any discussion with Mr. Dunn about the fact  
8 that you were going to write a memorandum?

9 MR. KELLY: As I said, I talked to him the day of  
10 that briefing and after the October 23rd incident at Toledo,  
11 I may have talked to him again and expressed my concerns. I  
12 did talk to my immediate supervisor, Mr. Eric Swanson and we  
13 talked it over and I decided to write the memo.

14 MR. GORINSON: I see. Now, this memorandum went to  
15 several people. Can you identify them for us? Who is Mr.  
16 Karrasch?

17 MR. KELLY: Mr. Karrasch is the Manager of Plant  
18 Integration Unit.

19 MR. GORINSON: Mr. Swanson.

20 MR. KELLY: Mr. Swanson was my supervisory engineer.

21 MR. GORINSON: In your department, in Plant Integra-  
22 tion?

23 MR. KELLY: Yes. He works for Mr. Karrasch also.

24 MR. GORINSON: Mr. Finnin.

25 MR. KELLY: Mr. Finnin, at the time, was in Nuclear



1 Service. I don't know what his title was.

2 MR. GORINSON: Okay. And Mr. Dunn.

3 MR. KELLY: He is the Manager of ECCS.

4 MR. GORINSON: Mr. Labelle.

5 MR. KELLY: Mr. Labelle was the Manager of our  
6 Safety Analysis Unit; another unit of the Plant Design section.

7 MR. GORINSON: Mr. Elliott.

8 MR. KELLY: Mr. Elliott was Manager of Training.

9 MR. GORINSON: Mr. Hallman.

10 MR. KELLY: Mr. Hallman was the Manager in Nuclear  
11 Service, also.

12 MR. GORINSON: And this memorandum was based on your  
13 concerns arising out of those transients at Davis-Besse 1.

14 MR. KELLY: Yes.

15 MR. GORINSON: And in it you recommended that guide-  
16 lines be set. Is that correct?

17 MR. KELLY: Oh, yes. I see what you are referring  
18 to.

19 MR. GORINSON: Do you see where I am looking at in  
20 the memorandum?

21 MR. KELLY: I recommend the following guidelines be  
22 sent. Yes.

23 MR. GORINSON: And those would be sent to who?

24 MR. KELLY: Well, I -- I was asking in the memo for  
25 them to review what we were sending out to the customers and

1 if it was not right or they didn't feel that it was adequate,  
2 then I recommended that this be sent to the customer.

3 MR. GORINSON: I see. So, these would be guidelines  
4 that would be sent to the customers, if approved.

5 MR. KELLY: Yes. And if necessary.

6 MR. GORINSON: Now, why did you select these parti-  
7 cular people to send your memorandum to?

8 MR. KELLY: Mr. Karrasch was my Unit Manager. I  
9 send him copies of everything I write to keep him informed of  
10 what I am doing. I talked to Mr. Swanson. He was my super-  
11 visory engineer and he and I had discussed sending the memo  
12 out. Ron Finnin, I knew worked in the Plant Performance Sec-  
13 tion of Nuclear Service and I wanted to get his opinion of  
14 what I was sending.

15 Mr. Dunn was the Manager of ECCS. He had expressed  
16 a concern at my debriefing after the initial Davis-Besse inci-  
17 dent and I knew he would be interested in it and I wanted to  
18 keep him informed that I was taking an action on this.

19 Mr. Labelle was Manager of Safety Analysis and I  
20 wanted to see if he had any input into it. I was sending it  
21 to Mr. Elliott because I had talked to his people about it and  
22 I wanted to keep him informed that I was pursuing this to try  
23 and get some written guidelines. And, again, Mr. Hallman, was  
24 Ron Finnin's manager.

25 MR. GORINSON: In the last sentence of your memorandum

1 it says, I would appreciate your thoughts on this subject.

2 Do you see that, sir?

3 MR. KELLY: Yes, I do.

4 MR. GORINSON: Did any of the seven people you  
5 wrote the memo to, give you their thoughts?

6 MR. KELLY: No.

7 MR. GORINSON: Did you go to any of these people  
8 and ask them what they thought?

9 MR. KELLY: No, I did not.

10 MR. GORINSON: Sir, does Babcock and Wilcox have a  
11 system called "Preliminary Safety Concerns"?

12 MR. KELLY: Yes.

13 MR. GORINSON: And at B and W, had that system been  
14 in effect at the time you wrote your November 1, 1977 memoran-  
15 dum?

16 MR. KELLY: Yes, it was.

17 MR. GORINSON: What is the purpose of the Preliminary  
18 Safety Concerns system at Babcock and Wilcox?

19 MR. KELLY: It is to bring attention to a significant  
20 or preliminary safety concern. To bring management attention,  
21 get it resolved, have the information disseminated as necessary.

22 MR. GORINSON: Why didn't you put your November 1,  
23 1977, memo in the form of a Preliminary Safety Concern?

24 MR. KELLY: I had talked to the instructors in our  
25 Training Department. They had reassured me that they were

1 teaching when to secure high pressure injection. I agreed  
2 with what they were teaching. When I wrote this memo, I was  
3 not even -- by no means sure that there was a safety concern.  
4 It was not clear to me. My purpose was to get somebody to  
5 investigate what was being told to the customers and at that  
6 point correct it if necessary. And also, I felt that people  
7 in my distribution like Mr. Dunn would be better qualified  
8 than myself to determine if it was a valid concern for a pre-  
9 liminary safety concern. At the time, I didn't think it was  
10 a significant safety concern.

11 MR. GORINSON: I see. So, at that point, you weren't  
12 sure whether it would be safety concern or not.

13 MR. KELLY: Yes.

14 MR. GORINSON: Which department in Balrock and Wil-  
15 cox has responsibility for those Preliminary Safety Concern  
16 items?

17 MR. KELLY: Licensing.

18 MR. GORINSON: And that is headed by Mr. Taylor?

19 MR. KELLY: Yes.

20 MR. GORINSON: Was anybody from Licensing included  
21 on this distribution of your memorandum?

22 MR. KELLY: No, they were not.

23 MR. GORINSON: What was the reason for that, sir?

24 MR. KELLY: I was looking at this as a working memo-  
25 randum to bring attention to what I thought was a concern. I

1 did not think it was a significant safety concern. I felt that  
2 there were people better qualified than me to determine that  
3 like Mr. Dunn. I wasn't sure when I wrote this memo if -- I  
4 wasn't sure that we weren't already telling him everything I  
5 had in this memo on when to secure high pressure injection.

6 MR. GORINSON: Now, beside the seven people who did  
7 not give you their thoughts, was there anyone other than these  
8 people who did respond to your memorandum?

9 MR. KELLY: Yes. I got a written memo back from  
10 Frank Walters, from Nuclear Services.

11 MR. GORINSON: Can we please put in front of Mr.  
12 Kelly what has been premarked as Commission Hearing Exhibit  
13 Number 2? And that is a handwritten letter from J. F. Walters,  
14 Nuclear Service to J. J. Kelly, Plant Integration and the date  
15 of it is November 10, 1977: Subject: High Pressure Injection  
16 during Transient. Do you have that in front of you, Mr. Kelly?

17 MR. KELLY: Yes, I do.

18 MR. GORINSON: Is that the memo you got from Mr.  
19 Walters?

20 MR. KELLY: Yes.

21 MR. GORINSON: And you reviewed that memo at or  
22 about the time you received it on November 10, 1977?

23 MR. KELLY: Yes, I did.

24 MR. GORINSON: Did you go back to Mr. Walters after  
25 you reviewed the memorandum?

1 MR. KELLY: No.

2 MR. GORINSON: Was there some reason why you did  
3 not go back to Mr. Walters?

4 MR. KELLY: After reading Mr. Walters' memo a few  
5 times over again in my mind, I didn't feel like Mr. Walters  
6 was answering the questions that I had asked or was not address-  
7 ing the concerns, my concern on the operators securing high  
8 pressure injection during a LOCA. I thought that he had mis-  
9 read what I was after and his letter confused me. I didn't  
10 see any advantage at that time to pursuing it with Mr. Walters.  
11 Instead, it prompted me -- since that was the only response I  
12 had gotten -- to escalate the problem up from my level up into  
13 a management position.

14 MR. GORINSON: I see. Well, let's look at the first  
15 paragraph of Mr. Walters' memorandum and it says there, in  
16 talking with training personnel and in the opinion of this  
17 writer, the operators at Toledo responded in a correct manner,  
18 considering how they had been trained and the reasons behind  
19 the training. Do you see that paragraph?

20 MR. KELLY: Yes.

21 MR. GORINSON: What did you believe Mr. Walters  
22 meant in that paragraph when you received it on November 10  
23 and reviewed it?

24 MR. KELLY: I took his words literally. He is say-  
25 ing that he talked with training personnel and in the opinion

1 of this writer, Mr. Walters, the operators in Toledo responded  
2 in a correct mannner, considering the way they had been trained  
3 and the reasons behind the training.

4 MR. GORINSON: All right. Did you focus on the  
5 words "considering how they had been trained and the reasons  
6 behind that training". Does that raise any question for you?

7 MR. KELLY: No. Because at that time I had already  
8 talked to the training people and I was convinced that they  
9 were training the operators correctly. And I just assumed  
10 that Mr. Walters was confused or he had asked the wrong quest-  
11 ions of them.

12 MR. GORINSON: I see. But based on that paragraph,  
13 it would appear, would it not that there was -- at least on  
14 the surface -- could be read to be a conflict between what Mr.  
15 Lind was telling you and what Mr. Walters was saying in his  
16 memorandum?

17 MR. KELLY: Yes.

18 MR. GORINSON: Did you take any steps to resolve the  
19 conflict?

20 MR. KELLY: No. I escalated the problem to Mr. Dunn.

21 MR. GORINSON: Let's look at the second paragraph.  
22 My assumption in the training assumes first that RC pressure and  
23 pressurizer level will tend in the same direction under a LOCA.  
24 Do you see that sentence?

25 MR. KELLY: Yes.



1 MR. GORINSON: Is that what had happened at Davis-  
2 Besse?

3 MR. KELLY: Not during the LOCA portion of that  
4 transient, no. As I think I stated, pressurizer level was  
5 going up when they had the electromatic relief valve stuck  
6 open and pressure was going down.

7 MR. GORINSON: And he says there, does he not, that  
8 the training assumes that they will trend in the same direction?

9 MR. KELLY: He says, "my assumption", he is talking  
10 about himself, and the training assumes they will go in the  
11 same direction. That is what he says, yes.

12 MR. GORINSON: After reading that paragraph, did you  
13 believe there was a conflict between what Mr. Lind had told  
14 you and what Mr. Walters was writing in his memorandum?

15 MR. KELLY: Did I believe there was a conflict? Yes,  
16 there was a conflict.

17 MR. GORINSON: But you did not go back to Mr. Lind?

18 MR. KELLY: No. I had three or four operators tell  
19 me what they were teaching and I didn't know what Frank was  
20 referring to.

21 MR. GORINSON: And you didn't go back to Mr. Walters?

22 MR. KELLY: No.

23 MR. GORINSON: Is it fair to say that taking the  
24 Walters' memorandum as a whole, because as what you perceived  
25 to be misunderstandings or inaccuracies in Mr. Walters' analysis,



1 that you essentially dismissed Mr. Walters' memorandum.

2 MR. KELLY: Yes. Its only value to me was to esca-  
3 late the problem.

4 MR. GORINSON: To Mr. Dunn?

5 MR. KELLY: Yes.

6 MR. GORINSON: And to the best of your knowledge  
7 after the matter was escalated to Mr. Dunn, did he write two  
8 memoranda stating his concerns about operator interference  
9 about high pressure injection?

10 MR. KELLY: Yes.

11 MR. GORINSON: And those memoranda were written in  
12 February of 1978?

13 MR. KELLY: Yes.

14 MR. GORINSON: And you received both memoranda?

15 MR. KELLY: Yes, I did.

16 MR. GORINSON: And after you read the memoranda, did  
17 anything happen at Babcock and Wilcox to resolve the problem  
18 that you had raised in your November 1, 1977 memo?

19 MR. KELLY: After Mr. Dunn's second memorandum, I  
20 thought the problem was resolved.

21 MR. GORINSON: And by resolved, what do you mean?

22 MR. KELLY: Well, the second one states that he had  
23 had a meeting with Nuclear Service personnel and they had  
24 reached an agreement on what words should be sent out to the  
25 customers -- I am paraphrasing this -- and that he was satisfied

1 that those were adequate and he would like to amend the wording  
2 in his first memo to agree with his second one and he was wri-  
3 ting all of this to Mr. Taylor. And, therefore, from my view-  
4 point, I could see that ECCS and Mr. Dunn had resolved the  
5 problem with Nuclear Service. They had reached an agreement  
6 on the words to be sent out to the customers and I thought the  
7 problem was resolved at that point.

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. GORINSON: And you thought those words were then  
2 going to go out to the customers?

3 MR. KELLY: Yes.

4 MR. GORINSON: Just briefly, you mentioned there was  
5 a loss of feed water at Davis-Besse I on September 24, 1977,  
6 correct?

7 MR. KELLY: Yes.

8 MR. GORINSON: That also occurred at TMI II on  
9 March 28, 1979?

10 MR. KELLY: Yes.

11 MR. GORINSON: There was a PORV stuck open at Davis-  
12 Besse I on September 24, 1977, is that correct?

13 MR. KELLY: Yes.

14 MR. GORINSON: That also occurred at TMI II on  
15 March 28, 1979?

16 MR. KELLY: Yes.

17 MR. GORINSON: And at Davis-Besse I on September 24,  
18 1977, the pressurizer level increased while pressure was  
19 decreasing, is that correct?

20 MR. KELLY: Yes.

21 MR. GORINSON: That also occurred at TMI II on  
22 March 28, 1979, did it not?

23 MR. KELLY: Yes.

24 MR. GORINSON: And finally, at Davis-Besse I, on  
25 September 24, 1977, the operators throttled back the HPI?

1 MR. KELLY: Yes.

2 MR. GORINSON: And they also did that at TMI II,  
3 didn't they?

4 MR. KELLY: Yes. There were differences, too.

5 MR. GORINSON: Mr. Chairman, I would request that  
6 Exhibits 1 and 2 be included in the hearing record.

7 CHAIRMAN KEMENY: So ordered.

8 MR. GORINSON: I have no further questions.

9 CHAIRMAN KEMENY: Thank you. Do any commissioners  
10 have questions from the witness before -- Professor Taylor?

11 COMMISSIONER TAYLOR: I would like to follow up on  
12 a remark that was made. You said there were differences.  
13 Could you briefly say what you think the important differences  
14 were between the sequence up to the point where high pressure  
15 injection was turned off at Davis-Besse and at TMI.

16 MR. KELLY: At Davis-Besse the operators relatively  
17 quickly discovered that the electromatic relief valve was  
18 stuck open, the PORV, I mean within 20 minutes. At Three  
19 Mile Island II it was over 2 hours before the operators dis-  
20 covered that that valve was stuck open. At Davis-Besse the  
21 operators, early in the transient, stopped two of the reactor  
22 coolant pumps, one in each loop, to minimize their heat-up  
23 rate. At Three Mile Island II, the operators stopped all four  
24 of the reactor coolant pumps. They were significant differ-  
25 ences, in my mind.

1 CHAIRMAN KEMENY: Could you repeat that last point?  
2 I didn't quite get just the last point.

3 MR. KELLY: At Davis-Besse, they stopped one reactor  
4 coolant pump in each loop. In other words, they left one pump  
5 running in each loop continuously throughout the entire transi-  
6 ent. At Three Mile Island they stopped all four of the  
7 reactor coolant pumps.

8 CHAIRMAN KEMENY: Professor Pigford?

9 COMMISSIONER PIGFORD: Do you happen to know on what  
10 basis did the operators at Davis-Besse learn that the relief  
11 was stuck?

12 MR. KELLY: I don't know what thought process they  
13 went through, no -- not that that is your question.

14 COMMISSIONER PIGFORD: Had that been discussed in  
15 any of the discussions on that incident which you have attended?

16 MR. KELLY: Not that I can remember.

17 COMMISSIONER PIGFORD: I wasn't asking the thought  
18 process, necessarily. Were there any signals indicating that?

19 MR. KELLY: Oh, yes. They had -- their crunch tank  
20 had overpressurized and the rupture disk had ruptured, and they  
21 could have that signal available to them.

22 COMMISSIONER PIGFORD: Is that what led them to  
23 decide it had been stuck open?

24 MR. KELLY: It could have contributed to it, cer-  
25 tainly, if they had look at it. What I am saying is, I don't

1 know, personally, what they looked at. There was a signal  
2 available to them.

3 COMMISSIONER PIGFORD: And what about the tail pipe  
4 system? Could that logically have led to the information that  
5 was of interest?

6 MR. KELLY: The relief valve discharge temperature?

7 COMMISSIONER PIGFORD: Yes.

8 MR. KELLY: Yes. Yes. These were signals that were  
9 available, reactor building temperature and pressure.

10 COMMISSIONER PIGFORD: But apparently you didn't re-  
11 view those signals when you reviewed the accident.

12 MR. KELLY: No. My responsibility was to determine  
13 the sequence of events as it affected the NSS and not neces-  
14 sarily an interview with the operators to find out why they  
15 did anything. It was more important to me to determine that  
16 it had been shut after 20 minutes than to determine why it had  
17 been shut.

18 CHAIRMAN KEMENY: Governor Peterson?

19 COMMISSIONER PETERSON: Since March 28, 1979, have  
20 the managers of Babcock and Wilcox investigated why the lesson  
21 learned at Davis-Besse was not brought to bear on the operation  
22 at Three Mile Island?

23 MR. KELLY: I don't know.

24 CHAIRMAN KEMENY: Dr. Marks?

25 COMMISSIONER MARKS: Mr. Kelly, you said that you

1 were sent to, as I understood you, TMI II on March 28.

2 MR. KELLY: Yes, that is correct.

3 COMMISSIONER MARKS: You were on site in the control  
4 room on March 28?

5 MR. KELLY: No, sir. I was dispatched from Lynchburg  
6 to Harrisburg. I was not allowed on site. I did not get  
7 actually onto Three Mile Island until Thursday afternoon,  
8 March 29.

9 COMMISSIONER MARKS: Why were you not allowed in?  
10 Is that standard procedure?

11 MR. KELLY: I was told that I was not allowed on  
12 site. They had radiation problems, and they were just limit-  
13 ing site access at that time.

14 COMMISSIONER MARKS: You were the only representa-  
15 tive of Babcock and Wilcox dispatched to the site?

16 MR. KELLY: No, sir, there was -- three of us left  
17 very early that day -- well, around noon we were on a chartered  
18 plane, and later in that day two more people joined us at --  
19 near Harrisburg. We didn't get onto the Island.

20 COMMISSIONER MARKS: None of you were allowed on?

21 MR. KELLY: No.

22 COMMISSIONER MARKS: Who were the others that accom-  
23 panied you, and what were their functions in the company?

24 MR. KELLY: Bob Winks accompanied me. He is in our  
25 Control Analysis Unit, which is another unit of our Plant



1 Design Section. He was -- and Bob Twilly accompanied me. He  
2 is in Nuclear Service. Our function was to go up there and  
3 review the available plant data and try to reconstruct a  
4 sequence of events and, secondarily, to assist our on-site  
5 people in any manner that we could.

6 Later in the day, we were joined by Eric Yoheim,  
7 a radiochemist, and Dale Ewell, another radiochemist.

8 COMMISSIONER MARKS: Who refused you access to the  
9 site?

10 MR. KELLY: The message was relayed to me by Greg  
11 Shedell, who is a B&W employee, and I was at his house. He  
12 had gotten it from Lee Rogers, who is also a B&W employee who  
13 was in the control room at the time as site operations  
14 manager, and I don't know where Lee Rogers got the information.

15 COMMISSIONER MARKS: So it went from Lee Rogers to  
16 Greg --

17 MR. KELLY: Shedell.

18 COMMISSIONER MARKS: -- Shedell, to you?

19 MR. KELLY: Yes.

20 COMMISSIONER MARKS: And you don't know who told  
21 Rogers to tell you not to come onto the site?

22 MR. KELLY: That's right, I do not know.

23 COMMISSIONER MARKS: Did you consider that a reason-  
24 able directive?

25 MR. KELLY: I felt like I could have been useful on



1 site. I also felt like I had to yield to their judgment.  
2 They were on site, and I was not.

3 COMMISSIONER MARKS: Is it conceivable that if you  
4 had been given access, you might have identified some of the  
5 problems, in view of your previous experience with the Davis-  
6 Besse and the differences that you just pointed out to Dr.  
7 Taylor?

8 MR. KELLY: No, sir, because by the time I got there  
9 to where I was available to be on site, the reactor coolant  
10 pumps had already been turned off, and it was hours and hours  
11 into the transient.

12 COMMISSIONER MARKS: But you just said you thought  
13 you might be helpful. How do you think you could have been  
14 helpful?

15 MR. KELLY: Well, in the recovery stage if they  
16 needed people to communicate, if they needed people to advise  
17 them as to what was going on. I think I could have been help-  
18 ful at that point.

19 COMMISSIONER MARKS: Can you be more specific?

20 MR. KELLY: Well, I may have, if I had had the infor-  
21 mation available to me, been able to make recommendations on  
22 the recovery. I was not allowed on there. I was not exposed  
23 to the information. I don't think I can be any more specific.

24 COMMISSIONER MARKS: Do you know who makes decisions  
25 on sending out someone from B&W to investigate a transient?

1 MR. KELLY: I don't know where the decision origin-  
2 ates with, no, sir. I don't know.

3 COMMISSIONER MARKS: And I guess you don't know how  
4 many transients have been investigated with respect to B&W  
5 reactors.

6 MR. KELLY: I couldn't give you a number. I know  
7 that Bob Winks, who I mentioned, went and investigated a  
8 transient at the SMUD utility.

9 COMMISSIONER MARKS: At what?

10 MR. KELLY: SMUD, Sacramento.

11 COMMISSIONER MARKS: Sacramento, California?

12 MR. KELLY: Yes.

13 CHAIRMAN KEMENY: Governor Babbitt?

14 COMMISSIONER BABBIT: Mr. Kelly, when you returned  
15 to Davis-Besse for the briefing in Lynchburg, did you indicate  
16 that Mr. MacMillan was there for that briefing?

17 MR. KELLY: Sir, he was there for a portion of it.  
18 He was not there for the whole thing. I remember him coming  
19 in and I remember him leaving.

20 COMMISSIONER BABBIT: Do you recall which portion he  
21 was there for?

22 MR. KELLY: No. I was just trying to do that since  
23 this has started, and I don't remember which portion.

24 COMMISSIONER BABBIT: Do you recall whether it was  
25 during your part of the presentation or -- who was it, Mr.

Bowen Reporting Company

1 Faist was the other lecturer?

2 MR. KELLY: He was there during my part of the  
3 investigation, which would be going over the graphs -- I am  
4 implying this now. I went over the graphs and explained, to  
5 my knowledge, what the sequence of events was at that time,  
6 and he stayed for that portion of it, at least.

7 COMMISSIONER BABBIT: He was there for that portion?

8 MR. KELLY: Yes.

9 COMMISSIONER BABBIT: Do you recall whether he asked  
10 any questions?

11 MR. KELLY: He did not.

12 COMMISSIONER BABBIT: Mr. Kelly, going back to your  
13 discussion with the instructors -- I believe Mr. Lind was one  
14 the instructors?

15 MR. KELLY: Yes, he was one.

16 COMMISSIONER BABBIT: During those discussions, did  
17 Mr. Lind or any of the other instructors give you their opin-  
18 ion of how they could do a better job or what they might have  
19 done in the past that they would now correct in light of this  
20 discussion?

21 MR. KELLY: At the time they did not, but since the  
22 accident I have gone back to see what they have done, and I  
23 have reread -- I'm sorry, I didn't reread, I initially read --  
24 the simulator casualty procedures and the wording involved in  
25 there that we write down on when to secure high pressure

1 injectio. I talked to them about specific drills that they  
2 give, where they point out that pressurizer level and pressure  
3 can diverge and go in different directions, and they teach  
4 these as routine.

5 COMMISSIONER BABBIT: Those discussions were subse-  
6 quent to the Three Mile Island incident, were they?

7 MR. KELLY: Yes, yes.

8 COMMISSIONER BABBIT: Okay. You don't have any  
9 recollection of their analyzing to you at the time of the dis-  
10 cussions immediately after the Davis-Besse incident?

11 MR. KELLY: Only that they told me that they tell  
12 the operators to be aware of pressurizer level, primary plant  
13 pressure, and reactor coolant average temperature at the same  
14 time when they consider securing high pressure injection. I  
15 remember Mr. Lind telling me that.

16 COMMISSIONER BABBIT: But you don't remember any  
17 other analytical discussion of the training process, simply  
18 his conclusion that he had been over all of those points?

19 MR. KELLY: Sir, maybe I don't know what you mean  
20 by analytical discussion.

21 COMMISSIONER BABBIT: Well, my difficulty is, in all  
22 candor, your answer sounds too pat, frankly, and it sounds as  
23 if you went down and talked with them and they said, that's  
24 very interesting, but we have certainly covered all of those  
25 points, and it doesn't sound very real to me, frankly.

1 MR. KELLY: I had worked with Mr. Lind and Mr. Hal-  
2 myer at Florida. I knew both of them. I trusted them and  
3 respected their judgment. When I explained the sequence of  
4 events and they told me that the operators had been trained  
5 not to do that or they had been trained to recognize that  
6 casualty, I believed them, yes, sir.

7 CHAIRMAN KEMENY: Commissioner Haggerty?

8 COMMISSIONER HAGGERTY: The high pressure injection  
9 system is really a very significant and essential safety  
10 feature in relation to the reactor, is it not?

11 MR. KELLY: Yes.

12 COMMISSIONER HAGGERTY: I gather that your concern  
13 was related to whether an adequate, completely adequate, set  
14 of instructions was being made to the operators that reflected  
15 all of the aspects of operating the HPI.

16 Now, could you tell us what might be the negative  
17 consequences of leaving HPI on under those circumstances that  
18 existed at Davis-Besse and Three Mile Island. What were the  
19 negative things, the bad things that could happen?

20 MR. KELLY: If the reactor coolant system leak were  
21 small enough, you might -- or if there was not a reactor  
22 coolant system leak -- you would fill the reactor coolant  
23 system completely solid and collapse the steam bubble in the  
24 pressurizer and start discharging water out through the relief  
25 valves.

1 COMMISSIONER HAGGERTY: And what would that do?

2 MR. KELLY: It would -- in perspective, it would  
3 continue to cool the cooler. You would be pumping water in  
4 and out through the relief valves.

5 COMMISSIONER HAGGERTY: In essence, nothing of real  
6 consequence.

7 MR. KELLY: No.

8 COMMISSIONER HAGGERTY: Is there any potential for  
9 damage by -- to the system by leaving HPI on? In other words,  
10 not terminating under the set of circumstances outlined;  
11 that is, decreasing the pressure and increasing levels, that  
12 you can think of?

13 MR. KELLY: No, there wouldn't be anything wrong with  
14 leaving it on.

15 COMMISSIONER HAGGERTY: Isn't it true that HPI is  
16 not present in all reactor systems of the general type -- it  
17 is present in all B&W systems, but not all of them have HPI?

18 MR. KELLY: I'm sorry, I can't -- I don't know. I  
19 can't comment on that.

20 COMMISSIONER HAGGERTY: I think the important thing,  
21 though, is that you believe that HPI was a significant safety  
22 tool, and you were concerned that perhaps the instruction re-  
23 lating to that tool was not completely adequate so that the  
24 operators would understand how it ought to be used under a  
25 variety of circumstances, isn't that correct?

1 MR. KELLY: That is essentially correct, yes, sir.

2 CHAIRMAN KEMENY: Commissioner McPherson?

3 COMMISSIONER MCPHERSON: Mr. Kelly, I believe you  
4 said earlier in your responses to counsel that when you wrote  
5 the memorandum of November 1, you were not sure that there was  
6 a significant safety concern.

7 MR. KELLY: Yes.

8 COMMISSIONER MCPHERSON: And I am interested in the  
9 meaning of that term, since in the memorandum there appears  
10 this sentence: "Since there are accidents which require the  
11 continuous operation of the high pressure injector system, I  
12 wonder what guidance, if any, we should be giving to our cus-  
13 tomers on when they can safely shut the system down following  
14 an accident."

15 Does that not express a concern about safety?

16 MR. KELLY: Yes, sir, that is why I wrote the memo.  
17 In my mind, the operative words there, "I wonder what guidance,  
18 if any...", I was not sure when I wrote the memo that we were  
19 not adequately already guiding the customers on what to do.

20 COMMISSIONER MCPHERSON: So that the operation of a  
21 high pressure injection system or its termination is a signi-  
22 ficant safety concern, but whether or not B&W was providing  
23 the guidance was unknown to you, and it was that that you  
24 didn't know. You were uncertain about its significance, is  
25 that correct?



1 MR. KELLY: Well, I was convinced that we were  
2 training the operators in what to do. I wasn't convinced in  
3 what the written words we were putting out was, and that is  
4 what I was trying to address.

5 CHAIRMAN KEMENY: Professor Pigford?

6 COMMISSIONER PIGFORD: Mr. Kelly, I wanted to ask  
7 you about some other aspects of the Davis-Besse accident that  
8 you may have knowledge of as a result of your review. Was the  
9 auxiliary feed water lost at Davis-Besse?

10 MR. KELLY: Sir, one of the pumps on the number two  
11 generator did not come up to full speed. The other auxiliary  
12 feed water pump did operate correctly.

13 COMMISSIONER PIGFORD: So perhaps that is another  
14 way in which it differs from TMI.

15 MR. KELLY: Yes, sir, only one of the -- at TMI  
16 neither auxiliary feed water pump was available for the first  
17 8 minutes of the transient.

18 COMMISSIONER PIGFORD: To your knowledge, does that  
19 difference during the first 8 minutes result in any large  
20 difference in the transient itself?

21 MR. KELLY: I wouldn't think it would make a large  
22 difference.

23 COMMISSIONER PIGFORD: Have you seen any analysis of  
24 that?

25 MR. KELLY: I have not seen them. I believe that

1 Mr. Dunn has run analyses like that, and he would be able to  
2 answer that.

3 COMMISSIONER PIGFORD: You don't think it would make  
4 a large difference, but these words are qualitating. Could  
5 you be more specific? How much difference?

6 MR. KELLY: Well, what I meant was, I don't think  
7 that the isolation of the feed water for 8 minutes at TMI II  
8 or the fact that the one feed water pump did not come up to  
9 full speed at Davis-Besse is as significant as the small loss  
10 of coolant accident that resulted at both plants. That was  
11 the overriding portion of the transient that had to be brought  
12 under control, in my mind.

13 COMMISSIONER PIGFORD: Was natural circulation  
14 established at Davis-Besse?

15 MR. KELLY: No, they never stopped the reactor  
16 coolant pumps.

17 COMMISSIONER PIGFORD: Are you familiar with the  
18 procedures that operators are supposed to follow in these  
19 small break loss of coolant accidents?

20 MR. KELLY: I have read the procedures that our  
21 training department uses in their simulator instructions. I  
22 am not familiar with what procedures each individual utility  
23 has developed for itself.

24 COMMISSIONER PIGFORD: Is this in -- could you then  
25 tell me this: suppose, at Davis-Besse, that the off-site

1 power had been lost, which means the pumps cannot operate --

2 MR. KELLY: Yes.

3 COMMISSIONER PIGFORD: -- the main cooling pumps.

4 And suppose the pressurizer relief valve had closed when it  
5 was supposed to. What procedures are the operators supposed  
6 to follow in that case?

7 MR. KELLY: He would be in a natural circulation  
8 mode of core cooling, in that case, so he would be following  
9 a natural circulation procedure.

10 COMMISSIONER PIGFORD: Can he just let it run on  
11 automatic? Is that all he needs to do?

12 MR. KELLY: The system will function automatically.  
13 He would have to monitor to make sure that it does function  
14 automatically.

15 COMMISSIONER PIGFORD: He doesn't have to improve  
16 on the automatic controls and do anything -- open any valves,  
17 close any valves?

18 MR. KELLY: No, sir. If the system is lined up it  
19 will fill up to the appropriate level on the secondary side of  
20 the steam generators and naturally circulate.

21 COMMISSIONER PIGFORD: Suppose auxiliary feed water  
22 is also lost. Then what must he do? Excuse me, let me pre-  
23 cede that with a question. If auxiliary feed water is also  
24 lost and if the relief valve is closed properly, are you aware  
25 of the procedure that the operator must follow?

1 MR. KELLY: No.

2 COMMISSIONER PIGFORD: You have not seen those at  
3 the instruction at the simulation?

4 MR. KELLY: No, I did not read that procedure.

5 COMMISSIONER PIGFORD: Do you know if they are there  
6 or not?

7 MR. KELLY: No, I do not.

8 COMMISSIONER PIGFORD: You have no knowledge of  
9 these procedures?

10 MR. KELLY: You are talking about a compound casual-  
11 ty, I believe, is that right? You are saying that you have  
12 lost off-site power and now you have also lost auxiliary feed  
13 water?

14 COMMISSIONER PIGFORD: Yes. The one thing that does  
15 work is the pressurizer relief valve is closed.

16 MR. KELLY: Yes.

17 COMMISSIONER PIGFORD: You are not familiar with  
18 the procedure on that?

19 MR. KELLY: I'm not -- I don't know if there is a  
20 written procedure on that, no.

21 COMMISSIONER PIGFORD: Well, do you know any pro-  
22 cedure, written or otherwise?

23 MR. KELLY: No.

24 COMMISSIONER PIGFORD: All right.

25 CHAIRMAN KEMENY: Commissioner Trunk?

1           COMMISSIONER TRUNK: How often has each relief valve  
2 failed to open?

3           MR. KELLY: I'm sorry, I can't hear that.

4           COMMISSIONER TRUNK: How often has each relief  
5 valve failed to open, or to close, I mean, to your knowledge?

6           MR. KELLY: I think I remember seeing a report on  
7 the order of 20 times, perhaps. I don't know. I can only  
8 tell you that I am aware that they didn't shut at Davis-Besse  
9 and Three Mile Island.

10          COMMISSIONER TRUNK: And you haven't investigated  
11 why?

12          MR. KELLY: Why, ma'am?

13          COMMISSIONER TRUNK: Why it doesn't do its job.

14          MR. KELLY: Well, I know why the one at Davis-Besse  
15 didn't shut. There was a missing relay in there that would  
16 prevent that valve from reseating and getting an adequate  
17 blowdown before it would have to reopen, so the valve sat  
18 t here and chattered at least nine times very rapidly opening  
19 and shutting until it beat itself apart. The valve at Three  
20 Mile Island, I believe we will find out why it didn't reshut  
21 when we can gain access to that valve.

22          COMMISSIONER TRUNK: But since you knew that it had  
23 18 other failures, didn't you do anything about it to make  
24 sure that it would close?

25          MR. KELLY: Ma'am, I didn't know that until -- that

1 there were 18 other failures -- until I read a report here  
2 recently.

3 CHAIRMAN KEMENY: Mr. Kelly, may I ask you the  
4 following question? Since your concern was whether adequate  
5 information was being sent out to the customers, what is your  
6 understanding of the process by which B&W decides to send  
7 instructions to customers?

8 MR. KELLY: The instructions were sent out from our  
9 Nuclear Service Department, and that is why I included the  
10 Nuclear Service people on my original memo. And if we could  
11 get agreement, if they thought that they were not adequate,  
12 then they would be the ones who would draft the appropriate  
13 words and disseminate them to the customers. Nuclear Service  
14 generates recommended operating procedures.

15 CHAIRMAN KEMENY: Do you know of other instances  
16 whether you, yourself, or someone else in your department has  
17 suggested sending out instructions to customers?

18 MR. KELLY: On any subject at all?

19 CHAIRMAN KEMENY: Well, on potential safety issues.

20 MR. KELLY: There are site instructions sent out  
21 and bulletins sent out to the customers routinely.

22 CHAIRMAN KEMENY: No, but I meant, did you know of  
23 any that were initiated by you or your department? Let me be  
24 more specific. I am trying to find out whether you, and even-  
25 tually your supervisors, sending such a suggestion is a very

1 common occurrence, only in a hundred, or are fairly rare.

2 MR. KELLY: It is the only time I have ever done it.

3 CHAIRMAN KEMENY: The only time you have ever done  
4 it.

5 MR. KELLY: Yes.

6 CHAIRMAN KEMENY: And you don't, from personal  
7 knowledge, know of another instance like that?

8 MR. KELLY: Not that I can recall now.

9 CHAIRMAN KEMENY: Yes. So, therefore, as far as you  
10 know, it is not an exceedingly common occurrence that this  
11 should happen?

12 MR. KELLY: That is correct.

13 CHAIRMAN KEMENY: Commissioner Lewis?

14 COMMISSIONER LEWIS: I noticed, Mr. Kelly,  
15 on your memorandum that you used the word "generic."

16 MR. KELLY: Yes, ma'am.

17 COMMISSIONER LEWIS: Why did you use the term  
18 "generic" on that memorandum?

19 MR. KELLY: To me, it meant I was concerned about  
20 all the B&W customers and whether they were getting this infor-  
21 mation, and the block on the thing that says "customers," I  
22 could have put a word that said "all." I could have put -- I  
23 could have individually listed every utility. I just used  
24 "generic" as a synonym for all customers.

25 COMMISSIONER LEWIS: So you were indicating, in other



1 words, that you felt this was a problem, the problem that you  
2 saw at Davis-Besse was applicable to all of the B&W plants.  
3 Is that correct?

4 MR. KELLY: Yes. My concern over whether we were  
5 sending, if we were sending appropriate words out, was applied  
6 to all plants, not just Davis-Besse, yes.

7 COMMISSIONER LEWIS: Okay. Let me just draw for  
8 you a scenario. Suppose that the operators at TMI II knew  
9 what you knew at Davis-Besse. Suppose this information had  
10 been transmitted to them. Do you think that accident is  
11 likely to have happened?

12 MR. KELLY: I cannot say that it would have made  
13 any difference because I thought they already had -- being  
14 trained in what they were supposed to do.

15 COMMISSIONER LEWIS: But obviously, they didn't  
16 have it, because they were not proceeding in a way that it  
17 is obvious -- I mean, they didn't recognize that the PORV was  
18 stuck open, and so on. Had they known that, had they known  
19 that this kind of incident had happened 18 months earlier and  
20 that information had been transmitted to TMI II, do you think  
21 that the accident could have been prevented?

22 MR. KELLY: Again, you are asking me to speculate  
23 something --

24 COMMISSIONER LEWIS: Yes.

25 MR. KELLY: -- that I have already considered --

1 I investigated -- let me answer this way -- I investigated  
2 the Davis-Besse transient and also the Three Mile Island II  
3 transient, and I was reviewing the graphs of the Three Mile  
4 Island II transient, it was obvious to me what had happened.  
5 That's all I can say.

6 CHAIRMAN KEMENY: Mr. Kelly, could I try Commis-  
7 sioner Lewis' question in a slightly different way? I don't  
8 ask that you speculate whether the operators did or did not  
9 have proper instructions. Simply the following factual ques-  
10 tion: your memorandum of November 1 has certain suggested  
11 procedures on HPI termination. Suppose those had been fol-  
12 lowed at TMI II? Would that have made a substantial differ-  
13 ence in the course of the accident?

14 MR. KELLY: The question is if they were to follow  
15 these instructions --

16 CHAIRMAN KEMENY: Yes.

17 MR. KELLY: -- yes, that would have made a differ-  
18 ence, I believe.

19 CHAIRMAN KEMENY: A favorable difference?

20 MR. KELLY: Yes.

21 CHAIRMAN KEMENY: A quite substantial one?

22 MR. KELLY: Yes.

23 CHAIRMAN KEMENY: Thank you. Dr. Marks?

24 COMMISSIONER MARKS: I want to just follow up on  
25 something, a question I heard. Although you were not allowed

1 access to the site, did Mr. Rogers, who was in the control  
2 room during your presence in the proximity of the site consult  
3 you during the period before you had gained access to the  
4 site, or any of the other members of B&W that had been dis-  
5 patched?

6 MR. KELLY: No, Mr. Rogers was just calling Mr.  
7 Shedell and talking to him, and the rest of us were in Mr.  
8 Shedell's house. But the only communication was between Mr.  
9 Rogers and Mr. Shedell.

10 COMMISSIONER MARKS: Well, did Mr. Shedell consult  
11 you on the basis of Mr. Rogers' conversations with him?

12 MR. KELLY: He was telling us the information that  
13 he had available, and he was relaying that same information  
14 back to Lynchburg and asking them for recommendations.

15 COMMISSIONER MARKS: You mean you served no function  
16 while you sat there?

17 MR. KELLY: That's right.

18 COMMISSIONER MARKS: I see. Did Lynchburg advise  
19 Shedell with regard to any aspects of the accident during this  
20 period between the morning of the 28th until you gained access  
21 to the site?

22 MR. KELLY: That day, the first day of the accident  
23 I can remember Mr. Shedell relaying information to Lynchburg  
24 and asking for Lynchburg's recommendation on restarting a  
25 reactor coolant pump. They had already shut them down at this

1 point in time. When we went out to dinner, the five of us,  
2 and came back to Mr. Shedell's house after dinner, the reactor  
3 coolant pump was running, so I assumed that the recommendation  
4 did come through and was relayed to the people on the site  
5 and they acted on it.

6 I don't remember Mr. Shedell saying that Lynchburg  
7 says to do this and --

8 COMMISSIONER MARKS: Was there any discussion on the  
9 28th of any aspects of TMI II relevant to your previous expe-  
10 rience with Davis-Besse?

11 MR. KELLY: No, there was not. The information at  
12 Mr. Shedell's house was too fragmentary for me to make the  
13 connection at that point.

14 COMMISSIONER MARKS: You mean, during the 28th, it  
15 did not occur to you that there were things going on at TMI II  
16 which recalled the Davis-Besse accident?

17 MR. KELLY: No.

18

19

20

21

22

23

24

25

1 1 CHAIRMAN KEMENY: Commissioner McBride.

2 COMMISSIONER MC BRIDE: Mr. Kelly, I wonder if  
3 you would describe in greater detail the difference  
4 that following your instructions, as outlined in the  
5 November 1st memorandum, you outlined the difference  
6 you feel that following those instructions would have  
7 made at Three-Mile.

8 MR. KELLY: In step B of that instruction, it  
9 says once the high pressure injection is initiated,  
10 don't stop it unless average temperature is stable or  
11 going down and pressurizer level is increasing and  
12 primary pressure is at least 1600 pounds and increasing.

13 That's not what they did. They had them going  
14 in opposite directions when they stopped high pressure  
15 injection. I think if they would have left it on  
16 through those instructions, core cooling would have  
17 continued to be provided.

18 COMMISSIONER MC BRIDE: That means that TMI  
19 would have been insignificant, as opposed to the serious  
20 situation we're now in, and cooling continued.

21 MR. KELLY: That's my opinion. It may have  
22 been, yes.

23 COMMISSIONER MC BRIDE: Thank you.

24 CHAIRMAN KEMENY: Do you have further questions,  
25 Professor Pigford? Yes?

LA 2 1 COMMISSIONER PIGFORD: Mr. Kelly, I recall that  
2 you said earlier that you thought the open relief valves,  
3 the stuck open relief valve would be more important to  
4 safety than the loss of auxiliary feedwater. Is that  
5 correct?

6 MR. KELLY: Than the loss of feedwater for that  
7 time period, yes, eight minutes or something like that.

8 COMMISSIONER PIGFORD: Now, let's take this  
9 case. Given that we have a reactor in which the feed-  
10 water was lost, for some time period, like eight minutes,  
11 then which is better, to have the relief valve stuck  
12 open or come closed? Assuming everything else works  
13 properly, the high pressure injection works automatically  
14 and so forth, which is better, to have the relief  
15 stay open during that eight minutes or closed? Which  
16 is better for safety? Which is better to keep the core  
17 from being uncovered?

18 MR. KELLY: If you lost feedwater for eight  
19 minutes and no auxiliary feedwater, pressure's going to  
20 be high enough to open that relief valve. It will be  
21 open.

22 COMMISSIONER PIGFORD: Mr. Kelly, do you think  
23 it will stay open for eight minutes?

24 MR. KELLY: If you're not removing primary  
25 heat, it may open and shut and reopen.

LA 3 1

COMMISSIONER PIGFORD: Could you please say  
2 that once more?

3 MR. KELLY: If you're not removing any core  
4 heat, the pressure will continue to go up and relieve  
5 and go down. And then when it reseats, it will reopen  
6 again.

7 COMMISSIONER PIGFORD: Yes, okay. So it will  
8 close and then reopen, which is the way it's designed.  
9 But from the point of view of avoiding core damage,  
10 which is better, for that intermittent opening or for  
11 it to just stay open?

12 MR. KELLY: You're asking questions outside of  
13 my area of expertise. But it seems like it may be  
14 better to let it stay open and blow down and get high  
15 pressure injection on.

16 CHAIRMAN KEMENY: Mr. Kelly, just before excusing  
17 you, I just wanted to summarize two or three major  
18 points that I believe you brought out. One is you  
19 wrote the memorandum in November of 1977, which we  
20 went through, in which you made certain recommendations.  
21 That is correct, is it not?

22 MR. KELLY: Yes.

23 CHAIRMAN KEMENY: And secondly, you brought out  
24 that there were some significant differences, there were  
25 also some significant similarities in the events of



LA 4 1 Davis-Besse one and TMI two.

2 MR. KELLY: Yes.

3 CHAIRMAN KEMENY: And that you stated your  
4 opinion that if particularly the second part of your  
5 recommendation had been followed at TMI two, the  
6 accident would have been a minor one rather than a major  
7 one, in your opinion.

8 MR. KELLY: That's my --

9 CHAIRMAN KEMENY: Thank you. Mr. Kelly, you're  
10 excused, subject to recall.

11 Would chief counsel please call and swear in  
12 the second witness?

13 MR. GORINSON: Bert Dunn, please.

14 MR. EDGAR: Mr. Chairman, my name is George  
15 Edgar. I'm counsel for Babcock and Wilcox. Mr. Dunn  
16 had reached me early this morning by telephone and  
17 explained that he had missed the plane, but he expected  
18 to come directly to auditorium by 9:30. And he is not  
19 here yet. He intends to be here. But I have no further  
20 information.

21 He has just arrived.

22 CHAIRMAN KEMENY: While waiting for Mr. Dunn,  
23 may I ask counsel if we have any late information on a  
24 certain event in the Dunn family?

25 MR. EDGAR: I didn't hear you.

LA 5

1 CHAIRMAN KEMENY: While we're waiting for Mr.  
2 Dunn, may I ask if the counsel has any late information  
3 on a certain expected event in Mr. Dunn's family?

4 MR. EDGAR: I have nothing. This may indeed  
5 be the cause of the delay.

6 CHAIRMAN KEMENY: Yes. For the information of  
7 the rest of you -- I understand he's here, isn't he?  
8 Do I understand Mr. Dunn is in the building?

9 MR. EDGAR: Yes, he's just at the witness check-  
10 in table.

11 CHAIRMAN KEMENY: Very good.

12 Mr. Chief Counsel, would you please swear in  
13 the witness?

14 MR. GORINSON: Mr. Dunn, would you raise your  
15 right hand? Do you solemnly swear that the testimony  
16 you are about to give will be complete, the whole  
17 truth, and nothing but the truth, so help you God?

18 MR. DUNN: I do.

19 CHAIRMAN KEMENY: Would you please state your  
20 name for the record and your current position with  
21 Babcock and Wilcox?

22 MR. DUNN: My name is Bert Merit Dunn. I am  
23 manager of emergency core cooling analysis for Babcock  
24 and Wilcox.

CHAIRMAN KEMENY: Thank you. Chief counsel?

LA

6 1

MR. GORINSON: Thank you, Mr. Chairman.

2

3

Mr. Dunn, the emergency core cooling analysis unit is part of the design section. Is that correct?

4

5

MR. DUNN: It is part of the plant design section.

6

7

MR. GORINSON: Plant design section. That's also part of the engineering department at Babcock and Wilcox.

8

9

MR. DUNN: That is correct.

10

11

MR. GORINSON: What are the responsibilities of your ECCS unit?

12

13

14

15

16

17

18

19

20

21

22

MR. DUNN: Our responsibilities would be mainly to provide assurance that the emergency core cooling system, as designed, would prevent excessive core problems under the condition that a loss of coolant accident had occurred at the nuclear plant. We also have additional responsibilities associated with hydraulic loads, which can occur initially at the time of a loss of coolant accident, and for certain considerations regarding the efflux or the fluid that leaves the primary system during a loss of coolant accident, its interactions within the reactor building.

23

24

MR. GORINSON: What are your duties as manager of that unit, Mr. Dunn?

25

MR. DUNN: That would involve maintaining an

Bowers Reporting Company

LA 7 1 adequate staff, being the coordinator for the unit's  
2 activities, providing tools for the staff, and, I  
3 suppose, being in charge of the procedures or technical  
4 ways in which we provide the verification for the  
5 emergency core cooling system design.

6 MR. GORINSON: When did you first learn about  
7 the events that occurred at the Davis-Besse plant on  
8 September 24th, 1977?

9 MR. DUNN: I would say it would be within one  
10 or two days after the event, perhaps the same day.

11 MR. GORINSON: Did you, within a few days of  
12 that event, attend a briefing that Mr. Kelly gave on  
13 Davis-Besse?

14 MR. DUNN: Yes, I believe I did.

15 MR. GORINSON: And what information about the  
16 Davis-Besse events were you given at that briefing?

17 MR. DUNN: The specifics of that information I  
18 have not been able to recall at this time. I think we  
19 were given a general description of the primary system  
20 parameters and how they evolved throughout the transient.

21 MR. GORINSON: Did you reach a conclusion at  
22 some time that the Davis-Besse transient of September 24th,  
23 1977, was not a normal transient?

24 MR. DUNN: Yes, sir.

25 MR. GORINSON: When did that happen?

LA 8 1 MR. DUNN: I again think that would have been  
2 within a few days of the 24th.

3 MR. GORINSON: And what led you to the conclusion  
4 that it was an unusual transient?

5 MR. DUNN: The transient involved the failing  
6 in the open position of a relief valve on the top of  
7 the pressurizer, termed, I believe, the PORV valve.  
8 That valve is not supposed to fail in the open position.  
9 It's supposed to reclose, following a pressure spike  
10 in the primary system, and it had remained open for  
11 an extended period of time.

12 MR. GORINSON: Were there other events that  
13 occurred during that transient that you considered  
14 unusual?

15 MR. DUNN: Yes, there had been a termination  
16 of the high pressure injection system during the  
17 first minutes of the transient. I can't give you an  
18 exact time. I could obtain that information. But it  
19 was at a time I felt was inappropriate.

20 MR. GORINSON: And you learned all those things  
21 before Mr. Kelly sent his November 1, 1977 memorandum?

22 MR. DUNN: Yes, sir.

23 MR. GORINSON: And did you discuss the Davis-  
24 Besse transient with Mr. Kelly?

25 MR. DUNN: I would have to say I had many

LA 9 1 discussions with Mr. Kelly on the Davis-Besse transient.

2 MR. GORINSON: Before he sent this memorandum?

3 MR. DUNN: I believe so.

4 MR. GORINSON: And did you encourage him to

5 send this memorandum?

6 MR. DUNN: I believe in the depositions we

7 gave you, I said I did. I think that's still correct.

8 There's some controversy on actively I encouraged it.

9 I certainly would have, and I was seeking such a

10 memorandum to be issued.

11 MR. GORINSON: Had the issue of operator

12 interruption of high pressure injection been analyzed

13 at Babcock and Wilcox before the Davis-Besse accident?

14 MR. DUNN: Not to my knowledge.

15 MR. GORINSON: Was it your view, at or about

16 the time that Mr. Kelly sent this memorandum, that

17 Babcock and Wilcox customers should be given more

18 guidance on the operation of high pressure injection?

19 MR. DUNN: I believe I'd rather say that

20 we were seeking a forum of discussion on the issue.

21 For reasons that at that time I may not have been aware

22 of, the action in that event could have been quite

23 proper. I did not feel it was at that time. As of

24 today, I still do not feel that was a proper action.

25 But I would say we were seeking a forum for discussion

LA 10 1 to make a decision as to whether or not the operators  
2 should be informed or be given additional guidance.

3 MR. GORINSON: You said something about some-  
4 thing not being a proper action. What were you referring  
5 to?

6 MR. DUNN: I was referring to the termination  
7 of high pressure injection, as it occurred during that  
8 transient, specifically the Davis-Besse transient of  
9 September 24th.

10 MR. GORINSON: Okay. We'll come back to my  
11 question, sir. Was it your view at that time that  
12 Babcock and Wilcox customers should be given more  
13 guidance on high pressure injection?

14 MR. DUNN: I suppose, considering that at that  
15 time, I personally felt that was inappropriate action,  
16 then I would have to say that I felt that they should  
17 have been given more guidance, or informed of the  
18 event.

19 MR. GORINSON: Before Mr. Kelly sent his  
20 November 1, 1977 memorandum, did you speak with B and  
21 W's training department to find out what operators were  
22 being taught about high pressure injection?

23 MR. DUNN: No, sir, I did not.

24 MR. GORINSON: You did receive a copy of Mr.  
25 Kelly's November 1, 1977 memorandum.



LA 11 1

MR. DUNN: Yes.

2

MR. GORINSON: Did you prepare a response?

3

MR. DUNN: No.

4

MR. GORINSON: Did you give Mr. Kelly your thoughts on the subject orally?

6

MR. DUNN: I believe that's correct.

7

MR. GORINSON: What did you tell Mr. Kelly?

8

MR. DUNN: Again there would be many discussions in and around this time frame. And the particulars of

10

what I would have told Mr. Kelly I cannot recall. I

11

can say that I felt his memo was aimed at the point

12

I was trying to get resolved, and we were trying to

13

start a forum.

14

MR. GORINSON: Were you in agreement with

15

Mr. Kelly's recommended guidelines in his November 1

16

memo? And to help you, there should be a copy of

17

Mr. Kelly's November 1 memo there on the table.

18

MR. DUNN: I think it would be best to say

19

that the instructions contained in items A and B of

20

this memo point in the right direction, in the direction

21

that I would indicate -- would feel would be very

22

positive towards resolving my concerns. But I'm not

23

sure that I would wholly agree that they were entirely

24

adequate at that time. Again we were trying to start

25

a forum in which we could completely, you might say, knock

LA 12 1 out all of the considerations.

2 MR. GORINSON: You wanted further discussion  
3 on the subject?

4 MR. DUNN: Further discussion. What I wanted  
5 was a full reactor coolant system. I'm not sure that  
6 this prescription of 1600 PSIG provides me that.

7 MR. GORINSON: When you say a full reactor  
8 cooling system, what do you mean, sir?

9 MR. DUNN: I mean full of water, in its liquid  
10 form.

11 MR. GORINSON: You mean going solid, is that  
12 what that's --

13 MR. DUNN: I would not mean going solid.  
14 I used reactor coolant system. I would rather it be  
15 considered reactor coolant system less the pressurizer.

16 MR. GORINSON: After Mr. Kelly wrote his  
17 memorandum, what happened? Was there any response?

18 MR. DUNN: Not that I was aware of.

19 MR. GORINSON: Did Mr. Kelly tell you whether  
20 he was getting response from the company, from the  
21 people he'd written to?

22 MR. DUNN: The lack of response on the Kelly  
23 memo, or to integration in general prompted a follow-on  
24 memo by myself. I'm sure that in preparing that memo,  
25 I asked the question as to whether there had been

LA 13 1 response on this issue.

2 MR. GORINSON: Could we put in front of Mr. Dunn  
3 what's been premarked as Commission Hearing Exhibit Number  
4 3? This is a memo from Bert Dunn to Jim Taylor, dated  
5 February 9th, 1978. Do you have that in front of you,  
6 sir?

7 MR. DUNN: Yes.

8 MR. GORINSON: Is this the follow-up memo you  
9 just referred to?

10 MR. DUNN: Yes.

11 MR. GORINSON: And specifically what led you  
12 to write this memorandum on February 9th, 1978?

13 MR. DUNN: I think the best characterization  
14 would be that I had not seen positive action, which  
15 I could interpret as leading to instructions to prevent  
16 premature operator termination of high pressure injection  
17 or resolution of my concern in a fashion that  
18 would say it really wasn't premature.

19 MR. GORINSON: You sent this to Jim Taylor.  
20 He's the manager of licensing. Is that correct?

21 MR. DUNN: That's correct.

22 MR. GORINSON: And why did you address this to  
23 him?

24 MR. DUNN: I felt Mr. Taylor was an influential  
25 person concerned with safety and could, so to speak, start

1 the ball rolling.

2 MR. GORINSON: I see. Now, on the second page  
3 of your memorandum, you list as copiees various other  
4 individuals in the organization. Can we just quickly  
5 go through and identify those people and what their  
6 titles are?

7 Who is Mr. Swanson?

8 MR. DUNN: Mr. Swanson is a supervisor in the  
9 integration unit. Integration is an additional unit  
10 within the plant design section. In particular, I  
11 believe Mr. Swanson is Mr. Kelly's supervisor.

12 MR. GORINSON: Mr. Roy?

13 MR. DUNN: Mr. Roy, at this time, was the  
14 manager of the plant design section.

15 MR. GORINSON: And today what is Mr. Roy's  
16 position?

17 MR. DUNN: He is the manager of the engineering  
18 department.

19 MR. GORINSON: Mr. Karrasch?

20 MR. DUNN: Mr. Karrasch would be the manager  
21 of the integration unit.

22 MR. GORINSON: Mr. Bailey?

23 MR. DUNN: Mr. Bailey is a ngeener within the  
24 licensing section, assigned to the generic licensing  
25 unit.

LA 15

1 MR. GORINSON: Mr. Kelly, that's the Mr. Kelly  
2 who had written the November 1, 1977 memorandum. Is  
3 that right?

4 MR. DUNN: Yes, sir.

5 MR. GORINSON: Mr. Kane?

6 MR. DUNN: Mr. Kane is a member of the licensing  
7 section. At the time of issuance of this memo, he  
8 was either a unit manager, in charge of operating plants,  
9 or on special assignment to that section.

10 MR. GORINSON: Mr. Agar?

11 MR. DUNN: Mr. Agar is additionally a unit  
12 manager in the licensing section.

13 MR. GORINSON: Mr. Pittman?

14 MR. DUNN: Mr. Pittman, I cannot specifically  
15 give you his title. He is a member of the nuclear  
16 service department.

17 MR. GORINSON: Mr. Phinny?

18 MR. DUNN: Mr. Phinny would also be a member of  
19 the nuclear service department.

20 MR. GORINSON: And Mr. Scott?

21 MR. DUNN: Again, I believe Mr. Scott is a member  
22 of the nuclear service department.

23 MR. GORINSON: In writing this February 9th, 1978  
24 memorandum, you were addressing the same concern that had  
25 previously been addressed by Mr. Kelly.

16 1

MR. DUNN: Yes, sir, I believe that's correct.

2

MR. GORINSON: And thus the concern that arose out of the events at Davis-Besse one?

4

MR. DUNN: Yes.

5

MR. GORINSON: And can we look at the second paragraph of your February 9th, 1978 memo, the last sentence of that second paragraph? Would you read that for us, sir?

9

MR. DUNN: Yes, I think I'd like to say that up until this time, I believe the memo contains a description of the events at Davis-Besse. And I carry on to say, "Had this event occurred in a reactor at full power with other than insignificant burnup, it is quite possible, perhaps probable, that core uncovering and possible fuel damage would have resulted."

16

MR. GORINSON: And what did you base that on, that conclusion?

18

MR. DUNN: Primarily my experience involved with the prediction of loss of coolant accidents, for approximately eight years, and a knowledge that high pressure injection, under the conditions of a loss of coolant accident, is necessary to prevent the events I've described.

24

MR. GORINSON: I see. It was your view, was it not, as expressed at the beginning of the third paragraph,

25

Bowers Reporting Company

LA 17

1 that Babcock and Wilcox had not supplied sufficient infor-  
2 mation to reactor operators in the area of recovery from  
3 LOCA?

4 MR. DUNN: Well, inasmuch as I wrote that  
5 sentence, yes.

6 MR. GORINSON: And was this memorandum also  
7 designed to provide a basis for discussion?

8 MR. DUNN: I believe that was my intent in  
9 writing this.

10 MR. GORINSON: Why were these particular  
11 individuals copied on the memorandum to Mr. Taylor?

12 MR. DUNN: I would say that, in all probability,  
13 Mr. Kelly and myself and probably Mr. Swanson discussed  
14 my issuance of a memo, for which I was responsible for  
15 the content. But we accumulated names of people within  
16 the various sections that we felt could start a forum  
17 of discussion during which an acceptable prescription  
18 for termination of high pressure injection could be  
19 identified.

20 MR. GORINSON: Did you include the training  
21 department in that forum for discussion, at all?

22 MR. DUNN: I don't believe so.

23 MR. GORINSON: Did you talk to the training  
24 department before writing your memorandum?

25 MR. DUNN: No, sir, I did not.



LA 18 1 MR. GORINSON: Are you aware of a system at  
2 Babcock and Wilcox called a preliminary safety concern  
3 system?

4 MR. DUNN: Yes.

5 MR. GORINSON: And what department is respon-  
6 sible for that system? For administering it.

7 MR. DUNN: The administration responsibilities  
8 lie within the licensing section of the engineering  
9 department.

10 MR. GORINSON: Is that Mr. Taylor's section?

11 MR. DUNN: Mr. Taylor is the person to which  
12 the form is addressed, and responsible at least for  
13 the initial form of discussions and distribution of the  
14 concern.

15 MR. GORINSON: Why wasn't this memorandum  
16 on a preliminary safety concern form?

17 MR. DUNN: I think the answer would be that I  
18 felt that this memorandum, if it were successful in  
19 instigating a review of my concerns and achieving  
20 resolution of those concerns, would have been sufficient.  
21 Had this not accomplished that in my mind, I believe  
22 then I would have issued a PSC.

23 MR. GORINSON: Did you consider this to be a  
24 safety concern at the time you wrote the memorandum?

25 MR. DUNN: I consider it to be a highly possible

LA 19

1 concern to the safety of a plant.

2 MR. GORINSON: And something that's a highly  
3 possible concern for the safety of a plant, is that  
4 something that normally goes on the preliminary safety  
5 concern form?

6 MR. DUNN: It would be a candidate for the  
7 preliminary safety concern form. I would say it's not  
8 absolutely mandatory that it goes on that.

9 MR. GORINSON: So you thought that putting it  
10 in memorandum form would still get the attention you  
11 believed it deserved.

12 MR. DUNN: Yes.

13 MR. GORINSON: Did Mr. Taylor respond to your  
14 February 9th memorandum?

15 MR. DUNN: I'm unclear on that point. I  
16 mentioned in my discussions during the deposition that  
17 there may have been a telephone communication between  
18 myself and Mr. Taylor. There was no written communica-  
19 tion.

20 MR. GORINSON: Well, can you tell us what the  
21 substance of that telephone communication was with  
22 Mr. Taylor?

23 MR. DUNN: Well, if, in fact, it occurred -- and  
24 I mentioned that I was very unclear on that, it would be  
25 what you'd call a ghost in my memory -- the content, as

LA 20 1 it appears there, is that Mr. Taylor was redirecting the  
2 memo to the nuclear service department.

3 MR. GORINSON: Did he tell you why he was  
4 redirecting it to the nuclear service department?

5 MR. DUNN: I don't believe so, in that  
6 conversation.

7 MR. GORINSON: Did you point out to Mr. Taylor  
8 during that telephone conversation the last paragraph  
9 of your memo of February 9th, which says, "I believe  
10 this is a very serious matter and deserves our prompt  
11 attention and correction"?

12 MR. DUNN: I would not say I specifically pointed  
13 that out. I think I felt that Mr. Taylor had read the  
14 memo and understood its implications.

15 MR. GORINSON: But he did not tell you why  
16 it was being routed to the nuclear service department.

17 MR. DUNN: Well, I wouldn't say he did not  
18 tell me. I said I did not recall that conversation in  
19 detail, or even if it really occurred.

20 MR. GORINSON: Have you ever learned from Mr.  
21 Taylor why he routed this memorandum to the nuclear  
22 service department?

23 MR. DUNN: He has given me some reasons.

24 MR. GORINSON: What were those reasons?

25 MR. DUNN: He felt the memo was misdirected and

LA 21

1 for resolution should have gone to nuclear service.

2 MR. GORINSON: Did he tell you why it was  
3 misdirected?

4 MR. DUNN: He felt that it was a matter of a  
5 changing procedure, which would be accomplished -- or  
6 could be accomplished best by that department.

7 MR. GORINSON: After you had put in your  
8 February 9th memo, what occurred next, sir?

9 MR. DUNN: As I recall, the first thing that  
10 occurred is I was approached by a member of the nuclear  
11 service department and we held discussions concerning  
12 the memo. I believe, to some extent, there was a  
13 brief explanation as to why I considered it inappropriate,  
14 the termination of high pressure injection, as it  
15 occurred in Davis-Besse.

16 Following that, a alternate prescription for  
17 termination of high pressure injection was put forward  
18 by this person. And after review and discussion of the  
19 alternate procedure, I concluded that it satisfied my  
20 concerns, as well as the one I had provided in my  
21 February 29th memo. Nuclear service felt it was more  
22 practical, more implementable. And I documented my  
23 agreement with that alternate prescription in a follow-on  
24 memo.

Bowers Reporting Company

25 MR. GORINSON: Who was the person from nuclear

A 22 1 service that you were dealing with?

2 MR. DUNN: Well, I'm going to have to give a  
3 hazy response to that. I've searched my memory many  
4 times to try and identify that individual. And I cannot  
5 positively identify him. But I have asked around the  
6 section, the nuclear service section, as to who that  
7 individual would be. And the most likely candidate  
8 would be Mr. Carl Goslow.

9 MR. GORINSON: Now, just so we understand, is  
10 it fair to say that the people you were dealing with  
11 from nuclear service did not dispute your prediction  
12 that, had the event occurred in the reactor at full  
13 power with other than insignificant burnup, it is quite  
14 possible, perhaps probable, that core uncovering and  
15 possible fuel damage would have resulted? Did they  
16 challenge that during your discussion?

17 MR. DUNN: They may have. I would say that  
18 after the discussion and the explanation of the reasons  
19 I had for predicting that, that they -- the individual,  
20 I'm using the word "they"; that's probably overstating  
21 it -- the individual with whom I was discussing the  
22 events deferred to my judgement, if he didn't necessarily  
23 believe it. And I'd say I felt he was believing me.

24 MR. GORINSON: But from your perception, they  
25 did not challenge you -- or he did not challenge you, from

LA 23 1 your discussions with him.

2 MR. DUNN: Again, I would say that we had, I  
3 think, a discussion of the reasons I made the prediction.  
4 Now, that means he probably asked me something on the  
5 order of how could this happen, which is a possible  
6 challenge. But by the end of those discussions, there  
7 weren't those concerns evident in the talking, the  
8 bantering.

9 MR. GORINSON: He didn't tell you you were  
10 wrong.

11 MR. DUNN: No, not anything that flat.

12 MR. GORINSON: Is it fair to say the bulk of  
13 the discussions concerned the prescription?

14 MR. DUNN: Yes, it would be fair to say that.

15 MR. GORINSON: Can we put in front of Mr. Dunn  
16 a document that's been premarked as Commission Exhibit  
17 Number 4, and it is a memorandum dated February 16th,  
18 1978, from Bert Dunn to Jim Taylor, subject, operator  
19 interruption, high pressure injection? Do you have  
20 Exhibit Number 4 in front of you, Mr. Dunn?

21 MR. DUNN: I have my February 16th memo in  
22 front of me.

23 MR. GORINSON: Okay. Is that the follow-up  
24 memo you were referring to?

25 MR. DUNN: Yes.

LA 24 1 MR. GORINSON: And this represented the resolu-  
2 tion of the discussions between yourself and the person  
3 from nuclear service?

4 MR. DUNN: Yes.

5 MR. GORINSON: And, as you state in the last  
6 paragraph, you found the scheme to be acceptable?

7 MR. DUNN: Yes.  
8  
9  
10  
11  
12  
13  
14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25



TMI  
7/18/79

1

Tape 4

73

1 MR. GORINSON: You sent this memorandum to Mr. Taylor  
2 as well. What was your reason for doing that?

3 MR. DUNN: I believe this memo goes to Mr. Taylor as  
4 an attempt to communicate with him that action had taken place  
5 on my concerns and that in my opinion a prescription which would  
6 satisfy myself as well as the nuclear service had been agreed to.

7 MR. GORINSON: Did you know at that time that Mr. Taylor  
8 believed that these memos had been misdirected?

9 MR. DUNN: I think misdirected -- the word misdirected  
10 comes out much later. I knew at that time -- let me restate that  
11 a little bit -- if my memory of the phone conversation is ac-  
12 curate, and I would like to again say that it is very foggy, I  
13 would have known that Mr. Taylor had passed this on to the  
14 Nuclear Service Department.

15 MR. GORINSON: Was it still your view though as of  
16 February 16th that licensing was playing a part in the resolution  
17 of this matter?

18 MR. DUNN: Certainly, by issuing the original memo to  
19 Mr. Taylor, action which had not been evident for over a month  
20 had started.

21 MR. GORINSON: So the answer would be yes? You assumed  
22 licensing was playing a part in this?

23 MR. DUNN: Well, I don't know that they were playing  
24 an active part in it but it had the appearance that at least  
25 they were an instigator of some value.

Bowers Reporting Company

486 123

sg 2 1 MR. GORINSON: So the answer from your point of view  
2 was that you assumed they were playing some part in it? Is that  
3 correct?

4 MR. DUNN: If that part could be as small as a tele-  
5 phone call to somebody in Nuclear Service or a communication  
6 that would say, hey, I think you ought to do something about  
7 this, then they may have had a part.

8 MR. GORINSON: Now, as you understood it on February  
9 16th, 1978, were the recommendations contained in that memo  
10 going to be distributed to B and W's customers?

11 MR. DUNN: I was operating under that assumption.

12 MR. GORINSON: Excuse me, I didn't --

13 MR. DUNN: I was operating under that assumption.

14 MR. GORINSON: So it was your understanding that it  
15 was going to be sent to customers?

16 MR. DUNN: Yes, I would think that would be the only  
17 way in which the recommendations could be incorporated.

18 MR. GORINSON: And were those recommendations sent to  
19 the customers? After February 16th, 1978?

20 MR. DUNN: To my knowledge, no.

21 MR. GORINSON: Did you have further discussions with  
22 Nuclear Service between February and August of 1978 as to prob-  
23 lems or concerns that Nuclear Service had with the recommendations  
24 contained in your February 16th memorandum?

25 MR. DUNN: Again, to my knowledge, I did not have

sg 3

1 discussions of that nature.

2 MR. GORINSON: Do you know what Nuclear Service did  
3 with your February 16th memorandum?

4 MR. DUNN: I know of some follow-up communication on  
5 the memorandum.

6 MR. GORINSON: What follow-up communication is that,  
7 sir?

8 MR. DUNN: In August -- or I believe it is in August,  
9 I think it is August 3rd of 1978 a memo was written from Mr.  
10 Don Hallman to Mr. Bruce Karrasch on this subject.

11 MR. GORINSON: Could we give Mr. Dunn a copy of what has  
12 been pre-marked as Commission Exhibit number five? This is an  
13 August 3rd memorandum from D.F. Hallman to B.A. Karrasch. Is  
14 this the memorandum you were just referring to, Mr. Dunn?

15 MR. DUNN: Yes, sir.

16 MR. GORINSON: When were you told about that August 3rd  
17 memorandum?

18 MR. DUNN: I am not exactly sure. I think it was with-  
19 in a month of March 28, 1979. It was certainly after March 28,  
20 1979.

21 MR. GORINSON: So it was after March 28, 1979 that you  
22 learned about it?

23 MR. DUNN: That I became aware of it, yes.

24 MR. GORINSON: The memorandum, you will note, lists  
25 you as copy "E" in the right hand corner.

1 MR. DUNN: Yes, sir.

2 MR. GORINSON: But to your knowledge, and to your  
3 recollection, you do not remember seeing that memorandum before  
4 March 28th, 1979?

5 MR. DUNN: That is correct.

6 MR. GORINSON: What was your reaction when you heard  
7 about the existence of this August 3rd, 1978 memorandum?

8 MR. DUNN: I don't think my reaction is printable. I  
9 was very upset.

10 MR. GORINSON: Why was that?

11 MR. DUNN: Primarily because it was one of the first  
12 indicators that I had that the instructions had not gone out.  
13 And I believe I had also had verbal discussions that the in-  
14 structions had not gone out. I also expected, when I heard about  
15 it, that I had been on distribution for this memo and that would  
16 then mean that I had the possibility -- or would have had the  
17 possibility to again instigate action along the lines of my con-  
18 cern.

19 MR. GORINSON: Looking at the memorandum itself,  
20 Nuclear Service, in the middle of the paragraph, Mr. Hallman  
21 recommends that two incidents should be evaluated. Do you see  
22 that?

23 MR. DUNN: Items one and two?

24 MR. GORINSON: Yes, sir.

25 MR. DUNN: Yes, I see that.

sg 5

1 MR. GORINSON: What was your reaction to those con-  
2 cerns that were being raised by Nuclear Service?

3 MR. DUNN: At what time, sir?

4 MR. GORINSON: When you learned of the memorandum and  
5 had an opportunity to read it.

6 MR. DUNN: I think my reaction would be that I did not  
7 believe them to be concerns but worthy of evaluation and that I  
8 would say we should probably check those items for consequences  
9 but that in my belief they would not provide consequences severe  
10 enough to change the prescriptions.

11 MR. GORINSON: Let us take a look at the first one.  
12 It says that the pressurizer goes solid with one or more HPI  
13 pumps continuing to operate. Would there be a pressure spike  
14 before the release opened which could cause damage to the RCS.  
15 Do you see that?

16 MR. DUNN: Yes, sir.

17 MR. GORINSON: If that question were answered affirma-  
18 tively, would that give rise to a safety concern?

19 MR. DUNN: I think my answer should be that there are  
20 concerns about going solid when it is not necessary but in line  
21 with the conditions for which we are using the high pressure  
22 injection system in the event of a loss of coolant accident,  
23 this concern would not be as weighty as the accident.

24 MR. GORINSON: So it would be a less significant  
25 concern? Is that what you are saying?

Bowers Reporting Company

1 MR. DUNN: I think that is probably pretty good.

2 MR. GORINSON: What about the second question? What  
3 damage would the water surge through the relief valve discharge  
4 piping and quench tank cause? If that is answered affirmatively,  
5 does that give rise to any safety concern?

6 MR. DUNN: By affirmatively, you mean that damage  
7 would occur?

8 MR. GORINSON: Yes, there is damage.

9 MR. DUNN: Well, underwriting these concerns would be  
10 the possibility that if we hadn't had a LOCA and the prescription  
11 was followed, there may be the possibility of creating one. How-  
12 ever, again, the prescription is necessary to survive a loss of  
13 coolant accident and I would say that should take precedent.  
14 We would not have, for example, core damage in these events. We  
15 would probably have some equipment that would have to be re-  
16 placed. We would have effluent into the reactor building if  
17 the quench tank, for example, burst. But we would be in a re-  
18 coverable mode.

19 MR. GORINSON: So there would be equipment damage? Is  
20 that what you are saying?

21 MR. DUNN: Well, if I break a quench tank -- I consider  
22 that equipment damage.

23 MR. GORINSON: Now, the last sentence of the paragraph  
24 that follows those questions, says, "yet, the references suggest"  
25 and I see the references at the top of your two memoranda, "the

sg 7

1 possibility of uncovering the core if present HPI policy is con-  
2 tinued". See that?

3 MR. DUNN: Yes.

4 MR. GORINSON: Is core uncovering a significant safety  
5 concern?

6 MR. DUNN: Not core uncovering in itself. A loss of  
7 coolant accident, I think is a significant safety issue. Okay?  
8 During the loss of coolant accident we can undergo a certain de-  
9 gree of core uncovering and here, when I talk about core uncovering  
10 I am talking about two separated regions of cooling -- a region  
11 of basically water with steam bubbles located in it and I would  
12 say that portion of the core below that region is covered; and  
13 a region of just steam above that region, that portion I would  
14 call uncovered. We can have that type of event to a certain ex-  
15 tent. We cannot have a large amount of it without having severe  
16 core damage. Now, core damage itself is not the end of the game.  
17 Exceedingly high temperatures are required to cause the major  
18 concerns with the loss of coolant accident. Again, these high  
19 temperatures would be possible at slightly greater core uncovering  
20 than those that would cause fuel damage.

21 MR. GORINSON: When you have got core uncovering it is  
22 significant though, is it not?

23 MR. DUNN: I think it is significant, yes.

24 MR. GORINSON: To your knowledge, were those two ques-  
25 tions in the August 3rd memorandum evaluated by the Plant



1 Integration Section? After the memorandum was received by them?

2 MR. DUNN: I would have to testify with hearsay infor-  
3 mation on that point.

4 MR. GORINSON: Go ahead.

5 MR. DUNN: Well, I don't know that they were evaluated.  
6 What I have heard is that Nuclear Service was told to go ahead  
7 with my instructions -- do what I wanted done, in other words.

8 MR. GORINSON: When were they told that?

9 MR. DUNN: I don't know that.

10 MR. GORINSON: And who was it that told them that?

11 MR. DUNN: Bruce Karrasch told me that he told them  
12 that.

13 MR. GORINSON: Did he give you a time when he told  
14 them that?

15 MR. DUNN: No.

16 MR. GORINSON: Let me have placed in front of you what  
17 has been pre-marked as Exhibit Six and also Exhibit Seven. These  
18 are notifications that were sent out by Babcock and Wilcox fol-  
19 lowing the TMI II on supplementary operating instructions for  
20 the HPI system. One is dated April 4th, 1979 and that is Ex-  
21 hibit Six. Exhibit Seven is dated April 17th, 1979 --

22 CHAIRMAN KEMENY: Did I hear you state that these were  
23 sent out after the Three Mile Island accident?

24 MR. GORINSON: Yes. Mr. Dunn, were you consulted  
25 prior to the time the April 4th, 1979 instructions to customers

1 went out from B and W?

2 MR. DUNN: Yes, sir.

3 MR. GORINSON: And do you know if your February 9th  
4 and February 16th memos were reviewed before this instruction was  
5 sent out to the customers?

6 MR. DUNN: I believe that these instructions relied  
7 heavily on my input and in creating the ideas which were to be  
8 supplied to the operating plants, I relied on my February 16th  
9 memo.

10 MR. GORINSON: And to your knowledge, was this the  
11 first time that the company had sent out the supplemental in-  
12 structions that you were requesting be sent out?

13 MR. DUNN: From the Babcock and Wilcox Company to the  
14 operating utilities, yes, I believe we had communication with  
15 the NIC in which basically supplied this formula prior to the  
16 issuance of this.

17 MR. GORINSON: But prior to that time, the recommended  
18 procedure set out in the February 16th memorandum had not gone  
19 out to the customers?

20 MR. DUNN: To my knowledge that is correct.

21 MR. GORINSON: Exhibit 7, which is the April 17th  
22 revision or modification to the original supplementary instruc-  
23 tions, could you explain the basis for that modification, sir?

24 MR. DUNN: I may not be able to explain the basis  
25 totally but I think I can shed a considerable amount of light on

10 1 it. It is my understanding that some of our customers were con-  
2 cerned about going solid in a condition where the reactor had  
3 not undergone a loss of coolant accident. This primarily relates  
4 to the containment of the 20 minute dead space in the original  
5 instructions. The original instructions contained the words,  
6 if high pressure injection is actuated, leave it in place for  
7 20 minutes, or words to that effect. During 20 minutes it would  
8 be possible to pump enough water into a reactor coolant system  
9 to fill it solid and cause the PORV or the code safeties to  
10 relieve fluid. If we did not have a loss of coolant accident  
11 that action would be unnecessary. To allow some relief from  
12 the 20 minute rule, we wrote the third section which still indi-  
13 cates a full reactor coolant system with water and allows you  
14 to terminate the high pressure injection if it is necessary to  
15 prevent the prssurizer from becoming, growing, an indicated off-  
16 scale.

17 MR. GORINSON: So the modification was done at the  
18 incidence of B and W's customers?

19 MR. DUNN: Well, the customers were concerned about  
20 it I think. At least one of our management personnel was also  
21 concerned about the issue. I don't know whether he was concerned  
22 before the customers got concerned or afterwards.

23 MR. GORINSON: What is his name?

24 MR. DUNN: Allan Momak.

25 MR. GORINSON: Let us turn to another subject, if we

sg 11

1 can, Mr. Dunn. In February of 1979, there was a meeting in  
2 Lynchburg concerning the loss of pressurizer level indication,  
3 off-scale on the low side. Were you present at that meeting?

4 MR. DUNN: I think so.

5 MR. GORINSON: Maybe we can help you a little with  
6 this. Put in front of Mr. Dunn a document which has been marked  
7 as Hearing Exhibit Number 8 and it is from J.T. Willse, Licen-  
8 sing to the distribution. It concerns loss of pressurizer level  
9 indication. Have you seen that memo before?

10 MR. DUNN: I am not absolutely sure. I think I have  
11 seen this memo in the depositions and I have probably seen it  
12 before that time.

13 MR. GORINSON: But it shows you as being in attendance  
14 at that meeting.

15 MR. DUNN: Yes, that is indicated.

16 MR. GORINSON: What was the NRC's concern, as you under-  
17 stand it, that gave rise to that meeting?

18 MR. DUNN: The NRC, if I am correct and I am not a  
19 lead party in this meeting, I am a participant but not a lead  
20 person -- I believe their concern was that if the steam gene-  
21 rators were to overflow during an event that would cause the  
22 initiation of the auxiliary feedwater system, the system could  
23 be depressurized or cooled to the extent that the steam space  
24 in the pressurizer would expand into the reactor coolant system  
25 proper.

Bowers Reporting Company

g 12 1 MR. GORINSON: And would that cause a loss of pres-  
2 surizer level indication?

3 MR. DUNN: Certainly, in order to expand into the  
4 reactor coolant system the water -- I said steam space expand --  
5 that would mean the water would drop below the low level indi-  
6 cator.

7 MR. GORINSON: Now, in preparation for this February  
8 14th meeting, did you have an internal B and W meeting?

9 MR. DUNN: Yes.

10 MR. GORINSON: And did you attend that meeting?

11 MR. DUNN: I believe I did.

12 MR. GORINSON: Was that on February 9th?

13 MR. DUNN: That is what I have been told.

14 MR. GORINSON: In any event it was within a few days  
15 of the February 14th meeting?

16 MR. DUNN: Yes.

17 MR. GORINSON: And what was discussed at that meeting?

18 MR. DUNN: It is my understanding and recollection that  
19 that was a dry run of our presentations to be given at the 14th  
20 meeting.

21 MR. GORINSON: So you just worked through the presen-  
22 tation that you were giving to the NRC?

23 MR. DUNN: That is my recollection.

24 MR. GORINSON: Who was present at the February 9th  
25 meeting? The best that you can remember.

sg 13

1 MR. DUNN: Well, there were a number of people involved  
2 in and around this time. I don't know that I can really re-  
3 construct that meeting in my head. There would have been Mr.  
4 Bob Winks, I believe very surely that he was at the meeting;  
5 additionally, I think Mr. Eric Swanson was at the meeting;  
6 probably a number of other people that I don't recall at this  
7 time, as well.

8 MR. GORINSON: At that February 9th meeting, did you  
9 raise the problem of the pressurizer level going up, as well as  
10 going down?

11 MR. DUNN: No, I did not.

12 MR. GORINSON: You just confined your attention to  
13 pressurizer level going down?

14 MR. DUNN: Yes. My role in the discussions at this  
15 time was to provide back-up information which would state that  
16 even if the steam bubble expanded in RCS, the reactor coolant  
17 system, there would not be any adverse consequences of that.

18 MR. GORINSON: Did it occur to you that it might be  
19 a subject to be raised, considering that this meeting would also  
20 concern another transient that had occurred?

21 MR. DUNN: No. We were discussing an event entirely  
22 separate from a loss of coolant accident.

23 MR. GORINSON: Was there a meeting with the utilities  
24 prior to the date of the February 14th meeting?

25 MR. DUNN: Not that I am aware of.

1 MR. GORINSON: You didn't attend any such meeting?

2 MR. DUNN: No.

3 MR. GORINSON: Now, on the bottom of the second page  
4 it states the conclusion, stated by Mr. Foster of the NRC. He  
5 stated that the loss of pressurizer level indication was merely  
6 an operational inconvenience and that loss of pressurizer level  
7 was not a safety concern. You see that, sir?

8 MR. DUNN: Yes.

9 MR. GORINSON: Had that been discussed during the  
10 meeting? The question of it being an operational inconvenience  
11 rather than a safety concern?

12 MR. DUNN: During the February 14th meeting?

13 MR. GORINSON: Yes.

14 MR. DUNN: I would assume that it had been. I am sure  
15 that that is the point we were trying to make to the NRC during  
16 that meeting.

17 MR. GORINSON: Was that point discussed during the Feb-  
18 ruary 9th meeting?

19 MR. DUNN: In all probability. We were trying to get  
20 that conclusion to be drawn.

21 MR. GORINSON: Okay. Would you explain to the Commission  
22 what the operational inconvenience would be for the operator?

23 MR. DUNN: Well, as far as determining the condition  
24 of the reactor coolant system, as to whether or not it has steam  
25 in it and its margins between a solid reactor coolant system



sg 15 1 plus the pressurizer, if you will, and a system in which he had  
2 steam, he would not have level information that would indicate  
3 how far away from injecting steam into the primary system he  
4 would be and he would have to rely on pressure and temperature  
5 readings to achieve that information.

6 MR. GORINSON: So he would have the pressure and tem-  
7 perature readings to rely on even if he didn't have the level  
8 indication?

9 MR. DUNN: Yes.

10 MR. GORINSON: That would be the operational incon-  
11 venience?

12 MR. DUNN: Yes. I also believe he may be for a short  
13 time out of specifications.

14 MR. GORINSON: Excuse me, I didn't hear that.

15 MR. DUNN: He might be for a short time out of his  
16 technical specifications. I can't swear to that but it would  
17 seem that those would require him to maintain his pressurizer  
18 level within indication.

19 MR. GORINSON: So that he might possibly be outside  
20 technical specs?

21 MR. DUNN: Momentarily.

22 MR. GORINSON: Did you, at any time, review the Michel-  
23 son report?

24 MR. DUNN: Yes, sir.

25 MR. GORINSON: When did B and W become aware of the

sg 16 1 Michelson report?

2 MR. DUNN: I think I get this date wrong every time I  
3 discuss it. This time I am going to say in April. I have got  
4 a copy of the Michelson report with the date stamped on there.

5 MR. GORINSON: And was your group assigned to do an  
6 evaluation analysis of what Michelson was saying?

7 CHAIRMAN KEMENY: Excuse me, April of which year?

8 MR. DUNN: Oh, April of 1978.

9 CHAIRMAN KEMENY: Thank you.

10 MR. GORINSON: Okay, so it was April of '78 and at  
11 that time you received the assignment to evaluate and analyze  
12 the Michelson report?

13 MR. DUNN: My unit was made aware of the Michelson  
14 report. It was a request from a customer and we would receive,  
15 I guess, an assignment to evaluate it.

16 MR. GORINSON: And who in your group was given that  
17 assignment?

18 MR. DUNN: Mr. Bob Jones.

19 MR. GORINSON: And did you reach any conclusions as  
20 to the merits of the Michelson report?

21 MR. DUNN: Yes, I believe we reached conclusions as  
22 to the merits of the Michelson report. Bob was the original  
23 person within ECCS aware of the report. I was made aware of  
24 the report in a briefing that he gave to me. I think we would  
25 say that we concluded that an individual within the TVA organization

sg 17

1 had done a review and I think it might best be characterized as  
2 a developmental review and that he was creating a lot of his  
3 arguments from first principals, as opposed from somebody else's  
4 arguments of small breaks. He had a number of questions about  
5 those small breaks and the evolutions of the LOCA transients  
6 and did not understand how these issues or concerns were incor-  
7 porated within our evaluation of small breaks and that we should  
8 provide him with information which would illustrate or show him  
9 how these concerns were incorporated; or, if you will take  
10 another word, allowed in our evaluation of small breaks.

11 MR. GORINSON: Well, is what you are saying that the  
12 issues raised by Michelson were already included in B and W  
13 analyses?

14 MR. DUNN: Yes.

15 MR. GORINSON: So that in your view there was nothing  
16 new in the Michelson report?

17 MR. DUNN: In my view there was nothing new in the  
18 Michelson report. We had either directly included the phenomena  
19 or we had bounded it.

20 MR. GORINSON: Let me have put in front of you --

21 CHAIRMAN KEMENY: Excuse me, Chief Counsel, would you  
22 give us a definition of what bounding means?

23 MR. DUNN: What it means to me is that as far as the  
24 consequences of a loss of coolant accident, I have done a number  
25 of evaluations which in my opinion, and in the opinion of the

1 reviewers I am sure, result in worse conditions or worse results  
2 it will use cladding temperatures, a typical result, or a  
3 typical parameter you would look at, these accidents would re-  
4 sult in higher peak cladding temperatures. There are other  
5 criteria which you evaluate than just peak clad temperature.  
6 In any case we seek to provide analyses which are worst relative  
7 to that -- those criteria -- and convince ourselves that in  
8 fact we have chosen the appropriate accidents to evaluate.

ape 5  
9 MR. GORINSON: Let me have put in front of you, Mr.  
10 Dunn, a document that has been pre-marked as Hearing Exhibit  
11 Number 9 and it says at the top Michelson Story Comments. It is  
12 a hand-written document. Do you have that in front of you sir?

13 MR. DUNN: Yes, sir.

14 MR. GORINSON: Is the date on that document April 14th,  
15 1979?

16 MR. DUNN: Either April 14th or April 19th.

17 MR. GORINSON: Okay. It is an April date.

18 MR. DUNN: Yes.

19 MR. GORINSON: And was this document prepared by your?

20 MR. DUNN: Yes.

21 MR. GORINSON: For what purpose was this document pre-  
22 pared?

23 MR. DUNN: The "Michelson Report" had become a public  
24 issue. This document was prepared to provide background material  
25 via which Babcock and Wilcox could respond to the, at that time,

1 criticism for which the Michelson report was being used.

2 MR. GORINSON: Who did copies go to, Mr. Dunn? This  
3 document?

4 MR. DUNN: Of this particular one I believe it only  
5 went to my boss. I used it in briefing various people that were  
6 to appear in public but I don't believe I gave a copy of it to  
7 anybody but my boss. Now, I could be wrong on that. There  
8 could be other copies.

9 MR. GORINSON: And who were the people that you briefed  
10 with this document?

11 MR. DUNN: There were a number of them. I probably  
12 was involved in briefing Dr. Don Roy. I can't recall the  
13 specific incidents. I certainly discussed it in depth with my  
14 boss. It was apparent in a number of forums that might cause  
15 him to have to respond on the Michelson report issue and at one  
16 time we did have a discussion with Mr. John MacMillan on the  
17 issue.

18 MR. GORINSON: Okay. When was the discussion with  
19 Mr. MacMillan?

20 MR. DUNN: It was before one of his congressional  
21 hearings and I would have to go back and talk to some people  
22 about the specific date. I can't give you a date, probably  
23 about a month after the accident.

24 MR. GORINSON: Mr. Chairman, I would ask that Exhibits  
25 3 through 9 be included as part of the hearing record.

1 CHAIRMAN KEMENY: So ordered.

2 (The documents previously marked for  
3 for identification as Exhibits 3  
4 through 9 were received in evidence.)

4 MR. GORINSON: I have no further questions.

5 CHAIRMAN KEMENY: Mr. Dunn, you are Manager of the  
6 ECCS Analysis Unit within planned design, is that correct?

7 MR. DUNN: That is correct.

8 CHAIRMAN KEMENY: And would it be correct to say that  
9 the ECCS system is one of the very important safety systems  
10 within the nuclear power generation system?

11 MR. DUNN: I would believe that.

12 CHAIRMAN KEMENY: Therefore, in effect, you hold a  
13 highly responsible position?

14 MR. DUNN: Yes, sir.

15 CHAIRMAN KEMENY: Within that context I would like to  
16 turn to your initial memorandum, the memorandum of February 9 --  
17 you don't need to look at it in detail, I am not going to ask  
18 you detailed questions about it -- but I am curious then how  
19 many memoranda vaguely of that sort have you written in the past  
20 few years? I mean, is it one, is it ten, is it a hundred?

21 MR. DUNN: Being as you have used the word memorandum,  
22 from myself or my unit -- I might very well delegate such a memo-  
23 randum to somebody else --

24 CHAIRMAN KEMENY: Yes, I understand that.

25 MR. DUNN: There may be four or five. I can recall two

sg 21

1 at this time.

2 CHAIRMAN KEMENY: Very good. You recall two but there  
3 may have been four or five. At any rate it is not twenty or  
4 thrity memoranda.

5 MR. DUNN: No, sir.

6 CHAIRMAN KEMENY: So it is not an example that your  
7 unit would have been flooding the company with memoranda of this  
8 kind?

9 MR. DUNN: No, sir. I believe we do our job very well.  
10 I would say we are not necessarily perfect but the instance  
11 where we have to do these kind of things are not daily.

12 CHARIMAN KEMENY: To the best of your recollection  
13 have your other memoranda used phrases roughly similar to "this  
14 is a very serious matter and deserves our prompt attention"?

15 MR. DUNN: No, I think that phrase was picked because  
16 I had not seen action. Okay. The other memorandums I am re-  
17 calling, we had started action and action was under way so I  
18 don't think that particular phraseology would be appropriate.

19 CHAIRMAN KEMENY: Yes. So in that manner you were  
20 using that phrase in effect, because you felt action was impor-  
21 tant in this case?

22 MR. DUNN: At this time that is my recollection of why  
23 I used it, primarily from the words here. I don't remember.

24 CHAIRMAN KEMENY: How concerned were you later that  
25 year that you were not seeing action?



1 MR. DUNN: I was unconcerned. I was operating under  
2 the assumption that we had reached agreement and that action  
3 had taken place.

4 CHAIRMAN KEMENY: Yes. By action here, I assume you  
5 mean that you thought that proper instructions -- instructions  
6 you consider proper had been sent to customers, would that be  
7 correct?

8 MR. DUNN: Well, I would defer on the word instruction  
9 and say that at the least we had provided them with the incidence  
10 of Davis Besse and the opportunity to avail themselves of the  
11 instructions.

12 CHAIRMAN KEMENY: That was your assumption and that  
13 is why you were not more concerned?

14 MR. DUNN: Yes.

15 CHAIRMAN KEMENY: Other commissioners? Commissioner  
16 McPherson?

17 COMMISSIONER MCPHERSON: Just a brief recapitulation:  
18 You wrote the first memorandum on February 9th, 1978 and you  
19 succeeded that with one on February 16th, 1978, both pointing  
20 to this potentially serious problem. On August 3rd, 1978 Mr.  
21 Hallman in Nuclear Services expressed some concerns that they  
22 had and said that as a result of those concerns and their lack  
23 of resolution, there had been no methods, no instructions, no  
24 recommendations sent to customers. Finally, on April 4th, 1979  
25 instructions were sent out which were amended on April 17th, 1979.

sg 23 1 Is that statement as to the memoranda correct?

2 MR. DUNN: As I recall.

3 COMMISSIONER MCPHERSON: So that is a total of about  
4 20 months from the first memorandum of yours on February 9th to  
5 the final memorandum of April 17th, embodying these recommen-  
6 dations to the customers. That is February 9th, '78; April 17th,  
7 '79 --

8 MR. DUNN: Yes, sir.

9 COMMISSIONER MCPHERSON: And, of course, Three Mile  
10 Island had intervened on March 28th, '79. Can you, in layman's  
11 terms, describe the differences between your recommendations on  
12 February 9th and the final methods sent out on April 17th? Can  
13 you describe either the evolution of that recommendation or  
14 simply the differences between the two?

15 MR. DUNN: Let me try. Let me first say that what is  
16 attempting to be accomplished here is that during the recovery  
17 from a small break, prior to turning off the systems which are  
18 allowing you to survive the incident, we are attempting to achieve  
19 a reactor coolant system condition which is as much like normal  
20 as possible. And in my mind that means with almost as much water  
21 in the system as we had during the start of the event. In that  
22 fashion then a second event or if termination has been premature,  
23 we can restart the systems and continue the accident in as good  
24 a condition as we were to survive the initiation of it. In that  
25 fashion then the evaluation of the initial event becomes a

24 1 bounding evaluation of the second phase. So we are trying to  
2 get a reactor coolant system full of water again. The difference  
3 between the two issuances. instructions, does not really change  
4 that intent. So from that standpoint, from the practical stand-  
5 point of what it is meant to accomplish, it would accomplish it  
6 almost identically. With the single exception that, whereas  
7 we instructed a dead band space of 20 minutes in which we did  
8 not want anybody doing anything, we modified that in order to  
9 allow prevention of an accident provided the one single event  
10 of the pressurizer becoming full was evident. We still maintain  
11 even in that instruction, the requirement to have a sub-cooled  
12 reactor coolant system so that the system would have still been  
13 full of water. It is just as good an instruction but sometimes  
14 you like to put a little dead space in for evaluation so that  
15 actions don't take place too rapidly.

16 COMMISSIONER MCPHERSON: The changes between the '78  
17 recommendation versus the April 17th, '79, the final message  
18 to customers are not substantial. If I understand what you are  
19 saying they are not substantial in their specifics?

20 MR. DUNN: To the intent of the instruction that is  
21 true. The provision for eliminating the 20 minute rule may very  
22 well be substantial. Okay. If I had this action for another  
23 event, I would not like to cause a loss of coolant accident and  
24 part of that instruction may very well be quite substantial.

25 COMMISSIONER MCPHERSON: Mr. Dunn, at any point in

sg 25

1 the period after the Davis Besse accident, to your knowledge,  
2 did any personnel from the Nuclear Regulatory Commission ever  
3 express concern about the state of high pressure injection sys-  
4 tem instruction for training? With respect to B and W reactors?

5 MR. DUNN: Could I have the timeframe of that, sir?

6 COMMISSIONER MCPHERSON: Well, any time after Davis  
7 Besse.

8 MR. DUNN: It is my understanding that a memo was  
9 written within the staff and that --

10 COMMISSIONER MCPHERSON: Within whose staff?

11 MR. DUNN: Within the NRC staff. And that it bears a  
12 strong relationship to the subject of termination of high pressure  
13 injection.

14 COMMISSIONER MCPHERSON: Bears a strong relationship?

15 MR. DUNN: I believe it is almost identical, expressed  
16 in slightly different terms to my subject in my February memos.  
17 And it, I think, relates to Davis Besse transient. I am not  
18 really sure of that. It dwells on the loop seal configuration  
19 for our pressurizer surge line, which I think is somewhat inap-  
20 propriate. It is not a proper point to dwell on but I believe  
21 it also indicates that because of this loop seal there may be  
22 a termination of the high pressure injection at the wrong time,  
23 or it may be doesn't state it quite that distinctly, it may say  
24 that this may cause an indicated high pressurizer level at a  
25 time when the reactor coolant system proper is not full of water.

sg 26 1 That may be more accurate as to the content of that memo.

2 COMMISSIONER MCPHERSON: Was that memo sent to B and  
3 W?

4 MR. DUNN: Not to my knowledge.

5 COMMISSIONER MCPHERSON: It remained within the Nuclear  
6 Regulatory Commission?

7 MR. DUNN: That is my knowledge at this time, yes, sir.  
8 We have that memo now.

9 COMMISSIONER MCPHERSON: But you had no knowledge of  
10 it during February 1978?

11 MR. DUNN: That is the state of my knowledge. That  
12 is my opinion, yes. We did not know about that until after  
13 March 28, 1979.

14 CHAIRMAN KEMENY: Commissioner Pigford?

15 COMMISSIONER PIGFORD: Mr. Dunn, referring to your  
16 recommendation in your memorandum of February 16, your second  
17 recommendation -- the hot leg -- let the hot pressure injection  
18 be such that the hot leg temperature is more than 50 degrees  
19 Fahrenheit below the saturation temperature -- was it your  
20 expectation that this would be an instruction to the operator?

21 MR. DUNN: Was it my recommendation?

22 COMMISSIONER PIGFORD: was it your expectation that  
23 this would lead to instruction to the operator?

24 MR. DUNN: Yes, sir.

25 COMMISSIONER PIGFORD: Was it your understanding that

sg 27

1 the operators would have some means of determining the satu-  
2 ration temperature?

3 MR. DUNN: They have thermacouples on the hot legs.

4 COMMISSIONER PIGFORD: How does that give you the  
5 saturation temperature?

6 MR. DUNN: Well -- oh, I am sorry. They have therma-  
7 couples from which to read the reactor coolant temperature. The  
8 saturation temperature would have to be inferred from the re-  
9 actor coolant system pressure, either via diagrams supplied to  
10 him within a procedure or via access to what we would call state  
11 equations, or via steam tables.

12 COMMISSIONER PIGFORD: Did the recommendation that  
13 B and W finally sent out include those provisions of determining  
14 the saturation temperature?

15 MR. DUNN: Well, I think I have misled you a little  
16 bit. The actually mechanics of how this type of instruction is  
17 implemented within a control room would not be my domain. It  
18 would only be that those mechanics should accomplish this fact,  
19 or what I am trying to accomplish here. I believe we did provide  
20 a graph either directly with the instructions or after that time  
21 from which a person could correlate the variables necessary.

22 COMMISSIONER PIGFORD: That would be some attachment  
23 to the instructions of April 17, 1979?

24 MR. DUNN: Either to that one or it had already gone  
25 out.

Bowers Reporting Company

1 COMMISSIONER PIGFORD: Gone out previously?

2 MR. DUNN: It may have gone out previously.

3 COMMISSIONER PIGFORD: About when would you think?

4 MR. DUNN: I am not sure. It is certainly not very  
5 hard to have access to that information.

6 COMMISSIONER PIGFORD: Was it your understanding that  
7 the operators at the B and W plants normally do this translation  
8 to obtain pressure and to obtain saturation temperature? Was  
9 it your understanding at the time you wrote this memorandum?

10 MR. DUNN: I don't think I asked myself that question.  
11 I would think it would be my understanding that they did not  
12 normally do that.

13 COMMISSIONER PIGFORD: Did you have any knowledge  
14 as to whether that translation was included as part of the  
15 training program at B and W?

16 MR. DUNN: No, I did not.

17 COMMISSIONER PIGFORD: You have no knowledge?

18 MR. DUNN: I have no knowledge.

19 CHAIRMAN KEMENY: Commissioner Marrett?

20 COMMISSIONER MARRETT: I would like to go back to  
21 your memo of February 9th, the third paragraph, the incident  
22 points out that we have not supplied sufficient information to  
23 reactor operators, is the reference there to the utility or to  
24 the actual person?

25 MR. DUNN: Yes, the words probably are slightly



1 confusing. I would say the reference is to the utility.

2 COMMISSIONER MARRETT: To the utility?

3 MR. DUNN: Yes.

4 COMMISSIONER MARRETT: So am I understanding it cor-  
5 rectly that although this was sent to Licensing, the unit that  
6 actually was responsible later was Nuclear Service or customer  
7 service. That is the department that was handed this?

8 MR. DUNN: Well, we have an assumption on my part, you  
9 know, during this time period -- and with that in mind. I as-  
10 sumed them to be responsible. With that in mind, yes, Nuclear  
11 Service would be the person handling that.

12 COMMISSIONER MARRETT: But what I am asking -- this  
13 memo did go to Nuclear Service and the subsequent memo, or the  
14 one that followed you next one did come from Nuclear Service?  
15 Is that right?

16 MR. DUNN: The August memo?

17 COMMISSIONER MARRETT: Yes.

18 MR. DUNN: The August memo came from Nuclear Service.  
19 This memo, the follow-up, February 16th memo is not directed to  
20 Nuclear Service but it had Nuclear Service personnel on it for  
21 distribution.

22 COMMISSIONER MARRETT: I believe a point in the organi-  
23 zational chart, training is a section in Nuclear Service. Is  
24 that correct?

25 MR. DUNN: I believe that is correct, yes.

sg 30 1           COMMISSIONER MARRETT: Now, when you make a reference  
2 to there being insufficient information to reactor operators,  
3 was there any indication -- although I understand you were not  
4 directly in contact with training -- but was there any challenge  
5 made to that statement on the argument that training -- the  
6 training department was already taking care of HPI questions  
7 through the training that was given? In other words, was there  
8 a response saying, this is unnecessary because we have, in fact,  
9 in the training incorporated directions directly to the operators,  
10 the persons in the control rooms themselves? Did anything come  
11 up that said that training was taking care of this already?

12           MR. DUNN: Well, first it is my understanding that  
13 B and W supplies training to the personnel at the customer's  
14 request. So we could not, I believe, presume to have trained  
15 every operator that operates one of our plants. I believe the  
16 customers have the option of other people within the nuclear  
17 community to provide training to their operators, and can, in  
18 fact, do it themselves if they wish.

19           Secondly, there was, to my knowledge, no such challenge  
20 to my concerns. No such statement that said, hey, we have al-  
21 ready done all of this.

22           COMMISSIONER MARRETT: There certainly have been state-  
23 ments in some of the other material, that there was indication  
24 from some person, at least with reference to HPI, training was  
25 taking this into consideration. Did you have, based on your

1 impressions if you were not directly involved with training,  
2 any ideas about what was going on in the training department  
3 with reference to these issues?

4 MR. DUNN: Did I have --?

5 COMMISSIONER MARRETT: Did you have any impressions  
6 about what training was doing about these areas?

7 MR. DUNN: At the time that I wrote this memo?

8 COMMISSIONER MARRETT: Yes.

9 MR. DUNN: No, ma'am.

10 CHAIRMAN KEMENY: Mr. Marks?

11 COMMISSIONER MARKS: Mr. Dunn, when a transient such  
12 as the Davis Besse or the TMI II occurs, is there a regular  
13 practice at B and W which involves individuals knowledgeable  
14 about reaction to emergency, to gather somewhere to be able to  
15 respond to the emergency?

16 MR. DUNN: There is no regular procedure for that but  
17 it occurs I believe as a natural course of events.

18 COMMISSIONER MARKS: What does that mean?

19 MR. DUNN: Obviously, we are intimately concerned with  
20 the plant and with the successful mitigation of an event. The  
21 first contact is made generally through the Service Department  
22 and if there is support to be given to the plant, they would  
23 assemble the necessary people to provide that support.

24 COMMISSIONER MARKS: But there is no, so to speak,  
25 table of organization for such an assembly that you know of?

32 1 MR. DUNN: In the form of a procedure that would  
2 call out a certain number of people to go to a certain room  
3 and gather to correspond on a certain telephone, or perhaps a  
4 command central, there is none that I know of.

5 COMMISSIONER MARKS: And none has been instituted yet?

6 MR. DUNN: Well, I may not be capable of responding  
7 to that question. I will say I do not know of one.

8 COMMISSIONER MARKS: You are certainly not involved?

9 MR. DUNN: No, I --

10 COMMISSIONER MARKS: Do you want to express an opinion  
11 as to whether you think it would be desirable as a -- in terms  
12 of the adequacy and orderliness of a response to support in  
13 dealing with an emergency?

14 MR. DUNN: I could express a personal opinion. I  
15 think it is desirable. I think one has to be very careful  
16 with such things. The utility is the person that is on the  
17 location; has the best information; and other people who are  
18 not intimately familiar with the operation of a nuclear power  
19 plant, particularly if given authority, could cause extremely  
20 severe problems at that plant during an accident. Now, I would  
21 personally feel that if such a committee were put in place,  
22 properly trained and qualified for that particular plant, or  
23 type of plant, depending on the need -- by type of plant I  
24 mean I would feel qualified to counsel in response to emergency  
25 core cooling, procedures, modifications if they are needed for

1 a reason that I don't know of today on any of the B and W  
2 plants, I would not feel qualified to respond on a Westinghouse  
3 plant. I think that would be highly inappropriate for me to do  
4 that. In that fashion, yes.

5 COMMISSIONER MARKS: Mr. Kelly testified that on  
6 March 28th the on-site B and W representative was calling through  
7 to Lynchburg for advice. Were you involved in providing that  
8 advice?

9 MR. DUNN: I was involved in the Lynchburg command  
10 post, which I think would be a proper characterization of that  
11 room at that time, from time to time, mainly during the after-  
12 noon of the 28th. I found out about the incident actually at  
13 about 11:30 of that morning. I don't know that -- it was not  
14 clear that we were in direct communication with control and with  
15 that individual. I believe we were late in the evening when  
16 the pumps started but we were generating advice and attempting  
17 to get it to the customer.

18 COMMISSIONER MARKS: Were you sort of satisfied with  
19 the procedures or was there any sort of post-crisis analysis  
20 of whether this was a satisfactory way of dealing with this  
21 type of crisis?

22 MR. DUNN: There is no analysis of that to my know-  
23 ledge. Personally I was not satisfied with it.

24 COMMISSIONER MARKS: Do you know who makes the deci-  
25 sions about sending people out to investigate transients with

1 B and W plants, such as the Davis Besse or TMI II?

2 MR. DUNN: I believe it is a joint decision. I think  
3 in the case of Davis Besse it was arrived at jointly between  
4 the manager of Nuclear Service and the manager of plant design.  
5 There may have been some equipment personnel that went along  
6 as well.

7 COMMISSIONER MARKS: You are not involved in those  
8 decisions?

9 MR. DUNN: I can be consulted in those decisions if  
10 it appears that personnel with the background in my field would  
11 be useful in either diagnosing the problems or supporting the  
12 customer. Generally, the people that go to the field, they are  
13 to collect the information and diagnose.

14 COMMISSIONER MARKS: Were you consulted about sending  
15 out a team in the Davis Besse or TMI II before they were sent  
16 out?

17 MR. DUNN: I wasn't consulted. I believe that at  
18 approximately 11:30 I was made aware that it was in all likeli-  
19 hood a stuck open QRV and I suggested that it might be appro-  
20 priate we did have a few sentence communication on that and  
21 what we decided was that we were going to collect data at a  
22 place for analysts, in Lynchburg, and that if at some time in  
23 the future the data that had been collected proved inadequate  
24 from the standpoint of whatever use I would make of it, that  
25 then it might be appropriate to send one of my personnel. And

1 I think that is a correct decision to make.

2 COMMISSIONER MARKS: I am not clear. We understand  
3 that a team was sent out which left Lynchburg around noon.

4 MR. DUNN: Yes.

5 COMMISSIONER MARKS: And what I am trying to find out  
6 is were you involved in the decision to send the team and its  
7 composition, since, as I understand it, you are in charge of  
8 the emergency core cooling systems and if I understand what  
9 that means, it is conceivable at least that you should be in-  
10 volved in that kind of decision as to whether to send and who  
11 to send.

12 MR. DUNN: Well, the personnel that were sent, if I  
13 can try and explain this to you -- were sent primarily from  
14 the standpoint of data collection to provide data back to Lynch-  
15 burg so that an understanding of the accident could be obtained  
16 within Lynchburg and we could learn from it. I did not believe  
17 these were -- it was the intent then to send these people up  
18 there to resolve the accident. Okay? They certainly would  
19 have been made available and I think a little later in the day,  
20 the consequences of the accident became more well-known to us  
21 and we did start trying to do that.



1 CHAIRMAN KEMENY: Commissioner Haggerty.

2 COMMISSIONER HAGGERTY: The preliminary safety  
3 concern procedure, as contrasted with your memo, you  
4 explained why you wrote a memo. What happens with a  
5 PSC, however? What's the difference in procedure?  
6 When it gets into licensing, I understand that licensing  
7 has to react. But does it start a different chain of  
8 events? Does the PSC, for example, go outside of  
9 B and W, to NRC or to the particular customer involved,  
10 if that were the case?

11 MR. DUNN: The PSC is a more formalized way  
12 of resolving a concern. It may or may not progress  
13 to the point where the information about the concern  
14 would go outside of Lynchburg. I could say its  
15 benefits are primarily in that it more mechanistically  
16 assures resolution of a concern. It has a wide distri-  
17 bution, as to potential for involving a lot of people.  
18 If, at the end of the procedure, the concern is  
19 considered reportable, then there it would be communicated  
20 to the NRC, but only if it was considered reportable.

21 COMMISSIONER HAGGERTY: Presumably a PSC has  
22 to be resolved, one way or the other. I presume that's  
23 part of the procedure. That's what you mean by being  
24 formal. It has to be pursued to some kind of conclusion,  
25 either that nothing further needs to be done or that

LA

2

1 something needs to be done.

2

MR. DUNN: Presumably, yes.

3

COMMISSIONER MC PHERSON: Pat, can I interrupt  
4 you to ask a question on that? In the PSC procedure,  
5 are there deadlines for response? That is, if you  
6 had written that memo on a PSC form on February 9th,  
7 1978, and it had gotten into -- it inaugurated the  
8 process of the safety concern, would there have been  
9 deadlines for people to respond to your memo, in the  
10 course of that process?

11

MR. DUNN: Well, there may have been deadlines.  
12 They would not be created by the PSC procedure. They  
13 would have been created very much in the same fashion  
14 that deadlines could have been created out of my  
15 memos. It would depend on the extent to which the  
16 concern had to be evaluated. The PSC procedure does  
17 not say, you do this in this much time, until after  
18 the event is termed reportable. At that time -- and I  
19 don't know whether this was in effect in February of  
20 '79. But at least today, the time an event is declared  
21 reportable, our vice president is made aware of it and  
22 he then has 48 hours within which to communicate the  
23 information to the NRC.

24

COMMISSIONER MC PHERSON: That's an event such  
25 as Davis-Besse.

Bowers Reporting Company

LA 3 1 MR. DUNN: No, that's from a PSC. Let's say,  
2 as an example, it's declared this is a safety concern.  
3 It's no longer preliminary. It becomes a reportable  
4 item. The vice president is notified. And then there's  
5 the only fixed deadline, which is 48 hours to report it  
6 to the Commission.

7 COMMISSIONER HAGGERTY: Do you initiate a PSC?

8 MR. DUNN: I have had PSCs written from my  
9 unit, partially been involved in them. I do not believe  
10 that I've been the person that signed the bottom line,  
11 though.

12 COMMISSIONER HAGGERTY: But your department has  
13 initiated a PSC.

14 MR. DUNN: My unit has, yes.

15 COMMISSIONER HAGGERTY: Your unit has. Your  
16 memo, of course, was addressed to the licensing --  
17 head of licensing. It did deal with a safety matter.  
18 One way or another, he, in turn, felt it was a nuclear  
19 service activity, rather than a responsibility to  
20 resolve, presumably because of the communication and  
21 training, since they were both in nuclear service,  
22 that they could handle the entire thing. Certainly you  
23 must have felt the memorandum was more flexible or that  
24 this thing was at somewhat lower levels of seriousness  
25 than would require a PSC, or there's something distasteful

LA 4

1 about starting a PSC.

2 MR. DUNN: In general, I would prefer handling  
3 work through the less formal mechanism of memos and  
4 interaction on a personal basis. If that doesn't work,  
5 I'm prepared to write a preliminary safety concern.

6 CHAIRMAN KEMENY: Professor Taylor.

7 COMMISSIONER TAYLOR: Is there any work at  
8 B and W that you would characterize as research and  
9 development on emergency core cooling system design,  
10 operation, possible problems, opportunities for fixing?

11 MR. DUNN: Well, I think we have, in the past,  
12 fixed the emergency core cooling system, at least in  
13 one area. There is work that goes forward from time  
14 to time within the research divisions on phenomena  
15 during a loss of coolant accident. Generally, this  
16 work is what we would term as single effects. To give  
17 an example, B and W has tested the coolability of a  
18 reactor core under small break conditions, in which  
19 there is a boiling pot mode of heat transfer, to verify  
20 that our predictions of that type of heat transfer are  
21 accurate and to verify some other information about  
22 that type of heat transfer.

23 That does not necessarily mean a check of the  
24 system itself. Those particular experiments resulted  
25 very favorably to us. Our ideas about how that cooling

A 5 1 mechanism would occur were supported, borne out, and,  
2 in fact, shown to be better than we would require.  
3 So that kind of verified our ideas.

4 There are times when, in the review of the  
5 accident analysis -- there's no formal procedure to say,  
6 hey, we're going to, every six months, look at the ECCS  
7 system and try to dream up what's wrong with it. But  
8 from time to time, knowledgeable engineers have concerns  
9 about it. And, in at least one incidence, that's led  
10 to a modification of the system, to require cross-  
11 connects to the high pressure injection lines, to  
12 maximize the effective injection of the high pressure  
13 system under the assumption of a single failure in the  
14 system.

15 COMMISSIONER TAYLOR: Now, is the work that  
16 you've just been giving examples of work that's done --  
17 I believe you used the phrase "research division," or  
18 "research unit," is that separate from the engineering  
19 division, or whatever it is, of B and W? In other  
20 words, let me ask this. Is this work that you do in your  
21 unit, or is this organization a separate group of people  
22 at B and W?

23 MR. DUNN: It could go both ways. Within  
24 Lynchburg, we have two types of units or personnel  
25 concerned with emergency core cooling or loss of coolant

LA 6

1 accidents. There is my unit, which is responsible for  
2 the licensing activities, in terms of generation of data  
3 to provide the NRC to convince them that the systems  
4 are appropriate, well-designed, and will function.  
5 I would call us the first line, or the troops.

6 We have a support organization, which is  
7 primarily concerned with developing methods. Generally,  
8 these would be things we would request. We might ask  
9 that a certain heat transfer correlation be investigated  
10 for applicability and perhaps incorporated in our  
11 computer codes.

12 I could do that work. I am free to do that  
13 work if it's necessary. But, by and large, the work  
14 would be performed by what we would call the technical  
15 staff personnel, which is a separate organization.

16 COMMISSIONER TAYLOR: Is that separate from  
17 engineering?

18 MR. DUNN: No, that is not separate from  
19 engineering. That is still within engineering. It's  
20 a separate section within engineering.

21 The mechanical R & D, or the physical R & D,  
22 wherein we're taking a pipe and running it and seeing  
23 how fast water flows through it, for example, that  
24 would be performed either in our alliance research  
25 center or in the -- there is a small research center which

A 7 1 occasionally becomes involved -- we become involved with  
2 for chemical type effects. Or it could be contracted  
3 out to a university, for example.

4 COMMISSIONER TAYLOR: Do you have much contact  
5 with the people in the research center, in the sense  
6 that it would be natural, or unusual, for you to  
7 discuss, for example, the Davis-Besse transient or any  
8 other real operational question that you become aware  
9 of? Or do you tend to address your own unit to that  
10 and not interact with the research center?

11 MR. DUNN: From the standpoint of an operational  
12 concern, I would not interact, in all likelihood, with  
13 the research center. If I needed basic information to  
14 address a concern in operations and this was outside of  
15 my present state of knowledge, I might very well go to  
16 them. But I would not expect that that type of contact  
17 would be made. Our involvement with them generally is  
18 along the lines of, I would like to perform this test  
19 to see what happens; these are the parameters around  
20 which I want to base the test; this is the type of event  
21 I want to test; and this is what I want measured.

22 COMMISSIONER TAYLOR: Is all or most of that  
23 work company-supported, or is there any significant  
24 amount of what one might call R & D on ECCS performance,  
25 design, and so on, that's supported by the government,



LA 8

1 specifically by NRC?

2 MR. DUNN: By and large, the vast majority of  
3 R & D efforts in emergency core cooling systems and  
4 the results or effects or impacts of those systems on  
5 loss of coolant accidents is performed by the government.

6 COMMISSIONER TAYLOR: Does B and W do quite  
7 a bit of that work? Do you have any sense of how much  
8 work of this kind is done in B and W, under contract to  
9 NRC?

10 MR. DUNN: Well, I'm not sure that I can give  
11 you a total response to that. I think we probably do  
12 not do too much physical testing. But I'm not sure  
13 how much involved we are in programs like the Navy  
14 programs, in which there may be contracts associated  
15 with emergency core cooling, which I'm not intimately  
16 aware of, or well aware of even. So I can't respond  
17 totally to that. You can really talk to the R & D  
18 division.

19 We do have a number of analytical programs  
20 with the government, in which we are investigating  
21 preliminary concerns with, for example, alternate fuel  
22 cycles, what are the ECCS concerns for alternate fuel  
23 cycles, maybe what are the ECCS concerns, which should  
24 we look at if we decide to create a new reactor design.

25 COMMISSIONER TAYLOR: Are you aware of any

LA 9 1 discussion, any papers, for example, on the Davis-Besse  
2 transient that have turned up at meetings of the  
3 American Nuclear Society or any comparable professional  
4 organization, as opposed to formal memoranda within  
5 B and W or communications between NRC and B and W?  
6 What I'm trying to get at is the extent to which the  
7 nuclear engineering analysis community, as a whole, goes  
8 into these questions of what happened at Davis-Besse  
9 and what does that imply for our particular system  
10 whether it's B and W or Westinghouse or whatever.

11 I have a sense -- and I'm trying to get some  
12 idea of whether it's correct or not -- that, at that  
13 level of detail, that is, what happened at Davis-Besse,  
14 there's very little sort of professional general  
15 discussion of these matters at professional conferences  
16 and so on. Is that view correct or not?

17 MR. DUNN: That's, I think, a fairly difficult  
18 question to respond to. It's very wide range. Relative  
19 to the aspect of the high pressure injection termina-  
20 tion, the event I thought was most serious, I don't  
21 believe there has been presentations -- Let me rephrase  
22 this a little bit. Treating the Davis-Besse incident  
23 of September 24th, if that's right, as a loss of coolant  
24 accident, I don't believe there has been presentations  
25 in the forums you suggested. There may very well have

LA 10

1 presentations in the forum of what happened, a description  
2 of the events that occurred standpoint, or perhaps  
3 somebody was interested in some other aspect that occurred  
4 at the same time, steam generator performance, for  
5 example, and I might not know about that.

6 CHAIRMAN KEMENY: Professor Lewis.

7 COMMISSIONER LEWIS: Mr. Dunn, I'd just like to  
8 get something clear. When did you first become aware  
9 of the Hallman memorandum? Was that after Three Mile  
10 Island or earlier, the August memorandum?

11 MR. DUNN: That was after Three Mile Island.

12 COMMISSIONER LEWIS: In other words, you  
13 didn't know about that at the February 14th meeting  
14 that was held in Lynchburg?

15 MR. DUNN: Well, the memo wasn't issued --  
16 oh, yes, it was.

17 COMMISSIONER LEWIS: It was before.

18 MR. DUNN: I got my dates backwards. No, I  
19 was not aware of it at that time.

20 COMMISSIONER LEWIS: So when that meeting was  
21 held in Lynchburg, the meeting that was called by the  
22 NRC and that was attended by the utilities, at that  
23 time, you thought the word had already gone out about  
24 high pressure injection. Is that correct?

25 MR. DUNN: Yes, ma'am. But that wouldn't be

A 11 1 the reason I wouldn't have mentioned it at that meeting.

2 COMMISSIONER: Okay, I'm kind of curious.

3 I was looking at Mr. Willse's memorandum and he said,  
4 "This meeting was requested by the Region II inspectors.  
5 The purpose of this meeting was thought to be to discuss  
6 the loss of pressurizer level indication on all B and W  
7 plants." It seems to me it was a perfect time for this  
8 particular issue to be raised. And I wonder why, or  
9 whether it was raised at that meeting.

10 MR. DUNN: Well, that meeting was called to  
11 address concerns associated with overcooling transients,  
12 where we have shrunk the primary system. It was not  
13 called to address concerns where we are losing pounds  
14 of water. We still have as much water available in  
15 those events to start with, as we do when we finish them.  
16 Quite likely, the make-up systems for the reactor will  
17 turn on to higher capacity and we'll wind up with more  
18 water.

19 Mentioning of a concern about high pressurizer  
20 or mentioning my concern with Davis-Besse, I think  
21 would have just had the result of diverting the meeting.  
22 And appropriate personnel were probably not at that  
23 meeting. There would have been some cross-connect in  
24 the fashion that I was at that meeting, and I believe  
25 I'm an appropriate personnel for those discussions. But

LA 12 1 I believe that the only result would have been a  
2 diversion of the meeting and getting the meeting side-  
3 tracked and not accomplishing, or accomplishing as well  
4 what the meeting was intended to accomplish.

5 COMMISSIONER LEWIS: Is it possible that you  
6 didn't raise the question because it was an NRC meeting  
7 and not particularly a private meeting between B and W  
8 and the utilities? I mean, was the presence of the NRC  
9 at that meeting an inhibiting factor in your not raising  
10 this question?

11 MR. DUNN: Actually, ma'am, I'm not a very  
12 inhibited person. I would say not. I would say there  
13 are ways to talk to the NRC. You can discuss things  
14 with them. I just don't think that I would have felt  
15 that an appropriate time to have such a discussion.

16 COMMISSIONER LEWIS: Now in hindsight, you're  
17 aware that a Met. Ed. representative was at that  
18 meeting. Mr. Hillbush was attending that particular  
19 meeting six weeks before Three Mile Island.

20 MR. DUNN: I wasn't aware of that until you  
21 mentioned it. But that wouldn't allow it. I was  
22 under the impression that most of the customers were  
23 at that meeting, and they are certainly one of them.

24 COMMISSIONER LEWIS: So had this question been  
25 raised, he might have been aware of some of the problems.

1 MR. DUNN: I suppose that's true.

2 COMMISSIONER LEWIS: Okay, thank you.

3 CHAIRMAN KEMENY: Commissioner Trunk?

4 COMMISSIONER TRUNK: Have you or any of your staff  
5 ever sat in on an operator training class, you know, to  
6 give a lecture or to see that courses were run correctly?

7 MR. DUNN: We have, from time to time,  
8 participated in operating training, in the form of  
9 providing a lecture on loss of coolant accidents. We  
10 do not do this frequently. In general, there is a  
11 group, which is called safety analysis, it's a unit  
12 within the plant design section, which does provide  
13 a lecture on accidents. Most of the time it has occurred  
14 that they have provided, in addition, the lecture on  
15 loss of coolant accident. We certainly have discussions  
16 among ourselves as to what they may present. But, by  
17 and large, they decide what to present at that lecture.

18 We also need to understand that the lectures,  
19 that series of lectures is optional to the utility.  
20 They do not have to purchase that from Babcock and  
21 Wilcox.

22 As far as sitting in in a fashion which would  
23 give me a good review of the overall operator training,  
24 during which you might expect me to spot where the  
25 training was inappropriate or stressed the wrong things,

LA 14

1 et cetera, we have not done that, prior to March 28th.  
2 I believe we're trying to formulate plans to accomplish  
3 that.

4 COMMISSIONER TRUNK: Have you ever taken a  
5 B and W training course, or anybody on your staff?

6 MR. DUNN: People on my staff have taken a  
7 B and W training course. It's an abbreviated course  
8 aimed at normal operations, not emergency.

9 COMMISSIONER TRUNK: Well, where do the people  
10 get the emergency training, then? How do they get it?  
11 Shouldn't they be versed in everything?

12 MR. DUNN: My people?

13 COMMISSIONER TRUNK: Everybody, yeh.

14 MR. DUNN: I don't think everybody can know  
15 everything. We're responsible for having a design  
16 and place capable of mitigating a loss of coolant  
17 accident. You've got me in a hard way. I have to  
18 agree with you that the operation of the system -- and  
19 in retrospect, I surely wish I had participated in  
20 the type of thing you're talking about. But at the  
21 time, we were operating under the assumption that if  
22 the accident was severe enough to cause the actuation of  
23 the high pressure injection system or the low pressure  
24 injection system, that it would be continued in operation.  
25 So I didn't have a reason to doubt the training.



LA 15 1 COMMISSIONER TRUNK: Well, I think if you would  
2 sit in on some of these things, you probably would have  
3 noticed it. From what I understand, you hadn't been to  
4 one of these things for three or four years, or you  
5 hadn't given a lecture.

6 MR. DUNN: Yes, I believe the lecture I gave  
7 myself was three or four years, or maybe even longer,  
8 ago. That wouldn't have spotted it for me, though,  
9 that lecture. Where I might have spotted such a thing  
10 was in participating with the operators and allowing,  
11 during the time that the normal instructors were giving  
12 them information.

13 COMMISSIONER TRUNK: Well, what determines if  
14 the instructors are qualified? I mean, is there anybody  
15 overseeing them?

16 MR. DUNN: Well, they certainly are part of  
17 an organization. They have management over them. And  
18 I suppose that management is responsible for seeing  
19 that their instructors are qualified.

20 COMMISSIONER TRUNK: But I'm under the  
21 impression that a team goes into the simulator. And  
22 maybe only one person pushes all the buttons and the  
23 other two just watch. I mean, what happens if one guy  
24 is sick and the other two have a replacement? They  
25 probably wouldn't know what to do.

LA 16

1 MR. DUNN: I think that's simplifying training  
2 considerable. I would not agree with your statement,  
3 the other two wouldn't know what to do. And I wouldn't  
4 agree that operators are that single-minded or trained  
5 to be that single-minded.

6 COMMISSIONER TRUNK: I have that plant in my  
7 back yard. I want it as safe as possible. I want  
8 those fellows to know the thing inside and out.

9 MR. DUNN: Yes, ma'am, I understand your  
10 concern. I want it to be that way, too.

11 CHAIRMAN KEMENY: Commissioner Trunk, we will  
12 have the manager of training for B and W as one of the  
13 witnesses, so you'll have further opportunity to  
14 explore that.

15 Mr. Pigford, did you have a question?

16 COMMISSIONER PIGFORD: In your recommendation  
17 of February 16th, the item two qualified it after a  
18 certain number of minutes. Wouldn't it be simpler just  
19 to state when you have such a loss of coolant accident,  
20 leave the high pressure injection on, period?

21 MR. DUNN: It may be.

22 COMMISSIONER PIGFORD: Is there any problem  
23 to that recommendation?

24 MR. DUNN: The only immediate problems to that  
25 recommendation, that occur to me, are, one, positive

LA 17 1 identification of a loss of coolant accident is a somewhat  
2 difficult process, particularly for extremely small  
3 loss of coolant accidents. If we break a large pipe on  
4 a system, the pressure falls right out of the bottom,  
5 the low pressure injection system, and the core flood  
6 tanks actuate, and that's generally quite obvious.  
7 For a small break, we achieve a reduction in reactor  
8 coolant system pressure and, in general, achieve  
9 saturated conditions. Something quite similar to that  
10 could occur, for example, in an overcooling transient,  
11 wherein a serious amount of cold water had been injected  
12 to the secondary side of the steam generator. If it  
13 were an overcooling transient, as opposed to a small  
14 break, the continuous injection of high pressure fluid  
15 has a potential for causing a loss of coolant accident.  
16 That would be one reason.

17 COMMISSIONER PIGFORD: Could you please explain?

18 MR. DUNN: Well, the reactor coolant system  
19 is only so big. It will contain, as a rough number,  
20 500,000 pounds of water. If I attempt to push 550,000  
21 pounds of water into the system, there is not enough  
22 room for it. This would cause very high pressure.  
23 And that pressure would have to be relieved. There are  
24 code safety valves supplied for that purpose. However,  
25 the code safety valves have a small possibility of

LA 18 1 becoming damaged. They may not reseal. And if I continued  
2 the high pressure injection, they wouldn't reseal,  
3 except momentarily, the nature of their relieving action.  
4 And that, then, becomes a loss of coolant accident,  
5 which, although in my mind there are not terribly bad  
6 consequences to that particular accident, we wouldn't  
7 want to have one. We wouldn't want to cause one.

8           The second item that may happen is the accident  
9 may be securable, as in the fashion of the PORV. That's  
10 a loss of coolant accident for which a block valve  
11 is provided and for which I can stop having a loss of  
12 coolant accident. Once I do that and reachieve a  
13 fairly normal condition of the reactor coolant system,  
14 in my mind, it's better to stop with the emergency  
15 systems and go back into the normal control of the plant.

16           COMMISSIONER PIGFORD: Now, in some of your  
17 reports, you have small break analyses, and you have mentioned  
18 that in some cases it is necessary to use operator action  
19 during the early stages of these accidents to mitigate the  
20 accident consequences. What kind of operator action  
21 did you find out?

22           MR. DUNN: Well, at B and W, we approach -- at  
23 least it's my opinion that we approach safety and a loss  
24 of coolant accident rather aggressively.

25           COMMISSIONER PIGFORD: Excuse me, if you can give

LA 19 1 a fairly short, specific answer, and then, if you need  
2 to elaborate, that would be good.

3 MR. DUNN: All right, well, I was going to  
4 go into that in the next sentence, and then I would  
5 like to elaborate, if I may.

6 As I mentioned, we approach it, I think, rather  
7 aggressively. There is an operator action required  
8 for mitigation of a small break, which relates to  
9 balancing the high pressure injection.

10 COMMISSIONER PIGFORD: Maybe it throttles the  
11 high pressure injection?

12 MR. DUNN: Not necessarily. Let me tell you  
13 what I'm trying to accomplish. And the particulars of  
14 how each utility would accomplish these facts are not  
15 immediately at my knowledge. I can find them out.  
16 I have provided criteria, what they should accomplish.

17 In the event of a small break, located between  
18 the high pressure injection injection point and the  
19 reactor vessel, additionally in the event that this  
20 break is at the bottom of the reactor coolant piping,  
21 at the very bottom, additionally in the event that this  
22 is a rather small break, and also that I have undergone  
23 a loss of one of my high pressure injection trains,  
24 for some reason -- that would be the single failure  
25 criteria -- it is possible that the active high pressure

LA 20 1 injection strain is injecting fluid in two locations.  
2 One of those locations is in an intact pipe and one of  
3 those locations is in the broken pipe. Under those  
4 specific circumstances, it's possible that the water  
5 injected in the broken leg, I call it, will not reach  
6 the reactor vessel. In order to achieve a higher  
7 ratio of water reaching the reactor vessel, we inform  
8 the operator to line up his pumps so that no more than  
9 30 percent of the total high pressure injection capability  
10 is going to any single injection nozzle. In that  
11 fashion, instead of running the risk of losing 50  
12 percent of my pump capacity, I only lose 30 percent of  
13 my pump capacity.

14 Now, it's my understanding that that is being  
15 made automatic within the plants. But for some period  
16 of time, they are doing that manually.

01  
MI  
-18-79  
ape 7

1 COMMISSIONER PIGFORD: If you have a loss of auxi-  
2 liary feedwater and a small break, what kind of operation  
3 operator intrusion is necessary to keep the core from being  
4 uncovered. Have you had that case?

5 MR. DUNN: We have bounded that case. I can respond  
6 to you.

7 COMMISSIONER PIGFORD: Please. My question is what  
8 kind of operator intrusion or action is required to keep the  
9 core from being uncovered?

10 MR. DUNN: The only intrusion for the small break  
11 would be the one I just described to you; whereas, we would  
12 want him to balance his high pressure injection in the event  
13 that the LOCA part of the scenario described was between an in-  
14 jection line and the reactor vessel. Other than that the re-  
15 actor will cool in a boiling mode successfully with just the  
16 high pressure injection.

17 COMMISSIONER PIGFORD: Suppose there is no break or  
18 the break is very, very small, what is required?

19 MR. DUNN: In that event, it would probably have to  
20 be a break so small as to be able to be mitigated by the normal  
21 makeup systems. In which case, we would term it a "leak".  
22 Perhaps, if I can divert you into a non-break, just a total  
23 loss of all feedwater --

24 COMMISSIONER PIGFORD: That is the case I am posing  
25 to you. What operator action is necessary?



DO2

1 MR. DUNN: Initiation of the high pressure injection  
2 system would be called for. There are, you know, auxiliary  
3 feedwater systems on the plant available to provide independent  
4 means of cooling. If both main and auxiliary feedwater are  
5 lost, obviously need a heat sink, I have to use a containment  
6 building.

7 COMMISSIONER PIGFORD: So, you have to initiate  
8 high pressure injection at high pressure. Is that correct?

9 MR. DUNN: Yes, sir.

10 COMMISSIONER PIGFORD: Now, have you analyzed since  
11 the Three Mile Island accident that transient using your com-  
12 puter codes? To be more specific, let's say calculation of  
13 the pressure, temperature and so forth during the first few  
14 hours.

15 MR. DUNN: We analyzed that type of transient in  
16 1973. We are presently repeating that particular transient  
17 and the status of that calculation is well along; probably  
18 75 percent complete. We have no reason to doubt the 1973 re-  
19 sults. We did want to perform them with the current state of  
20 knowledge. We have analyzed many very similar events. These  
21 have been the type of event of a PORD opening initially. The  
22 one you are describing will cause the PORD and the safeties to  
23 open at some time.

24 COMMISSIONER PIGFORD: Now, in the case of Three  
25 Mile Island, the auxiliary feedwater was unavailable for eight

03 1 minutes. From your analyses, if it had been available, how  
2 much difference would it have made to the transient, to the  
3 onset of core uncoverage, leaving all other operations and  
4 phases the same?

5 MR. DUNN: Leaving all other parameters the same,  
6 there may have been a difference in the results. Let me quan-  
7 tify and expand on this a little bit. The B and W ECCS systems  
8 will prevent the occurrences at Three Mile Island. I believe  
9 that or I wouldn't be in my position right now. And I am very  
10 sincere in stating that. We have several unique features  
11 associated with our systems which assist in the prevention of  
12 such accidents. The TMI-2 incident involves many parameters  
13 and I would like to go through those. There is the initiating  
14 event --

15 COMMISSIONER PIGFORD: Before you go into the detail,  
16 do you happen to know the non-specifics of the question. I  
17 think you are giving us some back up on the whole system,  
18 right?

19 MR. DUNN: I am going into the events at Three Mile  
20 Island to properly characterize the answer in my response to  
21 my question.

22 COMMISSIONER PIGFORD: Could you give us an answer  
23 and then you can provide the backup? Do you happen to have  
24 calculated this case?

25 MR. DUNN: The Three Mile Island simulation, sir?

1 CHAIRMAN KEMENY: The specific question, Mr. Dunn,  
2 was, how much difference did it make to the accident that the  
3 auxiliary feedwater was not available for eight minutes?

4 MR. DUNN: What I am trying to respond with is that  
5 is unclear as to how much difference that makes. It is not  
6 obvious that that would have prevented the occurrences of Three  
7 Mile Island. It is not -- there is the possibility that it  
8 would have. May I continue?

9 There is the initiating event in the loss of main  
10 feedwater. There is the non-availability of auxiliary feedwater  
11 for at least some time. Directly in response to your concern,  
12 this may have diverted the operator's attention or it may have  
13 caused further damage to the PORD than would have been expected  
14 under a normal loss of main feedwater event. Okay. Normally,  
15 we don't expect damages to the PORD. We do expect it to open  
16 and function.

17 I guess, in carrying it on, the third significant  
18 event is the termination or restriction of high pressure in-  
19 jection. Fourthly, the PORD must not be recognized as an open  
20 -- in an open position for 50 to 60 minutes.

21 Finally, the reactor coolant's pumps must be termin-  
22 ated. Those events must lie in approximate sequence of TMI-2  
23 and in the time frame that they occurred at TMI-2 in order to  
24 produce the results of that accident. Had the high pressure  
25 injection not been terminated, the system would have evolved

05 1 to an acceptable void fraction and no consequences would have  
2 been incurred. Had the reactor coolant pumps been maintained  
3 in position, the reactor could have cooled itself with steam  
4 flow.

5 So, the answer is that it is not obvious whether or  
6 not the auxiliary feedwater or lack of emergency feedwater to  
7 the secondary side of the steam generators was meaningful. I  
8 would certainly allow that the same process could have occurred  
9 had the auxiliary feedwater been available initially.

10 COMMISSIONER PIGFORD: Have you calculated the case,  
11 Mr. Dunn?

12 MR. DUNN: Yes. I am sorry. Excuse me. I have not  
13 calculated that case under the assumption that the high press-  
14 ure injection system was cut back.

15 COMMISSIONER PIGFORD: Had you calculated -- Excuse  
16 me. I will rephrase.

17 In an earlier analysis by your group, you reported  
18 some calculation of the effect of auxiliary feedwater being  
19 left closed and with a .04 square foot rate and you reported  
20 that as the worst case break in the range of interest. Does  
21 that mean that happens to be the size that gives you the worst  
22 results of all of the small breaks you considered?

23 MR. DUNN: I think somehow we have got some facts  
24 mixed up. If I am not wrong and if this is coming from my  
25 deposition and I may have been wrong, I think that was a .01

1 square foot break as opposed to a .04.

2 COMMISSIONER PIGFORD: I am referring to a report  
3 BAW 10104, Revision 3, dated August 1, 1977.

4 MR. DUNN: Okay.

5 COMMISSIONER PIGFORD: You remember that?

6 MR. DUNN: I remember it. I don't have it in front  
7 of me. The accident there does not involve the loss of auxil-  
8 iary feedwater to my recollection.

9 COMMISSIONER PIGFORD: Neglecting auxiliary feed-  
10 water has been investigated. What does it mean "neglecting  
11 it"?

12 MR. DUNN: I think it would be appropriate if I  
13 could have a copy of the report to get the context again.

14 COMMISSIONER PIGFORD: I will supply one. I certain-  
15 ly don't want to ask you from your report if you --

16 Do you see the paragraph with the circles around it?

17 MR. DUNN: Yes, sir. I am just trying to find the  
18 section in the report in which this statement is made.

19 In response to the word "neglecting" in here, it is  
20 my impression that this means not modeling, not having a simu-  
21 lation which would not have auxiliary feedwater available.

22 COMMISSIONER PIGFORD: Does that mean that in your  
23 model, you assume that it is not available? Is that correct?

24 MR. DUNN: We generally assume that the auxiliary  
25 feedwater is available.

07 1 COMMISSIONER PIGFORD: But I mean in that calculation?

2 MR. DUNN: Well, if in fact we were referring to a  
3 calculation here, yes, that would be what it means. I am not  
4 sure at this time whether this is a calculation or an analysis  
5 performed without the aid of computers, for example.

6 COMMISSIONER PIGFORD: Does it mean that in that  
7 particular case, the auxiliary feedwater was not available?

8 MR. DUNN: That is what I would believe it would  
9 mean.

10 COMMISSIONER PIGFORD: Then as you read through  
11 further, it appears that you are comparing it to an earlier  
12 calculation with auxiliary feedwater available and would you  
13 read out that sentence that has the results in it, that com-  
14 parison.

15 MR. DUNN: The sentence that starts, the calculated  
16 results?

17 COMMISSIONER PIGFORD: Yes. It is where comparison  
18 with the previous calculations, which I think are with auxil-  
19 iary feedwater available.

20 MR. DUNN: The calculated results showed an improve-  
21 ment in core liquid volume over the previous case reported in  
22 the SMUD ESFAS CR with auxiliary feedwater.

23 COMMISSIONER PIGFORD: And does that mean that it is --  
24 when you do not have auxiliary feedwater available, you improve  
25 the results?

1 MR. DUNN: No, sir.

2 COMMISSIONER PIGFORD: What does it mean?

3 MR. DUNN: It means that between the earlier analysis  
4 and the analysis methods -- excuse me -- between the earlier  
5 analysis and the methods that were in place for the earlier  
6 analysis, which I have to place in about the 1973 time frame  
7 for this, and the method of analysis justified in this report,  
8 a large number of other improvements in the simulation had  
9 occurred. And that because of those other model improvements  
10 which relate to fluid tracking within the primary system, re-  
11 sults of this calculation were -- and analysis -- and/or  
12 analysis were improved over the 1973 variety.

13 COMMISSIONER PIGFORD: Even though this one now  
14 has no feedwater available, the other things may result in a  
15 net improvement. Is that correct?

16 MR. DUNN: Yes, sir.

17 COMMISSIONER PIGFORD: Now, tell me if the feedwater  
18 were not available in such a transient and if you lost outside  
19 power, which is the case that you calculate, then which is  
20 better from the point of view of insuring that the core remains  
21 covered with water? To have the pressure relief valve stay  
22 open or to have it open and close as designed?

23 MR. DUNN: Could I have the first parts of the  
24 question again?

25 COMMISSIONER PIGFORD: If you lost outside power



1 and if you had no auxiliary feedwater?

2 MR. DUNN: Okay. If I lost outside power and I had  
3 no auxiliary feedwater, would it be better to have the relief  
4 valves open and close as they are designed to do or to have  
5 them stay open?

6 COMMISSIONER PIGFORD: Yes. From the point of view,  
7 strictly, of keeping the core covered with water.

8 MR. DUNN: Now, as I understand our system, the  
9 core would stay covered in both cases. From the standpoint  
10 of margins of covering, if the valves were to stay open, after  
11 some period of time, the reactor coolant system would evolve  
12 to a lower pressure, which would increase the capability of  
13 the high pressure injection systems to supply water and that  
14 may then mean that we would have a larger margin to core un-  
15 covery.

16 COMMISSIONER PIGFORD: Okay. In which case would  
17 you have the temperature farther below the saturation tempera-  
18 ture at a given time of an accident.

19 MR. DUNN: I do not believe we would be below the  
20 saturation pressure in either case. Perhaps, if the valve is  
21 opening and closing, there may be times at which we are a  
22 small degree below saturation.

23 COMMISSIONER PIGFORD: Mr. Dunn, does your group  
24 also evaluate the effects on containment of these calculated  
25 accidents?

1 MR. DUNN: To a certain extent. We evaluate the  
2 resultant pressure and temperature within the containment as  
3 a result of the types of accidents and we involve the -- calcu-  
4 late the hydraulic loadings in the fashion of jet entrenchment  
5 calculations. And that is at an option to the utility.

6 COMMISSIONER PIGFORD: Do you happen to recall at  
7 what time in the Three Mile Island accident the containment  
8 pressure reached the negative sufficient because the isolation  
9 of the containment?

10 MR. DUNN: No, sir. I do not recall that at this  
11 time. It is my understanding that it did at one time, but I  
12 don't recall exactly when that occurred.

13 COMMISSIONER PIGFORD: Well, what would you expect  
14 from such an accident, at one kind?

15 MR. DUNN: Well, the accident at Three Mile Island.

16 COMMISSIONER PIGFORD: Or such an accident. You  
17 have analyzed such accidents for other reactors, haven't you?

18 MR. DUNN: Yes. I think it is important as to  
19 whether it is a loss of coolant accidents somewhere in the  
20 piping or a loss of coolant accidents which has some control  
21 in the form of quench tank. I would expect the reactor build-  
22 ing to go to the required signal, which I believe is 4 PSIG.  
23 Let me say, slowly. It would not go that level rapidly.

24 COMMISSIONER PIGFORD: For the Pebble Springs plant,  
25 your analysis for the case of loss of feedwater and for a small

011 1 break accident projected the containment isolation at four  
2 pounds per square inch, at less than ten minutes. Is that  
3 correct?

4 MR. DUNN: That may very well be. I didn't come  
5 prepared to discuss details on Pebble Springs.

6 COMMISSIONER PIGFORD: Okay. That analysis was  
7 done back in --

8 MR. DUNN: Pardon me a minute. Would you excuse me,  
9 sir. There is a contract for which B and W has responsibility.  
10 I usually refer to it as PG and E. I am not absolutely posi-  
11 tive that

12 COMMISSIONER PIGFORD: That is the one.

13 MR. DUNN: That is the one. Okay.

14 COMMISSIONER PIGFORD: In fact, let me state my  
15 conditions a little clearly to show you the relevance. As  
16 stated all feedwater is lost and water is lost through the  
17 pressurizer, through the relief valve, through the reactor  
18 coolant drain bank. And then it says that in less than ten  
19 minutes, containment pressure reaches the 4 PSI set point.  
20 Does that still sound reasonable to you?  
21

1 MR. DUNN: What size break was this?

2 COMMISSIONER PIGFORD: Well, it appears to be the  
3 relief through the pressurizer, which I guess is the length  
4 of the supplemental relief valve.

5 MR. DUNN: You mean the PORV?

6 COMMISSIONER PIGFORD: Yes.

7 MR. DUNN: Well, to respond to you, sir, I would  
8 have to go and do a calculation on that particular event.

9 COMMISSIONER PIGFORD: If I show you the table,  
10 which I am assuming was supplied by your group, would that  
11 help?

12 MR. DUNN: That table could have been supplied by  
13 our group.

14 COMMISSIONER PIGFORD: Does some other group in  
15 B&W supply such analyses to their customers?

16 MR. DUNN: No, I don't believe another group within  
17 B&W. The question in my mind is whether we supplied that or  
18 whether the architect-engineer supplied that information.

19 COMMISSIONER PIGFORD: Does the architect-engineer  
20 himself do this kind of analysis?

21 MR. DUNN: Yes, sir, at times. It would depend on  
22 the utility's option as to who they contracted to do that.

23 CHAIRMAN KEMENY: Commissioner Pigford, could I try  
24 a suggestion, since there are a couple of areas in which the  
25 witness really was not prepared in the sense that we hadn't

1 prepped him to be prepared for this area. Would it be satis-  
2 factory to you if you submitted those questions in writing,  
3 simply requested from Mr. Dunn an answer to your question?

4 COMMISSIONER PIGFORD: Of course.

5 CHAIRMAN KEMENY: It seems, since you clearly came  
6 well prepared in the areas in which you were previously ques-  
7 tioned, it would seem to me fairer if you submitted these in  
8 writing. Would that be acceptable to B&W counsel?

9 COMMISSICNER PIGFORD: Certainly.

10 MR. DUNN: Yes.

11 COMMISSIONER PIGFORD: Since I have kind of confused  
12 the record, at least let me make a short statement on where I  
13 am heading so he can think about it. I am puzzled that in the  
14 NERP analysis that I have before me which appears in the  
15 Tedesco Report from the NRC, which is for Portland General  
16 Electric, a B&W reactor, and I have stated the conditions,  
17 the containment seems to isolate so quickly, at less than 10  
18 minutes, whereas my understanding from Three Mile Island is  
19 that the containment did not isolate until much, much, much  
20 longer. And I think other parts of the record will show how  
21 long, and so I am not going to take the chance of making a  
22 mistake of showing, telling. I think it is hours. And I  
23 am curious as to the difference. Thank you.

24 MR. EDGAR: May we have one clarification on this?  
25 Mr. Dunn does not know at this time whether or not the analysis

1 in question was performed by B&W or not, and if indeed that  
2 was not the case, would it be suitable to the Commission to  
3 direct that question to the person to whom the analysis -- or  
4 who did the analysis?

5 CHAIRMAN KEMENY: Absolutely. Yes, that is per-  
6 fectly acceptable to the Commission.

7 Let's see, I believe Governor Babbitt wished to ask  
8 some questions. Governor Babbitt?

9 COMMISSIONER BABBITT: Mr. Dunn, I am interested  
10 whether prior to the distribution of the Fairburn memo of  
11 April 4, 1979, with respect to the use of the high pressure  
12 injection system, prior to that time, where would I go for  
13 writings or documents indicating what B&W policy was for the  
14 use of HPI during these low pressure transients?

15 MR. DUNN: I think you would have to go to two loca-  
16 tions. The operating procedures for a reactor are within the  
17 domain of the utility as, for that matter, are final approval  
18 of almost everything. B&W prepares guidelines for emergency  
19 procedures, it is my understanding. Within the emergency  
20 procedures, you would find information relative to that.

21 It would then occur to me that you should go to the  
22 training department who is instructing operators on how to  
23 deal with the operation of the plant and evaluate what they  
24 are saying. At least that is what I would do if I was seeking  
25 the information you are.

1 CHAIRMAN KEMENY: In a moment I am going to declare  
2 a recess. I did not do it earlier because I know, Mr. Dunn,  
3 that you are anxious to return to your family. Incidentally,  
4 we wish your wife the very best. The event hasn't occurred  
5 yet, has it?

6 MR. DUNN: No, it hasn't, sir. Thank you.

7 CHAIRMAN KEMENY: We wish you the very best. Just  
8 to try to sum up two or three key points, returning your  
9 memoranda of concern in February of 1978, there you suggested  
10 certain types of procedures. My question does not relate to  
11 every detail of that procedure, just to that kind of recom-  
12 mendation. Would it be fair to say that that type of proce-  
13 dure would have been relevant to the Three Mile Island II  
14 accident?

15 MR. DUNN: Well, I think that is a very good ques-  
16 tion. I don't think that type of procedure would have hurt.  
17 I believe, had the principles behind my concerns been part of  
18 the operators' general knowledge, that in that case it could  
19 very well have prevented the results at TMI II. If the in-  
20 structions had been embodied in the form of a procedure, then  
21 we have to ask ourselves what were the procedures at Three  
22 Mile Island. I can't swear to it, but I have been led to  
23 understand that the emergency procedures there called for  
24 maintaining high pressure injection until the system was above  
25 1600 psig.



1           If my procedure had been followed as that one ap-  
2           parently was, and I don't want to throw stones or anything  
3           like that, it might not have made any difference.

4           CHAIRMAN KEMENY: But -- let's see, was that last  
5           reference that if your procedure had been followed at which  
6           point, it would have made more difference?

7           MR. DUNN: At which point during the transient?

8           CHAIRMAN KEMENY: Yes. It wasn't quite clear to  
9           some of us, at which point would your procedure have made more  
10          difference?

11          MR. DUNN: At the point -- what I -- let me just say  
12          it almost the same way and see if it becomes clearer. It is  
13          my understanding that within the emergency procedures for  
14          Three Mile Island there is a statement that says you leave  
15          the high pressure injection functioning until the reactor's  
16          coolant system reaches 1600 psi or above, okay? To my know-  
17          ledge, during the time that the core damage occurred, the  
18          reactor coolant system was not above 1600 psi. It certainly  
19          was not above that value during the time at which we were  
20          seriously depleting the water inventory in the reactor cooling  
21          system.

22          That would be the point in time in which my instruc-  
23          tions would have been valuable. Had my instructions been  
24          followed as that one was, you know, it wouldn't make any  
25          difference.

1 CHAIRMAN KEMENY: P . . . the best of your knowledge,  
2 your instructions, or anything equivalent to it, was not fol-  
3 lowed at TMI II, is that correct? I am not asking what their  
4 instructions were, but you have analyzed what happened there.

5 MR. DUNN: Yes, sir. Nothing equivalent to my  
6 instructions was followed at TMI II during the first at least  
7 two hours, 2-1/2 hours, of the transient.

8 CHAIRMAN KEMENY: Yes. I am talking only about that  
9 period, and is it -- as an expert on the high pressure injec-  
10 tion system, is it your opinion that if something equivalent  
11 to your recommendations had been followed during that period,  
12 it would have made a substantial difference?

13 MR. DUNN: Yes, sir. Had my instructions been  
14 followed at TMI II, we would not have had core damage; we  
15 would have had a minor incident.

16 CHAIRMAN KEMENY: Thank you. The witness is excused,  
17 and the Commission will take a ten-minute recess.

18 (Witness excused.)

19 (Brief recess.)  
20  
21  
22  
23  
24  
25

TMI  
7/18/79  
1  
Tape 9

1 CHAIRMAN KEMENY: Mr. Chief Counsel, please swear in  
2 the witness.

3 MR. GORINSON: Mr. Walters, would you raise your right  
4 hand? Do you solemnly swear that the testimony you are about  
5 to give will be the truth, the whole truth, and nothing but the  
6 truth, so help you God?

7 MR. WALTERS: I do.

8 CHAIRMAN KEMENY: Could you please state for the re-  
9 cord your full name and your current position at B and W?

10 MR. WALTERS: My name is James Michael Walters. I  
11 am Supervisory Engineer, the Plant Performance Section of  
12 Nuclear Service, now known as Customer Service.

13 CHAIRMAN KEMENY: Chief Counsel?

14 MR. GORINSON: Mr. Rockwell.

15 MR. ROCKWELL: Thank you, Mr. Chairman. Mr. Walters  
16 would you tell the Commission what the Plant Performance Services  
17 Section does?

18 MR. WALTERS: We have general responsibility in the  
19 area of plant testing, mainly physics testing, and overall  
20 document production for plant testing and guidance for operators  
21 instructions.

22 MR. ROCKWELL: And would you describe what the fun-  
23 ction of the Nuclear Service Department, now the Customer Ser-  
24 vice Department, is.

25 MR. WALTERS: We are mainly -- draft plant operations,

9 2 1 getting a plant all aligned initially, testing the performance  
2 of the plant both initially and subsequently but mainly in the  
3 operation and performance area.

4 MR. ROCKWELL: And Mr. Walters, specifically, what is  
5 your job as the Supervisory Engineer in the Plant Performance  
6 Services Section?

7 MR. WALTERS: My responsibility is again, mainly to  
8 supply procedures, mainly testing procedures that we think are  
9 necessary to test the plant either in the initial start-up or  
10 in the case of relayed cycles on operating reactors, mainly  
11 coolant physics testing.

12 MR. ROCKWELL: Mr. Walters, I direct your attention  
13 to Hearing Exhibit number 1, which should be on your table. Do  
14 you have it before you? It is a memorandum from Mr. Kelly to  
15 a number of individuals.

16 MR. WALTERS: Yes, we have a copy.

17 MR. ROCKWELL: You have Hearing Exhibit number 1 before  
18 you?

19 MR. WALTERS: Yes, sir.

20 MR. ROCKWELL: Do I correctly identify it as a Novem-  
21 ber 1st, 1977 memorandum from Mr. Kelly to a number of indivi-  
22 duals?

23 MR. WALTERS: That is correct.

24 MR. ROCKWELL: Did that memorandum come to your at-  
25 tention at some point on or about November 1st, 1977?

sg 3  
1 MR. WALTERS: That is correct.

2 MR. ROCKWELL: How did it come to your attention?

3 MR. WALTERS: I received it in my in basket from my  
4 immediate supervisor, Mr. Hallman.

5 MR. ROCKWELL: And where there any instructions when  
6 it came to you?

7 MR. WALTERS: Yes, sir. It has something on the  
8 order of what do I think about this, or something like that.

9 MR. ROCKWELL: Did you talk to Mr. Hallman at that  
10 time?

11 MR. WALTERS: I do not recall. I probably did.

12 MR. ROCKWELL: Did you respond to the Kelly Memorandum  
13 in connection with Mr. Hallman's note to you?

14 MR. WALTERS: Yes, I did.

15 MR. ROCKWELL: In preparing your response did you con-  
16 sult with some people at Babcock and Wilcox?

17 MR. WALTERS: Yes, I did.

18 MR. ROCKWELL: I refer you now to Hearing Exhibit Num-  
19 ber 2. Do you have that before you?

20 MR. WALTERS: Yes, I do.

21 MR. ROCKWELL: And is that your response to Kelly's  
22 November 1st, 1977 memorandum?

23 MR. WALTERS: Yes, that is true.

24 MR. ROCKWELL: Do I correctly identify it as a Novem-  
25 ber 10th, 1977 memorandum from yourself to Mr. Kelly?

sg 4  
1 MR. WALTERS: Yes, sir.

2 MR. ROCKWELL: In preparing your response, can you  
3 tell me who you talked to at B and W?

4 MR. WALTERS: Well, yes. I have testified before  
5 that I talked with ex training personnel within -- outside of  
6 the training department but still within Nuclear Services.  
7 Since the last deposition, I am a little hazy on the actual  
8 people I talked to -- I talked to the three people identified  
9 before, Mr. Gossolo, Street, and Smith. At this time only Mr.  
10 Smith remembers me talking with him on this matter.

11 MR. ROCKWELL: This is based on conversations which  
12 you had with these three people since your deposition?

13 MR. WALTERS: That is correct.

14 MR. ROCKWELL: In reviewing the Kelly memorandum,  
15 when it came to you, did you believe that it raised a valid  
16 point?

17 MR. WALTERS: Yes.

18 MR. ROCKWELL: Did you have any concerns about the  
19 way Mr. Kelly had raised his prescription?

20 MR. WALTERS: Yes. We -- I say we, me and Mr. Smith --  
21 after talking with him, we did have some concerns.

22 MR. ROCKWELL: Would you describe them please?

23 MR. WALTERS: As I stated before, I want to make sure  
24 we get the process probably because of our input, our concern  
25 was addressing a non-LOCA initiator transient, and overcooling

sg 5

1 transient, and that is an area we were concerned and if we  
2 literally played reliance on the prescription in Mr. Kelly's  
3 memo that we may take the plant solid in ensuing transients.

4 MR. ROCKWELL: In reference to Mr. Smith whom you be-  
5 lieve you consulted in preparing your memorandum, am I correct  
6 in understanding that he was a former instructor in the Babcock  
7 and Wilcox Training Department?

8 MR. WALTERS: That is correct.

9 MR. ROCKWELL: And that he had a number of years of  
10 experience in that Department as an instructor?

11 MR. WALTERS: That is correct.

12 MR. ROCKWELL: But at the time you talked to him, he  
13 had moved on to the Customer Service Department? Is that cor-  
14 rect?

15 MR. WALTERS: That is correct.

16 MR. ROCKWELL: I am referring you now to Hearing Ex-  
17 hibit Number 2. Let me read to you the first paragraph, Mr.  
18 Walters: "In talking with training personnel and in the opinion  
19 of this writer the operators at Toledo responded in the correct  
20 manner considering how they had been trained and the reasons be-  
21 hind the training". What was your understanding, Mr. Walters,  
22 of how they had been trained? In light of your use of that term  
23 in that paragraph?

24 MR. WALTERS: I thought that generally speaking the  
25 operators had been trained to diagnose pressure level and pressure



6 1 training in the same direction and that in the TECO transient  
2 that he correctly responded in this, in the second part of the  
3 TECO transient.

4 MR. ROCKWELL: Would it be fair to say, Mr. Walters,  
5 that based on your knowledge in the fall of 1977, the termi-  
6 nation of high pressure injection on the basis of the pressurizer  
7 level was appropriate?

8 MR. WALTERS: No, it would not.

9 MR. ROCKWELL: It is not fair to say that?

10 MR. WALTERS: No.

11 MR. ROCKWELL: Would you provide Mr. Walters with a  
12 copy of his deposition?

13 I am referring you, Mr. Walters, to the second sec-  
14 tion of your deposition, page 14, line 10. Do you recall that  
15 deposition being taken on July 13, 1979?

16 MR. WALTERS: Yes.

17 MR. ROCKWELL: And there was a court reporter present?  
18 Is that correct?

19 MR. WALTERS: Yes.

20 MR. ROCKWELL: My questions and your answers were  
21 taken down, is that correct?

22 MR. WALTERS: That is correct.

23 MR. ROCKWELL: Quoting now from line 10, question:  
24 You have to say yes, that termination of HPI, on the basis of  
25 pressurizer level alone was appropriate in terms of your know-

sg 7  
1 ledge in the fall of 1977. Is that correct? Answer: Yes. Is  
2 that transcript accurate?

3 MR. WALTERS: Yes.

4 MR. ROCKWELL: That was based on your knowledge and  
5 experience, having been an employee at Babcock and Wilcox for  
6 some eight to ten years as of the fall in 1977?

7 MR. WALTERS: I think it is fair to say that in most  
8 general cases that is true. Not in all cases.

9 MR. ROCKWELL: Referring you now, Mr. Walters, to the  
10 second paragraph of your memorandum, let me read the first  
11 sentence: "My assumption and the training assumes first that  
12 RC Pressure and Pressurizer Level will trend in the same direction  
13 under a LOCA." Is that an accurate reading of the sentence?

14 MR. WALTERS: Yes, sir.

15 MR. ROCKWELL: Do you believe that nuclear reactor  
16 operators in general at that time had the same assumption?

17 MR. WALTERS: I think so.

18 MR. ROCKWELL: Referring you now to the fourth para-  
19 graph, Mr. Walters, I quote: "If you intend to go solid," this  
20 is on page two, "If you intend to go solid what about problems with  
21 vessel mechanics." Would you tell us what problems of vessel  
22 mechanics you were concerned about?

23 MR. WALTERS: As I stated in my deposition before, I  
24 was involved, being in Nuclear Service and with the responsibi-  
25 lity for keeping these plants operating, I was essentially

sg 8 1 concerned about an availability problem in that if we took the  
2 plant solid, that the ensuing analysis or paper work involved  
3 would present us with a long down time on that particular plant.

4 MR. ROCKWELL: Would that mean that a long down time  
5 would mean a substantial time off line for the plant?

6 MR. WALTERS: That is correct.

7 MR. ROCKWELL: And the plant would not be generating  
8 electricity during that time?

9 MR. WALTERS: That is correct.

10 MR. ROCKWELL: You referred to hydro-ing the RCS in  
11 your memo. By that you mean going solid, Mr. Walters?

12 MR. WALTERS: Yes, sir.

13 MR. ROCKWELL: Were the operators ever taught to go  
14 solid at any time? And by operators I mean operators generally.

15 MR. WALTERS: I do not believe they were ever taught  
16 to go solid, that is correct.

17 MR. ROCKWELL: Would it be fair to say that they were  
18 never taught to go solid under any conditions?

19 MR. WALTERS: To the best of my knowledge.

20 MR. ROCKWELL: And that is based again on your ex-  
21 perience and on your having been employed at B and W for some  
22 ten years as of the fall of 1977?

23 MR. WALTERS: That is correct.

24 MR. ROCKWELL: And would it also be fair to say that  
25 your assumption is that they were taught -- not only were they

sg 9

1 never taught to go solid but they were taught never to go solid?

2 MR. WALTERS: I did not have first-hand information  
3 that they were never taught to go solid, no.

4 MR. ROCKWELL: Is that your understanding?

5 MR. WALTERS: That is my understanding.

6 MR. ROCKWELL: After Mr. Kelly received your memo-  
7 randum, did he contact you about the points that you raised in  
8 your memorandum?

9 MR. WALTERS: No, I do not remember any contact with  
10 Mr. Kelly concerning his memo.

11 MR. ROCKWELL: To your knowledge, did anything happen  
12 in the three months between the time your memorandum was directed  
13 to Mr. Kelly and the time that Mr. Dunn's memorandum was issued  
14 on February 9th, 1978?

15 MR. WALTERS: I initiated no action, nor do I person-  
16 ally know of any.

17 MR. ROCKWELL: Were you aware of any action being  
18 taken during that period of time?

19 MR. WALTERS: No, I am not.

20 MR. ROCKWELL: Let me go back a moment, Mr. Walters,  
21 if your assumption that you indicated a moment ago is true,  
22 namely that operators believed on the basis of their training  
23 instruction that they are never to go solid, would it be pos-  
24 sible to create instructions which would distinguish for  
25 operators those circumstances where they might permissibly go

1 solid? And those circumstances where they should not go solid?

2 And to provide that to the operators in the form of instruction?

3 MR. WALTERS: Yes, I think that is true.

4 MR. ROCKWELL: To your knowledge, has that instruc-  
5 tion never been written or provided to operators?

6 MR. WALTERS: Not to my knowledge.

7 MR. ROCKWELL: Did you receive Mr. Dunn's memorandum  
8 on or about February 9th? Now, I refer you to Hearing Depo-  
9 sition, Exhibit 3.

10 MR. WALTERS: Excuse me?

11 MR. ROCKWELL: I am referring you to Hearing Deposi-  
12 tion, Exhibit 3. Did you receive that memorandum from Mr. Dunn  
13 on or about February 9th, 1978?

14 MR. WALTERS: I received a copy of the memo, yes.

15 MR. ROCKWELL: Okay. How did that come to your at-  
16 tention?

17 MR. WALTERS: Mr. Street brought the memo to my at-  
18 tention.

19 MR. ROCKWELL: Did you then bring it to the attention  
20 of your supervisor?

21 MR. WALTERS: At some period of time after that I  
22 am sure I did, but at what time I do not remember.

23 MR. ROCKWELL: That would be Mr. Hallman?

24 MR. WALTERS: That is correct.  
25

LA  
TMI  
7/18/79  
ape 10

1 MR. ROCKWELL: Who assumed, within your depart-  
2 ment or section, the responsibility for acting on and  
3 following up on Dunn's February 9th memorandum?

4 MR. WALTERS: I accepted the responsibility.

5 MR. ROCKWELL: Did you have a reaction to that  
6 memorandum once you had read it?

7 MR. WALTERS: Yes, essentially the same reaction  
8 that I had to the previous Kelly memo.

9 MR. ROCKWELL: In other words, your concerns  
10 about the prescription that was offered in the memorandum  
11 were the same?

12 MR. WALTERS: That is correct.

13 MR. ROCKWELL: Did you undertake to do anything  
14 about that concern at that point?

15 MR. WALTERS: Yes, sir, I assigned a Mr.  
16 Gossolo to go down and talk to Mr. Dunn and to see if  
17 we could address our concerns about the prescription that  
18 he had offered.

19 MR. ROCKWELL: To your knowledge, did Mr. Gossolo  
20 do that?

21 MR. WALTERS: Yes, sir.

22 MR. ROCKWELL: And what was the result of that?

23 MR. WALTERS: I think the outcome of the dis-  
24 cussion was Mr. Dunn's second memo.

25 MR. ROCKWELL: And that would be Hearing Exhibit

LA 2 1 No. 4. Do you have a copy of that before you?

2 MR. WALTERS: Yes, sir.

3 MR. ROCKWELL: And that was a result, as I  
4 understand it, then, of conversations which Mr. Gossolo  
5 had had, at your direction, with Mr. Dunn.

6 MR. WALTERS: That is correct.

7 MR. ROCKWELL: Did you receive a copy of the  
8 February 16th memorandum?

9 MR. WALTERS: Yes, at some point, I did.

10 MR. ROCKWELL: Okay, you are not listed on the  
11 distribution of that memorandum, are you?

12 MR. WALTERS: That is correct.

13 MR. ROCKWELL: How did you receive it? From  
14 whom?

15 MR. WALTERS: I don't believe I've been able  
16 to recall, but I assume it would have been Mr. Street  
17 again.

18 MR. ROCKWELL: When you received it, did you  
19 have a chance to review it?

20 MR. WALTERS: Yes, sir.

21 MR. ROCKWELL: What was your opinion of the  
22 revised prescription that that February 16th memorandum  
23 offered?

24 MR. WALTERS: My personal opinion was that it  
25 still did not address the overcooling transient, overcooling



LA 3 1 initiated transient that we'd been talking about all along,  
2 as well as other concerns, how I would pass this along  
3 to operators, how would they understand and be able to  
4 react to this prescription.

5 MR. ROCKWELL: What did you do about the concerns  
6 that you held at that point, after February 16th?

7 MR. WALTERS: As the best I remember, and again  
8 I talked to Mr. Gossolo in the last couple days, I  
9 think I testified that we talked to Mr. Dunn after that,  
10 or Mr. Gossolo did. His statement to me, that was  
11 incorrect, that he talked to Mr. Cartin of that Plant  
12 Integration maybe one time after that about the subject,  
13 about what could we do about it.

14 MR. ROCKWELL: Am I correct in understanding  
15 that in conversations that you've had since your deposition,  
16 you've determined that Mr. Dunn was not contacted after  
17 February 16th, but rather Mr. Cartin of Plant Integration  
18 was.

19 MR. WALTERS: That's true.

20 MR. ROCKWELL: Did you ever tell Mr. Dunn,  
21 following your receipt of his February 16th memorandum,  
22 that you still had reservations about the prescription  
23 offered in it?

24 MR. WALTERS: No, I never talked to Mr. Dunn.

25 MR. ROCKWELL: And you believe Mr. Gossolo had

LA 4 1 perhaps one contact with Mr. Cartin, from the time after  
2 February 16th?

3 MR. WALTERS: That is correct.

4 MR. ROCKWELL: Did there come a time when you  
5 were concerned about whether appropriate or timely action  
6 was being taken?

7 MR. WALTERS: Yes, sir, I did.

8 MR. ROCKWELL: Can you describe what steps you  
9 took at that point?

10 MR. WALTERS: I don't know exactly what time,  
11 but previous to August 3rd, I had a conversation, or  
12 a couple of conversations with my immediate supervisor,  
13 Mr. Hallman. I made the suggestion that maybe we should  
14 draft a memo to Plant Integration and see if we could  
15 elicit some response through that means.

16 MR. ROCKWELL: Was that memorandum drafted by you?

17 MR. WALTERS: Yes, sir, it was.

18 MR. ROCKWELL: And referring you to Hearing  
19 Exhibit No. 5, do you have that before you?

20 MR. WALTERS: Yes, I do.

21 MR. ROCKWELL: And that memorandum, to your  
22 knowledge then, was forwarded to Mr. Karrasch on August 3rd,  
23 1978. Is that correct?

24 MR. WALTERS: As far as I know, it was.

25 MR. ROCKWELL: And Mr. Karrasch would be manager

LA 5 1 of the Plant Integration Unit in the Design Section of the  
2 Engineering Department. Is that correct?

3 MR. WALTERS: That is true.

4 MR. ROCKWELL: And he also is Mr. Kelly's super-  
5 visor. Is that correct?

6 MR. WALTERS: Yes, sir.

7 MR. ROCKWELL: Were the concerns that are expressed  
8 in that memorandum about the prescription offered by  
9 Mr. Dunn the same concerns that you had held back in  
10 the fall of 1977 and in February of 1978?

11 MR. WALTERS: Yes, sir, they were.

12 MR. ROCKWELL: Did the memorandum to Mr. Karrasch  
13 get the issue resolved?

14 MR. WALTERS: No, sir.

15 MR. ROCKWELL: Could you tell us what happened?

16 MR. WALTERS: Well, to the best of my knowledge,  
17 peripherally -- I was on the peripheral only -- I questioned  
18 Mr. Hallman and Mr. Hallman questioned Mr. Karrasch a  
19 couple of times verbally about a response to the memo.  
20 And we, as far as I know, did not receive one.

21 MR. ROCKWELL: Mr. Walters, referring to your  
22 concerns about going solid, can you tell us what your view  
23 of that concern is, in contrast, or in comparison to the  
24 possibility of core uncovering?

25 MR. WALTERS: Okay, when I talk about the

LA 6 1 initiator of the overcooling transient and not in LOCA  
2 situations, my concern was that once we were into an over-  
3 cooling transient, if the HPI pumps were left on for some  
4 X minutes, that we would put enough water into the system  
5 to go up against the code relief valves and therefore  
6 create a LOCA, and not that -- We had no problem, or  
7 we're not concerned with his prescription on a LOCA  
8 initiated event.

9 MR. ROCKWELL: Would it be a fair summary of your  
10 views to say that once you're in a loss of coolant  
11 accident that your concern about going solid is no longer  
12 present and that going solid is possible; in that situation,  
13 in your view?

14 MR. WALTERS: That is true, mainly meaning in a  
15 LOCA situation in '77, when I wrote the memo, I was not  
16 aware that the two parameters, RC pressure and pressurizer  
17 level, would trend in opposite directions under a small  
18 LOCA. Therefore, my assumption in the memo, as written,  
19 I assumed that these would trend in the same direction.  
20 And, therefore, under a LOCA situation, you would not  
21 really have a solid system with a high indicated pressurizer  
22 loss.

23 MR. ROCKWELL: To your knowledge, Mr. Walters,  
24 was the material that was set forth in Dunn's February 16th  
25 memorandum ever conveyed to B and W's utility customers

LA 7

1 before March 28th, 1979?

2 MR. WALTERS: To the best of my knowledge, it  
3 wasn't.

4 MR. ROCKWELL: It was not?

5 MR. WALTERS: It was not.

6 MR. ROCKWELL: From the time you first received  
7 Kelly's memorandum in the fall of 1977, did you ever  
8 personally talk with Mr. Dunn or Mr. Kelly about the con-  
9 cerns raised in their respective memoranda?

10 MR. WALTERS: No, I'm sure I didn't talk to  
11 Mr. Dunn and I do not believe I talked to Mr. Kelly.

12 MR. ROCKWELL: Mr. Chairman, that's all I have.

13 CHAIRMAN KEMENY: Thank you, Mr. Rockwell.

14 May I just follow up one question asked of you  
15 by counsel. As I understand it, your concern was that  
16 while the Dunn recommendations might be appropriate for  
17 the LOCA caused accident, they would not be appropriate  
18 for overcooling transients.

19 MR. WALTERS: That's a fair statement.

20 CHAIRMAN KEMENY: What happens to the reactor  
21 coolant temperatures in an overcooling accident?

22 MR. WALTERS: They experience a severely downward  
23 trend.

24 CHAIRMAN KEMENY: Severe downtrend. Therefore  
25 would it be reasonable to assume that it would be more than

8 1 50 degrees below the saturation point?

2 MR. WALTERS: I think that's true.

3 CHAIRMAN KEMENY: Yes. I'm only trying to pinpoint  
4 the nature of your concern, because in the revised memorandum  
5 which occurred after talking to one of your colleagues,  
6 the second point, which is presumably the one that concerns  
7 you, speaks of keeping it down for X minutes, but allowing  
8 it to go off, taking off high pressure injection, once  
9 you're 50 degrees below the saturation temperature.

10 MR. WALTERS: Yes.

11 CHAIRMAN KEMENY: And presumably in this accident,  
12 it would have been all along 50 degrees below the satura-  
13 tion.

14 MR. WALTERS: Yes, sir, I think so.

15 CHAIRMAN KEMENY: So, therefore, your concern was  
16 that under these circumstances, keeping it on for X, even  
17 if that were a small number of minutes, would be the  
18 inappropriate thing.

19 MR. WALTERS: Yes.

20 CHAIRMAN KEMENY: Could I ask you, then, is there  
21 some fairly clear way that an operator could determine  
22 early whether the accident was caused by a LOCA or not?

23 MR. WALTERS: I do not believe he can within a  
24 few minutes, let's say less than five minutes. I believe  
25 in the area of ten, twenty minutes, he can.

LA 9

1 CHAIRMAN KEMENY: Yes, but does that not create  
2 a dilemma, then, for the operator, that if you have a  
3 procedure where if it's caused by a LOCA, you should keep  
4 on the high pressure injection system for no less than a  
5 certain number of minutes, but if it isn't, he shouldn't,  
6 and it takes him longer than that to determine what caused  
7 the accident?

8 MR. WALTERS: Yes, sir, I agree. In fact, one  
9 part of my whole concern was how do I convey these  
10 prescriptions to the operator so that he will have a  
11 simple understanding of it.

12 CHAIRMAN KEMENY: Yes, I suspected that that was  
13 the case. I wanted to bring that out, as a matter of  
14 fact. Thank you.

15 Other commissioners? Commissioner Haggerty?

16 COMMISSIONER HAGGERTY: Mr. Walters, you keep  
17 relating your knowledge in the fall of 1977 to the pressure  
18 and level trending in the same direction. But the facts  
19 are that Kelly's memo of November 1st says the operator  
20 stopped HPI when pressurizer level began to recover without  
21 regard to primary pressure. So he was clearly raising the  
22 question of a difference in direction. The Dunn memo of  
23 February 9th does the same thing. So clearly, from both  
24 the design standpoint and the ECCS analysis standpoint,  
25 they were saying that you could have a circumstance, a



LA 10 1 clear statement of two phases existent, that the pressure  
2 and the temperature would not trend in the same direction.

3 MR. WALTERS: That was my first knowledge of that,  
4 yes, when these memo came to my attention.

5 COMMISSIONER HAGGERTY: Well, but your memo was  
6 written after the November 1st memo.

7 MR. WALTERS: Right. What I'm getting at is  
8 that I was not addressing my solution, or my concerns  
9 to the very first initial, say, five minutes, I think, in  
10 that area, of the TECO transient, where indeed, yes, they  
11 did trend in opposite directions. My concern was about  
12 20 minutes later, the operator found the stuck open relief  
13 valve, things appeared to begin then to get normal. The  
14 pressurizer level and pressure then again starting,  
15 recovered and trended in the same direction. And if we  
16 had left the HPI pumps on for a period of 20, 30, whatever  
17 minutes, we would then have gone up against the code  
18 relief valve, but not the initial action.

19 COMMISSIONER HAGGERTY: I understand that. It  
20 seems to me that you're raising questions that relate to  
21 difficulty of communicating this to operators, and the  
22 proper issue was how you resolve those difficulties, not  
23 really to avoid the issue. And I can understand the  
24 difficulty of conveying it to operators, with the indicators  
25 present and all the rest of that. But then that only made

LA 11 1 that issue more serious. If the problem of having two-  
2 phased condition was present, and hence terminating HPI  
3 was exactly wrong, then the issue was how do you convey that  
4 properly to operators, not avoiding it or postponing it  
5 because it's difficult to convey it. Is that not true?

6 MR. WALTERS: Yes, sir, I think that's true.

7 CHAIRMAN KEMENY: Commissioner Lewis.

8 COMMISSIONER LEWIS: Mr. Walters, isn't it true  
9 that one of the selling points for B and W is the avail-  
10 ability. It seems one of the pluses for your nuclear  
11 power facility is that it's more available than many of  
12 the other plants.

13 MR. WALTERS: I'm not personally aware of that,  
14 but it certainly would be, if that's the facts.

15 COMMISSIONER LEWIS: In other words, it would be  
16 to the advantage of a customer to have availability.

17 MR. WALTERS: Yes, ma'am, to all our concerns  
18 when it comes to electric power bills.

19 COMMISSIONER LEWIS: Okay. And, therefore, you're  
20 saying that generally speaking the operators are trained  
21 to lean in the direction of wanting to keep the facility  
22 available.

23 MR. WALTERS: Yes, I think they're always trained  
24 to try to minimize damage to the plant.

25 COMMISSIONER LEWIS: Okay. And in order to do that,

LA 12 1 they would try to avoid going solid.

2 MR. WALTERS: In most cases, true.

3 COMMISSIONER LEWIS: Given that mind set, isn't  
4 it possible that faced with the kind of transient that  
5 occurred at Davis-Besse and later at TMI two, the  
6 operators then would not even consider, until almost too  
7 late, the possibility of going solid?

8 MR. WALTERS: My personal opinion is, and what  
9 I know is that that's not true. They're taught not to rely  
10 on one single indication. They're taught to seek a third  
11 opinion, a qualifying piece of instrumentation, and not  
12 to rely on the one single, in this case, pressurizer  
13 level. So, no, I do not think that's the case.

14 COMMISSIONER LEWIS: Thank you.

15 CHAIRMAN KEMENY: Dr. Marks.

16 COMMISSIONER MARKS: I'd like to explore with you  
17 the follow-up on the August 3, 1978 memo, which apparently  
18 you drafted for Mr. Hallman to go to Mr. Karrasch.

19 MR. WALTERS: That's correct.

20 COMMISSIONER MARKS: Now, we've received testimony  
21 today which suggests that this was an important issue.  
22 Can you tell me why you didn't feel more urgency in getting  
23 a response to this? You didn't ever get a response to  
24 this memorandum, you said.

25 MR. WALTERS: That's true.

LA 13 1

COMMISSIONER MARKS: Well, don't you feel you had a responsibility to get a response to something that is potentially as important as this, for someone who is in charge of operating reactors?

MR. WALTERS: Well, that's a very difficult question to answer. I can only answer, that is true, but in the mainstream of business, day after day, some things, I reckon you have to say slip through the crack.

COMMISSIONER MARKS: Slip through the crack. How often do things slip through the crack, of this importance, do you think?

MR. WALTERS: Well, let's hope they're very seldom. I can't responsibly answer that question. Hopefully this is the only time, maybe, it's ever happened. It's only been highlighted since TMI two.

Bowers Reporting Company

1 CHAIRMAN KEMENY: Mr. McPherson

2 MR. MC PHERSON: These questions may not be properly  
3 addressed to you, but maybe you can help with their answers.  
4 The pilot operated relief valve that stuck open was purchased  
5 by B and W to its specifications from Dresser Industries. Is  
6 that correct?

7 MR. WALTERS: To my own knowledge, that is true.  
8 But I do not have that --

9 MR. MC PHERSON: You do not have first hand knowledge.  
10 There was testimony earlier today that there may  
11 have been as many as 20 incidents in which the pilot operated  
12 relief valve had stuck open, which is one event that places  
13 on the operator this terrific decision as to whether to know  
14 that by one means or another and to know what to do with the  
15 high pressure injection system that could have that effect.

16 First of all, do you know -- you are in charge of  
17 the Operating Reactors Division here. Does that problem, that  
18 frequency of malfunction come before you? Had you been aware  
19 that that valve was sticking open on occasion?

20 MR. WALTERS: I was aware that there had been maybe  
21 two or three transients on which the valve had stuck open,  
22 but nothing greater than that. I do not know where the number  
23 20 came from. The number 20 that was testified to this morning.

24 MR. MC PHERSON: Do you know how that valve works?  
25 Is it controlled from the control room?

DO2

1 MR. WALTERS: Very superficially, yes. I am not  
2 familiar with intimate details on it.

3 MR. MC PHERSON: Do you know whether the supplier of  
4 the valve was contacted to be talked to about the frequency  
5 of the malfunction of the valve.

6 MR. WALTERS: No, I have no knowledge of that.

7 MR. MC PHERSON: There was, I believe, evidence at  
8 an earlier hearing or perhaps it was in the Commission's trip  
9 to Three Mile Island that the control room operator had in  
10 effect set the signal to that valve to close, but because of  
11 the construction of the valve, the only signal that came back  
12 to him was that the signal had been sent. In other words, it  
13 did not come back to him that it had been reseated.

14 MR. WALTERS: Yes, I think that is a fair statement.

15 MR. MC PHERSON: That is kind of like one hand clap-  
16 ping in the old Chinese story. Was this a matter of any con-  
17 cern to your division that the control room operator could not  
18 be sure when he hit that button or lever that he was effectuat-  
19 ing what he was intending to do.

20 MR. WALTERS: I can't address that for the company.  
21 I think that there would be other situations that the operator  
22 would know the valve was not closed and regardless of whether  
23 the valve closed or not, there is a block valve there that he  
24 could have closed and have blocked it off at any rate.

25 MR. MC PHERSON: But he would really only use the

1 block valve if he knew that the other valve was open, wouldn't  
2 he?

3 MR. WALTERS: That is probably correct.

4 MR. MC PHERSON: If he had set a signal to close the  
5 other valve, but didn't know whether that signal had been  
6 effective or not in doing that, then he wouldn't know whether  
7 to close the block valve.

8 MR. WALTERS: In a short period of time, I believe  
9 that is true, but I don't believe that in a period of hours  
10 that that is correct.

11 MR. MC PHERSON: You think that that should have  
12 been identified earlier by the operator from the variety of  
13 evidence that was available to them.

14 MR. WALTERS: That is correct.

15 MR. MC PHERSON: Would it be your division's respon-  
16 sibility if it were learned that either the valve was contin-  
17 ually malfunctioning or that the signal was insufficient to  
18 properly advise the control room operator? Would it have  
19 been your division's responsibility or somebody else's respon-  
20 sibility in the Nuclear Service Department to have gone to the  
21 designers or to the suppliers and give us the better product.

22 MR. WALTERS: No. Not the responsibility of Nuclear  
23 Service. We would probably have or did highlight the situa-  
24 tion within the company, but there would be a mechanical  
25 equipment section of engineering that would take on the

Bowers Exporting Company



1 responsibility of going to the actual vendor and addressing  
2 that.

3 MR. MC PHERSON: Would the notice of those malfunc-  
4 tions come to you ordinarily in your operating reactor?

5 MR. WALTERS: Not ordinarily. Only on a peripheral --

6 MR. MC PHERSON: To whom would they go?

7 When something goes wrong in a plant, when a piece  
8 of vital equipment such as this malfunctions periodically, who  
9 learns about it in the plant?

10 MR. WALTERS: Within B and W?

11 MR. MC PHERSON: Yes.

12 MR. WALTERS: I reckon -- well, it is hard to  
13 answer because mainly a lot of people would know about it  
14 eventually. The first person that would probably be aware of  
15 it is the Manager of Operating Plant Services, which is in the  
16 Nuclear Service.

17 MR. MC PHERSON: Is that in the engineering?

18 MR. WALTERS: No. That is the Nuclear Service.

19 MR. MC PHERSON: Nuclear Services. Operating Plant  
20 Services, that is Mr. Phinny.

21 MR. WALTERS: That is correct.

22 MR. MC PHERSON: So, he would get these complaints?

23 MR. WALTERS: Yes.

24 CHAIRMAN KEMENY: Commissioner Marrett.

25 COMMISSIONER MARRETT: To return to your memo of

05 1 11, 1977, the second paragraph, my assumption and the training  
 2 assumes that the pressure and pressurizer will trend in the  
 3 same direction, I believe in the deposition taken most recently,  
 4 you indicate that that should not be "the training", but your  
 5 own training, is that correct?

6 MR. WALTERS: Yes, ma'am. I was trying to make a  
 7 clarification there that in this memo was my own opinion and  
 8 not the opinion of B and W's training department.

9 COMMISSIONER MARRETT: Are you suggesting by making  
 10 that revision that you did not want to comment on the kind of  
 11 training that is given in B and W, that you were not knowledge-  
 12 able enough about that training? I would like to understand  
 13 the difference between having stated "the training", which  
 14 was interpreted as B and W training and your revision which  
 15 now says you are only talking about your own training.

16 MR. WALTERS: Right. I did not want to mislead that  
 17 -- I was never trained by the B and W training center to be an  
 18 operator. My training is peripheral training in talking to  
 19 quite a few people, not necessarily what B and W training  
 20 department trains the utility operators.

21 COMMISSIONER MARRETT: So, are you suggesting that  
 22 you would not want to express -- or be able to describe B and  
 23 W training? Is that what you are saying by making that revision?

24 MR. WALTERS: Yes.

25 COMMISSIONER MARRETT: Then I suppose I have some

Bowers Reporting Company

D06

1 problems because in continuing on that deposition, you were  
2 asked were the operators taught to hydro the RCS at any time  
3 and your comment, no, the operators are not taught to hydro  
4 the RCS at any time. Would it be fair to say they are never  
5 taught to hydro the RCS; your answer, I think that is a fair  
6 statement. I am wondering how you could give a very positive  
7 indication here about what the operators are trained to here  
8 and give the hesitation that I now hear about knowledge on  
9 training. Is that a discrepancy?

10 MR. WALTERS: In the scenario of taking a plant  
11 solid, as I testified also, there is no reason during normal  
12 operation of a plant to allow a plant to go solid. Indeed,  
13 you do not want to do that. That is like a first law and not  
14 something that I question or not what the B and W training  
15 center says. I am pretty sure that that has been the case.  
16 You lose pressure control as well as maybe ensuing problems.  
17 I think maybe me and the training center would agree on that  
18 subject. I am just trying not to speak for them, the training  
19 department.

20 COMMISSIONER MARRETT: When did you discover having  
21 made that slight error in the statement itself, the inclusion  
22 of the "the" before the training? Was that in reviewing the  
23 memo quite recently or subsequent?

24 MR. WALTERS: Well, I think I saw that a week ago or  
25 something and last Friday in the deposition, when I had the

1 chance, I made that statement.

2 COMMISSIONER MARRETT: Did that come about after a  
3 discussion with anyone? To be perfectly candid, someone might  
4 get the impression that this was after a great deal of discus-  
5 sion, saying what are the implications of indicating "the"  
6 training, as opposed to taking on the responsibility of saying  
7 simply this is myself who is giving the statement. I guess  
8 I would just like to get some clarification. Was this your  
9 looking back over and saying, I shouldn't have used that word.  
10 That is not what I meant. Or was it, what interpretation might  
11 be given if I talk about B and W training in general.

12 MR. WALTERS: Well, what prompted it was, indeed,  
13 was the first scenario and questions from counsel, the first  
14 deposition. We seemed to be going around in circles on this  
15 and I decided I had better make it more clear as soon as I got  
16 the chance of what I was really talking about regardless of  
17 what the English sounded like.

18 CHAIRMAN KEMENY: Let's see, Mr. Walters, I would  
19 like to try to pull together certain threads.

20 Suppose, just for a moment, you had had no concern  
21 about Mr. Dunn's memorandum. What would have been the sequence  
22 of events to get the information out to customers? I know  
23 you have concerns. I am stipulating that. But suppose you  
24 wouldn't have had concerns, what would have happened to Mr.  
25 Dunn's concerns?

Bowers Reporting Company

1 MR. WALTERS: We would have, within the service or-  
2 ganization, I would have assigned it to one of my engineers  
3 and we would have come up with some formulation that we send  
4 out by a process known as site instruction to the individual  
5 customers.

6 CHAIRMAN KEMENY: And that would have been sent out  
7 to all your customers or all of your relevant customers?

8 MR. WALTERS: That is true.

9 CHAIRMAN KEMENY: On what kind of timetable. What  
10 is a typical time period after you have made such a decision?

11 MR. WALTERS: Probably less than a month.

12 CHAIRMAN KEMENY: Less than a month.

13 MR. WALTERS: It varies. Some go out. If there is  
14 an urgent problem and we are aware of all of it, it goes out  
15 probably in 24 hours. Some may take a few weeks. It depends  
16 on how much discussion between engineering and us to formulate  
17 the final answers.

18 CHAIRMAN KEMENY: Yes. However, you did have some  
19 serious concerns and, therefore, you persuaded your supervisor,  
20 Mr. Hallman, as I understand, to raise the issue with Plant  
21 Integration and you weren't getting answers and in August of  
22 last year, you were still pushing -- if I may use that word --  
23 to get this resolved.

24 MR. WALTERS: That is true.

25 CHAIRMAN KEMENY: And was it at any time prior to

1 March of this year resolved to your satisfaction?

2 MR. WALTERS: Prior to March of this year?

3 CHAIRMAN KEMENY: Yes.

4 MR. WALTERS: No, it was not resolved to my satis-  
5 faction.

6 CHAIRMAN KEMENY: Not r solved. Therefore, from  
7 this testimony, if your concerns had not existed Mr. Dunn's  
8 February memorandum might have been out to the customers say  
9 in March or April of last year or if the August memorandum  
10 had been responded fairly promptly, the information might  
11 have been out to the customers before the end of calendar '78.

12 MR. WALTERS: I think that is a fair assumption.

13 CHAIRMAN KEMENY: But these events did not happen  
14 and therefore Three Mile Island 2 did not have these instructions  
15 or instructions like these available prior to the accident.

16 MR. WALTERS: They did not have information from  
17 this particular memo I sent to them.

18 Thank you. You are excused, subject to recall and  
19 given the lateness of the hour, the Commission will recess  
20 until 10:00 A. M. tomorrow morning.

21 (Thereupon, the Commission was recess until 10:00  
22 A. M. on July 19, 1979.)  
23  
24  
25



THE BABCOCK & WILCOX COMPANY  
POWER GENERATION GROUP

EXHIBIT 1  
Page 1 of 1

To	Distribution	DATE	July 18-20, 1979
From	J. J. Kelly, Plant Integration	FILE NO. OR REF.	VIII 3
Cust.	Generic	DATE	November 1, 1977
Subj.	Customer Guidance On High Pressure Injection Operation		

This letter is cover and customer and not subject only.

DISTRIBUTION

B. A. Karrasch  
E. W. Swanson  
R. J. Finnia  
B. M. Dunn  
D. W. LaBelle  
N. S. Elliott  
D. F. Hallman

Two recent events at the Toledo site have pointed out that perhaps we are not giving our customers enough guidance on the operation of the high pressure injection system. On September 24, 1977, after depressurizing due to a stuck open electromagnetic relief valve, high pressure injection was automatically initiated. The operator stopped HPI when pressurizer level began to recover, without regard to primary pressure. As a result, the transient continued on with boiling in the RCS, etc. In a similar occurrence on October 23, 1977, the operator bypassed high pressure injection to prevent initiation, even though reactor coolant system pressure went below the actuation point.

Since there are accidents which require the continuous operation of the high pressure injection system, I wonder what guidance, if any, we should be giving to our customers on when they can safely shut the system down following an accident? I recommend the following guidelines be sent:

- a) Do not bypass or otherwise prevent the actuation of high/low pressure injection under any conditions except a normal, controlled plant shutdown.
- b) Once high/low pressure injection is initiated, do not stop it unless: Tave is stable or decreasing and pressurizer level is increasing and primary pressure is at least 1600 PSIG and increasing.

I would appreciate your thoughts on this subject.

**POOR ORIGINAL**

JJK:jl

486.. 227



J. J. Kelly Plant Integration

F. Walters Nuclear Service

THREE MILE ISLAND COMMISSION

EXHIBIT 2  
July 19-20, 1979

FILE NO. OR REF.

TOLEDO

DATE

High Pressure Injection during transient

11/18/77

Re. Your letter to DISTRIBUTION; Same Subject  
Dated NOV 2, 1977.

In talking with the training personnel and  
in the opinion of this writer the operators at Toledo  
operated in the correct manner considering how they  
were trained and the reasons behind this training.

My assumption and the training assumes first that  
RCS pressure and pressure level will tend in the  
same direction under a LOCA. For a small leak  
they keep the H-P system on up to a certain flow to  
maintain pressure level.

In the particular case at Toledo, there was no  
LOCA of any intake and with the small leak the inventory  
in the system came back as expected but due to the  
design of the RCS the RCS pressure cannot respond  
quickly when the pressure starts to rise.

**POOR ORIGINAL**

old water now pushed back into the pressure  
casing the H.P. I system, or after pressure level indicates  
is latched high, will result in the RCS pressure  
receding and essentially hydrating the RCS when  
it becomes solid. If this is the intent of your letter  
the thoughts behind it, then the operators are not  
expected to hydrate the RCS everytime the H.P. I pumps  
are initiated.

If you intend to go solid what about problems with  
valve mechanics. Also will the Code and electromagnetic  
valves solid water (via steam) at significant flow rates  
to keep the RCS from being hydrated.

P.C. R. J. FINNIN

POOR ORIGINAL

THE BASCOCK & WILCOX COMPANY  
POWER GENERATION GROUP

EXHIBIT 3

Page 1 of 2

THREE MILE ISLAND COMMISSION

EXHIBIT 3

July 18-20, 1979

Jim Taylor, Manager, Licensing

From

Bert M. Dunn, Manager, ECCS Analysis (2113)

Cust.

*Bert M. Dunn*

105 443-3

File No.  
or Ref.

Subj.

Date

Operator Interruption of High Pressure Injection

February 9, 1978

This letter is for the customer and the recipient only.

This memo addresses a serious concern within ECCS Analysis about the potential for operator action to terminate high pressure injection following the initial stage of a LOCA. Successful ECCS operation during small breaks depends on the accumulated reactor coolant system inventory as well as the ECCS injection rate. As such, it is mandatory that full injection flow be maintained from the point of emergency safety features actuation system (ESFAS) actuation until the high pressure injection rate can fully compensate for the reactor heat load. As the injection rate depends on the reactor coolant system pressure, the time at which a compensating match-up occurs is variable and cannot be specified as a fixed number. It is quite possible, for example, that the high pressure injection may successfully match up with all heat sources at time  $t_1$  and that due to system depressurization be inadequate at some later time  $t_2$ .

The direct concern here arose out of the recent incident at Toledo. During the accident the operator terminated high pressure injection due to an apparent system recovery indicated by high level within the pressurizer. This action would have been acceptable only after the primary system had been in a subcooled state. Analysis of the data from the transient currently indicates that the system was in a two-phase state and as such did not contain sufficient capacity to allow high pressure injection continuation. This became evident at some 20 to 30 minutes following termination of injection when the pressurizer level again collapsed and injection had to be reinitiated. During the 20 to 30 minutes of noninjection flow they were continuously losing important fluid inventory even though the pressurizer indicated high level. I believe it fortunate that Toledo was at an extremely low power and extremely low burnup. Had this event occurred in a reactor at full power with other than insignificant burnup it is quite possible, perhaps probable, that core uncover and possible fuel damage would have resulted.

The incident points out that we have not supplied sufficient information to reactor operators in the area of recovery from LOCA. The following rule is based on an attempt to allow termination of high pressure injection only at a time when the reactor coolant system is in a subcooled state and the pressurizer is indicating at least a normal level for small breaks. Such conditions guarantee full system capacity and thus assure that during any follow on transient would be no worse than the initial accident. I, therefore, recommend that operating procedures be written to allow for termination of high pressure injection under the following two conditions only:

**POOR ORIGINAL**

1. Low pressure injection has been actuated and is flowing at a rate in excess of the high pressure injection capability and that situation has been stable for a period of time (10 minutes).
2. System pressure has recovered to normal operating pressure (2200 or 2250 psig) and system temperature within the hot leg is less than or equal to the normal operating condition (605°F or 620°F).

I believe this is a very serious matter and deserves our prompt attention and correction.

BMD/lc

cc: E.W. Swanson  
D.E. Roy  
B.A. Karrasch  
E.A. Bailey  
J. Kelly  
Z.R. Kane  
J.D. Agar  
R.L. Pittman  
J.D. Phinny  
T. Scott

POOR ORIGINAL

THE BABCOCK & WILCOX COMPANY  
NUCLEAR GENERATION GROUP

EXHIBIT 4  
Page 1 of 1

NEW ZEALAND COMMISSION

4

July 18-20, 1979

Jim Taylor, Manager, Licensing

from

Bert H. Dunn, Manager, ECCS Analysis (2133)

303 443.5

subject

File No.  
or Ref.

subject

Date

Operator Interruption of High Pressure Injection

February 16, 1978

This letter is cover and contains and one subject only.

In review of my earlier memo on this subject, dated February 9, 1978, Field Service has recommended the following procedure for terminating high pressure injection following a LOCA.

1. Low pressure injection has been actuated and is flowing at a rate in excess of the high pressure injection capability and that situation has been stable for a period of time (10 minutes). Same as previously stated.
2. At X minutes following the initiation of high pressure injection, termination is allowed provided the hot leg temperature indication plus appropriate instrument error is more than 50°F below the saturation temperature corresponding to the reactor coolant system pressure less instrument error. X is a time lag to prevent the termination of the high pressure injection immediately following its initiation. It requires further work to define its specific value, but it is probable that 10 minutes will be adequate. The need for the delay is that normal operating conditions are within the above criteria and thus it is conceivable that the high pressure injection would be terminated during the initial phase of a small LOCA.

I find that this scheme is acceptable from the standpoint of preventing adverse long range problems and is easier to implement. Therefore, I wish to modify the procedure requested in my first memo to the one identified here.

cc: E.W. Swanson  
D.H. Roy  
B.A. Karrassch  
E.A. Bailey  
J. Kelly  
E.R. Kane  
J.D. Agar  
E.L. Piatman  
J.D. Phinny  
E. Scott

*R. Dunn*

POOR ORIGINAL

486 232



BABCOCK & WILCOX COMPANY  
RE GENERATION GROUP

NUCLEAR REGULATORY COMMISSION  
5

cc: E. H. Kane  
J. D. Phinney  
B. W. Street  
B. M. Dunn  
J. F. Walters

E. A. Karsausch, Manager, Plant Integration

D. F. Hallinan, Manager, Plant Performance Services Section (1149)

BD5 463.5

File No.  
or Ref.

Date.

Operator Interruption of High Pressure Injection (HPI)

August 3, 1978

(This letter is cover and contains no subject only.)

- References: (1) B. M. Dunn to J. Taylor, same subject, February 9, 1978.  
 (2) B. M. Dunn to J. Taylor, same subject, February 16, 1978.

References 1 and 2 (attached) recommend a change in BW's philosophy for HPI system use during low-pressure transients. Basically, they recommend leaving the HPI pumps on, once HPI has been initiated, until it can be determined that the hot leg temperature is more than 50°F below Tsat for the RCS pressure.

Nuclear Service believes this mode can cause the RCS (including the pressurizer) to go solid. The pressurizer reliefs will lift, with a water surge through the discharge piping into the quench tank.

We believe the following incidents should be evaluated:

1. If the pressurizer goes solid with one or more HPI pumps continuing to operate, would there be a pressure spike before the reliefs open which could cause damage to the RCS?
2. What damage would the water surge through the relief valve discharge piping and quench tank cause?

To date, Nuclear Service has not notified our operating plants to change HPI policy consistent with References 1 and 2 because of our above-stated questions. Yet, the references suggest the possibility of uncovering the core if present HPI policy is continued.

We request that Integration resolve the issue of how the HPI system should be used. We are available to help as needed.

*D. F. Hallinan*

D. F. Hallinan

DFH/feh  
Attachments

POOR ORIGINAL

THE BABCOCK & WILCOX COMPANY  
POWER GENERATION GROUP

NOTE INSTRUCTION NO. 3.35 Page 1 of 2  
7/301 8/11/5  
DISTRIBUTION 3, 4, 5, 7, 8, 9, 11  
RESPONSE REQ'D FROM All  
APPROVED *[Signature]* 5011

To DISTRIBUTION  
From G.T. FAIRBURN, SERVICE MANAGER *[Signature]*

805 663.5

Cust. DPC, MET ED, FPC, AP&L, SMUD, & TECO

File No. T 3.35  
or Ref.

Subj. SUPPLEMENTARY OPERATING INSTRUCTIONS FOR HPI SYSTEM

Date APRIL 4, 1979

This letter is cover one customer and one subject only.

DISTRIBUTION

CD RUSSELL  
RC LUKEN  
JI JANIS  
GT FAIRBURN

THREE ISLAND COMMISSION  
READING EXHIBIT 4  
DATE July 18-20, 1979  
WITNESS

The following information has been reviewed and approved for transmittal to your customer. Please advise your customer by telecon that this is being forwarded and then telecopy information.

"Although details of the causes and course of events of the incident at Metropolitan Edison's TMI-2 plant on March 28, 1979 are still being developed, it appears that the incident was initiated by a loss-of-main feedwater flow (LOFW) and that a distinguishing characteristic of this transient compared to other previous LOFW transients was the securing of the High Pressure Injection (HPI) system. Consequently, all operating plants are advised to implement the following immediately:

If the HPI system has actuated because of low pressure condition, it must remain in operation until either:

1. Both LPI pumps are in operation and flowing at a rate in excess of 1000 gpm each and the situation has been stable for 20 minutes.

OR

2. The HPI system has been in operation for 20 minutes and all hot and cold leg temperatures are at least 50° below the saturation temperature for the existing RCS pressure. If 50° subcooling cannot be maintained, the HPI shall be reactivated.

" If the HPI system has been activated and if RC pumps are in operation, at least one RCP pump per loop should be maintained."

GTF/hh

- cc: GJ Brazill      WS Delicate  
 JH Taylor        KR Ellison  
 CE Mahaney      JR Bonart  
 EJ Domaleski    JA Lind  
 CC Winterich    RL Pittman  
 RL Boyer         Central Files -

REVIEWED FOR ACCURACY	
ENGINEERING: <i>[Signature]</i>	DATE: 4/4/79
NUCLEAR SERVICE: <i>[Signature]</i>	DATE: 4/12/79

**POOR ORIGINAL**



Babcock & Wilcox

Power Generation Group

P.O. Box 1260, Lynchburg, Va. 24505  
Telephone: (804) 384-5111

April 4, 1979  
TMI-79-47

Mr. G. P. Miller  
Station Superintendent  
Metropolitan Edison Company  
P.O. Box 480  
Middletown, PA 17057

Subject: Three Mile Island Nuclear Generating Station - Unit 1  
TMI-2 Loss of Feedwater Transient

Dear Mr. Miller:

Although details of the causes and course of events of the incident at Metropolitan Edison's TMI-2 plant on March 28, 1979 are still being developed, it appears that the incident was initiated by a loss-of-main feedwater flow (LOFW) and that a distinguishing characteristic of this transient compared to other previous LOFW transients was the securing of the High Pressure Injection (HPI) system. Consequently, all operating plants are advised to implement the following immediately:

If the HPI system has actuated because of low pressure condition, it must remain in operation until either:

1. Both LPI pumps are in operation and flowing at a rate in excess of 1000 GPM each and the situation has been stable for 20 minutes.

OR

2. The HPI system has been in operation for 20 minutes and all hot and cold leg temperatures are at least 50° below the saturation temperature for the existing RCS pressure. If 50° subcooling cannot be maintained, the HPI shall be reactivated.

If the HPI system has been activated and if RC pumps are in operation, at least one RCP pump per loop should be maintained.

This information supplements that previously transmitted. If you have any questions regarding this advisory, please advise.

Very truly yours,

G. I. Fairburn  
Service Manager

- GTF/hh
- cc: RM Klingaman
  - JF Hilbish
  - LL Lawyer
  - JL Seelinger
  - CR Montgomery
  - LC Rogers
  - SL Smith

- cc: JD Phinney
- RL Pittman
- TM Dixens
- GM Olds
- HA Bailey

Record Ctr. NSS-5 TT.2

486 235

The Babcock & Wilcox Company / Es

POOR ORIGINAL

THE BABCOCK & WILCOX COMPANY  
POWER GENERATION GROUP

EXHIBIT 7  
SITE INSTRUCTION NO. 11/113 page 1 of 4

To	DISTRIBUTION 115779114
From	R. E. HAM/G. T. FAIRBURN, NUCLEAR SERVICE RESPONSE REQ'D FROM 115779114
	G. J. BRAZILL, PLANT INTEGRATION <i>H. Brazill 4/16/79</i> APPROVED <i>[Signature]</i> 105 442.1
Cust.	DPC, MET ED, FPC, AP&L, SMUD, TECO
	File No. or Ref. T3.35
Subj.	SUPPLEMENTARY OPERATING INSTRUCTIONS FOR HPI
	Date APRIL 17, 1979

This letter is copy for customer and see subject only.

RE: G. T. FAIRBURN TO DISTRIBUTION, SAME SUBJECT, T3.35,  
APRIL 4, 1979.

THE OPERATING INSTRUCTIONS, GIVEN IN THE ABOVE REFERENCE, FOR OPERATOR ACTION TO OVERRIDE THE ENGINEERING SAFETY FEATURES ACTUATION SYSTEM AND TERMINATE HPI HAVE BEEN REVISED.

THIS REVISION (ATTACHED) ALLOWS THE OPERATOR AN ALTERNATIVE TO THE 20 MINUTE OPERABILITY PERIOD, UNDER CERTAIN CONDITIONS, TO PRECLUDE THE PRESSURIZER FROM GOING SOLID. PLEASE REVIEW AND TRANSMIT THESE REVISED INSTRUCTIONS TO ALL AFFECTED B&W CUSTOMERS.

THREE MILE ISLAND COMMISSION  
EXHIBIT 7  
DATE July 18-20, 1979  
WITNESS

ENGINEERING DEPARTMENT REVIEW & APPROVAL

*[Signature]* FOR B.M. DUNN DATE 4/17/79  
B.M. DUNN, UNIT MANAGER, ECCS

*[Signature]* DATE 4/17/79  
E. A. WOLACK, MANAGER, PLANT DESIGN

*[Signature]* DATE 4/17/79  
REVIEWED FOR ACCURACY - D. H. ROY, MANAGER, ENGINEERING DEPT.

ENGINEERING: *[Signature]* DATE: 4/17/79  
PLANT SERVICE: *[Signature]* DATE: 4/17/79  
J. FINNIN, LICENSING DATE 4/17/79

LRG:fh  
Attach 2

- cc: L. R. Curtin *[Signature]*
- B. M. Dunn
- N. S. Elliott
- R. J. Finnin
- D. F. Hallman
- R. E. Kosiba
- D. W. Labelle
- D. H. Roy
- E. W. Swanson
- J. H. Taylor
- R. W. Winks
- E. A. Wolack

POOR ORIGINAL

SUPPLEMENTAL OPERATING INSTRUCTIONS  
FOR HPI SYSTEM OPERATION

ALTHOUGH DETAILS OF THE CAUSES AND COURSE OF EVENTS OF THE INCIDENT AT METROPOLITAN EDISON'S TMI-2 PLANT ON MARCH 28, 1979 ARE STILL BEING DEVELOPED, IT APPEARS THAT THE INCIDENT WAS INITIATED BY A LOSS-OF-MAIN FEEDWATER FLOW (LOFW) AND THAT A DISTINGUISHING CHARACTERISTIC OF THIS TRANSIENT COMPARED TO OTHER PREVIOUS LOFW TRANSIENTS WAS THE SECURING OF THE HIGH PRESSURE INJECTION (HPI) SYSTEM. CONSEQUENTLY, ALL OPERATING PLANTS ARE ADVISED TO IMPLEMENT THE FOLLOWING IMMEDIATELY:

IF THE HPI SYSTEM HAS ACTUATED BECAUSE OF LOW PRESSURE CONDITION, IT MUST REMAIN IN OPERATION UNTIL ONE OF THE FOLLOWING CRITERIA IS SATISFIED:

1. BOTH LPI PUMPS ARE IN OPERATION AND FLOWING AT A RATE IN EXCESS OF 1000 GPM EACH AND THE SITUATION HAS BEEN STABLE FOR 20 MINUTES.

OR

2. THE HPI SYSTEM HAS BEEN IN OPERATION FOR 20 MINUTES AND ALL HOT AND COLD LEG TEMPERATURES ARE AT LEAST 50° BELOW THE SATURATION TEMPERATURE FOR THE EXISTING RCS PRESSURE. IF 50° SUBCOOLING CANNOT BE MAINTAINED, THE HPI SHALL BE REACTIVATED.

OR

3. ALL HOT AND COLD LEG TEMPERATURES ARE AT LEAST 50° BELOW THE SATURATION TEMPERATURE FOR THE EXISTING RCS PRESSURE, AT LEAST ONE RC PUMP IN EACH LOOP IS RUNNING, AND THE ACTION IS NECESSARY TO PREVENT THE INDICATED PRESSURIZER LEVEL FROM GOING OFF-SCALE HIGH. IF 50° SUBCOOLING CANNOT BE MAINTAINED, THE HPI SHALL BE REACTIVATED.

IF THE HPI SYSTEM HAS BEEN ACTIVATED AND IF RC PUMPS ARE IN OPERATION, AT LEAST ONE RCP PUMP PER LOOP SHOULD BE MAINTAINED.

POOR ORIGINAL

Babcock & Wilcox

Power Generation Group

P.O. Box 1250, Lynchburg, Va. 24505

Telephone: (804) 384-5111

April 18, 1979  
TMI-79-56

Mr. G. P. Miller  
Station Superintendent  
Metropolitan Edison Company  
P.O. Box 480  
Middletown, PA 17057

Subject: Three Mile Island Nuclear Generating Station - Unit 1  
HPI - Operating Instructions


Reference: Letter, GT Fairburn to GP Miller, TMI-79-47, dated 4/4/79

Dear Mr. Miller:

The operating instructions, given in the above reference, for operator action to override the engineering safety features actuation system and terminate HPI have been revised. This revision (attached) allows the operator an alternative to the 20 minute operability period, under certain conditions, to preclude the pressurizer from going solid.

This information supplements that previously transmitted. If you have any questions regarding this advisory, please advise.

Very truly yours,



G. T. Fairburn  
Service Manager

GTF/hh  
Attachment

cc: w/attachment  
RM Klingaman  
JF Hilbish  
LL Lawyer  
JL Seelinger  
CR Montgomery  
LC Rogers  
SL Smith

bcc: GM Olds  
JD Phinney  
Record Ctr. NSS-5/TT.2

**POOR ORIGINAL**

SUPPLEMENTAL OPERATING INSTRUCTIONS

FOR HPI SYSTEM OPERATION

REV. 01 - 4/17/79

Although details of the causes and course of events of the incident at Metropolitan Edison's TMI-2 plant on March 28, 1979 are still being developed, it appears that the incident was initiated by a loss-of-main feedwater flow (LOFW) and that a distinguishing characteristic of this transient compared to other previous LOFW transients was the securing of the high pressure injection (HPI) system. Consequently, all operating plants are advised to implement the following immediately:

If the HPI system has actuated because of low pressure condition, it must remain in operation until one of the following criteria is satisfied:

1. Both LPI pumps are in operation and flowing at a rate in excess of 1000 gpm each and the situation has been stable for 20 minutes.

OR

2. The HPI system has been in operation for 20 minutes and all hot and cold leg temperatures are at least 50° below the saturation temperature for the existing RCS pressure. If 50° subcooling cannot be maintained, the HPI shall be reactivated.

OR

3. All hot and cold leg temperatures are at least 50° below the saturation temperature for the existing RCS pressure, at least one RC pump in each loop is running, and the action is necessary to prevent the indicated pressurizer level from going off-scale high. If 50° subcooling cannot be maintained, the HPI shall be reactivated.

If the HPI system has been activated and if RC pumps are in operation, at least one RC pump per loop should be maintained.

POOR ORIGINAL



THE BASCOCK & WILCOX COMPANY  
POWER GENERATION GROUP

EXHIBIT 8  
page 1 of 8

To	Distribution	DATE	July 18-20, 1979
On	J. T. Willse, Licensing (2208) <i>JTW</i>	WITNESSES	
Cust.	Toledo	File No. or Ref.	4.2.3
Subj.	Loss of Pressurizer Level Indication	Date	March 9, 1979

This letter is cover one customer and one service only.

Distribution:

R. L. Reed	R. W. Winks
R. C. Luken	L. R. Cartin
J. T. Janis	E. A. Womack
G. T. Fairburn	D. Mars
C. D. Russell	J. O. Howard
J. H. Taylor	J. D. Agar
E. R. Kane	F. R. Faist

A meeting to discuss the loss of pressurizer level indication at DB-1 was convened February 14, 1979 at the B&W offices in Lynchburg. Those in attendance were:

J. E. Kohler	NRC Region III
J. E. Foster	NRC Region III
D. Anderson	NRC/OIE/LCVIP
Sushil Jain	Toledo Edison
J. F. Hilbush	Metropolitan Edison
R. A. Dietrich	SMUD
M. D. White	Arkansas
J. T. Enos	Arkansas
E. R. Kane	B&W
R. C. Luken	"
G. H. Klein	"
F. R. Faist	"
B. M. Dunn	"
L. R. Cartin	"
R. W. Winks	"
J. T. Willse	"

This meeting was requested by the Region III inspectors. The purpose of this meeting was thought to be to discuss the loss of pressurizer level indication on all B&W plants. The utilities were present to discuss incidences where loss of level indication occurred at their plants.

Mr. Foster of the NRC opened the meeting by stating that the purpose of this meeting was to investigate an allegation by an NRC inspector that B&W had not responded in a timely manner to resolve the loss of pressurizer level indication concern at DB-1. He apologized to the utilities for his method of requesting information from them; not realizing that the utilities would feel compelled to send

POOR ORIGINAL

486 240

representatives to this meeting. Mr. Foster next asked the utilities to respond to the questions he had submitted (letter attached). The questions were:

- (1) What previous experience of loss of pressurizer level have occurred?
- (2) The facility where the event(s) were experienced.
- (3) The dates of occurrence.
- (4) Whether the NRC was informed of the event.
- (5) What evaluation of the event was performed?

Duke Power and Florida Power did not send a representative to the meeting because they have not experienced a loss of pressurizer level indication.

Mr. Hilbish stated that TMI #1 had not experienced any loss of pressurizer level indication. TMI #2 had two such events (4/23/78 & 11/7/78) both of which were reported to the NRC in LER's. Both of these events were thoroughly evaluated.

Mr. Enos stated that ANO-1 had experienced 2 transients during which pressurizer level indication had been lost. Neither event had been officially reported to the NRC although their inspectors were aware of both events. Both events were evaluated by B&W and the ANO safety committee. As a result of those evaluations ANO believes that loss of pressurizer level indication is only an operational inconvenience and that RC pressurizer is sufficient to determine if the pressurizer has gone "dry".

Mr. Dieterich acknowledged that SMUD has had approximately 38 trips during which loss of level indication occurred on 5 to 10 of those transients. These events were not officially reported to the NRC although their inspectors were aware of the loss of pressurizer level indication. SMUD also had experienced two rapid cooldown transients during which pressurizer level indication was lost, these transients were evaluated and reported to the NRC.

Mr. Jain described the one transient where loss of level indication had occurred at Toledo. This transient was evaluated and reported to the NRC in an LER. He further described the discussions that had occurred between Toledo, the NRC, and B&W. The remainder of the morning was spent discussing the consequences of loss of level indication, the differences between DB-1 and the other B&W plants, and the dual level set point for the steam generator at Toledo.

Mr. Foster closed the morning meeting by thanking the utilities for their cooperation. He stated that as far as he was concerned loss of pressurizer level indication was merely an operational inconvenience and that the loss of pressurizer level was not a safety concern. He was recommending that this issue be closed. He agreed to send copies of his report to all utilities in attendance.

POOR ORIGINAL




Messrs. Foster and Kohler spent most of the afternoon reviewing the Toledo correspondence file pertaining to the overcooling transient. As a result of this review and the morning discussions Messrs. Foster and Kohler were convinced that B&W had responded in a manner consistent with the magnitude of the problem.

Mr. Foster summarized the days meeting by stating that he believed B&W had been exonerated of the charge that they had not responded in a timely manner, that the loss of pressurizer level indication was only an operational inconvenience, and that the loss of pressurizer level was not a safety concern. The only item that remained open was a review of the DB-1 operating instructions to insure that Toledo was operating the plant in the manner prescribed by B&W.

Copies of Arkansas, SMUD and Met. Ed. written responses to the NRC questions are attached.

JTW/fw  
Attachment

**POOR ORIGINAL**



METROPOLITAN EDISON COMPANY . . . MEMBER OF GENERAL PUBLIC UTILITIES CORPORATION

POST OFFICE BOX 542 READING, PENNSYLVANIA 19602

TELEPHONE 215 - 929-3501

February 3, 1979

GQL 0200

Mr. Joel T. Janis  
Service Manager  
Webcock & Wilam  
P.O. Box 1260  
Lynchburg, Virginia 24505

Dear Mr. Janis:

Three Mile Island Nuclear Station, Unit 2 (TMI-2)  
Loss of Pressurizer Level Indication

In response to your letter of February 2, 1979 concerning loss of pressurizer level indication, the following answers to the questions referenced in the NRC letter of January 31, 1979 are provided:

1. Two occurrences have taken place following reactor trips which resulted in loss of pressurizer level indication.
2. Metropolitan Edison Company
3. Three Mile Island, Unit 2
4. a. April 23, 1978  
b. November 7, 1978
5. Yes - a. Inspection Report 78-17, dated May 31, 1978  
LIR 78-033/LT, dated May 8, 1978  
Special Report, dated July 24, 1978  
b. Inspection Report 78-23, dated November 30, 1978  
Special Report 78-65/99X, dated January 30, 1979
6. Following each of these two events an evaluation was made to determine the effect on the Reactor Coolant System.
  - a. In the April 23, 1978 event, although the pressurizer level indication had gone below zero, evaluations demonstrate that the core remained covered throughout the transient.


POOR ORIGINAL

5. In the November 7, 1978 event, although the pressurizer level indication had gone below zero, a volume of 840 gallons of water remained in the pressurizer. The core remained covered throughout the transient.

No events concerning loss of pressurizer level indication have occurred at Three Mile Island Unit 1 during operation.

As currently scheduled, I will attend the strategy meeting on Tuesday, February 13, 1979 at Lynchburg.

Sincerely,



for J. F. Hibish  
Supervisor-Generation Licensing


JFH:LR:cas

**POOR ORIGINAL**

February 9, 1979

3.12 79 PM

*2/15/79*



W. A. T. Davis  
District Manager  
Nuclear Energy and Safety  
P. O. Box 1250  
Martinsburg, Virginia 24605

Loss of Pressure Level Indication  
Safety, Unit No. 1  
Loss of Pressure Level Indication

Mr. Davis:

Your letter of February 2, 1979 requested information concerning the loss of pressure level indication at Reactor Unit No. 1. Our design incorporates three separate level measurement systems to provide a backup for in case of a loss of level indication due to instrument malfunction.

Direct readout of pressure level was lost during the loss of non-nuclear instrumentation power and resulting transient on March 23, 1972. During this event, the signal to the indicator was lost; however, a computer system provided level information to the control room operators.

It is also possible for the pressure level to fall below a certain level due to water hammer during the accident following a reactor trip. 2,000 gallons of water will remain in the pressurizer at this point however, the introduction of high pressure injection results in a loss of the instrument signal. Results of this investigation on the accident during our meeting with you in Martinsburg on February 10, 1979. With a large volume of water in the system, and the reactor is shutdown during these conditions, the situation was not considered to be a safety significance.

Sincerely yours,

*D. H. Patten*

D. H. Patten, Manager  
Generation Engineering Department

**POOR ORIGINAL**

ARKANSAS POWER & LIGHT COMPANY

PO BOX 221 LITTLE ROCK, ARKANSAS 72202 (501) 371-4141

February 20, 1979

DONALD A. RUSTEN  
DIRECTOR  
TECHNICAL AND  
ENVIRONMENTAL SERVICES

NDC 8770

Mr. Ray Luken, Service Manager  
Babcock & Wilcox Company  
Nuclear Power Generation Division  
P. O. Box 1260  
Lynchburg, Virginia 24505

Subject: Pressurizer Level Indication  
(File: 3740)

Gentlemen:

The following is provided in response to your letter of February 2, 1979 (ANC-79-13).

Item 1: What previous experiences of loss of pressurizer level have occurred?

Response: ANC-1 has never lost pressurizer level due to normal operational transients. We have, on a few occasions, lost pressurizer indication; however, pressurizer level was maintained in each instance.

Item 2. The name of the involved utility for these events.

Response: Arkansas Power and Light Company.

Item 3. The facility where the event(s) were experienced.

Response: Arkansas Nuclear One - Unit One.

Item 4. The dates of occurrence.

Response: Specific dates are not readily available. They were in late 1974 and 1975.

Item 5. Whether the NRC was informed of the event.

Response: NRC was not formally informed, however at least two Region IV inspectors were aware of the occurrences.

POOR ORIGINAL

Mr. R. C. Luxer.

-2-

February 20, 1979


EXHIBIT 8  
page 8 of 8

Item 6: What evaluation of the event was performed?

Response. The events were reviewed in detail by the Plant Safety Committee (PSC), Safety Review Committee (SRC) and B2W. The conclusion of the reviews (to the satisfaction of the I&E inspectors) was that the occurrences were not of safety significance and that the public health and safety was not endangered.

If we can be of further assistance, please contact us.

Very truly yours,

  
Donald A. Rueter

DAR:JTE:vb

cc: Messrs. M. L. Pendergrass  
R. D. Lane  
J. S. Grisham  
W. C. Phillips  
B. A. Terwilliger  
J. Griffin  
J. O'Hanlon

POOR ORIGINAL

POOR ORIGINAL



Michelson Story Comments

C. Michelson, of TVA, provided  
B&W with a critique of small  
breaks for the B&W RCS in  
May of 1978. Also a follow up letter  
was provided in February of 1979.  
Also these critiques Mr. Michelson  
makes the following major points.

1. The HPI may bypass the  
reactor core and split the  
RCS directly via the break thus  
not providing core cooling.

The steam generator must remove  
significant portion of the decay  
heat for certain size of small  
breaks.

3. Pressure level is not a  
measure of RCS liquid inventory.

4. Low letter parts of the analysis  
the heat source effects of the  
steam generator must be included  
in the analysis.

5. Natural circulation may be interrupted  
by formation of voids in primary  
system and it natural circulation

67671-02-81  
July 18-20, 1979

POOR ORIGINAL



is terminated repressurization will occur before being draining sufficient to establish steam condensation. pag 249

In addressing these points it is important to note that the criticisms and concerns raised by Mr. Michelon are based on the assumption that the R.C. pumps are tripped or not pumping. The discussion here relates to pumps off. B291 has performed analyses with pumps on and off in order to determine the worst case. Although significantly different results are obtained between pumps on and off and system performance is very different the pumps off case is the worst condition.

All of Mr. Michelon's concerns are included in B291 evaluation model results.

POOR ORIGINAL

2) For smaller breaks the steam generator must remove a significant portion of decay heat. The limit becomes a no break case in which all energy must be removed by the steam generator. This consideration is effectively made in our analysis.

3) Pressure level is not a good indicator of primary liquid inventory. No operator action should be based on that signal alone. It is quite possible to have a smaller break causing a slow loss of B.C. inventory and eventual drop out of the core while maintaining a full pressure. If HPI is terminated prematurely, the only positive indication of a

POOR ORIGINAL

By the points we include this  
effects as follows.

- 1) Because HPI may by pass  
the core & it chooses best  
location to maximize that  
possibility. All breaks are modeled  
at the R.C. group discharge between  
the HPI injection point and  
the reactor vessel. Water injected  
in the broken cold leg runs  
directly at the break. Water injected  
in the intact leg can be bypassed  
by entering the downcomer and  
flowing out the break via the  
broken cold leg prior to  
flowing through the core. The  
point is well made and has  
been allowed for in our models.

POOR ORIGINAL

Liquid inventory is a subcool  
indication on all RCS pressure  
and temperature indicators except  
those in the pressurizer.

4) The heat contained in the  
steam generator severely alters  
the course of events for those  
breaks large enough to depressurize  
below the control pressure for  
the steam generator. This source  
remains and is considered in our  
analysis.

5) Natural circulation will be  
interrupted during the small  
break, a repressurization is  
probable for smaller breaks  
and it would be shown in our  
evaluation. Our only disagreement  
with Mr. Nicholson is his estimate



that natural circulation ends when the vessel head starts putting steam into the hot legs. The escape ratio of steam and water is such that natural circulation will continue for a considerably longer period based on fresh flow in the hot legs.

B & W provides bounding small break evaluations in its S&B material. The spectrum of evaluation is based on the following:

- 1) The CFT line accident,
- 2) one break for which LPE CFT and HPE help mitigate consequences,
- 3) one break for which only CFT and HPE help mitigate consequences,
- 4) one break which is solely dependent on HPE, and
- 5) additional breaks to confirm that the above have provided bounding evaluations.

From the very small breaks  
no evaluation is made for  
the following reasons.

1) Because of the vent valves and  
the once through nature of the  
steam generator, steam condensation  
in the generator or within occurs  
before the reactor core is  
uncovered.

2) If ~~steam~~ steam condensation  
is happening the RCS pressure  
will be at or around 1200 psia.

3) The existing larger break  
(HPI only mitigating system) occurs  
at lower system inventory and  
1200 psia or less and at higher  
decay heat levels. ~~Thus~~ This  
evaluation showed that at this  
time 1 HPI protected core.

4) At the last

POOR ORIGINAL

also be able to prevent core  
excursion because decay heat  
levels are lower.

5) System depressurization to code  
safetia is expected and of no  
known consequence. This  
condition and possible system  
oscillations during transition  
to code safetia pose no safety  
concerns. The condition can be  
avoided if desired by

1) increasing steam generator  
levels and depressurizing  
the generator.

2) Dumping or venting and  
R.C. sprays to mix primary  
steam with cold water, and

3) transition to decay heat  
removal system.

POOR ORIGINAL



However, the operator has at page 999  
Section 9 have etc of RWST and  
can recirculate from the swing  
area after that so there is  
no concern about operating  
on the work surface.

Mr. Michelson address some 29

other issues in his report. Discussion  
of each issue would require extensive  
interchange and be best accomplished  
in an open and limited scope meeting.

We believe allowance has been made for  
each of these issues within our design  
and design verification. The report  
is well thought out and although  
confliction may exist on some minor  
points, it describes fairly well  
the course of events during swing  
and work.

POOR ORIGINAL