



UNITED STATES
NUCLEAR REGULATORY COMMISSION
REGION III
799 ROOSEVELT ROAD
GLEN ELLYN, ILLINOIS 60137

TIC

Docket No. 50-358

JUL 25 1979

Cincinnati Gas and Electric Company
ATTN: Mr. Earl A. Borgmann
Vice President
Engineering Services
and Electric Production
139 East 4th Street
Cincinnati, OH 45201

Gentlemen:

Thank you for your letter dated June 21, 1979, informing us of the steps you have taken to correct the noncompliance identified in our letter dated May 16, 1979. Regarding item 2 we want to remind you that while Inspection Procedure 22A4387, Revision 4 was prepared and approved by the General Electric Company, final responsibility rests with CG&E to ensure the procedures used are clearly written and meet the requirements of 10 CFR 50, Appendix B, Criterion V. Our position remains that the procedure and FDDR used to inspect the control rods did not clearly indicate what was to be done. We expect your audits of existing General Electric procedures will be comprehensive enough to prevent future use of inadequate procedures. We will examine your corrective action during a future inspection.

Your cooperation with us is appreciated.

Sincerely,

James G. Keppler
James G. Keppler
Director

cc: Mr. J. R. Schott, Plant Super.

cc w/ltr dtd 6/21/79:

Central Files

Reproduction Unit NRC 20b

PDR

Local PDR

NSIC

TIC

Harold W. Kohn, Power Siting Comm.

Citizens Against a Radioactive
Environment

Helen W. Evans, State of Ohio

510 278

7

7908030555