

DR

**Florida
Power**
CORPORATION

June 18, 1979

19 JUN 21 AID: 02

USNRC REGULATORY
ADMINISTRATIVE

Mr. J. P. O'Reilly
Director
U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Suite 3100
101 North Marietta Street
Atlanta, GA 30303

Subject: Docket No. 50-302
Operating License No. DPR-72
IE Bulletin 79-01

Dear Mr. O'Reilly:

In response to the subject NRC Bulletin concerning Environmental Qualification of Class IE Equipment the following information is being provided:

1. The re-review program for Crystal River Unit 3 has been completed. The review consisted of examining safety related electrical equipment installed inside containment to ensure appropriate documentation of its qualification to function under postulated accident conditions (LOCA). For all equipment identified, adequate and appropriate documentation is available. See attached list.
2. The types of limit switches described in the subject bulletin are neither being used nor planned for use for a safety related function on safety related valves located inside containment.
3. For the written evidence of the qualification of electrical equipment required to function under accident conditions, see the attached list. No items were found not having qualification data available for review.
4. No items were identified as not meeting qualification requirements for the service intended.

7

7908030572


508 212

790381

Should you have any questions concerning our response, please contact this office.

Very truly yours,

FLORIDA POWER CORPORATION

A handwritten signature in cursive script that reads "W. P. Stewart". The signature is written in dark ink and is positioned below the typed name of the sender.

W. P. Stewart
Manager
Nuclear Operations

ETekcM03(D70)

Attachments

cc: U.S. Nuclear Regulatory Commission
Office of Inspection and Enforcement
Division of Reactor Operations Inspection
Washington, DC 20555

NRC Office of Inspection and Enforcement
Division of Reactor Construction Inspection
Washington, DC 20555

File Code: 3-0-3-a-3

PLANT NAME: Crystal River #1

TOP ORIGINAL

ITEM	EQUIPMENT DESCRIPTION	TIME REQ'D.	ENVIRONMENT (LOCATION)		QUAL.	QUAL. METHOD*	DOC. RLF**	REMARKS
			PARAMETER	SPEC.				
1	Power and Control Cable (Kerite)	Long Term		/		Seq.	1	
			Temp. (°F)		325			
			Press. (psig)		82			
			Rel. Hum.		100%			
			Radiation Rads		1.2×10^5			
Chem.	Boric Acid Sol.							
2	Instrumentation Cable (Continental Wire and Cable Corp.)	Long Term		/		Seq.	2	
			Temp. (°F)		340			
			Press. (psig)		100			
			Rel. Hum.		100%			
			Radiation (Rads)		1×10^8			
Chem.	---							
3	Control and Instrumentation Cable (Rockbestos)	Long Term		/		Seq.	3	
			Temp. (°F)		346			
			Press. (psig)		113			
			Rel. Hum.		100%			
			Radiation Rads		2×10^8			
Chem.	Boric Acid Sol.							
4	Instrumentation Cable (Boston Insulated Wire And Cable Co.)	Long Term		/		Seq.	4	
			Temp. (°F)		340			
			Press. (psig)		105			
			Rel. Hum.		100%			
			Radiation Rads		2×10^8			
Chem.	Boric Acid Sol.							

This list is a compilation of items by component. Do not list the same type of component more than once. Use limiting environment where more than one applies. *ie. separate effects, sequential, etc. **Please attach typed lists of reference documents

POOR ORIGINAL

508 215

PLANT NAME: Crystal River #1

ITEM	EQUIPMENT DESCRIPTION	TIME REQ'D.	ENVIRONMENT (LOCATION)			QUAL. METHOD*	DOC. REF**	REMARKS
			PARAMETER	SPEC.	QUAL.			
2	Neutron Detector (Westinghouse Type WL 23636 B)	15 sec.	Temp. (°F) ^{Sur.} Temp.	212	212	Seq.	5	Not required for LOCA, only SSLE & REA
			Press. (psig)	150	150			
			Rel. Hum.	90%	100%			
			Radiation Rads	3×10^9	3×10^9			
			Chem.	---	---			
6	Differential Pressure Transmitters (Bailey Meter Model BY)	24 hrs.	Temp. (°F)	286	296	Seq.	5	
			Press. (psig)	60	60			
			Rel. Hum.	100%	100%			
			Radiation Rads	2×10^4	5×10^4			
			Chem.	---	---			
7	Pressure Transmitter (Foxboro Model ELGH)	24 hrs.	Temp. (°F)	286	318	Seq.	5	
			Press. (psig)	60	90			
			Rel. Hum.	100%	100%			
			Radiation Rads	2×10^4	2.4×10^4			
			Chem.	---	---			
8	Temperature Element Rosemount Model 177 HW	24 hrs.	Temp. (°F)	600	600	Seq.	5	
			Press. (psig)	3125	3125			
			Rel. Hum.	100%	100%			
			Radiation Rads	2×10^4	1×10^8			
			Chem.	---	---			

This list is a compilation of items by component. Do not list the same type of component more than once. Use limiting environment where more than one applies. *ie, separate effects, sequential, etc. **Please attach typed lists of reference documents

POOR ORIGINAL

PLANT NAME: Crystal River #3

ITEM	EQUIPMENT DESCRIPTION	TIME REQ'D.	ENVIRONMENT (LOCATION)				QUAL. METHOD*	DOC. REF.**	REMARKS
			PARAMETER	SPEC.	QUAL.	QUAL.			
9	Pressure Transmitter (Rosemont Model 1152)	24 hrs.	Temp. (°F) Press. (psig) Rel. Hum. Radiation Chem.	286 59 100% 7 x 10 ⁴ ---	286 59 100% 7 x 10 ⁴ Boric Acid Sol.	Seq.	6		
10	Electrical Penetrations (Conax)	Long Term	Temp. (°F) Press. (psig) Rel. Hum. Radiation Chem.	281/325 55/825 100% 1.5 x 10 ⁸ ---	325 85 100% 1.5 x 10 ⁸ ---	Seq.	7,8	Testing did not include radiation.	
11	Terminal Blocks (Kulka Type 5TB and 7TB - used on Elect. Penet.)	Long Term	Temp. (°F) Press. (psig) Rel. Hum. Radiation Chem.	/	/	Seq.	9	Terminal blocks are physically mounted in a "vented enclosure." Separate thermal test was performed to a temp. of 600° F for 20 secs.	
12	Terminal Blocks (States Co. type ZM - used in sealed, Nema 4 equiv., terminal boxes.)	Long Term	Temp. (°F) Press. (psig) Rel. Hum. Radiation Chem.	/	/	Seq.	10	Type ZM is similar to Type NT and is qualified by comparison.	

This list is a compilation of items by component. Do not list the same type of component more than once.
 *ie, separate effects sequential, etc.
 **please attach typed lists of reference documents.

PLAN NAME: Crystal River #1

POOR ORIGINAL

508

ITEM	EQUIPMENT DESCRIPTION	TIME REQ'D.	ENVIRONMENT (LOCATION)			QUAL. METHOD*	DOC. REF**	REMARKS
			PARAMETER	SPEC.	QUAL.			
13	Reactor Building Fan Assemblies (Westinghouse)	24 hrs.	Temp. (°F)	281	320	Seq.	11,12	
			Press. (psig)	70	80			
			Rel. Hum.	100%	100%			
			Radiation Rads	1×10^7	1.4×10^8			
			Chem.	---	---			
14	Electric Motor Operators (Limitorque)	Long Term	Temp. (°F)	/	329	Seq.	13	
			Press. (psig)	/	90			
			Rel. Hum.	/	100%			
			Radiation	/	---			
			Chem.	/	Boric Acid Sol.			
15	Triax Connectors (Amphenol 53175/52975)	15 sec.	Temp. (°F)	/	/	/	/	Not required for LOCA, only SSLB & REA. Connectors are installed inside Elect. Penet. enclosure.
			Press. (psig)	/	/			
			Rel. Hum.	/	/			
			Radiation	/	/			
			Chem.	/	/			
16	Electric Motor Operators (Limitorque)	Long Term	Temp. (°F)	/	300	Seq.	#14	
			Press. (psig)	/	70			
			Rel. Hum.	/	100%			
			Radiation Rads	/	2.04×10^8			
			Chem.	/	Boric Acid Sol.			

This list is a compilation of items by component. Do not list the same type of component more than once. Use limiting environment where more than one applies. *ie, separate effects, sequential, etc. **Please attach typed lists of reference documents

DOCUMENTATION REFERENCES

1. Kerite Co. "Report on the Effects of Gamma Radiation and Autoclaving on Kerite Power and Control Cables" dated 4/30/70.
2. FIRL Report F-C2935 "Test of Electrical Cables Under Simulated Post-Accident Reactor Containment Service" dated Oct. 1970 and addendum dated Nov. 1970.
3. FIRL Report F-C3798 "Qualification Tests of Electrical Cables Under Simulated Reactor Containment Service Conditions Including Loss-of-Coolant Accident While Electrically Energized" dated March 1974.
4. BIW Report No. B910 "BIW Bostrad^{7e} Cables - Flame and Radiation Resistant Cables for Nuclear Power Plants" dated May 1975.
5. B&W Topical Report BAW-10003A, Rev. 4 dated January 1976.
6. B&W Report 58-0261-00.
7. Conax Test Report TR-17, "Prototype Test Report of Penetration Assemblies"
8. Conax Specification IP3-16, "Specification for Type Qualification of Electrical Penetration Sub-Assemblies"
9. FIRL Report F-C4927, "Steam and Chemical Spray Exposure Test of Electrical Terminal Blocks" dated February 1978.
10. GE letter dated 10/10/78; Electrical Terminal Block Testing.
11. Westinghouse Report WCAP-9003.
12. Westinghouse Report WCAP-7343-L
13. Philadelphia Gear Test Report #600168. "Test of Limitorque Valve Operator to Meet General Requirements of An Electric Valve Actuator in Nuclear Reactor Containment Environment: dated Jan. 2, 1969 and Addendum Number I dated April 29, 1969.
14. Philadelphia Gear Test Report #600456. "Nuclear Power Station Qualification Type Test Report on Limitorque Valve Actuator for IWR Service.", dated Sept., 1976.