

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | C | B | E | P | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5
7 8 9 14 15 25 26 30 57 58
LICENSEE CODE LICENSE NUMBER LICENSE TYPE CAT 58

CON'T
0 1 | L | 0 | 5 | 0 | - | 0 | 3 | 2 | 4 | 7 | 0 | 7 | 0 | 2 | 7 | 9 | 8 | 0 | 8 | 0 | 1 | 7 | 9 | 9
7 8 60 61 68 69 74 75 80
REPORT SOURCE DOCKET NUMBER EVENT DATE REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | While performing PT 19.6.0.1, Visual Inspection of Inaccessible Snubbers, the following
0 3 | snubbers were found inoperable: 1) 2E41-4SS45, HPCI steam line; 2) 2B32-SSB9B, 2A
0 4 | Recirc. pump suction line; 3) 2B21-34SS300, main steam relief F013H discharge.
0 5 | Technical Specification 3.7.5, 6.9.1.9.b
0 6 |
0 7 |
0 8 |

0 9 | S | H | E | X | S | U | P | O | R | T | D | Z |
7 8 9 10 11 12 13 18 19 20
SYSTEM CODE CAUSE CODE CAUSE SUBCODE COMPONENT CODE COMP. SUBCODE VALVE SUBCODE

17 | 7 | 9 | 0 | 2 | 1 | 0 | 3 | L | 0 |
7 8 9 21 22 23 24 26 27 28 29 30 31 32
LER/RO REPORT NUMBER EVENT YEAR SEQUENTIAL REPORT NO. OCCURRENCE CODE REPORT TYPE REVISION NO.

A | Z | A | A | 0 | 0 | 9 | 6 | N | N | A | B | 2 | 0 | 9 |
7 8 9 33 34 35 36 37 40 41 42 43 44 47
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUT-DOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | All snubbers were found to have low fluid levels due to seal failure. The snubbers
1 1 | were rebuilt, functionally tested, and reinstalled. Snubber inspections will continue
1 2 | per Technical Specifications frequency.
1 3 |
1 4 |

1 5 | G | 0 | 0 | 0 | NA | B | Periodic Test
7 8 9 10 12 13 44 45 46
FACILITY STATUS % POWER OTHER STATUS METHOD OF DISCOVERY DISCOVERY DESCRIPTION

1 6 | Z | Z | NA | NA |
7 8 9 10 11 44 45
ACTIVITY CONTENT RELEASED OF RELEASE AMOUNT OF ACTIVITY LOCATION OF RELEASE

1 7 | 0 | 0 | 0 | Z | NA |
7 8 9 11 12 13
PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION

1 8 | 0 | 0 | 0 | NA |
7 8 9 11 12
PERSONNEL INJURIES NUMBER DESCRIPTION

1 9 | Z | NA |
7 8 9 10
LOSS OF OR DAMAGE TO FACILITY TYPE DESCRIPTION

0 | N | NA |
7 8 9 10
PUBLICITY ISSUED DESCRIPTION

NAME OF PREPARER A. C. Tollison, Jr

PHONE: 919-457-9521

7908060415

514 338

NRC USE ONLY