

NUREG/CR-0815

TREE-1229

For U.S. Nuclear Regulatory Commission

EXPERIMENT DATA REPORT FOR SEMISCALE
MOD-3 LOWER PLENUM INJECTION
TEST S-07-9
(BASELINE TEST SERIES)

DEAN H. MIYASAKI KENNETH E. SACKETT
DAVID R. PACK

JUNE 1979



EG&G Idaho, Inc.



IDAHO NATIONAL ENGINEERING LABORATORY

DEPARTMENT OF ENERGY

IDAHO OPERATIONS OFFICE UNDER CONTRACT DE-AC07-76IDO1570

79 080 79 748
507 049

NOTICE

This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, or any of their employees, makes any warranty, expressed or implied, or assumes any legal liability or responsibility for any third party's use, or the results of such use, of any information, apparatus, product or process disclosed in this report, or represents that its use by such third party would not infringe privately owned rights.

The views expressed in this report are not necessarily those of the U.S. Nuclear Regulatory Commission.

Available from
National Technical Information Service
Springfield, Virginia 22161
Price: Printed Copy A12; Microfiche \$3.00

The price of this document for requesters outside the North American continent can be obtained from the National Technical Information Service.

507 050

**EXPERIMENT DATA REPORT FOR SEMISCALE
MOD-3 LOWER PLENUM INJECTION
TEST S-07-9
(BASELINE TEST SERIES)**

Dean H. Miyasaki
Kenneth E. Sackett
David R. Pack

**EG&G Idaho, Inc.
Idaho Falls, Idaho 83401**

Published June 1979

PREPARED FOR THE
U.S. NUCLEAR REGULATORY COMMISSION
AND THE U.S. DEPARTMENT OF ENERGY
IDAHO OPERATIONS OFFICE
UNDER CONTRACT NO. DE-AC07-76ID01570
NRC FIN NO. A6038

ABSTRACT

Recorded test data are presented for Test S-07-9 of the Semiscale Mod-3 baseline test series. This test is one of several Semiscale Mod-3 experiments conducted to investigate the thermal and hydraulic phenomena accompanying a hypothesized loss-of-coolant accident in a pressurized water reactor (PWR) system. Test S-07-9 was conducted from initial conditions of 16.10 MPa and 559 K to investigate the response of the Semiscale Mod-3 system to a blowdown transient following a simulated double-ended offset shear of the broken loop cold leg piping. The specific objective of this test was to provide reference data to evaluate integral blowdown and reflood behavior during a 200% cold leg break with emergency core coolant (ECC) injection into the vessel lower plenum of the Mod-3 system. The purpose of this report is to make available the uninterpreted data from Test S-07-9 for future data analysis. The data, presented in the form of graphics in engineering units, have been analyzed only to the extent necessary to ensure that they are reasonable and consistent.

This test was identical to Test S-07-8, except that the ECC injection from the accumulator was initiated at a higher accumulator pressure (6.92 MPa).

507 052

SUMMARY

Test S-07-9 was performed as part of the Semiscale Mod-3 portion of the Semiscale Program conducted by EG&G Idaho, Inc., for the United States Government. This test was part of the Mod-3 baseline test series (Test Series 7) performed to investigate the response of the Mod-3 system during a blowdown and reflood transient. Hardware configuration and test parameters were selected to yield a system response that simulates the response of a pressurized water reactor to the blowdown and reflood portions of a hypothesized loss-of-coolant accident (LOCA).

The objective of Test S-07-9 was to provide reference data to evaluate integral blowdown and reflood behavior during a 200% cold leg break with emergency core coolant injection into the vessel lower plenum of the Mod-3 system.

The Mod-3 system was equipped with a pressure vessel with simulated reactor internals and an external downcomer assembly; an intact loop with steam generator, pump, and pressurizer; a broken loop with steam generator, pump, and rupture assembly; high and low pressure coolant injection pumps and coolant injection accumulator for the vessel lower plenum; and a pressure suppression system with header, suppression tank, and steam supply system. The electrically heated core consisted of 25 rods of which 23 were powered.

Test S-07-9 was conducted from initial conditions of 16.10 MPa and 559 K with a simulated full size (200%) double-ended offset shear of the broken loop piping at an initial core power level of 2.00 MW. After initiation of blowdown, power to the heated core was reduced to simulate the predicted heat flux response of nuclear fuel rods during a LOCA.

Test S-07-9 was generally conducted as specified. Conditions which did not conform to the specified test configuration were considered acceptable for analysis purposes within the test objectives. The instrumentation used generally functioned as intended. Of 211 measurements taken, 206 produced usable data.

507 053

CONTENTS

ABSTRACT	ii
SUMMARY	iii
I. INTRODUCTION	1
II. SYSTEM, PROCEDURES, CONDITIONS, AND EVENTS FOR TEST S-07-9	2
1. SYSTEM CONFIGURATION AND TEST PROCEDURES	2
2. INITIAL TEST CONDITIONS AND SEQUENCE OF EVENTS	5
III. DATA PRESENTATION	9
IV. REFERENCES	184
APPENDIX A — DATA ACQUISITION SYSTEM CAPABILITIES	185
APPENDIX B — POSTTEST ADJUSTMENTS TO DATA FROM SEMISCALE MOD-3 TEST S-07-9	189
APPENDIX C — SELECTED DATA, WITH ESTIMATED TOTAL UNCERTAINTY BANDS FROM SEMISCALE MOD-3 TEST S-07-9	197

FIGURES

1. Semiscale Mod-3 system for cold leg break configuration — isometric	3
2. Semiscale Mod-3 system for cold leg break configuration — schematic	4
3. Semiscale Mod-3 system and instrumentation for cold leg break configuration — isometric	10
4. Semiscale Mod-3 system and instrumentation for cold leg break configuration — schematic	11
5. Semiscale Mod-3 pressure vessel and downcomer — cross section showing instrumentation	12
6. Semiscale Mod-3 pressure vessel — isometric showing instrumentation	13
7. Semiscale Mod-3 pressure vessel — penetrations and instrumentation	14
8. Semiscale Mod-3 downcomer — isometric showing instrumentation	15
9. Semiscale Mod-3 downcomer — penetrations and instrumentation	16
10. Semiscale Mod-3 heater core — plan view	17
11. Fluid temperature in intact loop hot leg (RFI-2 and TFI-1), from -20 to 300 s	29

12.	Fluid temperature in intact loop hot leg (RFI-2 and TFI-1), from -6 to 42 s	29
13.	Fluid temperature in intact loop cold leg (TFI-11), from -20 to 300 s	30
14.	Fluid temperature in intact loop cold leg (TFI-11), from -6 to 42 s	30
15.	Fluid temperature in intact loop cold leg (RFI-17 and TFI-17), from -20 to 300 s	31
16.	Fluid temperature in intact loop cold leg (RFI-17 and TFI-17), from -6 to 42 s	31
17.	Fluid temperature in broken loop hot leg (RFB-20 and TFB-20), from -20 to 300 s	32
18.	Fluid temperature in broken loop hot leg (RFB-20 and TFB-20), from -6 to 42 s	32
19.	Fluid temperature in broken loop cold leg (TFB-37), from -20 to 300 s	33
20.	Fluid temperature in broken loop cold leg (TFB-37), from -6 to 42 s	33
21.	Fluid temperature in broken loop cold leg (RFB-45 and TFB-45), from -20 to 300 s	34
22.	Fluid temperature in broken loop cold leg (RFB-45 and TFB-45), from -6 to 42 s	34
23.	Fluid temperature in downcomer (TFD-18F, TFD-152, TFD-294, TFD-364, and TFD-435), from -20 to 300 s	35
24.	Fluid temperature in downcomer (TFD-18F, TFD-152, TFD-294, TFD-364, and TFD-435), from -6 to 42 s	35
25.	Fluid temperature in vessel (TFV - 221Q), from -20 to 300 s	36
26.	Fluid temperature in vessel (TFV - 221Q), from -6 to 42 s	36
27.	Fluid temperature in vessel (TFV-11 and TFV-63R), from -20 to 300 s	37
28.	Fluid temperature in vessel (TFV-11 and TFV-63R), from -6 to 42 s	37
29.	Fluid temperature in vessel (TFV-552A, TFV-572W, and TFV-578A), from -20 to 300 s	38
30.	Fluid temperature in vessel (TFV-552A, TFV-572W, and TFV-578A), from -6 to 42 s	38
31.	Fluid temperature in vessel filler insulator gap (TIFV - 79D), from -20 to 300 s	39
32.	Fluid temperature in vessel filler insulator gap (TIFV - 79D), from -6 to 42 s	39
33.	Fluid temperature in vessel, core guide tube (TGFV - 330), from -20 to 300 s	40
34.	Fluid temperature in vessel, core guide tube (TGFV - 330), from -6 to 42 s	40
35.	Fluid temperature in core, Grid Spacer 1 (TFG-1AB-12), from -20 to 300 s	41
36.	Fluid temperature in core, Grid Spacer 1 (TFG-1AB-12), from -6 to 42 s	41
37.	Fluid temperature in core, Grid Spacer 3 (TFG-3AB-12), from -20 to 300 s	42

507 055

38.	Fluid temperature in core, Grid Spacer 3 (TFG-3AB-12), from -6 to 42 s	42
39.	Fluid temperature in core, Grid Spacer 5 (TFG-5AB-45), from -20 to 300 s	43
40.	Fluid temperature in core, Grid Spacer 5 (TFG-5AB-45), from -6 to 42 s	43
41.	Fluid temperature in core, Grid Spacer 8 (TFG-8AB-23), from -20 to 300 s	44
42.	Fluid temperature in core, Grid Spacer 8 (TFG-8AB-23), from -6 to 42 s	44
43.	Fluid temperature in core, Grid Spacer 10 (TFG-10AB-45), from -20 to 300 s	45
44.	Fluid temperature in core, Grid Spacer 10 (TFG-10AB-45), from -6 to 42 s	45
45.	Fluid temperature in vessel accumulator, coolant injection line (TFV-ECC-LP), from -20 to 300 s	46
46.	Fluid temperature in vessel accumulator, coolant injection line (TFV-ECC-LP), from -6 to 42 s	46
47.	Fluid temperature in intact loop steam generator, secondary feedwater line (TFI-SGFW), from -20 to 300 s	47
48.	Fluid temperature in intact loop steam generator, secondary feedwater line (TFI-SGFW), from -6 to 42 s	47
49.	Fluid temperature in intact loop steam generator, secondary side steam dome (TFI-SD), from -20 to 300 s	48
50.	Fluid temperature in intact loop steam generator, secondary side steam dome (TFI-SD), from -6 to 42 s	48
51.	Fluid temperature in broken loop, pressure suppression system tank (TFB-PS43 and TFB-PS330), from -20 to 300 s	49
52.	Fluid temperature in broken loop, pressure suppression system tank (TFB-PS43 and TFB-PS330), from -6 to 42 s	49
53.	Material temperature in intact loop (TMI-1T16 and TMI-17S16), from -20 to 300 s	50
54.	Material temperature in intact loop (TMI-1T16 and TMI-17S16), from -6 to 42 s	50
55.	Material temperature in broken loop (TMB-20B16), from -20 to 300 s	51
56.	Material temperature in broken loop (TMB-20B16), from -6 to 42 s	51
57.	Material temperature in broken loop (TMB-40B16 and TMB-45B16), from -20 to 300 s	52
58.	Material temperature in broken loop (TMB-40B16 and TMB-45B16), from -6 to 42 s	52
59.	Material temperature in downcomer (TMD-18F, TMD-152, and TMD-364), from -20 to 300 s	53
60.	Material temperature in downcomer (TMD-18F, TMD-152, and TMD-364), from -6 to 42 s	53

60	Material temperature in downcomer insulator (TIMD-18F, TIMD-152, TIMD-294, and TIMD-364), from -20 to 300 s	54
62	Material temperature in downcomer insulator (TIMD-18F, TIMD-152, TIMD-294, and TIMD-364), from -6 to 42 s	54
63	Material temperature in upper vessel (TMV + 221F and TMV + 79D), from -20 to 300 s	55
64	Material temperature in upper vessel (TMV + 221F and TMV + 79D), from -6 to 42 s	55
65	Material temperature in vessel, core guide tube (TGMV + 280 and TGMV-63), from -20 to 300 s	56
66	Material temperature in vessel, core guide tube (TGMV + 280 and TGMV-63), from -6 to 42 s	56
67	Material temperature in intact loop, steam generator tube (TMI-SGT61), from -20 to 300 s	57
68	Material temperature in intact loop, steam generator tube (TMI-SGT61), from -6 to 42 s	57
69	Material temperature in broken loop, steam generator tube (TMB-SGT734), from -20 to 300 s	58
70	Material temperature in broken loop, steam generator tube (TMB-SGT734), from -6 to 42 s	58
71	Core heater temperature, Rod B-3 (TH-B3-180, TH-B3-226, and TH-B3-353), from -20 to 300 s	59
72	Core heater temperature, Rod B-3 (TH-B3-180, TH-B3-226, and TH-B3-353), from -6 to 42 s	59
73	Core heater temperature, Rod C-2 (TH-C2-8, TH-C2-164, TH-C2-180, TH-C2-277, and TH-C2-321), from -20 to 300 s	60
74	Core heater temperature, Rod C-2 (TH-C2-8, TH-C2-164, TH-C2-180, TH-C2-277, and TH-C2-321), from -6 to 42 s	60
75	Core heater temperature, Rod C-3 (TH-C3-49, TH-C3-115, TH-C3-184, TH-C3-194, and TH-C3-230), from -20 to 300 s	61
76	Core heater temperature, Rod C-3 (TH-C3-49, TH-C3-115, TH-C3-184, TH-C3-194, and TH-C3-230), from -6 to 42 s	61
77	Core heater temperature, Rod D-2 (TH-D2-10, TH-D2-134, TH-D2-166, TH-D2-179, and TH-D2-254), from -20 to 300 s	62
78	Core heater temperature, Rod D-2 (TH-D2-10, TH-D2-134, TH-D2-166, TH-D2-179, and TH-D2-254), from -6 to 42 s	62

507 057

79.	Core heater temperature, Rod D-3 (TH-D3-71, TH-D3-132, TH-D3-206, and TH-D3-226), from -20 to 300 s	63
80.	Core heater temperature, Rod D-3 (TH-D3-71, TH-D3-132, TH-D3-206, and TH-D3-226), from -6 to 42 s	63
81.	Core heater temperature, Rod A-3 (TH-A3-208, TH-A3-229, and TH-A3-291), from -20 to 300 s	64
82.	Core heater temperature, Rod A-3 (TH-A3-208, TH-A3-229, and TH-A3-291), from -6 to 42 s	64
83.	Core heater temperature, Rod A-4 (TH-A4-40, TH-A4-108, TH-A4-181, and TH-A4-191), from -20 to 300 s	65
84.	Core heater temperature, Rod A-4 (TH-A4-40, TH-A4-108, TH-A4-181, and TH-A4-191), from -6 to 42 s	65
85.	Core heater temperature, Rod A-5 (TH-A5-164, TH-A5-179, and TH-A5-252), from -20 to 300 s	66
86.	Core heater temperature, Rod A-5 (TH-A5-164, TH-A5-179, and TH-A5-252), from -6 to 42 s	66
87.	Core heater temperature, Rod B-1 (TH-B1-321), from -20 to 300 s	67
88.	Core heater temperature, Rod B-1 (TH-B1-321), from -6 to 42 s	67
89.	Core heater temperature, Rod D-1 (TH-D1-178 and TH-D1-251), from -20 to 300 s	68
90.	Core heater temperature, Rod D-1 (TH-D1-178 and TH-D1-251), from -6 to 42 s	68
91.	Core heater temperature, Rod D-5 (TH-D5-137, TH-D5-179, TH-D5-254, and TH-D5-322), from -20 to 300 s	69
92.	Core heater temperature, Rod D-5 (TH-D5-137, TH-D5-179, TH-D5-254, and TH-D5-322), from -6 to 42 s	69
93.	Core heater temperature, Rod E-1 (TH-E1-252 and TH-E1-321), from -20 to 300 s	70
94.	Core heater temperature, Rod E-1 (TH-E1-252 and TH-E1-321), from -6 to 42 s	70
95.	Core heater temperature, Rod E-2 (TH-E2-109, TH-E2-190, and TH-E2-353), from -20 to 300 s	71
96.	Core heater temperature, Rod E-2 (TH-E2-109, TH-E2-190, and TH-E2-353), from -6 to 42 s	71
97.	Core heater temperature, Rod E-3 (TH-E3-134, TH-E3-207, TH-E3-223, and TH-E3-290), from -20 to 300 s	72
98.	Core heater temperature, Rod E-3 (TH-E3-134, TH-E3-207, TH-E3-223, and TH-E3-290), from -6 to 42 s	72

99.	Core heater temperature, Rod E-4 (TH-E4-180 and TH-E4-354), from -20 to 300 s	73
100.	Core heater temperature, Rod E-4 (TH-E4-180 and TH-E4-354), from -6 to 42 s	73
101.	Core heater temperature, Rod E-5 (TH-E5-227), from -20 to 300 s	74
102.	Core heater temperature, Rod E-5 (TH-E5-227), from -6 to 42 s	74
103.	Pressure in intact loop cold leg (PI-16 and PI-17AL), from -20 to 300 s	75
104.	Pressure in intact loop cold leg (PI-16 and PI-17AL), from -6 to 42 s	75
105.	Pressure in broken loop hot leg (PB-20B), from -20 to 300 s	76
106.	Pressure in broken loop hot leg (PB-20B), from -6 to 42 s	76
107.	Pressure in broken loop cold leg, pump side (PB-40B), from -20 to 300 s	77
108.	Pressure in broken loop cold leg, pump side (PB-40B), from -6 to 42 s	77
109.	Pressure in broken loop blowdown nozzle (PB-44-6A), from -20 to 300 s	78
110.	Pressure in broken loop blowdown nozzle (PB-44-6A), from -6 to 42 s	78
111.	Pressure in broken loop cold leg, vessel side (PB-45A), from -20 to 300 s	79
112.	Pressure in broken loop cold leg, vessel side (PB-45A), from -6 to 42 s	79
113.	Pressure in vessel upper and lower plenum (PV-13 and PV-442), from -20 to 300 s	80
114.	Pressure in vessel upper and lower plenum (PV-13 and PV-442), from -6 to 42 s	80
115.	Pressure in vessel ECC injection accumulator (PV-ACC1), from -20 to 300 s	81
116.	Pressure in vessel ECC injection accumulator (PV-ACC1), from -6 to 42 s	81
117.	Pressure in system steam generators, secondary side steam dome (PI-SD and PB-SD), from -20 to 300 s	82
118.	Pressure in system steam generators, secondary side steam dome (PI-SD and PB-SD), from -6 to 42 s	82
119.	Pressure in pressurizer (PI-PRIZE), from -20 to 300 s	83
120.	Pressure in pressurizer (PI-PRIZE), from -6 to 42 s	83
121.	Pressure in broken loop pressure suppression tank (PB-PSS), from -20 to 300 s	84
122.	Pressure in broken loop pressure suppression tank (PB-PSS), from -6 to 42 s	84
123.	Differential pressure in intact loop (DI-13V-1A), from -20 to 300 s	85
124.	Differential pressure in intact loop (DI-13V-1A), from -6 to 42 s	85

507 059

125.	Differential pressure in intact loop (DI-1A-6), from -20 to 300 s	86
126.	Differential pressure in intact loop (DI-1A-6), from -6 to 42 s	86
127.	Differential pressure in intact loop (DI-6-7), from -20 to 300 s	87
128.	Differential pressure in intact loop (DI-6-7), from -6 to 42 s	87
129.	Differential pressure in intact loop steam generator, inlet plenum to outlet plenum (DI-SGI-SGO), from -20 to 300 s	88
130.	Differential pressure in intact loop steam generator, inlet plenum to outlet plenum (DI-SGI-SGO), from -6 to 42 s	88
131.	Differential pressure in intact loop (DI-7-13), from -20 to 300 s	89
132.	Differential pressure in intact loop (DI-7-13), from -6 to 42 s	89
133.	Differential pressure in intact loop (DI-13-15), from -20 to 300 s	90
134.	Differential pressure in intact loop (DI-13-15), from -6 to 42 s	90
135.	Differential pressure in intact loop (DI-15-17A), from -20 to 300 s	91
136.	Differential pressure in intact loop (DI-15-17A), from -6 to 42 s	91
137.	Differential pressure in intact loop (DI-17A-DIA), from -20 to 300 s	92
138.	Differential pressure in intact loop (DI-17A-DIA), from -6 to 42 s	92
139.	Differential pressure in broken loop (DB-13V-20B), from -20 to 300 s	93
140.	Differential pressure in broken loop (DB-13V-20B), from -6 to 42 s	93
141.	Differential pressure in broken loop (DB-20B-21), from -20 to 300 s	94
142.	Differential pressure in broken loop (DB-20B-21), from -6 to 42 s	94
143.	Differential pressure in broken loop (DB-21-27A), from -20 to 300 s	95
144.	Differential pressure in broken loop (DB-21-27A), from -6 to 42 s	95
145.	Differential pressure in broken loop steam generator (DB-SGI-SGO), from -20 to 300 s	96
146.	Differential pressure in broken loop steam generator (DB-SGI-SGO), from -6 to 42 s	96
147.	Differential pressure in broken loop (DB-27A-37A), from -20 to 300 s	97
148.	Differential pressure in broken loop (DB-27A-37A), from -6 to 42 s	97
149.	Differential pressure in broken loop (DB-37A-40B), from -20 to 300 s	98

150.	Differential pressure in broken loop (DB-37A-40B), from -6 to 42 s	98
151.	Differential pressure in broken loop (DB-37A-40L), from -20 to 300 s	99
152.	Differential pressure in broken loop (DB-37A-40I), from -6 to 42 s	99
153.	Differential pressure in broken loop (DB-40B-43A), from -20 to 300 s	100
154.	Differential pressure in broken loop (DB-40B-43A), from -6 to 42 s	100
155.	Differential pressure in broken loop (DB-40B-45A), from -20 to 300 s	101
156.	Differential pressure in broken loop (DB-40B-45A), from -6 to 42 s	101
157.	Differential pressure in broken loop (DB-45A-43), from -20 to 300 s	102
158.	Differential pressure in broken loop (DB-45A-43), from -6 to 42 s	102
159.	Differential pressure in broken loop (DB-45A-D1A), from -20 to 300 s	103
160.	Differential pressure in broken loop (DB-45A-D1A), from -6 to 42 s	103
161.	Differential pressure in downcomer (DD-D1A-13A), from -20 to 300 s	104
162.	Differential pressure in downcomer (DD-D1A-13A), from -6 to 42 s	104
163.	Differential pressure in downcomer (DD-D1A-170), from -20 to 300 s	105
164.	Differential pressure in downcomer (DD-D1A-170), from -6 to 42 s	105
165.	Differential pressure in downcomer (DD-D1A-578), from -20 to 300 s	106
166.	Differential pressure in downcomer (DD-D1A-578), from -6 to 42 s	106
167.	Differential pressure in downcomer (DD-170-435), from -20 to 300 s	107
168.	Differential pressure in downcomer (DD-170-435), from -6 to 42 s	107
169.	Differential pressure in downcomer (DD-435-578), from -20 to 300 s	108
170.	Differential pressure in downcomer (DD-435-578), from -6 to 42 s	108
171.	Differential pressure in vessel (DV-578-501), from -20 to 300 s	109
172.	Differential pressure in vessel (DV-578-501), from -6 to 42 s	109
173.	Differential pressure in vessel (DV-578-13), from -20 to 300 s	110
174.	Differential pressure in vessel (DV-578-13), from -6 to 42 s	110
175.	Differential pressure in vessel (DV-501-442), from -20 to 300 s	111
176.	Differential pressure in vessel (DV-501-442), from -6 to 42 s	111

177.	Differential pressure in vessel (DV-501-105), from -20 to 300 s	112
178.	Differential pressure in vessel (DV-501-105), from -6 to 42 s	112
179.	Differential pressure in vessel (DV-501-13A), from -20 to 300 s	113
180.	Differential pressure in vessel (DV-501-13A), from -6 to 42 s	113
181.	Differential pressure in vessel (DV-442-278), from -20 to 300 s	114
182.	Differential pressure in vessel (DV-442-278), from -6 to 42 s	114
183.	Differential pressure in vessel (DV-278-154), from -20 to 300 s	115
184.	Differential pressure in vessel (DV-278-154), from -6 to 42 s	115
185.	Differential pressure in vessel (DV-105-13), from -20 to 300 s	116
186.	Differential pressure in vessel (DV-105-13), from -6 to 42 s	116
187.	Differential pressure in vessel (DV - 421 - 154), from -20 to 300 s	117
188.	Differential pressure in vessel (DV - 421 - 154), from -6 to 42 s	117
189.	Differential pressure in vessel (DV - 159-105), from -20 to 300 s	118
190.	Differential pressure in vessel (DV - 159-105), from -6 to 42 s	118
191.	Differential pressure in vessel (DV - 154-105), from -20 to 300 s	119
192.	Differential pressure in vessel (DV - 154-105), from -6 to 42 s	119
193.	Differential pressure in vessel ECC accumulator (DV-ACC1-LL), from -20 to 300 s	120
194.	Differential pressure in vessel ECC accumulator (DV-ACC1-LL), from -6 to 42 s	120
195.	Differential pressure in intact loop steam generator, secondary side liquid level (DI-SG-LL), from -20 to 300 s	121
196.	Differential pressure in intact loop steam generator, secondary side liquid level (DI-SG-LL), from -6 to 42 s	121
197.	Differential pressure in broken loop steam generator, secondary liquid level (DB-SS1-SS4), from -20 to 300 s	122
198.	Differential pressure in broken loop steam generator, secondary liquid level (DB-SS1-SS4), from -6 to 42 s	122
199.	Volumetric flow in intact loop (FI-1 and FI-11), from -20 to 300 s	123
200.	Volumetric flow in intact loop (FI-1 and FI-11), from -6 to 42 s	123
201.	Volumetric flow in intact loop (FI-16 and FI-17), from -20 to 300 s	124

202.	Volumetric flow in intact loop (FI-16 and FI-17), from -6 to 42 s	124
203.	Volumetric flow in broken loop (FB-20 and FB-37), from -20 to 300 s	125
204.	Volumetric flow in broken loop (FB-20 and FB-37), from -6 to 42 s	125
205.	Volumetric flow in broken loop (FB-40 and FB-45), from -20 to 300 s	126
206.	Volumetric flow in broken loop (FB-40 and FB-45), from -6 to 42 s	126
207.	Volumetric flow in downcomer (FD-424), from -20 to 300 s	127
208.	Volumetric flow in downcomer (FD-424), from -6 to 42 s	127
209.	Volumetric flow in vessel upper plenum (FV + 1), from -20 to 300 s	128
210.	Volumetric flow in vessel upper plenum (FV + 1), from -6 to 42 s	128
211.	Volumetric flow in vessel, high pressure injection system (FV-HPIS), from -20 to 300 s	129
212.	Volumetric flow in vessel, high pressure injection system (FV-HPIS), from -6 to 42 s	129
213.	Volumetric flow in vessel, low pressure injection system (FV-LPIS), from -20 to 300 s	130
214.	Volumetric flow in vessel, low pressure injection system (FV-LPIS), from -6 to 42 s	130
215.	Volumetric flow in vessel, ECC accumulator (FV-ACC1), from -20 to 300 s	131
216.	Volumetric flow in vessel, ECC accumulator (FV-ACC1), from -6 to 42 s	131
217.	Volumetric flow in intact loop, pressurizer surge line (FI-PRIZE), from -20 to 300 s	132
218.	Volumetric flow in intact loop, pressurizer surge line (FI-PRIZE), from -6 to 42 s	132
219.	Momentum flux in broken loop (NB-20), from -20 to 300 s	133
220.	Momentum flux in broken loop (NB-20), from -6 to 42 s	133
221.	Momentum flux in broken loop (NB-40), from -20 to 300 s	134
222.	Momentum flux in broken loop (NB-40), from -6 to 42 s	134
223.	Momentum flux in broken loop (NB-45), from -20 to 300 s	135
224.	Momentum flux in broken loop (NB-45), from -6 to 42 s	135
225.	Momentum flux in core outlet (NV-9), from -20 to 300 s	136
226.	Momentum flux in core outlet (NV-9), from -6 to 42 s	136

227.	Momentum flux in core inlet (NV-499), from -20 to 300 s	137
228.	Momentum flux in core inlet (NV-499), from -6 to 42 s	137
229.	Density in intact loop (GI-1T and GI-1B), from -20 to 300 s	138
230.	Density in intact loop (GI-1T and GI-1B), from -6 to 42 s	138
231.	Density in intact loop (GI-1C), from -20 to 300 s	139
232.	Density in intact loop (GI-1C), from -6 to 42 s	139
233.	Density in intact loop (GI-5VR), from -20 to 300 s	140
234.	Density in intact loop (GI-5VR), from -6 to 42 s	140
235.	Density in intact loop (GI-13T and GI-13B), from -20 to 300 s	141
236.	Density in intact loop (GI-13T and GI-13B), from -6 to 42 s	141
237.	Density in intact loop (GI-13C), from -20 to 300 s	142
238.	Density in intact loop (GI-13C), from -6 to 42 s	142
239.	Density in intact loop (GI-17T and GI-17B), from -20 to 300 s	143
240.	Density in intact loop (GI-17T and GI-17B), from -6 to 42 s	143
241.	Density in intact loop (GI-17C), from -20 to 300 s	144
242.	Density in intact loop (GI-17C), from -6 to 42 s	144
243.	Density in broken loop (GB-20VR), from -20 to 300 s	145
244.	Density in broken loop (GB-20VR), from -6 to 42 s	145
245.	Density in broken loop (GB-37), from -20 to 300 s	146
246.	Density in broken loop (GB-37), from -6 to 42 s	146
247.	Density in broken loop (GB-40VR), from -20 to 300 s	147
248.	Density in broken loop (GB-40VR), from -6 to 42 s	147
249.	Density in broken loop (GB-45VR), from -20 to 300 s	148
250.	Density in broken loop (GB-45VR), from -6 to 42 s	148
251.	Density in downcomer (GD-72B), from -20 to 300 s	149
252.	Density in downcomer (GD-72B), from -6 to 42 s	149
253.	Density in downcomer (GD-260B), from -20 to 300 s	150

254.	Density in downcomer (GD-260B), from -6 to 42 s	150
255.	Density in downcomer (GD-456B), from -20 to 300 s	151
256.	Density in downcomer (GD-456B), from -6 to 42 s	151
257.	Density in vessel (GV - 339), from -20 to 300 s	152
258.	Density in vessel (GV - 339), from -6 to 42 s	152
259.	Density in vessel (GV - 174), from -20 to 300 s	153
260.	Density in vessel (GV - 174), from -6 to 42 s	153
261.	Density in vessel (GV-11), from -20 to 300 s	154
262.	Density in vessel (GV-11), from -6 to 42 s	154
263.	Density in vessel (GV-154-23 and GV-164-AB), from -20 to 300 s	155
264.	Density in vessel (GV-154-23 and GV-164-AB), from -6 to 42 s	155
265.	Density in vessel (GV-243-23), from -20 to 300 s	156
266.	Density in vessel (GV-243-23), from -6 to 42 s	156
267.	Density in vessel (GV-313-23 and GV-323-AB), from -20 to 300 s	157
268.	Density in vessel (GV-313-23 and GV-323-AB), from -6 to 42 s	157
269.	Density in vessel (GV-383-23), from -20 to 300 s	158
270.	Density in vessel (GV-383-23), from -6 to 42 s	158
271.	Density in vessel (GV-483-23), from -20 to 300 s	159
272.	Density in vessel (GV-483-23), from -6 to 42 s	159
273.	Density in vessel (GV-528-588), from -20 to 300 s	160
274.	Density in vessel (GV-528-588), from -6 to 42 s	160
275.	Density in vessel (GV-546-23), from -20 to 300 s	161
276.	Density in vessel (GV-546-23), from -6 to 42 s	161
277.	Density in intact loop pressurizer (GI-PRIZE), from -20 to 300 s	162
278.	Density in intact loop pressurizer (GI-PRIZE), from -6 to 42 s	162
279.	Mass flow in intact loop (FI-1 and GI-1C), from -20 to 300 s	163
280.	Mass flow in intact loop (FI-1 and GI-1C), from -6 to 42 s	163

281.	Mass flow in intact loop (FI-16 and GI-17C), from -20 to 300 s	164
282.	Mass flow in intact loop (FI-16 and GI-17C), from -6 to 42 s	164
283.	Mass flow in intact loop (FI-17 and GI-17C), from -20 to 300 s	165
284.	Mass flow in intact loop (FI-17 and GI-17C), from -6 to 42 s	165
285.	Mass flow in broken loop (FB-20 and GB-20VR), from -20 to 300 s	166
286.	Mass flow in broken loop (FB-20 and GB-20VR), from -6 to 42 s	166
287.	Mass flow in broken loop (NB-20 and GB-20VR), from -20 to 300 s	167
288.	Mass flow in broken loop (NB-20 and GB-20VR), from -6 to 42 s	167
289.	Mass flow in broken loop (FB-37 and GB-37), from -20 to 300 s	168
290.	Mass flow in broken loop (FB-37 and GB-37), from -6 to 42 s	168
291.	Mass flow in broken loop (FB-40 and GB-40VR), from -20 to 300 s	169
292.	Mass flow in broken loop (FB-40 and GB-40VR), from -6 to 42 s	169
293.	Mass flow in broken loop (NB-40 and GB-40VR), from -20 to 300 s	170
294.	Mass flow in broken loop (NB-40 and GB-40VR), from -6 to 42 s	170
295.	Mass flow in broken loop (FB-45 and GB-45), from -20 to 300 s	171
296.	Mass flow in broken loop (FB-45 and GB-45), from -6 to 42 s	171
297.	Mass flow in broken loop (NB-45 and GB-45), from -20 to 300 s	172
298.	Mass flow in broken loop (NB-45 and GB-45), from -6 to 42 s	172
299.	Mass flow in downcomer (FD-424 and GD-456B), from -20 to 300 s	173
300.	Mass flow in downcomer (FD-424 and GD-456B), from -6 to 42 s	173
301.	Mass flow in vessel (FV-1, GV-11), from -20 to 300 s	174
302.	Mass flow in vessel (FV-1, GV-11), from -6 to 42 s	174
303.	Mass flow in vessel (NV-9 and GV-11), from -20 to 300 s	175
304.	Mass flow in vessel (NV-9 and GV-11), from -6 to 42 s	175
305.	Mass flow in vessel (NV-499 and GV-483-23), from -20 to 300 s	176
306.	Mass flow in vessel (NV-499 and GV-483-23), from -6 to 42 s	176
307.	Core heater high power bus amperage (AH-HI), from -20 to 300 s	177

308.	Core heater high power bus amperage (AH-HI), from -6 to 42 s	177
309.	Core heater high power bus voltage (VH-HI), from -20 to 300 s	178
310.	Core heater high power bus voltage (VH-HI), from -6 to 42 s	178
311.	Core heater low power bus amperage (AH-LO), from -20 to 300 s	179
312.	Core heater low power bus amperage (AH-LO), from -6 to 42 s	179
313.	Core heater low power bus voltage (VH-LO), from -20 to 300 s	180
314.	Core heater low power bus voltage (VH-LO), from -6 to 42 s	180
315.	Intact loop pump speed (SI-PUMP), from -20 to 300 s	181
316.	Intact loop pump speed (SI-PUMP), from -6 to 42 s	181
317.	Broken loop pump speed (SB-PUMP), from -20 to 300 s	182
318.	Broken loop pump speed (SB-PUMP), from -6 to 42 s	182
319.	Broken loop pump power (WB-PUMP), from -20 to 300 s	183
320.	Broken loop pump power (WB-PUMP), from -6 to 42 s	183
B-1.	Geometry used for processing of density data obtained from two-beam gamma densitometers	195
C-1.	Fluid temperature in intact loop hot leg (TFI-1)	206
C-2.	Fluid temperature in broken loop (TFB-20)	206
C-3.	Fluid temperature in downcomer (TFD-294)	207
C-4.	Fluid temperature in vessel (TFV-578A)	207
C-5.	Fluid temperature in vessel (TIFV + 79D)	208
C-6.	Fluid temperature in core, Grid Spacer 5 (TFG-5AB-45)	208
C-7.	Material temperature in intact loop hot leg (TMI-1T16)	209
C-8.	Material temperature in broken loop hot leg (TMB-20B16)	209
C-9.	Material temperature in downcomer (TMD-364)	210
C-10.	Material temperature in vessel (TMV + 79D)	210
C-11.	Core heater temperature, Rod C-2 (TH-C2-8)	211
C-12.	Core heater temperature, Rod C-2 (TH-C2-180)	211
C-13.	Pressure in intact loop cold leg (PI-16)	212

C-14. Pressure in broken loop cold leg (PB-45A)	212
C-15. Pressure in vessel accumulator (PV-ACC1)	213
C-16. Pressure in broken loop steam generator, secondary side steam dome (PB-SD)	213
C-17. Differential pressure in intact loop (DI-6-7)	214
C-18. Differential pressure in intact loop (DI-7-13)	214
C-19. Differential pressure in broken loop (DB-37A-40L)	215
C-20. Differential pressure in downcomer (DD-DIA-578)	215
C-21. Differential pressure in vessel (DV-501-105)	216
C-22. Differential pressure in intact loop steam generator, secondary side liquid level (DI-SG-LI)	216
C-23. Volumetric flow in intact loop (FI-1)	217
C-24. Volumetric flow in intact loop (FI-17)	217
C-25. Volumetric flow in broken loop (FB-45)	218
C-26. Volumetric flow in downcomer (FD-424)	218
C-27. Volumetric flow in vessel upper plenum (FV + 1)	219
C-28. Volumetric flow in vessel lower plenum, low pressure injection system (FV-LPIS)	219
C-29. Density in intact loop (GI-1T)	220
C-30. Density in intact loop (GI-1B)	220
C-31. Density in intact loop (GI-1C)	221
C-32. Density in intact loop (GI-17T)	221
C-33. Density in intact loop (GI-17B)	222
C-34. Density in intact loop (GI-17C)	222
C-35. Density in broken loop (GB-45VR)	223
C-36. Density in vessel (GV-11)	223
C-37. Mass flow in intact loop (FI-1 and GI-1C)	224
C-38. Mass flow in intact loop (FI-17 and GI-17C)	224
C-39. Mass flow in broken loop (FB-45 and GB-45VR)	225
C-40. Mass flow in vessel (FV + 1 and GV-11)	225

TABLES

I.	Conditions at Blowdown Initiation	6
II.	Primary Coolant Temperature Distribution Prior to Rupture	7
III.	Sequence of Events During Test S-07-9	8
IV.	Data Presentation for Semiscale Mod-3 Test S-07-9	18
B-I.	Constants for Differential Pressure Measurement Correction	192
C-I.	Random Uncertainty Standard Deviation	201
C-II.	General Measurement Engineering Uncertainty Sources and Uncertainty Values	226
C-III.	Time Periods When Flow Regime Uncertainties Were Applied	231

507 069

EXPERIMENT DATA REPORT FOR SEMISCALE MOD-3 LOWER PLENUM INJECTION TEST S-07-9 (BASELINE TEST SERIES)

I. INTRODUCTION

The Semiscale Mod-3 experiment represent the current phase of the Semiscale Program conducted by EG&G Idaho, Inc., for the United States Government. The program, which is sponsored by the Nuclear Regulatory Commission through the Department of Energy, is part of the overall program designed to investigate the response of a pressurized water reactor (PWR) system to a hypothesized loss-of-coolant accident (LOCA). The underlying objectives of the Semiscale Program are to quantify the physical processes controlling system behavior during a LOCA and to provide an experimental data base for assessing reactor safety evaluation models. The Semiscale Mod-3 Program has the further objective of providing support to other experimental programs in the form of instrumentation assessment, optimization of test series, selection of test parameters, and evaluation of test results.

Test S-07-9 was conducted March 21, 1979, in the Semiscale Mod-3 system as part of the baseline test series (Test Series 7). This series was designed to obtain thermal-hydraulic response data from blowdown, refill, and reflood transients in a simulated nuclear reactor having an electrically heated core. The specific objective of Test S-07-9 was to provide reference data to evaluate integral blowdown and reflood behavior during a 200% cold leg break with emergency core coolant (ECC) injection into the vessel lower plenum of the Mod-3 system. Hardware configuration and test parameters were selected to yield a system response that simulates the response of a PWR to a hypothesized LOCA blowdown transient.

The purpose of this report is to present the test data in an uninterpreted but readily usable form for use by the nuclear community in advance of detailed analysis and interpretation. Section II briefly describes the system configuration, procedures, and initial test conditions, and events that are applicable to Test S-07-9; Section III presents the data graphs and provides comments and supporting information necessary for interpretation of the data. A description of the overall Semiscale Program and test series, a more detailed description of the Semiscale Mod-3 system, and a description of the measurement and data processing techniques and uncertainties can be found in References 1 and 2.

II. SYSTEM, PROCEDURES, CONDITIONS, AND EVENTS FOR TEST S-07-9

The following system configuration, procedures, initial test conditions, and events are specific to Test S-07-9 as indicated.

1. SYSTEM CONFIGURATION AND TEST PROCEDURES

The Semiscale Mod-3 system used for the test consisted of a pressure vessel with simulated reactor internals, including a 25-rod core with 23 electrically heated rods and an external downcomer assembly; an intact loop with steam generator, pump, and pressurizer; a broken loop with steam generator, pump, and rupture assembly; high and low pressure injection pumps and coolant injection accumulator for the vessel lower plenum; and a pressure suppression system with a suppression tank, header, and steam supply system. The Semiscale Mod-3 experimental system configuration is described further in Reference 2. Figures 1 and 2 show the system configuration for the test.

For Test S-07-9, the nine center rods were powered 12.8% higher than the remaining 14 low powered rods, resulting in high and low power rod peak densities of 39.7 kW/m and 35.2 kW/m, respectively. The total core power was 2.00 MW. One rod (Rod E-5) was unpowered and another rod (Rod A-1) was replaced by a liquid level probe.

In preparation for the test, the system was filled with treated demineralized water and vented at strategic points to ensure a liquid-full system. Treated demineralized water in the steam generator feedwater tank was heated to 486 K, and the required levels were established in the steam generator secondary sides. The accumulator for the vessel lower plenum was filled with treated demineralized water, drained to specified initial levels, and pressurized with nitrogen to 6.92 MPa.^a Prior to warmup, the system was pressurized to check for leakage; system instrumentation was checked; and transducer readings were set to zero. Warmup to initial test conditions was accomplished with the heaters in the vessel core. During warmup, the purification and sampling systems were valved into the primary system to maintain water chemistry requirements and to provide a water sample at system conditions for subsequent analysis. At 50-K temperature intervals during warmup, detector readings were sampled to allow the integrity of the measurement instrumentation and the operability of the data acquisition system to be checked.

Prior to the initial core power level being established, the pressure suppression system was pressurized to 0.24 MPa with saturated steam from the steam supply system. After the core power was increased to 2.00 MW, initial test conditions were held for 607 s to establish equilibrium in the system. At the end of this period all auxiliary systems were isolated to prevent blowdown through those systems.

The system was successfully subjected to a simulated double-ended cold leg break through a rupture assembly and two blowdown nozzels having a total break area of 4.59 cm². Pressure to operate the rupture assembly and initiate blowdown was taken from an accumulator system filled with water and pressurized to 15.6 MPa with gaseous nitrogen. Immediately (within 0.02 s) after initiation for blowdown, the lines to the accumulator were again isolated. The effluent was ejected from the primary system into the pressure suppression system which was vented to maintain a constant pressure of 0.243 MPa. At blowdown, power to the primary coolant circulation pump was reduced and the pump was allowed to coast down to a speed of 130 rad/s which was maintained for the duration of the test. During the blowdown transient, power to the electrically heated core was automatically controlled to simulate the thermal response of nuclear heated fuel rods.

a. All pressures are presented as absolute values.

3




Fig. 1. Steam-to-steam heat exchanger for condenser break configuration - schematic




Fig. 1 Semiscale Mod-3 system for cold leg break configuration — isometric.

POOR ORIGINAL

507 073
~~507 072~~

For Test S-07-9, the coolant injection systems were arranged to discharge into the vessel lower plenum. The high pressure coolant injection pumps were started at initiation of blowdown with coolant injection starting at a pressure of 12.41 MPa, and continued running (as pressure decreased) to the end of the test (350 s). Low pressure coolant injection was initiated 34.5 s after blowdown at a system pressure of 1.10 MPa and was continued until test termination (350 s). Coolant injection from the vessel accumulator (CI-T-1) started 8.5 s after blowdown, and was terminated 46 s after blowdown. Total volume of coolant injected into the vessel from the accumulator was 44.5 l. Nitrogen from the accumulator was not discharged into the vessel lower plenum.

2. INITIAL TEST CONDITIONS AND SEQUENCE OF EVENTS

Conditions in the Semiscale Mod-3 system at initiation of blowdown are given in Tables I and II and the sequence of events relative to rupture is given in Table III.

TABLE I
CONDITIONS AT BLOWDOWN INITIATION

	<u>Test S-07-9</u>	
	<u>Measured^a</u>	<u>Specified</u>
Core power (MW)	2.00	2.0 \pm 0.05
System pressure (MPa)	16.09	15.51 \pm 0.17
Intact loop cold leg fluid temperature (K)	559	557 \pm 1
Broken loop cold leg fluid temperature (K)	555	557 \pm 1
Intact loop hot leg to cold leg temperature differential (K)	35	37 \pm 1
Broken loop hot leg to cold leg temperature differential (K)	39	37 \pm 1
Intact loop cold leg flow (1/s)	9.05	b
Broken loop cold leg flow (1/s)	2.60	b
Steam generator feedwater temperature ^c (K)	486	497 \pm 6
Intact loop steam generator liquid level (cm) (above top of tube sheet)	287	295 \pm 5
Broken loop steam generator liquid level (cm) (above top of tube sheet)	1,047	996 \pm 5
Pressure suppression tank pressure (MPa)	0.244	0.241 \pm 0.007
Pressure suppression tank temperature (K)	298	297 \pm 1

a. Measured initial conditions are taken from digital acquisition system read just prior to blowdown initiation. Those measured conditions which did not meet the specified conditions were considered acceptable.

b. Flow is not specified, since it must be adjusted to achieve the required differential temperature across the core.

c. One source of feedwater for both intact and broken loops.

TABLE II
 PRIMARY COOLANT TEMPERATURE DISTRIBUTION
 PRIOR TO RUPTURE^a

	Test S-07-9	
	Detector	Temperature (K)
Vessel lower plenum (bottom of lower plenum)	TFV-572W	555
Vessel lower plenum (top of lower plenum)	TFV-552A	555
Intact loop hot leg (near vessel)	RFI-2	594
Broken loop hot leg (near vessel)	RFB-20	594
Intact loop cold leg (near pump inlet)	TFI-11	555
Broken loop cold leg (near pump inlet)	TFB-37	559
Intact loop cold leg (near downcomer)	RFI-17	559
Broken loop cold leg (near downcomer)	RFB-45	555
Vessel upper head (middle)	TFV+221Q	555
Downcomer (top)	TFD-18F	558
Downcomer (middle)	TFD-294	559
Downcomer (bottom)	TFD-435	559

a. Average of data taken from -5 s to -0.5 s prior to blowdown initiation.

TABLE III
 SEQUENCE OF EVENTS DURING TEST S-07-9^a

Event	Time Relative To Rupture (s)
Core power level established	-607
Makeup pump and pressurizer heaters off	-2.5
Intact and broken loop steam generator feedwater and discharge valves closed	-1
Intact and broken loop pump controls initiated	0
High pressure injection system flow started	0
Core power decay transient started	2.5
ECC accumulator vessel lower plenum flow started	8.5
Low pressure injection system flow started ^b	34.5
Broken loop pump power terminated	350
Core power terminated	350

a. A time controlled sequencer was used to control critical events during the test.

b. Injection from high and low pressure injection system pumps and ECC accumulators did not start until system pressure dropped below preset pump or accumulator pressure, respectively.


III. DATA PRESENTATION

The data from Semiscale Mod-3 Test S-07-9 are presented with brief comment. Processing analysis has been performed only to the extent necessary to obtain appropriate engineering units and to ensure that the data are reasonable and consistent. In all cases, in converting transducer output to engineering units, a homogeneous fluid was assumed. Further interpretation and analysis should consider that sudden decompression processes such as those occurring during blowdown may have subjected the measurement devices to nonhomogeneous fluid conditions.

The performance of the system during Test S-07-9 was monitored by 211 detectors. The data obtained were recorded on both digital and analog data acquisition systems. The analog system was used to provide redundant data. The long-term data (-20 to 300 s) presented in this report were recorded at an effective sample rate of 2.875 points per second. Short-term data (-6 to 42 s) were recorded at an effective sample rate of 19.16 points per second.

The data are presented in some instances in the form of composite graphs to facilitate comparison of the values of given variables at several locations. The scales selected for the graphs do not reflect the obtainable resolution of the data. (The data processing techniques are described further in Reference 2 and Appendix A.)

Figures 3 through 10 and Table IV provide supporting information for interpretation of the data graphs shown in Figures 11 through 320 and provide relative locations of all detectors used during Test S-07-9. Table III groups the measurements according to measurement type, identifies the specific measurement location and range of the detector and actual recording range of the data acquisition system, provides brief comments regarding the data, and references the measurements and comments to the corresponding figure. Figures 11 through 320 present all the blowdown data obtained. Time zero on the graphs is the time of rupture initiation. Appendix A provides information explaining the data acquisition system capabilities. Appendix B explains posttest data processing for data conversion into engineering units and data adjustments. Appendix C presents an analysis of selected data which provide a guide to the uncertainty associated with data measurements in the Semiscale Mod-3 system.



POOR ORIGINAL

Fig. 3 Semiscale Mod-3 system and instrumentation for cold leg break configuration — isometric.




Fig. 5 Semiscale Mod-3 pressure vessel and downcomer - cross section showing instrumentation

507 081





Fig. 6 Semiscale Mod-3 pressure vessel — isometric showing instrumentation.

POOR ORIGINAL



POOR ORIGINAL

Fig. 7 Semiscale Mod-3 pressure vessel — penetrations and instrumentation.

507 083






Fig. 8 Semiscale Mod-3 downcomer — isometric showing instrumentation.

POOR ORIGINAL









POOR ORIGINAL

Test S-07-9
INEL A 9205

Fig. 9 Semiscale Mod-3 downcomer — penetrations and instrumentation.

507 085



-  Unpowered rod
-  Powered rod
-  Liquid level probe
-  Thermocouple location
-  Elevation of thermocouple above bottom of core-heated length (cm)

Test S-07-9
NE-A 90°

Fig. 10 Semiscale Mod-7 heater core — plan view.

TABLE IV

DATA PRESENTATION FOR SEMISCALE MOD-3 TEST S-07-9

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
COOLANT TEMPERATURE					
Chrome-Alumel thermocouples unless specified otherwise.					
Hot Leg		0 to 1533 K	0 to 820 K		
TK1-1	Hot leg, Spool 1, 30 cm from vessel center.			15,12	
TK1-2	Hot leg, Spool 2, 99 cm from vessel center, 10 cm upstream of hot leg injection port (platinum resistance bulb).	0 to 811 K	0 to 811 K	15,12	Temperature data applicable only for initial conditions. Transient temperature is to be used for trend only.
TK1-3	Cold leg, Spool 11, 438 cm from downcomer center.			15,14	Data appear normal, but data acquisition system noise caused a stepping of 1/57 of full scale.
TK1-7	Cold leg, Spool 17, 92 cm from downcomer center, 7 cm upstream of cold leg injection port (platinum resistance bulb).	0 to 811 K	0 to 811 K	15,14	Temperature data applicable only for initial conditions. Transient temperature is to be used for trend only.
TK1-11	Cold leg, Spool 13, 60 cm from downcomer center.			15,16	
Cold Leg		0 to 1533 K	0 to 820 K		
TK2-20	Hot leg, Spool 20, 73 cm from vessel center, 14 cm downstream of hot leg injection port (platinum resistance bulb).	0 to 811 K	0 to 811 K	15,18	Temperature data applicable only for initial conditions. Transient temperature is to be used for trend only.
TK2-22	Hot leg, Spool 20, 84 cm from vessel center, 25 cm downstream of hot leg injection port.			15,18	
TK2-31	Cold leg, Spool 31, 348 cm from downcomer center.			19,20	Data appear normal, but data acquisition system noise caused a stepping of 1/57 of full scale.
TK2-40	Cold leg, Spool 40, 220 cm from downcomer center, 16 cm downstream of cold leg injection port.				Detector failed.
TK2-45	Cold leg, Spool 45, 89 cm from downcomer center (platinum resistance bulb).	0 to 811 K	0 to 811 K	21,22	Temperature data applicable only for initial conditions. Transient temperature is to be used for trend only.
TK2-47	Cold leg, Spool 45, 18 cm from downcomer center.			21,22	
Downcomer		0 to 1533 K	0 to 820 K		
TKD-189	In downcomer inlet annulus, 18 cm below hot leg centerline at 75°.			23,24	
TKD-1-2	In downcomer extension, 152 cm below cold leg centerline.			23,24	
TKD-234	In downcomer extension, 294 cm below cold leg centerline.			23,24	
TKD-364	In downcomer extension, 364 cm below cold leg centerline.			23,24	
TKD-415	In downcomer instrument spool, 415 cm below cold leg centerline.			23,24	
Vessel		0 to 1533 K	0 to 820 K		
Vessel Upper Plenum					
TKV-210	In vessel upper head filler, 211 cm above cold leg centerline at 225°.			25,26	
TKV-31	In vessel, 31 cm below cold leg centerline.			25,28	
TKV-618	In vessel, 63 cm below cold leg center at 240°.			25,28	
Vessel Lower Plenum					
TKV-752A	On thermocouple rack in vessel lower plenum 552 cm below cold leg centerline at 0°.			29,30	
TKV-572W	In vessel lower plenum, 572 cm below cold leg centerline at 315°.			29,30	

POOR ORIGINAL

507 087

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^b		Figure ^a	Measurement Comments ^b
		Detector	System		
MATERIAL TEMPERATURE					
Chromel-Alumel thermocouples unless specified otherwise.					
<u>Hot Leg</u>					
TMI-1716	Hot leg, Spool 1, top, 1.6 cm from pipe inside diameter (ID) 68 cm from vessel center.	0 to 1533 K	0 to 820 K	53,54	
TMI-17316	Cold leg, Spool 17, side, 1.6 cm from pipe ID, 68 cm from downcomer center.			53,54	
<u>Breaker Loop</u>					
TMB-20816	Hot leg, Spool 20, bottom, 1.6 cm from pipe ID, 91 cm from vessel center.	0 to 1533 K	0 to 820 K	55,56	
TMB-40816	Cold leg, Spool 40, bottom, 1.6 cm from pipe ID, 207 cm from downcomer center.			57,58	
TMB-47816	Cold leg, Spool 45, bottom, 1.6 cm from pipe ID, 48 cm from downcomer center.			57,58	
<u>Downcomer</u>					
		0 to 1533 K	0 to 820 K		Data appear normal, but data acquisition system noise caused a stepping of 1.5% of full scale.
TMD-188	On downcomer inlet annulus, 18 cm below cold leg centerline at 257°.			59,60	
TMD-152	On downcomer extension, 152 cm below cold leg centerline.			59,60	
TMD-294	On downcomer extension, 294 cm below cold leg centerline.				Detector failed.
TMD-364	On downcomer extension, 364 cm below cold leg centerline.			59,60	
<u>Downcomer Insulator</u>					
		0 to 1533 K	0 to 820 K		
TIMD-188	On downcomer inlet annulus insulator, 18 cm below cold leg centerline at 257°.			61,62	
TIMD-152	On downcomer extension insulator, 152 cm below cold leg centerline.			61,62	
TIMD-294	On downcomer extension insulator, 294 cm below cold leg centerline.			61,62	
TIMD-364	On downcomer extension insulator, 364 cm below cold leg centerline.			61,62	
<u>Vessel</u>					
		0 to 1533 K	0 to 820 K		
TMV-7218	In vessel on upper head filler, 221 cm above cold leg centerline at 358°.			63,64	
TMV-790	In vessel on upper plenum upper filler, 79 cm above cold leg centerline at 457°.			63,64	
<u>Guide Tube</u>					
		0 to 1533 K	0 to 820 K		
TOMV-280	On guide tube, 280 cm above cold leg centerline.			65,66	
TOMV-61	On guide tube, 61 cm below cold leg centerline.			65,66	
<u>Steam Generator</u>					
		0 to 1533 K	0 to 820 K		
<u>Hot Leg</u>					
TW-50761	On a steam generator tube, 61 cm above bottom of tube sheet on OD of tube.			67,68	Data appear normal, but data acquisition system noise caused a stepping of 1.5% of full scale.
<u>Breaker Loop</u>					
		0 to 1533 K	0 to 820 K		
TMB-50734	On steam generator tube, 287 cm above bottom of tube sheet on OD of tube.			69,70	
HEATER					
Chromel-Alumel thermocouples.					
LOADING TEMPERATURE					
<u>High Power Heaters</u>					
		0 to 1533 K	0 to 1580 K		
TH-83-180	Heater at Column B, Row 3. Thermocouple 180 cm (2250°), 228 cm (2700°), and 353 cm (2100°) above bottom of heated length.			71,72	
TH-83-276				71,72	
TH-83-353				71,72	

POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
High Power Heaters (continued)					
TH-02-8	Heater at Column C, Row 2. Thermocouples 8 cm (285°), 184 cm (100°), 180 cm (225°), 237 cm (210°), and 321 cm (270°) above bottom of heated length.			73,74	
TH-02-184				73,74	
TH-02-180				73,74	
TH-02-237				73,74	
TH-02-321				73,74	
TH-03-29	Heater at Column C, Row 3. Thermocouples 49 cm (135°), 115 cm (165°), 184 cm (285°), 194 cm (225°), and 231 cm (90°) above bottom of heated length.			75,76	
TH-03-115				75,76	
TH-03-184				75,76	
TH-03-194				75,76	
TH-03-231				75,76	
TH-02-16	Heater at Column D, Row 2. Thermocouples at 78 cm (150°), 134 cm (135°), 181 cm (150°), 178 cm (165°), and 234 cm (155°) above bottom of heated length.			77,78	
TH-02-184				77,78	
TH-02-186				77,78	
TH-02-179				77,78	
TH-02-234				77,78	
TH-02-71	Heater at Column D, Row 3. Thermocouples 71 cm (135°), 132 cm (100°), 171 cm (120°), and 226 cm (120°) above bottom of heated length.			79,80	
TH-02-132				79,80	
TH-02-171				79,80	
TH-02-226				79,80	
Low Power Heaters		0 to 1531 k	0 to 1580 k		
TH-04-108	Heater at Column A, Row 3. Thermocouples 108 cm (165°), 228 cm (135°), and 281 cm (180°) above bottom of heated length.			81,82	
TH-04-228				81,82	
TH-04-281				81,82	
TH-04-66	Heater at Column A, Row 4. Thermocouples 46 cm (185°), 108 cm (225°), 181 cm (200°), and 181 (210°) above bottom of heated length.			81,84	
TH-04-108				81,84	
TH-04-181				81,84	
TH-04-181				81,84	
TH-05-164	Heater at Column A, Row 5. Thermocouples 164 cm (200°), 179 (180°), and 252 cm (165°), above bottom of heated length.			83,86	
TH-05-179				83,86	
TH-05-252				83,86	
TH-05-252				83,86	
TH-01-721	Heater at Column B, Row 1. Thermocouple 721 cm (270°) above bottom of heated length.			87,88	
TH-01-178	Heater at Column B, Row 3. Thermocouples 178 cm (130°) and 231 (270°) above bottom of heated length.			89,90	
TH-01-231				89,90	
TH-05-137	Heater at Column B, Row 5. Thermocouples 137 cm (25°), 179 cm (180°), 234 cm (145°), and 321 cm (175°) above bottom of heated length.			91,92	
TH-05-179				91,92	
TH-05-234				91,92	
TH-05-321				91,92	
TH-01-252	Heater at Column E, Row 1. Thermocouples 252 cm (120°), and 321 cm (180°) above bottom of heated length.			93,94	
TH-01-321				93,94	
TH-02-109	Heater at Column E, Row 2. Thermocouples 109 cm (30°), 190 cm (130°), and 193 cm (180°) above bottom of heated length.			95,96	
TH-02-190				95,96	
TH-02-193				95,96	
TH-03-134	Heater at Column E, Row 3. Thermocouples 134 cm (135°), 201 cm (130°), 221 (80°), and 290 cm (130°) above bottom of heated length.			97,98	
TH-03-201				97,98	
TH-03-221				97,98	
TH-03-290				97,98	
TH-04-180	Heater at Column E, Row 4. Thermocouples 180 cm (80°) and 254 cm (125°) above bottom of heated length.			99,100	
TH-04-254				99,100	
TH-05-227	Heater at Column E, Row 5. Thermocouple 227 cm (120°) above bottom of heated length.			101,102	
PREASTRESS					
Intact Loop					
PI-38	Cold leg, Spool 16, 144 cm from down-corer center (see off DR Exp).	0 to 17,237 MPa	0 to 20.19 MPa	103,104	
PI-174L	Cold leg, Spool 17, 60 cm from down-corer center (low range).	0 to 31447 MPa	0 to 3.45 MPa	103,104	Date acquisition system saturated to t = 21 s.
Broken Loop					
PB-208	Hot leg, Spool 20, 84 cm from axial center.	0 to 17,237 MPa	0 to 21.08 MPa	105,106	
PB-405	Cold leg, Spool 40, 209 cm from down-corer center.		0 to 21.96 MPa		

507 090
POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Broken Loop (continued)</u>					
PS-44-5A	Cold leg, Spool 44, downcomer side nozzle throat, 125 cm from downcomer center, OP.		0 to 20.85 MPa	109,110	
PS-45A	Cold leg, Spool 45, 90 cm from downcomer center, OP.		0 to 20.77 MPa	111,112	
<u>Vessel</u>					
PS-11	In vessel hot leg extension, 13 cm below cold leg centerline (see off OP tag).	0 to 17.237 MPa		113,114	
PS-42	In vessel, 92 cm below cold leg centerline.		0 to 20.67 MPa	113,114	
<u>PI System</u>					
PS-ACC1	In accumulator for vessel.	0 to 8.895 MPa	0 to 8.53 MPa	117,118	
<u>Steam Generator</u>					
<u>Intact Loop</u>					
PS-30	Intact loop steam generator, secondary side steam dome.		0 to 21.02 MPa	117,118	
<u>Broken Loop</u>					
PS-30	Broken loop steam generator, secondary side steam dome.		0 to 21.54 MPa	117,118	
<u>Pressurizer</u>					
PS-PK126	Pressurizer steam dome.	0 to 17.237 MPa	0 to 22.83 MPa	119,120	
<u>Pressure Suppression System</u>					
PS-PSS	Suppression tank top.	0 to 0.689 MPa	0 to 0.5 MPa	121,122	
<u>DIFFERENTIAL PRESSURE</u>					
Elevation difference between transducer taps is zero unless specified otherwise.					
<u>Intact Loop</u>					
DI-13V-1A	From vessel lower section of upper plenum, 13 cm below cold leg centerline to hot leg, Spool 1, 50 cm from vessel center. Lower upper plenum tap is 35 cm below Spool 1 tap.	+127 cm water	+16.78 kPa	123, 124	
DI-1A-6	Hot leg, Spool 1, 80 cm from vessel center to hot leg, Spool 6, 271 cm from vessel center.	+254 cm water	+33.76 kPa	123,124	
DI-6-7	Hot leg, Spool 6, 27 cm from vessel center to cold leg, Spool 7, 927 cm from downcomer center. Spool 6 tap is 47 cm above Spool 7 tap.	+345 kPa	+345 kPa	123,128	
DI-501-500	Intact loop steam generator, inlet plenum to outlet plenum, across primary side tubes.	+254 cm water	+33.49 kPa	129,130	
DI-7-13	Cold leg, Spool 7, 927 cm from downcomer center to primary pump suction, Spool 13, 332 cm from downcomer center.	+254 cm water	+33.42 kPa	131,132	
DI-15-15	Cold leg, Spool 15, 337 cm from downcomer center, across primary pump to cold leg, Spool 15, 175 cm from downcomer center. Spool 15 tap is 25 cm below Spool 15 tap.	+690 kPa	+690 kPa	133,134	
DI-15-17A	Cold leg, Spool 15, 175 cm from downcomer center, across cold leg injection port to cold leg, Spool 17, 60 cm from downcomer center.	+254 cm water	+34.0 kPa	135,136	
DI-17A-01A	Cold leg, Spool 17, 60 cm from downcomer to downcomer inlet annulus, 30 cm above cold leg centerline. Spool 17 tap is 30 cm below 01A tap.	+254 cm water	+33.6 kPa	137,138	
<u>Broken Loop</u>					
DI-13V-20B	In vessel from lower section of upper plenum, 13 cm below cold leg centerline to hot leg, Spool 20, 22 cm above cold leg centerline, 84 cm from vessel center. 13V tap is 35 cm below Spool 20 tap.	+762 cm water	+101 kPa	139,140	

POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^b		Figure ^c	Measurement Comments ^d
		Detector	System		
<u>Broken loop (continued)</u>					
DB-20B-21	Hot leg, Spool 20, 86 cm from vessel center to hot leg, Spool 21, 220 cm from vessel center.	+762 cm Water	+100 kPa	141,142	
DB-21-27A	Hot leg, Spool 21, 220 cm from vessel center in cold leg, Spool 27, 897 cm ix 4 cm above Spool 27A tap.	+361 kPa	+344 kPa	143,144	Data acquisition system saturated from $t = 0$ to $t = 2.2$ s, from $t = 5.0$ to 6.7 s, and from 8.3 to 15.8 s.
DB-501-500	Broken loop steam generator inlet leg, 582 cm from vessel center across primary side tubes to steam generator outlet leg, 951 cm from downcomer center. 501 tap is 72 cm above 500 tap.	+1380 kPa	+1381 kPa	145,146	
DB-37A-37A	Cold leg, Spool 37, 897 cm from downcomer center across broken loop pump extension to Spool 35, 348 cm from downcomer center. Spool 37 tap is 87 cm above Spool 37 tap.	+1370 cm Water	+170 kPa	147,148	
DB-37A-40B	Cold leg, Spool 37, broken loop pump inlet, 348 cm from downcomer center to cold leg, Spool 40 pump discharge, 209 cm from downcomer center. Spool 37 tap is 88 cm below Spool 40 tap.	+8895 kPa	+9223 kPa	149,150	
DB-37A-40C	Cold leg, Spool 37, broken loop pump inlet, 348 cm from downcomer center to cold leg, Spool 40 pump discharge, 209 cm from downcomer center. Spool 37 tap is 88 cm below Spool 40 tap (low range).	+890 kPa	+110 kPa	151,152	Data acquisition system saturated from $t = 0$ to $t = 35$ s.
DB-40B-43A	Cold leg, Spool 40 pump discharge, 209 cm from downcomer center across noncommunicative break nozzle and rupture assembly to cold leg, Spool 43, 180 cm from downcomer center.	+10 342 kPa	+13 799 kPa	153,154	Data acquisition system saturated from $t = 20$ to $t = 0$ s.
DB-40B-45A	Cold leg, Spool 40 pump discharge, 209 cm from downcomer center across noncommunicative break nozzle to cold leg, Spool 45, 89 cm from downcomer center.	+234 cm Water	+33.75 kPa	155,156	Data acquisition system saturated to $t = 0$ s.
DB-45A-43	Cold leg, Spool 45, 89 cm from downcomer across noncommunicative break nozzle to cold leg, Spool 43, 180 cm from downcomer center.	+10 342 kPa	+13 782 kPa	157,158	Data acquisition system saturated to $t = 0$ s.
DB-45A-01A	Cold leg, Spool 45, 89 cm from downcomer center to down-mer inlet annulus, 30 cm above cold leg centerline. Spool 45 tap is 30 cm below 01A tap.	+690 kPa	+690 kPa	159,160	
<u>Downcomer</u>					
DD-01A-15A	Downcomer inlet annulus, 30 cm above cold leg centerline to vessel lower upper plenum, 13 cm below cold leg centerline. Elevation difference between taps is 43 cm.	+345 kPa	+342 kPa	161,162	
DD-01A-170	Downcomer inlet annulus, 30 cm above cold leg centerline to downcomer extension, 170 cm below cold leg centerline. Elevation difference between taps is 200 cm.	+762 cm Water	+100 kPa	163,164	
DD-01A-578	Downcomer inlet annulus, 30 cm above cold leg centerline to vessel lower head, 578 cm below cold leg centerline. Elevation difference between taps is 608 cm.	+1370 cm Water	+174 kPa	165,166	
DD-170-435	Downcomer extension, 170 cm below cold leg centerline to downcomer instrumented spool piece, 435 cm below cold leg centerline. Elevation difference between taps is 265 cm.	+762 cm Water	+104 kPa	167,168	
DD-435-578	Downcomer instrumented spool piece, 435 cm below cold leg centerline to vessel lower head, 578 cm below cold leg centerline. Elevation difference between taps is 143 cm.	+254 cm Water	+33.54 kPa	169,170	

507 092
POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Downcomer (continued)</u>					
DV-578-501	Vessel lower head, 578 cm below cold leg centerline to lower core region, 501 cm below cold leg centerline. Elevation difference between taps is 77 cm.	+127 cm Water	+33.8 kPa	171,172	
DV-578-13	Vessel lower head, 578 cm below cold leg centerline to lower section of upper plenum, 13 cm below cold leg centerline. Elevation difference between taps is 565 cm.	+690 kPa	+687 kPa	171,174	
DV-501-442	Vessel lower core region, 501 cm below cold leg centerline to lower core region, 442 cm below cold leg centerline. Elevation difference between taps is 59 cm.	+254 cm Water	+34.2 kPa	175,176	
DV-501-105	Vessel lower core region, 501 cm below cold leg centerline to heater rod ground hub, 105 cm below cold leg centerline. Elevation difference between taps is 396 cm.	+762 cm Water	+107 kPa	177,178	
DV-501-134	Vessel lower plenum extension, 501 cm below cold leg centerline to lower upper plenum, 13 cm below cold leg centerline. Elevation difference between taps is 488 cm.	+345 kPa	+345 kPa	179,180	
DV-442-178	Vessel lower core region, 442 cm below cold leg centerline to mid-core region, 178 cm below cold leg centerline. Elevation difference between taps is 264 cm.	+1270 cm Water	+168.8 kPa	181,182	
DV-278-134	Vessel mid-core region, 278 cm below cold leg centerline to upper core region, 134 cm below cold leg centerline. Elevation difference between taps is 124 cm.	+1270 cm Water	+172 kPa	181,184	
DV-105-13	Heater rod ground hub, 105 cm below cold leg centerline to lower section of upper plenum, 13 cm below cold leg centerline. Elevation difference between taps is 92 cm.	+762 cm Water	+101 kPa	185,186	
DV-421-154	Vessel top head, 421 cm above cold leg centerline to core support tube, 154 cm above cold leg centerline. Elevation difference between taps is 267 cm.	+762 cm Water	+ 99.89 kPa	187,188	
DV-159-105	Lower section of vessel upper head extension, 159 cm above cold leg centerline to heater ground rod hub, 105 cm below cold leg centerline. Elevation difference between taps is 264 cm.	+2010 cm Water	+266.7 kPa	189,190	Data acquisition system saturated from 13.8 to 16.8 s.
DV-154-105	Core support tube, 154 cm above cold leg centerline to heater ground rod hub, 105 cm below cold leg centerline. Elevation difference between taps is 259 cm.	+762 cm Water	+102.8 kPa	191,192	Data acquisition system near or saturated from 15 to 16 s.
<u>ECC System</u>					
DV-ACC1-11	Top to bottom of vessel accumulator. Elevation difference between taps is 184 cm.	+762 cm Water	+104 kPa	193,194	
<u>Steam Generator</u>					
DI-60-11	Liquid level for intact loop steam generator. Elevation difference between taps is 206 cm.	+1270 cm Water	+166 kPa	195,196	
DI-60-184	Liquid level for broken loop steam generator. Elevation difference between taps is 1061 cm.	+1270 cm Water	+168.6 kPa	197,198	
VOLUMETRIC FLOW RATE	Turbine flowmeter, bidirectional.				Data acquisition system range may exceed rated detection range; however, turbine response is linear to flow rates well beyond the rated range.

POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>Intact Loop</u>					
FI-1	Hot leg, Spool 1, 38 cm from vessel center.	+2.52 to +25.2 t/s	+80 t/s	199,200	
FI-11	Cold leg, Spool 17, 429 cm from downcomer center.	+2.52 to +25.2 t/s	+100 t/s	199,200	
FI-16	Cold leg, Spool 16, 145 cm from downcomer center.	+5.05 to +50.5 t/s	+100 t/s	201,201	
FI-17	Cold leg, Spool 17, 38 cm from downcomer center.	+2.52 to +25.2 t/s	+100 t/s	201,202	
<u>Broken Loop</u>					
FB-20	Cold leg, Spool 20, 100 cm from vessel center.	+2.52 to +25.2 t/s	+60 t/s	203,204	
FB-37	Cold leg, Spool 37, 316 cm from downcomer center.	+2.52 to +25.2 t/s	+60 t/s	203,204	
FB-40	Cold leg, Spool 40, 183 cm from downcomer center.	+2.52 to +25.2 t/s	+80 t/s	205,204	
FB-45	Hot leg, Spool 45, 110 cm from downcomer center.	+2.52 to +25.2 t/s	+80 t/s	205,206	
<u>Downcomer</u>					
VB-42a	In downcomer, upstream of instrumented spool piece, 42a cm below cold leg centerline.	+2.52 to +25.2 t/s	+60 t/s	203,208	
<u>Vessel</u>					
IV	Core exit, 1 cm above cold leg centerline.	+2.52 to +25.2 t/s	+80 t/s	206,210	
<u>ECC System</u>					
EV-HP15	In line (immediate) after HP15 pump for vessel, 112-cm line.	+0.0316 to +0.316 t/s	+0.10 t/s	211,212	
EV-LP15	In line leading from LP15 pump for vessel, 112-cm line.	+0.047 to +0.473 t/s	+0.20 t/s	213,214	
EV-ACC1	In line leading from vessel accumulator.	+0.316 to +3.16 t/s	+5.0 t/s	215,216	
<u>Pressurizer</u>					
PI-PR12E	In pressurizer surge line.	+0.920 to +8.20 t/s	+9.0 t/s	217,218	
<u>MOMENTUM FLUX</u>					
<u>Broken Loop</u>					
NB-20	Hot leg, Spool 20, 29 cm from vessel center.	+0.05 to +0.5 N	+16.07 N	219,220	
NB-40	Cold leg, Spool 40, 215 cm from downcomer center.	+0.09 to +0.78 N	+24.08 N	221,222	
NB-45	Cold leg, Spool 45, 86 cm from downcomer center.	+0.22 to +04.5 N	+61.71 N	223,224	
<u>Vessel</u>					
NV-9	In vessel lower upper plenum region, 9 cm below cold leg centerline. Drag screen target flow area 34% of flow area.	+0.11 to +32.2 N	+30.51 N	225,226	
NV-499	In vessel at entrance to heated core, 499 cm below cold leg centerline. Drag screen target area 34% of flow area.	+0.08 to +35.1 N	+73.54 N	227,228	
<u>DENSITY</u>					
<u>Intact Loop</u>					
CI-1T	Hot leg, Spool 1, 77 cm from vessel center. T (tangential) ranges 270° to 360°. S (body) ranges 30° to 330°. C is a mathematical composite of T and S.	1.6 to 1600 kg/m ³		229,230	
CI-1B		0 to 1600 kg/m ³		229,230	
CI-1C				231,232	
CI-5VK	Hot leg, Spool 5, 228 cm from vessel center, vertical.			273,234	

507 094

POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
<u>U-tube Loop (continued)</u>					
GL-137	Cold leg, Spool 13, 342 cm from downcomer center. T (tangential) ranges 270° to 360°, B (body) ranges 30° to 330°. C is a mathematical composite of T and B.			235,238	
GL-138				235,236	
GL-139				237,238	
GL-137	Cold leg, Spool 17, 73 cm from downcomer center. T (tangential) ranges 270° to 360°, B (body) ranges 30° to 330°. C is a mathematical composite of T and B.			239,240	
GL-138				239,240	
GL-139				241,242	
<u>Broken Loop</u>		1.5 to 1600 kg/m ³	0 to 1600 kg/m ³		
GB-200R	Hot leg, Spool 20, 84 cm from vessel center, vertical.			243,244	
GB-37	Cold leg, Spool 37, 360 cm from downcomer center.			245,246	
GB-40VR	Cold leg, Spool 40, 230 cm from downcomer vertical.			247,248	
GB-45VR	Cold leg, Spool 45, 66 cm from downcomer vertical.			249,250	
<u>Downcomer</u>		1.5 to 1600 kg/m ³	0 to 1600 kg/m ³		
DD-12B	Downcomer, 72 cm below cold leg centerline. B (body) ranges 30° to 330°.			251,252	
DD-240B	Downcomer, 260 cm below cold leg centerline. B (body) ranges 30° to 330°.			253,254	
DD-456B	Downcomer, 456 cm below cold leg centerline. B (body) ranges 30° to 330°.			255,256	
<u>Vessel</u>		1.5 to 1600 kg/m ³	0 to 1600 kg/m ³		
GV-339	Vessel at top of control rod guide tube, 339 cm above cold leg centerline.			257,258	
GV-174	Vessel at top of core support tube, 174 cm above cold leg centerline.			259,260	Questionable data. Analysis of beam path indicated possible obstruction by thermocouple or heater rod. Effect is unknown. To be used for trend only.
GV-11	Vessel at base of core flow instrument housing, 11 cm below cold leg centerline.			261,262	
GV-154-23	Near top of core heated length, 154 cm below cold leg centerline between heater rod Rows 2 and 3.			263,264	Questionable data. Analysis of beam path indicated possible obstruction by thermocouple or heater rod. Effect is unknown. To be used for trend only.
GV-164-AB	Near top of core heated length, 164 cm below cold leg centerline between heater rod Columns A and B.			263,264	Questionable data. Analysis of beam path indicated possible obstruction by thermocouple or heater rod. Effect is unknown. To be used for trend only.
GV-243-23	Upper part of core heated length, 243 cm below cold leg centerline between heater rod Rows 2 and 3.			265,266	
GV-313-23	Near center of core heated length, 313 cm below cold leg centerline between heater rod Rows 2 and 3.			267,268	Questionable data. Analysis of beam path indicated possible obstruction by thermocouple or heater rod. Effect is unknown. To be used for trend only.
GV-323-AB	Near center of core heated length, 323 cm below cold leg centerline between heater rod Columns A and B.			267,268	
GV-383-23	Lower part of core heated length, 383 cm below cold leg centerline between heater rod Rows 2 and 3.			269,270	Questionable data. Analysis of beam path indicated possible obstruction by thermocouple or heater rod. Effect is unknown. To be used for trend only.
GV-483-23	At bottom of core heated length, 483 cm below cold leg centerline between heater rod Rows 2 and 3.			271,272	

507 095
POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^b		Figure ^c	Measurement Comments ^d
		Detector	System		
<u>Vessel (continued)</u>					
CV-502-AB	At bottom of core heated length, 502 cm below cold leg centerline between heater rod Columns A and B.				Detector failed.
CV-528-588	Vessel lower head, 528 cm below cold leg centerline, at 15% ± 588 cm below cold leg centerline at 185%.			274,234	
CV-546-73	In upper part of vessel lower plenum 546 cm below cold leg centerline between heater rod Rows 2 and 3.			275,235	
<u>Pressurizer</u>					
CI-PRIZZ	Pressurizer surge line.	1.6 to 1600 kg/m ³	0 to 1600 kg/m ³	273,278	
MASS FLOW RATE	Mass flow rate obtained by combining density (gamma attenuation technique) with volumetric flow rate (turbine flowmeter) or momentum flux (tag disc).	Range for mass flow is determined from ranges of individual detectors used in calculation.			
<u>Intact Loop</u>					
FI-1, CI-1C	Hot leg, Spool 1.			274,280	
FI-16, CI-17C	Cold leg, Spool 16.			281,282	
FI-17, CI-17C	Cold leg, Spool 17.			281,284	
<u>Broken Loop</u>					
FB-20, CB-20VR NB-20, CB-20VR	Hot Spool 20.			285,286 287,288	
FB-37, CB-37	Cold leg, Spool 37.			289,290	
FB-40, CB-40VR NB-40, CB-40VR	Cold leg, Spool 40.			291,292 293,294	
FB-45, CB-45VR NB-45, CB-45VR	Cold leg, Spool 45.			295,296 297,298	
<u>Downdriller</u>					
FD-424, GD-424B	Instrumented spool pipe.			299,300	
<u>Vessel</u>					
FW-1, GV-11	Core outlet.			301,302	
WV-9, GV-11	Core inlet.			303,304	
WV-499, GV-493-73	Core inlet.			305,308	
<u>CODE CHARACTERISTICS</u>					
<u>High Power Bus</u>					
AH-HI	Core amperage.	0 to 10 000 A	0 to 10 030 A	307,308	
VH-HI	Core voltage.	0 to 400 V	0 to 402 V	309,310	
<u>Low Power Bus</u>					
AH-LO	Core amperage.	0 to 10 000 A	0 to 9330 A	311,312	
VH-LO	Core voltage.	0 to 400 V	0 to 402 V	313,314	
<u>PUMP CHARACTERISTICS</u>					
<u>Intact Loop</u>					
SI-PUMP	Pump speed.	377 rad/s	377 rad/s	315,316	

Loose heater rod ground connections, resulted in uncertainties in core power levels of up to 2% of actual power, with a probability of effects being .2% of actual power or less.

507 096

POOR ORIGINAL

TABLE IV (continued)

Measurement	Location and Comments ^a	Data Acquisition Range ^a		Figure ^a	Measurement Comments ^b
		Detector	System		
Broken loop					
JE-210P	Pump speed.	3770 rad/s	3770 rad/s	317,518	
JE-210P	Pump power.		20 kW	319,520	

^a Statements at the beginning of a measurement category regarding location and comments, range, and figure apply to all subsequent measurements within the given category unless specified otherwise.

^b Devices which were subjected to overrange conditions during portions of the test were capable of withstanding these conditions without change in operating or measuring characteristics when the physical conditions were again within the detector range.

POOR ORIGINAL




Fig. 11 Fluid temperature in intact loop hot leg (RFI-2 and TFI-1), from -20 to 300 s.




Fig. 12 Fluid temperature in intact loop hot leg (RFI-2 and TFI-1), from -6 to 42 s.

507 098




Fig. 13 Fluid temperature in intact loop cold leg (TFI-11), from -20 to 300 s.




Fig. 14 Fluid temperature in intact loop cold leg (TFI-11), from -6 to 42 s.




Fig. 15 Fluid temperature in intact loop cold leg (RF1-17 and TF1-17), from -20 to 300 s.




Fig. 16 Fluid temperature in intact loop cold leg (RF1-17 and TF1-17), from -6 to 42 s.




Fig. 17 Fluid temperature in broken loop hot leg (RFB-20 and TFB-20), from -20 to 300 s.




Fig. 18 Fluid temperature in broken loop hot leg (RFB-20 and TFB-20), from -6 to 42 s.




Fig. 19 Fluid temperature in broken loop cold leg (TFB-37), from -20 to 300 s.




Fig. 20 Fluid temperature in broken loop cold leg (TFB-37), from -6 to 42 s.




Fig. 21 Fluid temperature in broken loop cold leg (RFB-45 and TFB-45), from -20 to 300 s.




Fig. 22 Fluid temperature in broken loop cold leg (RFB-45 and TFB-45), from -6 to 42 s.




Fig. 23 Fluid temperature in downcomer (TFD-18F, TFD-152, TFD-294, TFD-364, and TFD-435), from -20 to 300 s.




Fig. 24 Fluid temperature in downcomer (TFD-18F, TFD-152, TFD-294, TFD-364, and TFD-435), from -6 to 42 s.

507 104




Fig. 25 Fluid temperature in vessel (TFV + 221Q), from -20 to 300 s.




Fig. 26 Fluid temperature in vessel (TFV + 221Q), from -6 to 42 s.




Fig. 27 Fluid temperature in vessel (TFV-11 and TFV-63R), from -20 to 300 s.




Fig. 28 Fluid temperature in vessel (TFV-11 and TFV-63R), from -6 to 42 s.




Fig. 29 Fluid temperature in vessel (TFV-552A, TFV-572W, and TFV-578A), from -20 to 300 s.




Fig. 30 Fluid temperature in vessel (TFV-552A, TFV-572W, and TFV-578A), from -6 to 42 s.

507 107




Fig. 77 Core heater temperature, Rod D-2 (TH-D2-10, TH-D2-134, TH-D2-166, TH-D2-179, and TH-D2-254), from -20 to 300 s.




Fig. 78 Core heater temperature, Rod D-2 (TH-D2-10, TH-D2-134, TH-D2-166, TH-D2-179, and TH-D2-254), from -6 to 42 s.




Fig. 75 Core heater temperature, Rod C-3 (TH-C3-49, TH-C3-115, TH-C3-184, TH-C3-194, and TH-C3-230), from -20 to 300 s.




Fig. 76 Core heater temperature, Rod C-3 (TH-C3-49, TH-C3-115, TH-C3-184, TH-C3-194, and TH-C3-230), from -6 to 42 s.




Fig. 73 Core heater temperature, Rod C-2 (TH-C2-8, TH-C2-164, TH-C2-180, TH-C2-277, and TH-C2-321), from -20 to 300 s.




Fig. 74 Core heater temperature, Rod C-2 (TH-C2-8, TH-C2-164, TH-C2-180, TH-C2-277, and TH-C2-321), from -6 to 42 s.




Fig. 71 Core heater temperature, Rod B-3 (TH-B3-180, TH-B3-226, and TH-B3-353), from -20 to 300 s.




Fig. 72 Core heater temperature, Rod B-3 (TH-B3-180, TH-B3-226, and TH-B3-353), from -6 to 42 s.




Fig. 69 Material temperature in broken loop, steam generator tube (TMB-SGT734), from -20 to 300 s.




Fig. 70 Material temperature in broken loop, steam generator tube (TMB-SGT734), from -6 to 42 s.




Fig. 67 Material temperature in intact loop, steam generator tube (TMI-SGT61), from -20 to 300 s.




Fig. 68 Material temperature in intact loop, steam generator tube (TMI-SGT61), from -6 to 42 s.




Fig. 65 Material temperature in vessel, core guide tube (TGMV + 280 and TGMV-63), from -20 to 300 s.




Fig. 66 Material temperature in vessel, core guide tube (TGMV + 280 and TGMV-63), from -6 to 42 s.




Fig. 63 Material temperature in upper vessel (TMV + 221F and TMV + 79D), from -20 to 300 s.




Fig. 64 Material temperature in upper vessel (TMV + 221F and TMV + 79D), from -6 to 42 s.




Fig. 61 Material temperature in downcomer insulator (TIMD-18F, TIMD-152, TIMD-294, and TIMD-364), from -20 to 300 s.




Fig. 62 Material temperature in downcomer insulator (TIMD-18F, TIMD-152, TIMD-294, and TIMD-364), from -6 to 42 s.




Fig. 59 Material temperature in downcomer (TMD-18F, TMD-152, and TMD-364), from -20 to 300 s.




Fig. 60 Material temperature in downcomer (TMD-18F, TMD-152, and TMD-364), from -6 to 42 s.




Fig. 57 Material temperature in broken loop (TMB-40B16 and TMB-45B16), from -20 to 300 s.




Fig. 58 Material temperature in broken loop (TMB-40B16 and TMB-45B16), from -6 to 42 s.




Fig. 55 Material temperature in broken loop (TMB-20B16), from -20 to 300 s.




Fig. 56 Material temperature in broken loop (TMB-20B16), from -6 to 42 s.




Fig. 53 Material temperature in intact loop (TMI-1T16 and TMI-17S16), from -20 to 300 s.




Fig. 54 Material temperature in intact loop (TMI-1T16 and TMI-17S16), from -6 to 47 s.




Fig. 51 Fluid temperature in broken loop, pressure suppression system tank (TFB-PS43 and TFB-PS330), from -20 to 300 s.




Fig. 52 Fluid temperature in broken loop, pressure suppression system tank (TFB-PS43 and TFB-PS330), from -6 to 42 s.




Fig. 49 Fluid temperature in intact loop steam generator, secondary side steam dome (TFI-SD), from -20 to 300 s.




Fig. 50 Fluid temperature in intact loop steam generator, secondary side steam dome (TFI-SD), from -6 to 42 s.




Fig. 47 Fluid temperature in intact loop steam generator, secondary feedwater line (TF1-SGFW), from -20 to 300 s.




Fig. 48 Fluid temperature in intact loop steam generator, secondary feedwater line (TF1-SGFW), from -6 to 42 s.

507 124




Fig. 45 Fluid temperature in vessel accumulator, coolant injection line (TFV-ECC-LP), from -20 to 300 s.




Fig. 46 Fluid temperature in vessel accumulator, coolant injection line (TFV-ECC-LP), from -6 to 42 s.




Fig. 43 Fluid temperature in core, Grid Spacer 10 (TFG-10AB-45), from -20 to 300 s.




Fig. 44 Fluid temperature in core, Grid Spacer 10 (TFG-10AB-45), from -6 to 42 s.




Fig. 41 Fluid temperature in core, Grid Spacer 8 (TFG-8AB-23), from -20 to 300 s.




Fig. 42 Fluid temperature in core, Grid Spacer 8 (TFG-8AB-23), from -6 to 42 s.

127 507




Fig. 39 Fluid temperature in core, Grid Spacer 5 (TFG-5AB-45), from -20 to 300 s.




Fig. 40 Fluid temperature in core, Grid Spacer 5 (TFG-5AB-45), from -6 to 42 s.




Fig. 37 Fluid temperature in core, Grid Spacer 3 (TFG-3AB-12), from -20 to 300 s.




Fig. 38 Fluid temperature in core, Grid Spacer 3 (TFG-3AB-12), from -6 to 42 s.




Fig. 35 Fluid temperature in core, Grid Spacer 1 (TFG-1AB-12), from -20 to 300 s.




Fig. 36 Fluid temperature in core, Grid Spacer 1 (TFG-1AB-12), from -6 to 42 s.

021 209




Fig. 33 Fluid temperature in vessel, core guide tube (TGFV + 330), from -20 to 300 s.




Fig. 34 Fluid temperature in vessel, core guide tube (TGFV + 330), from -6 to 42 s.




Fig. 31 Fluid temperature in vessel filler insulator gap (TIFV + 79D), from -20 to 300 s.




Fig. 32 Fluid temperature in vessel filler insulator gap (TIFV + 79D), from -6 to 42 s.




Fig. 79 Core heater temperature, Rod D-3 (TH-D3-71, TH-D3-132, TH-D3-206, and TH-D3-226), from -20 to 300 s.




Fig. 80 Core heater temperature, Rod D-3 (TH-D3-71, TH-D3-132, TH-D3-206, and TH-D3-226), from -6 to 42 s.




Fig. 81 Core heater temperature, Rod A-3 (TH-A3-208, TH-A3-229, and TH-A3-291), from -20 to 300 s.




Fig. 82 Core heater temperature, Rod A-3 (TH-A3-208, TH-A3-229 and TH-A3-291), from -6 to 42 s.




Fig. 83 Core heater temperature, Rod A-4 (TH-A4-40, TH-A4-108, TH-A4-181, and TH-A4-191), from -20 to 300 s.




Fig. 84 Core heater temperature, Rod A-4 (TH-A4-40, TH-A4-108, TH-A4-181, and TH-A4-191), from -6 to 42 s.




Fig. 85 Core heater temperature, Rod A-5 (TH-A5-164, TH-A5-179, and TH-A5-252), from -20 to 300 s.




Fig. 86 Core heater temperature, Rod A-5 (TH-A5-164, TH-A5-179, and TH-A5-252), from -6 to 42 s.




Fig. 87 Core heater temperature, Rod B-1 (TH-B1-321), from -20 to 300 s.




Fig. 88 Core heater temperature, Rod B-1 (TH-B1-321), from -6 to 42 s.




Fig. 89 Core heater temperature, Rod D-1 (TH-D1-178 and TH-D1-251), from -20 to 300 s.




Fig. 90 Core heater temperature, Rod D-1 (TH-D1-178 and TH-D1-251), from -6 to 42 s.




Fig. 91 Core heater temperature, Rod D-5 (TH-D5-137, TH-D5-179, TH-D5-254, and TH-D5-322), from -20 to 300 s.




Fig. 92 Core heater temperature, Rod D-5 (TH-D5-137, TH-D5-179, TH-D5-254, and TH-D5-322), from -6 to 42 s.




Fig. 93 Core heater temperature, Rod E-1 (TH-E1-252 and TH-E1-321), from -20 to 300 s.




Fig. 94 Core heater temperature, Rod E-1 (TH-E1-252 and TH-E1-321), from -6 to 42 s.




Fig. 95 Core heater temperature, Rod E-2 (TH-E2-109, TH-E2-190, and TH-E2-353), from -20 to 300 s.




Fig. 96 Core heater temperature, Rod E-2 (TH-E2-109, TH-E2-190, and TH-E2-353), from -6 to 42 s.

507 140




Fig. 27. Core heater temperature, Rod E-3 (TH-E3-134, TH-E3-207, TH-E3-223, and TH-E3-290), from -20 to 300 s.




Fig. 28. Core heater temperature, Rod E-3 (TH-E3-134, TH-E3-207, TH-E3-223, and TH-E3-290), from -6 to 42 s.




Fig. 99 Core heater temperature, Rod E-4 (TH-E4-180 and TH-E4-354), from -20 to 300 s.




Fig. 100 Core heater temperature, Rod E-4 (TH-E4-180 and TH-E4-354), from -6 to 42 s.

507 142




Fig. 101 Core heater temperature, Rod E-5 (TH-E5-227), from -20 to 300 s.




Fig. 102 Core heater temperature, Rod E-5 (TH-E5-227), from -6 to 42 s.




Fig. 103 Pressure in intact loop cold leg (PI-16 and PI-17AL), from -20 to 300 s.




Fig. 104 Pressure in intact loop cold leg (PI-16 and PI-17AL), from -6 to 42 s.




Fig. 105 Pressure in broken loop hot leg (PB-20B), from -20 to 300 s.




Fig. 106 Pressure in broken loop hot leg (PB-20B), from -6 to 42 s.




Fig. 107 Pressure in broken loop cold leg, pump side (PB-40B), from -20 to 300 s.




Fig. 108 Pressure in broken loop cold leg, pump side (PB-40B), from -6 to 42 s.

507 146




Fig. 109 Pressure in broken loop blowdown nozzle (PB-44-6A), from -20 to 300 s.




Fig. 110 Pressure in broken loop blowdown nozzle (PB-44-6A), from -6 to 42 s.




Fig. 111 Pressure in broken loop cold leg, vessel side (PB-45A), from -20 to 300 s.




Fig. 112 Pressure in broken loop cold leg, vessel side (PB-45A), from -6 to 42 s.




Fig. 113 Pressure in vessel upper and lower plenum (PV-13 and PV-442), from -20 to 300 s.




Fig. 114 Pressure in vessel upper and lower plenum (PV-13 and PV-442), from -6 to 42 s.




Fig. 115 Pressure in vessel ECC injection accumulator (PV-ACCI), from -20 to 300 s.




Fig. 116 Pressure in vessel ECC injection accumulator (PV-ACCI), from -6 to 42 s.




Fig. 117 Pressure in system steam generators, secondary side steam dome (PI-SD and PB-SD), from -20 to 300 s.




Fig. 118 Pressure in system steam generators, secondary side steam dome (PI-SD and PB-SD), from -6 to 42 s.

507 151




Fig. 119 Pressure in pressurizer (PI-PRIZE), from -20 to 300 s.




Fig. 120 Pressure in pressurizer (PI-PRIZE), from -6 to 42 s.




Fig. 121 Pressure in broken loop pressure suppression tank (PB-PSS), from -20 to 300 s.




Fig. 122 Pressure in broken loop pressure suppression tank (PB-PSS), from -6 to 42 s.




Fig. 123 Differential pressure in intact loop (DI-13V-1A), from -20 to 300 s.




Fig. 124 Differential pressure in intact loop (DI-13V-1A), from -6 to 42 s.

507 154




Fig. 125 Differential pressure in intact loop (DI-1A-6), from -20 to 300 s.




Fig. 126 Differential pressure in intact loop (DI-1A-6), from -6 to 42 s.




Fig. 127 Differential pressure in intact loop (DI-6-7), from -20 to 300 s.




Fig. 128 Differential pressure in intact loop (DI-6-7), from -6 to 42 s.

507 156




Fig. 129 Differential pressure in intact loop steam generator, inlet plenum to outlet plenum (DI-SGI-SGO), from -20 to 300 s.




Fig. 130 Differential pressure in intact loop steam generator, inlet plenum to outlet plenum (DI-SGI-SGO), from -6 to 42 s.




Fig. 131 Differential pressure in intact loop (DI-7-13), from -20 to 300 s.




Fig. 132 Differential pressure in intact loop (DI-7-13), from -6 to 42 s.

507 158




Fig. 133 Differential pressure in intact loop (DI-13-15), from -20 to 300 s.




Fig. 134 Differential pressure in intact loop (DI-13-15), from -6 to 42 s.




Fig. 135 Differential pressure in intact loop (DI-15-17A), from -20 to 300 s.




Fig. 136 Differential pressure in intact loop (DI-15-17A), from -6 to 42 s.




Fig. 137 Differential pressure in intact loop (DI-17A-D1A), from -20 to 300 s.




Fig. 138 Differential pressure in intact loop (DI-17A-D1A), from -6 to 42 s.




Fig. 139 Differential pressure in broken loop (DB-13V-20B), from -20 to 300 s.




Fig. 140 Differential pressure in broken loop (DB-13V-20B), from -6 to 42 s.




Fig. 141 Differential pressure in broken loop (DB-20B-21), from -20 to 300 s.




Fig. 142 Differential pressure in broken loop (DB-20B-21), from -6 to 42 s.




Fig. 143 Differential pressure in broken loop (DB-21-27A), from -20 to 300 s.




Fig. 144 Differential pressure in broken loop (DB-21-27A), from -6 to 42 s.




Fig. 145 Differential pressure in broken loop steam generator (DB-SG1-SG0), from -20 to 300 s.




Fig. 146 Differential pressure in broken loop steam generator (DB-SG1-SG0), from -6 to 42 s.




Fig. 147 Differential pressure in broken loop (DB-27A-37A), from -20 to 300 s.




Fig. 148 Differential pressure in broken loop (DB-27A-37A), from -6 to 42 s.

507 166




Fig. 149 Differential pressure in broken loop (DB-37A-40B), from -20 to 300 s.




Fig. 150 Differential pressure in broken loop (DB-37A-40B), from -6 to 42 s.




Fig. 151 Differential pressure in broken loop (DB-37A-40L), from -20 to 300 s.




Fig. 152 Differential pressure in broken loop (DB-37A-40L), from -6 to 42 s.




Fig. 153 Differential pressure in broken loop (DB-40B-43A), from -20 to 300 s.




Fig. 154 Differential pressure in broken loop (DB-40B-43A), from -6 to 42 s.




Fig. 155 Differential pressure in broken loop (DB-40B-45A), from -20 to 300 s.




Fig. 156 Differential pressure in broken loop (DB-40B-45A), from -6 to 42 s.

507 170




Fig. 157 Differential pressure in broken loop (DB-45A-43), from -20 to 300 s.




Fig. 158 Differential pressure in broken loop (DB-45A-43), from -6 to 42 s.

507 171




Fig. 159 Differential pressure in broken loop (DB-45A-D1A), from -20 to 300 s.




Fig. 160 Differential pressure in broken loop (DB-45A-D1A), from -6 to 42 s.




Fig. 161 Differential pressure in downcomer (DD-DIA-13A), from -20 to 300 s.




Fig. 162 Differential pressure in downcomer (DD-DIA-13A), from -6 to 42 s.

507 173




Fig. 163 Differential pressure in downcomer (DD-D1A-170), from -20 to 300 s.




Fig. 164 Differential pressure in downcomer (DD-D1A-170), from -6 to 42 s.

507 174




Fig. 165 Differential pressure in downcomer (DD-DIA-578), from 0 to 300 s.




Fig. 166 Differential pressure in downcomer (DD-DIA 578), from -6 to 42 s.

507 175




Fig. 167 Differential pressure in downcomer (DD-170-435), from -20 to 300 s.




Fig. 168 Differential pressure in downcomer (DD-170-435), from -6 to 42 s.

507 176




Fig. 169 Differential pressure in downcomer (DD-435-578), from -20 to 300 s.




Fig. 170 Differential pressure in downcomer (DD-435-578), from -6 to 42 s.




Fig. 171 Differential pressure in vessel (DV-578-501), from -20 to 300 s.




Fig. 172 Differential pressure in vessel (DV-578-501), from -6 to 42 s.

507 178




Fig. 173 Differential pressure in vessel (DV-578-13), from -20 to 300 s.




Fig. 174 Differential pressure in vessel (DV-578-13), from -6 to 42 s.




Fig. 175 Differential pressure in vessel (DV-501-442), from -20 to 300 s.




Fig. 176 Differential pressure in vessel (DV-501-442), from -6 to 42 s.




Fig. 177 Differential pressure in vessel (DV-501-105), from -20 to 300 s.




Fig. 178 Differential pressure in vessel (DV-501-105), from -6 to 42 s.

507 181




Fig. 179 Differential pressure in vessel (DV-501-13A) from -20 to 300 s.




Fig. 180 Differential pressure in vessel (DV-501-13A), from -6 to 42 s.




Fig. 181 Differential pressure in vessel (DV-442-278), from -20 to 300 s.




Fig. 182 Differential pressure in vessel (DV-442-278), from -6 to 42 s.

507 183




Fig. 183 Differential pressure in vessel (DV-278-154), from -20 to 300 s.




Fig. 184 Differential pressure in vessel (DV-278-154), from -6 to 42 s.




Fig. 185 Differential pressure in vessel (DV-105-13), from -20 to 300 s.




Fig. 186 Differential pressure in vessel (DV-105-13), from -6 to 42 s.

507 185




Fig. 187 Differential pressure in vessel (DV + 421 + 154), from -20 to 300 s.




Fig. 188 Differential pressure in vessel (DV + 421 + 154), from -6 to 42 s.

507 186




Fig. 189 Differential pressure in vessel (DV + 159-105), from -20 to 360 s.




Fig. 190 Differential pressure in vessel (DV + 159-105), from -6 to 42 s.




Fig. 191 Differential pressure in vessel (DV + 154-105), from -20 to 300 s.




Fig. 192 Differential pressure in vessel (DV + 154-105), from -6 to 42 s.




Fig. 193 Differential pressure in vessel ECC accumulator (DV-ACC1-LL), from -20 to 300 s.




Fig. 194 Differential pressure in vessel ECC accumulator (DV-ACC1-LL), from -6 to 42 s.




Fig. 195 Differential pressure in intact loop steam generator, secondary side liquid level (DI-SG-LL), from -20 to 300 s.




Fig. 196 Differential pressure in intact loop steam generator, secondary side liquid level (DI-SG-LL), from -6 to 42 s.




Fig. 197 Differential pressure in broken loop steam generator, secondary liquid level (DB-SS1-SS4), from -20 to 300 s.




Fig. 198 Differential pressure in broken loop steam generator, secondary liquid level (DB-SS1-SS4), from -6 to 42 s.




Fig. 199 Volumetric flow in intact loop (FI-1 and FI-11), from -20 to 300 s.




Fig. 200 Volumetric flow in intact loop (FI-1 and FI-11), from -6 to 42 s.




Fig. 201 Volumetric flow in intact loop (FI-16 and FI-17), from -20 to 300 s.




Fig. 202 Volumetric flow in intact loop (FI-16 and FI-17), from -6 to 42 s.

507 193




Fig. 203 Volumetric flow in broken loop (FB-20 and FB-37), from -20 to 300 s.




Fig. 204 Volumetric flow in broken loop (FB-20 and FB-37), from -6 to 42 s.




Fig. 205 Volumetric flow in broken loop (FB-40 and FB-45), from -20 to 300 s.




Fig. 206 Volumetric flow in broken loop (FB-40 and FB-45), from -6 to 42 s.




Fig. 207 Volumetric flow in downcomer (FD-424), from -20 to 300 s.




Fig. 208 Volumetric flow in downcomer (FD-424), from -6 to 42 s.




Fig. 209 Volumetric flow in vessel upper plenum (FV + 1), from -20 to 300 s.




Fig. 210 Volumetric flow in vessel upper plenum (FV + 1), from -6 to 42 s.




Fig. 211 Volumetric flow in vessel, high pressure injection system (FV-HPIS), from -20 to 300 s.




Fig. 212 Volumetric flow in vessel, high pressure injection system (FV-HPIS), from -6 to 42 s.




Fig. 213 Volumetric flow in vessel, low pressure injection system (FV-LPIS), from -20 to 300 s.




Fig. 214 Volumetric flow in vessel, low pressure injection system (FV-LPIS), from -6 to 42 s.




Fig. 215 Volumetric flow in vessel, ECC accumulator (FV-ACC1), from -20 to 300 s.




Fig. 216 Volumetric flow in vessel, ECC accumulator (FV-ACC1), from -6 to 42 s.




Fig. 217 Volumetric flow in intact loop, pressurizer surge line (F1-PRIZE), from -20 to 300 s.




Fig. 218 Volumetric flow in intact loop, pressurizer surge line (F1-PRIZE), from -6 to 42 s.




Fig. 219 Momentum flux in broken loop (NB-20), from -20 to 300 s.




Fig. 220 Momentum flux in broken loop (NB-20), from -6 to 42 s.




Fig. 221 Momentum flux in broken loop (NB-40), from -20 to 300 s.




Fig. 222 Momentum flux in broken loop (NB-40), from -6 to 42 s.




Fig. 223 Momentum flux in broken loop (NB-45), from -20 to 300 s.




Fig. 224 Momentum flux in broken loop (NB-45), from -6 to 42 s.

507 204




Fig. 225 Momentum flux in core outlet (NV-9), from -20 to 300 s.




Fig. 226 Momentum flux in core outlet (NV-9), from -6 to 42 s.




Fig. 227 Momentum flux in core inlet (NV-499), from -20 to 300 s.




Fig. 228 Momentum flux in core inlet (NV-499), from -6 to 42 s.

507 206




Fig. 229 Density in intact loop (GI-1T and GI-1B), from -20 to 300 s.




Fig. 230 Density in intact loop (GI-1T and GI-1B), from -6 to 42 s.




Fig. 231 Density in intact loop (GI-1C), from -20 to 300 s.




Fig. 232 Density in intact loop (GI-1C), from -6 to 42 s.




Fig. 233 Density in intact loop (GI-5VR), from -20 to 300 s.




Fig. 234 Density in intact loop (GI-5VR), from -6 to 42 s.

507 209




Fig. 235 Density in intact loop (GI-13T and GI-13B), from -20 to 300 s.




Fig. 236 Density in intact loop (GI-13T and GI-13B), from -6 to 42 s.

507 210




Fig. 237 Density in intact loop (GI-13C), from -20 to 300 s.




Fig. 238 Density in intact loop (GI-13C), from -6 to 42 s.




Fig. 239 Density in intact loop (GI-17T and GI-17B), from -20 to 300 s.




Fig. 240 Density in intact loop (GI-17T and GI-17B), from -6 to 42 s.




Fig. 241 Density in intact loop (GI-17C), from -20 to 300 s.




Fig. 242 Density in intact loop (GI-17C), from -6 to 42 s.




Fig. 243 Density in broken loop (GB-20VR), from -20 to 300 s.




Fig. 244 Density in broken loop (GB-20VR), from -6 to 42 s.




Fig. 245 Density in broken loop (GB-37), from -20 to 300 s.




Fig. 246 Density in broken loop (GB-37), from -6 to 42 s.




Fig. 247 Density in broken loop (GB-40VR) from -20 to 300 s.




Fig. 248 Density in broken loop (GB-40VR), from -6 to 42 s.




Fig. 249 Density in broken loop (GB-45VR), from -20 to 300 s.




Fig. 250 Density in broken loop (GB-45VR), from -6 to 42 s.

507 217




Fig. 251 Density in downcomer (GD-72B), from -20 to 300 s.




Fig. 252 Density in downcomer (GD-72B), from -6 to 42 s.




Fig. 253 Density in downcomer (GD-260B), from -20 to 300 s.




Fig. 254 Density in downcomer (GD-260B), from -6 to 42 s.




Fig. 255 Density in downcomer (GD-456B), from -20 to 300 s.




Fig. 256 Density in downcomer (GD-456B), from -6 to 42 s.




Fig. 257 Density in vessel (GV + 339), from -20 to 300 s.




Fig. 258 Density in vessel (GV + 339), from -6 to 42 s.




Fig. 259 Density in vessel (GV + 174), from -20 to 300 s.




Fig. 260 Density in vessel (GV + 174), from -6 to 42 s.




Fig. 261 Density in vessel (GV-11), from -20 to 300 s.




Fig. 262 Density in vessel (GV-11), from -6 to 42 s.




Fig. 263 Density in vessel (GV-154-23 and GV-164-AB), from -20 to 300 s.




Fig. 264 Density in vessel (GV-154-23 and GV-164-AB), from -6 to 42 s.




Fig. 265 Density in vessel (GV-243-23), from -20 to 300 s.




Fig. 266 Density in vessel (GV-243-23), from -6 to 42 s.




Fig. 267 Density in vessel (GV-313-23 and GV-323-AB), from -20 to 300 s.




Fig. 268 Density in vessel (GV-313-23 and GV-323-AB), from -6 to 42 s.

507 225




Fig. 269 Density in vessel (GV-383-23), from -20 to 300 s.




Fig. 270 Density in vessel (GV-383-23), from -6 to 42 s.




Fig. 271 Density in vessel (GV-483-23), from -20 to 300 s.




Fig. 272 Density in vessel (GV-483-23), from -6 to 42 s.

507 228




Fig. 273 Density in vessel (GV-528-588), from -20 to 300 s.




Fig. 274 Density in vessel (GV-528-588), from -6 to 42 s.

507 229




Fig. 275 Density in vessel (GV-546-23), from -20 to 300 s.




Fig. 276 Density in vessel (GV-546-23), from -6 to 42 s.

507 230




Fig. 277 Density in intact loop pressurizer (GI-PRIZE), from -20 to 300 s.




Fig. 278 Density in intact loop pressurizer (GI-PRIZE), from -6 to 42 s.




Fig. 279 Mass flow in intact loop (FI-1 and GI-1C), from -20 to 300 s.




Fig. 280 Mass flow in intact loop (FI-1 and GI-1C), from -6 to 42 s.

507 232




Fig. 281 Mass flow in intact loop (FI-16 and GI-17C), from -20 to 300 s.




Fig. 282 Mass flow in intact loop (FI-16 and GI-17C), from -6 to 42 s.




Fig. 283 Mass flow in intact loop (FI-17 and GI-17C), from -20 to 300




Fig. 284 Mass flow in intact loop (FI-17 and GI-17C), from -6 to 42 s.

507 234




Fig. 285 Mass flow in broken loop (FB-20 and GB-20VR), from -20 to 300 s.




Fig. 286 Mass flow in broken loop (FB-20 and GB-20VR), from -6 to 2 s.

507 235




Fig. 287 Mass flow in broken loop (NB-20 and GB-20VR), from -20 to 300 s.




Fig. 288 Mass flow in broken loop (NB-20 and GB-20VR), from -6 to 42 s.




Fig. 289 Mass flow in broken loop (FB-37 and GB-37), from -20 to 300 s.




Fig. 290 Mass flow in broken loop (FB-37 and GB-37), from -6 to 42 s.




Fig. 291 Mass flow in broken loop (FB-40 and GB-40VR), from -20 to 300 s.




Fig. 292 Mass flow in broken loop (FB-40 and GB-40VR), from -6 to 42 s.




Fig. 293 Mass flow in broken loop (NB-40 and GB-40VR), from -20 to 300 s.




Fig. 294 Mass flow in broken loop (NB-40 and GB-40VR), from -6 to 42 s.




Fig. 295 Mass flow in broken loop (FB-45 and GB-45), from -20 to 300 s.




Fig. 296 Mass flow in broken loop (FB-45 and GB-45), from -6 to 42 s.




Fig. 297 Mass flow in broken loop (NB-45 and GB-45), from -20 to 300 s.




Fig. 298 Mass flow in broken loop (NB-45 and GB-45), from -6 to 42 s.




Fig. 299 Mass flow in downcomer (FD-424 and GD-456B), from -20 to 300 s.




Fig. 300 Mass flow in downcomer (FD-424 and GD-456B), from -6 to 42 s.

507 242




Fig. 301 Mass flow in vessel (FV + 1 and GV-11), from -20 to 300 s.




Fig. 302 Mass flow in vessel (FV + 1 and GV-11), from -6 to 42 s.




Fig. 303 Mass flow in vessel (NV-9 and GV-11), from -20 to 300 s.




Fig. 304 Mass flow in vessel (NV-9 and GV-11), from -6 to 42 s.




Fig. 305 Mass flow in vessel (NV-499 and GV-483-23), from -20 to 300 s.




Fig. 306 Mass flow in vessel (NV-499 and GV-483-23), from -6 to 42 s.




Fig. 307 Core heater high power bus amperage (AH-HI), from -20 to 300 s.




Fig. 308 Core heater high power bus amperage (AH-HI), from -6 to 42 s.

507 246




Fig. 309 Core heater high power bus voltage (VH-HI), from -20 to 300 s.




Fig. 310 Core heater high power bus voltage (VH-HI), from -6 to 42 s.

507 247




Fig. 311 Core heater low power bus amperage (AH-LO), from -20 to 300 s.




Fig. 312 Core heater low power bus amperage (AH-LO), from -6 to 42 s.




Fig. 313 Core heater low power bus voltage (VH-L0), from -20 to 300 s.




Fig. 314 Core heater low power bus voltage (VH-L0), from -6 to 42 s.

507 249




Fig. 315 Intact loop pump speed (SI-PUMP), from -20 to 300 s.




Fig. 316 Intact loop pump speed (SI-PUMP), from -6 to 42 s.

507 250




Fig. 317 Broken loop pump speed (SB-PUMP), from -20 to 300 s.




Fig. 318 Broken loop pump speed (SB-PUMP), from -6 to 42 s.




Fig. 319 Broken loop pump power (WB-PUMP), from -20 to 300 s.




Fig. 320 Broken loop pump power (WB-PUMP), from -6 to 42 s.

IV. REFERENCES

L. T. Bell et al., *Semiscale Program Description*, TREE-NUREG-1210 (May 1978).

M. T. Patton, *Semiscale Mod-3 Test Program and System Description*, NUREG/CR-0239, TREE-NUREG-1212 (July 1978).

APPENDIX A
DATA ACQUISITION SYSTEM CAPABILITIES

507 254

APPENDIX A

DATA ACQUISITION SYSTEM CAPABILITIES

The Semiscale Mod-3 system provides for the acquisition, processing, and presentation of test data. The test data system comprises detectors, signal conditioners, signal processors, and recording and display equipment. The data obtained are principally recorded on an on-line digital system. Selected data channels are also recorded on an analog system.

The on-line digital system is called the digital data acquisition and processing system (DDAPS). The DDAPS has dual and single speed capabilities with identical storage and data output limitations. The dual speed mode is used to extend the recording time when obtaining high frequency data.

From each of up to 240 data channels, the test data system stores 20 blocks of data. Each block of data contains 920 words (each word is the abscissa and ordinate of a data point) of digital information. These 920 words represent a fixed storage display.

The maximum measured throughput rate for the system is 24 000 words per second. This throughput rate can be reduced in increments of 100 words per second. The throughput rate, the number of data channels recorded, and the fixed display of 920 points per block determine the time base for displaying the data.

After the data have been stored, data reduction can be made for presentation and analysis purposes. Because of hardware limitations and aesthetic considerations of data presentation, only certain time bases are used when the data are reduced. For data displayed from -20 to 300 s, the recorded data are made to occupy a 320-s span yielding a time base of 16 s.

Generally, 920 points from a given data channel are displayed in the nominal time base of 16 s. Integral (1 to 20) multiples of 16 s may be used as variations on the nominal time base. Because the output is fixed at 920 points, data compression is accomplished by averaging adjacent data points to give the desired compression.

507 255

APPENDIX B

POSTTEST ADJUSTMENTS TO DATA FROM SEMISCALE MOD-3
TEST S-07-9

507 256

APPENDIX B

POSTTEST ADJUSTMENTS TO DATA FROM SEMISCALE MOD-3 TEST S-07-9

Many of the transducers used in the Semiscale Mod-3 system exhibit significant sensitivity to one or more spurious inputs. Strain gage bridge circuits used in pressure transducers, differential pressure transducers, and drag discs are sensitive to changes in ambient temperature. Differential pressure cells are also sensitive to changes in system pressure. Photomultiplier tubes used as gamma ray detectors in the density transducers are sensitive to temperature changes, as well as to random variations in the locations of the radiation sources. Core power measurements depend on a calibrated resistor, whose resistance changes in value as a function of time and power level as it heats up.

Although the uncertainties introduced into the data by spurious secondary inputs generally do not exceed the specified uncertainty ranges of the transducers, significant improvement in measurement accuracy can be achieved if the secondary sensitivity can be identified and removed. Since the exact values of the spurious inputs to which different transducers might be sensitive cannot often be easily predicted and are sometimes inconvenient to measure, secondary effects have been accounted for by correcting the data after the test rather than by using elaborate real time programs in the data acquisition system computer. The methods and results of the posttest data correction analysis for Test S-07-9 are presented in the following paragraphs and tables.

1. DIFFERENTIAL PRESSURE MEASUREMENTS

Pressure sensitivity in the differential pressure cells in the main system loop is determined from the pretest system pressure check. Digital data are recorded for all measurements at ambient temperature, with no system flow, at pressures of ambient, 5575, 8964, 10 817, 12 517, and 15 751 kPa. The output of the differential pressure cells is plotted against system pressure, with the resulting plots used to describe the pressure response of the transducers.

Corrections to differential pressure data were made using the following equation:

$$F'(t) = F(t) + P_1 P(t) \quad (B-1)$$

where

$F'(t)$ = corrected data, kPa

$F(t)$ = raw data, kPa

P_1 = pressure sensitivity, kPa/MPa

$P(t)$ = pressure data from indicated transducer used for pressure correction sensitivity, MPa.

Values of the constants are given in Table B-I.

507 257

TABLE B-I

CONSTANTS FOR DIFFERENTIAL PRESSURE MEASUREMENT CORRECTION
(TEST S-07-9)

<u>Detector Identification</u>	<u>P₁</u>	<u>P(t)</u>
DI-13V-1A	-0.024	PV-13
DI-1A-6		
DI-6-7	-0.053	PI-16
DI-SGI-SGO	0.027	PI-16
DI-7-13	-0.027	PI-16
DI-13-15	1.567	PI-16
DI-15-17A		
DI-17A-DIA		
DB-13V-20B	0.100	PV-13
DB-20B-21	0.090	PV-13
DB-21-27A	-1.067	PV-13
DB-SGI-SGO	2.000	PV-13
DB-27A-37A	-0.053	PV-13
DB-37A-40B	-0.290	PV-13
DB-37A-40L	-0.066	PV-13
DB-40B-43A		
DB-40B-45A	0.018	PB-45A
DB-45A-43		
DB-45A-DIA	0.467	PB-45A
DD-DIA-13V	-0.400	PI-16
DD-DIA-170	-0.057	PI-16
DD-DIA-578	-0.011	PI-16
DD-170-435	-0.055	PI-16
DD-435-578	-0.033	PI-16
DV+421+154	0.020	PV-13
DV+159-105	-0.305	PV-13
DV+154-105	0.027	PV-13
DV-578-501	-0.021	PV-13
DV-578-13A	-1.933	PV-13

TABLE B-I (continued)

<u>Detector Identification</u>	<u>P₁</u>	<u>P(t)</u>
DV-501-442	-0.027	PI-16
DV-501-105	0.057	PV-13
DV-501-13A	-0.100	PI-16
DV-442-278	-0.013	PI-16
DV-278-154	-0.033	PI-16
DV-105-13A		
DI-SG-LL		
DB-SS1-SS4		
DV-ACC1-LL		

2. DENSITY MEASUREMENTS

Density calculations are based on the voltage output of the photomultiplier tubes in the gamma-attenuation densitometer assemblies. The equation used for converting voltage to density is as follows:

$$\rho = C_0 + C_1 F(t) \quad (B-2)$$

where

- ρ = the density, kg/m³
- C_0 = offset, kg/m³
- C_1 = conversion factor, (kg/m³)/v
- $F(t)$ = transducer output, v.

Constants C_0 and C_1 are adjusted to match the final data to density values calculated from measured pressure and temperature values at the preblowdown and post drain conditions, effectively giving the data an in-place calibration. These calculations are made in the Mod-3 system prior to initial data release and are not considered posttest adjustments.

Some density measurements are obtained using a two-beam gamma densitometer which operates on the same basic principle of gamma attenuation as does the single-beam gamma densitometer. Each beam originates from the same gamma source and is allowed to pass through separate portions of the piping cross-sectional flow area to obtain an average density measurement in that particular region. The geometrical relationship of the gamma beam path through the piping and geometrically related variables used for processing of data from a two-beam gamma densitometer are shown in Figure B-1. The average density measured by each individual gamma beam is obtained using the same equation as is used for the single-beam gamma densitometers.

507 259

In the Semiscale Mod-3 system, two-beam gamma densitometers provide information which allows the calculation of a better average density than that obtained from a single beam in a horizontal pipe. A mathematical model is used for processing the two-beam data to obtain the improved average density information. The processing method used is based on a froth-water model coupled with information from the two individual gamma beams and related beam path and piping cross-sectional geometry. The resulting information is recorded and reported under the density measurement identification ending with a "C", for example, GI-17C.

The use of the froth-water model for obtaining average density from a two-beam gamma densitometer in a horizontal pipe is based on observations indicating that flow regimes in the Semiscale Mod-3 system can be modeled by a layer of water on the bottom of the pipe with a degree of froth on the surface. For homogeneous flow conditions such as all froth or all liquid the model remains valid. At any point in time slug flow is also modeled. The froth-water model does not model annular or inverted annular flows very well. However, these flows are not expected to exist for significant portions of a Semiscale Mod-3 system blowdown in horizontal piping. Density gradients from the top to the bottom of the pipe may exist showing no distinct location change from water to froth. This flow is neither totally homogeneous nor stratified, but the froth-water model does provide an adequate approximation of the average density characteristic of this flow pattern.

The average density obtained by using the gamma beam geometry shown in Figure B-1 and by applying the froth-water model is given by

$$\bar{\rho} = \alpha_f \rho_1 + (1 - \alpha_f) \rho_w \text{ kg/m}^3 \quad (\text{B-3})$$

where

- $\bar{\rho}$ = average cross-sectional density
- ρ_1 = average density measured by the upper beam (measures the froth density)
- ρ_w = density of liquid water (at local system conditions)
- $\alpha_f = 1 + (1/2\pi) (\sin\beta - \beta) =$ volumetric fraction containing froth.

The angle which β represents is shown in Figure B-1. Values for β are obtained as follows:

$$\beta = 2 \cos^{-1} (1 - 2h) \quad (\text{B-4})$$

where

$$h = \frac{H}{D} = \cos^2\theta \left(\frac{\rho_2 - \rho_1}{\rho_w - \rho_1} \right)$$

where

- $H = l_w \cos\theta$ (l_w and θ are defined in Figure B-1)
- $D =$ piping inside diameter
- $\rho_2 =$ the average density measured by the lower gamma beam.

Average density is not calculated using the two-beam froth-water model when the angle is not favorable due to system hardware restrictions in positioning the source. The froth-water model requires separate density sampling in both the upper and lower portions of the piping cross section.




Fig. B-1 Geometry used for processing of density data obtained from two beam gamma densitometers.

507 261

APPENDIX C

**SELECTED DATA WITH ESTIMATED TOTAL UNCERTAINTY
BANDS FROM SEMISCALE MOD-3 TEST S-07-9**

507 262

APPENDIX C

SELECTED DATA WITH ESTIMATED TOTAL UNCERTAINTY BANDS FROM SEMISCALE MOD-3 TEST S-07-9

Analysis has been performed on selected data from Test S-07-9 to provide a guide to the uncertainty associated with data measurements in the Semiscale Mod-3 system. The end result of the analysis is presented as uncertainty bands about the measured data which represent a 95% confidence level.

The uncertainty bands are obtained by combining uncertainties obtained from analysis of the data itself (random uncertainty) and engineering analysis of the measurement system (engineering uncertainty). The procedure by which uncertainty bands were established for the data presented in this appendix is described in the following paragraphs.

The data trace under analysis was empirically fitted with a linear difference equation, which was subject to a white noise input at each sampling time point. The objective of the empirical fitting procedure was to characterize the white noise, which was taken to represent the random uncertainty. The procedures for fitting the difference equation are discussed in depth in Reference C-1. A data trace was often segmented and different equations were fitted to each segment with statistical correlations between successive observations accounted for by the fitting procedure. The white noise input was assumed to arise from a normally distributed population. The standard deviation of the white noise, as found during the fitting procedures, was taken as an estimate of the random uncertainty standard deviation and is shown in Table C-I in appropriate engineering units. The traces of the uncertainty band analysis are shown in Figures C-1 through C-40.

Other uncertainties in the data exist because of such factors as variability in installation procedures and techniques, calibration uncertainties, variability in materials, and temperature and pressure sensitivities. These uncertainties and the procedures for estimating them are discussed in Reference C-2. They are referred to as engineering uncertainties and the estimates are largely subjective. Because of the continuing effort to improve the accuracy of the measured data, such as through the use of better transducers, better signal conditioning and processing equipment, and better calibration and installation techniques, the engineering uncertainties for data from most of the transducer systems have changed from those published in Reference C-2. Table C-II provides a summary of engineering uncertainty values obtained from current analysis techniques as applied to the data presented herein.

In addition to the normal hardware and installation related sources of engineering uncertainty, a significant measurement uncertainty results when the current transducer systems are subjected to separated two-phase flow regimes during the course of the blowdown transient. Accordingly, for those data affected (fluid density, volumetric flow, and mass flow), which are presented in this appendix, a more extensive assessment was conducted of additional engineering uncertainty due to flow regime effects. Table C-III identifies the data analyzed and the period in the blowdown process for which flow regime uncertainties were included as a part of the total engineering uncertainty. The time of occurrence of separated two-phase flow and the resulting effect on the uncertainty of the data were evaluated by considering, on an individual basis, each detector output with reference to indications by other auxiliary measurements.

The gamma densitometer density measurement data are affected by two-phase separated flow regimes. The resulting transducer output is a measurement of the average attenuation of the gamma beam through the measured medium. The beam attenuation, in turn, is interpreted through physical relationship to be a measure of the average density along the beam path. When stratified type flow was considered present, the gamma beam attenuation was considered to be a result of a liquid layer and steam at system conditions.

With this assumption and the system geometry, a void fraction was calculated and a new "effective" average density was calculated. The difference between the average density based on the assumption of homogeneous conditions and the average density for stratified conditions was considered to be the uncertainty.

The flow regime uncertainties of the turbine flowmeter were estimated by calculating a void fraction and the cross-sectional liquid and steam flow area for stratified flow. This calculation was accomplished using methods similar to those used to calculate the average density for stratified flows. A simple model was used to equate the forces on the turbine with the assumption of a known void fraction, stratified flow, known component densities, and slip ratio greater than unity. This process provided phase velocities. With the phase densities, velocities, and void fraction, a volumetric flow rate could be calculated. The difference between this value and the measured value was considered to be the uncertainty.

The overall standard deviation of a data point is taken as the root of the sum of the random uncertainty variance and the total engineering uncertainty variance; that is,

$$\sigma_o = \sqrt{\sigma_R^2 + \sigma_E^2} \quad (C-1)$$

where

- σ_o = overall standard deviation of a data point
- σ_R^2 = random uncertainty variance
- σ_E^2 = engineering uncertainty variance.

The uncertainty bands for the data are computed about the value given by the fitted difference equation y_i at time point i ; that is,

$$\text{uncertainty band} = y_i \pm 1.96 \sigma_o \quad (C-2)$$

With due regard to the fact that σ_E has been estimated subjectively, the uncertainty band may be interpreted as an approximate 95% confidence interval within which any true value of the measured variable is consistent with the data.

On certain occasions, the symmetrical uncertainty band given by Equation (C-2) is not appropriate. On those occasions, asymmetrical uncertainty bands were computed; that is, with the width being greater on one side of y_i than on the other.

Finally, the original data trace, along with its uncertainty band from Equation (C-2), was input to a computer plot package. The resulting plot contained the actual data trace surrounded by an uncertainty band derived both from random uncertainty and engineering uncertainty considerations. The indicated uncertainty bands after thermocouple dryout occurred for the fluid temperature measurements should be ignored. Uncertainty bands for these segments of the data were not obtained and bands only appear because of limitations in the plotting package.

TABLE C-1

RANDOM UNCERTAINTY STANDARD DEVIATION
(TEST S-07-9)

Measurement	Random Uncertainty Standard Deviation	Period of Application (s)		Figure
	σ_R			
TFI-1	0.004	-20	to -0.4	C-1
	1.511	-0.4	to 5	
	1.935	5	to 48	
	0.408	48	to 300	
TFB-20	0.141	-20	to -0.4	C-2
	1.935	-0.4	to 4	
	1.541	4	to 69	
	3.168	69	to 300	
TFD-294	0.004	-20	to -0.4	C-3
	2.807	-0.4	to 27	
	6.208	27	to 55	
	1.405	55	to 113	
	0.610	113	to 180	
	1.386	180	to 300	
TFV-578A	0.0	-20	to 0.04	C-4
	3.296	0.04	to 5	
	0.964	5	to 300	
TIFV+79D	0.994	-20	to 0.9	C-5
	1.374	0.9	to 8	
	0.394	8	to 84	
	0.558	84	to 153	
	0.186	153	to 238	
	0.146	238	to 300	
TFG-5AB-45	0.0	-20	to -0.4	C-6
	22.793	-0.4	to 5	
	17.778	5	to 11	
	.001	11	to 17	
	7.713	17	to 21	
	28.077	21	to 26	
	23.364	26	to 35	
	27.941	35	to 41	
	1.502	41	to 300	
	TMI-1T16	0.079	-20	
0.345		2	to 300	

TABLE C-I (continued)

Measurement	Random Uncertainty Standard Deviation	Period of Application		Figure
	σ_R	(s)		
TMB-20B16	0.041	-20	to 0.04	C-8
	0.652	0.04	to 5	
	0.724	5	to 48	
	0.852	48	to 55	
	0.249	55	to 101	
	1.078	101	to 107	
	0.366	107	to 300	
TMD-364	0.280	-20	to 300	C-9
T IV+79D	0.168	-20	to 0.9	C-10
	0.618	0.9	to 8	
	0.282	8	to 32	
	0.086	32	to 253	
	0.214	253	to 300	
TH-C2-8	0.070	-20	to -0.4	C-11
	2.791	-0.4	to 6	
	0.885	6	to 28	
	15.681	28	to 33	
	3.597	33	to 55	
	1.509	55	to 90	
	0.786	90	to 300	
TH-C2-180	1.075	-20	to -0.4	C-12
	8.174	-0.4	to 5	
	4.648	5	to 174	
	2.011	174	to 300	
PI-16	0.006	-20	to -0.4	C-13
	1.006	-0.4	to 5	
	0.021	5	to 300	
PB-45A	0.002	-20	to -0.4	C-14
	1.104	-0.4	to 5	
	0.026	5	to 300	
PV-ACC1	0.0003	-20	to 6	C-15
	0.013	6	to 13	
	0.006	13	to 46	
	0.003	46	to 300	
PB-SD	0.008	-20	to 180	C-16
	0.005	180	to 220	
	0.020	220	to 300	

TABLE C-I (continued)

Measurement	Random Uncertainty	Period of		Figure
	Standard Deviation	Application		
	σ_R	(s)		
DI-6-7	0.544	-20	to -0.8	C-17
	23.294	-0.8	to 4	
	3.437	4	to 36	
	3.910	36	to 80	
	1.668	80	to 300	
DI-7-13	0.136	-20	to -0.8	C-18
	1.159	-0.8	to 4	
	2.360	4	to 12	
	4.325	12	to 19	
	0.389	19	to 70	
DB-57A-40L	0.099	70	to 300	C-19
	1.652	-20	to -0.8	
	222.84	-0.8	to 5	
	0.002	5	to 32	
	6.436	32	to 36	
DD-DIA-578	9.119	36	to 47	C-20
	3.232	47	to 300	
	0.189	-20	to -0.8	
	18.657	-0.8	to 5	
	3.474	5	to 34	
DV-501-105	8.490	34	to 90	C-21
	2.558	90	to 300	
	0.108	-20	to -0.8	
	22.765	-0.8	to 5	
	1.874	5	to 53	
DI-SG-LL	0.942	53	to 300	C-22
	0.312	-20	to -0.4	
	0.655	-0.4	to 4	
	0.112	4	to 300	
	0.024	-20	to -0.4	
1.064	-0.4	to 5		
1.528	5	to 36		
3.407	36	to 50		
1.317	50	to 220		
FI-17	0.934	220	to 300	C-24
	0.034	-20	to -0.4	
	1.082	-0.4	to 5	
	1.770	5	to 34	
	4.924	34	to 56	
FI-17	2.874	56	to 268	C-24
	3.109	268	to 300	

TABLE C-I (continued)

Measurement	Random Uncertainty Standard Deviation	Period of Application		Figure
	σ_R	(s)		
FB-45	0.457	-20	to -0.4	C-25
	4.546	-0.4	to 4	
	1.006	4	to 10	
	1.886	10	to 14	
	2.563	14	to 38	
	3.776	38	to 53	
	2.578	53	to 300	
FD-424	0.020	-20	to -0.4	C-26
	4.547	-0.4	to 5	
	0.905	5	to 28	
	0.982	28	to 110	
	0.740	110	to 300	
FV+1	0.019	-20	to -0.4	C-27
	2.541	-0.4	to 5	
	2.003	5	to 29	
	4.035	29	to 50	
	1.188	50	to 300	
FV-LPIS	1.756	-20	to -0.8	C-28
	3.083	-0.8	to 9	
	0.254	9	to 34	
	10.036	34	to 39	
	2.112	39	to 46	
	0.558	46	to 300	
GI-1T	7.408	-20	to 0.04	C-29
	61.927	0.04	to 5	
	7.029	5	to 161	
	11.290	161	to 300	
GI-1B	2.713	-20	to -0.4	C-30
	35.415	-0.4	to 5	
	57.173	5	to 20	
	7.265	20	to 235	
	14.595	235	to 300	
GI-1C	4.832	-20	to -0.04	C-31
	55.050	-0.04	to 5	
	23.382	5	to 25	
	3.606	25	to 151	
	9.112	151	to 300	
GI-17T	12.831	-20	to 9	C-32
	75.417	9	to 16	
	8.614	16	to 300	

507 268

TABLE C-I (continued)

Measurement	Random Uncertainty Standard Deviation	Period of Application (s)		Figure
	σ_R			
GI-17B	4.152	-20	to 0.5	C-33
	31.449	0.5	to 11	
	6.440	11	to 156	
	5.925	156	to 300	
GI-17C	7.457	-20	to 0.5	C-34
	13.535	0.5	to 9	
	51.434	9	to 17	
	4.257	17	to 300	
GB-45VR	11.651	-20	to 3	C-35
	19.221	3	to 8	
	33.902	8	to 18	
	9.382	18	to 155	
	14.014	155	to 300	
GV-11	2.686	-20	to -0.4	C-36
	66.754	-0.4	to 4	
	14.172	4	to 12	
	36.746	12	to 20	
	7.881	20	to 30	
	5.015	30	to 160	
	21.030	160	to 300	
FI-1, GI-1C	0.053	-20	to -0.4	C-37
	0.579	-0.4	to 5	
	0.167	5	to 26	
	0.111	26	to 300	
FI-17, GI-17C	0.060	-20	to -0.8	C-38
	0.828	-0.8	to 6	
	0.461	6	to 12	
	0.166	12	to 300	
FB-45, GB-45VR	0.216	-20	to -0.4	C-39
	3.408	-0.4	to 4	
	0.557	4	to 22	
	0.209	22	to 151	
	0.294	151	to 300	
FV+1, GV-11	0.040	-20	to -0.4	C-40
	1.316	-0.4	to 5	
	0.235	5	to 50	
	0.199	50	to 151	
	0.324	151	to 300	




Fig. C-1 Fluid temperature in intact loop hot leg (TFI-1).




Fig. C-2 Fluid temperature in broken loop (TFB-20).

507 270




Fig. C-3 Fluid temperature in downcomer (TFD-294).




Fig. C-4 Fluid temperature in vessel (TFV-578A).




Fig. C-5 Fluid temperature in vessel (TIFV + 79D).




Fig. C-6 Fluid temperature in core, Grid Spacer 5 (TFG-5AB-45).




Fig. C-7 Material temperature in intact loop hot leg (TMI-1T16).




Fig. C-8 Material temperature in broken loop hot leg (TMB-20B16).




Fig. C-9 Material temperature in downcomer (TMD-364).




Fig. C-10 Material temperature in vessel (TMV + 79D).

507 274




Fig. C-11 Core heater temperature, Rod C-2 (TH-C2-8).




Fig. C-12 Core heater temperature, Rod C-2 (TH-C2-180).




Fig. C-13 Pressure in intact loop cold leg (PI-16).




Fig. C-14 Pressure in broken loop cold leg (PB-45A).

507 276




Fig. C-15 Pressure in vessel accumulator (PV-ACC1).




Fig. C-16 Pressure in broken loop steam generator, secondary side steam dome (PB-SD).

507 211




Fig. C-17 Differential pressure in intact loop (DI-6-7).




Fig. C-18 Differential pressure in intact loop (DI-7-13).




Fig. C-19 Differential pressure in broken loop (DB-37A-40L).




Fig. C-20 Differential pressure in downcomer (DD-DIA-578).




Fig. C-21 Differential pressure in vessel (DV-501-105).




Fig. C-22 Differential pressure in intact loop steam generator, secondary side liquid level (DI-SG-LL).




Fig. C-23 Volumetric flow in intact loop (FI-1).




Fig. C-24 Volumetric flow in intact loop (FI-17).




Fig. C-25 Volumetric flow in broken loop (FB-45).




Fig. C-26 Volumetric flow in downcomer (FD-424).

507 282




Fig. C-27 Volumetric flow in vessel upper plenum (FV + 1).




Fig. C-28 Volumetric flow in vessel lower plenum, low pressure injection system (FV-LPIS).




Fig. C-29 Density in intact loop (GI-1T).




Fig. C-30 Density in intact loop (GI-1B).




Fig. C-31 Density in intact loop (GI-1C).




Fig. C-32 Density in intact loop (GI-17T).




Fig. C-33 Density in intact loop (GI-17B).




Fig. C-34 Density in intact loop (GI-17C).

507 286




Fig. C-35 Density in broken loop (GB-45VR).




Fig. C-36 Density in vessel (GV-11).

507 287




Fig. C-37 Mass flow in intact loop (FI-1 and GI-1C).




Fig. C-38 Mass flow in intact loop (FI-17 and GI-17C).




Fig. C-39 Mass flow in broken loop (FB-45 and GB-45VR).




Fig. C-40 Mass flow in vessel (FV+1 and GV-11).

TABLE C-II

GENERAL MEASUREMENT ENGINEERING UNCERTAINTY SOURCES AND UNCERTAINTY VALUES
(TEST S-07-9)

Measurement Category	Uncertainty Sources	Uncertainty Value	Expected Uncertainty Values
Fluid Temperature	Changes in homogeneity of the thermocouple wire due to cold working	± 1.11 K	± 1.66 K, $R \leq 550$ K ^a $\pm [1.42 + (0.0021 R)^2]^{1/2}$, $R > 550$ K ^a where R = transducer reading (K)
	Data interpretation from standard reference tables	± 1.11 K, to 550 K $\pm 0.0021 R$, $R > 550$ K	
	General data acquisition processing	± 0.42 K	
	Thermal aging of the thermocouples	± 0.28 K	
Material Temperature	Changes in homogeneity of the thermocouple wire due to cold working	± 1.11 K	± 3.33 K, $R \leq 550$ K $\pm [9.75 + (0.0021 R)^2]^{1/2}$, $R > 550$ K
	Thermocouple radial position	± 2.78 K	
	Data interpretation from standard reference tables	± 1.11 K, to 550 K $\pm 0.0021 R$, $R > 550$ K	

TABLE C-II (continued)

Measurement Category	Uncertainty Sources	Uncertainty Value	Expected Uncertainty Values
Material Temperature (continued)	General data acquisition and processing	+0.42 K	where R = transducer reading (K)
	Thermal aging of the thermocouples	+0.28 K	
Pressure	Entrance effects	+0.3% of transducer full scale	+0.44% of transducer full scale
	Calibration	+0.26% of transducer full scale	
	Temperature sensitivity	+0.13% of transducer full scale	
	General data acquisition and processing	+0.15% of system full scale	
Differential Pressure	Installation	+0.3% of transducer full scale	

TABLE C-II (continued)

Measurement Category	Uncertainty Sources	Uncertainty Value	Expected Uncertainty Values
Differential Pressure (continued)	Calibration		
	Transducer ranges +4.96 through +199.26 kPa	$+[(0.05) + (0.5 R/FS)^2]^{1/2} \%$ of transducer full scale	} +2% of transducer full scale ^b where R = transducer reading (kPa) FS = transducer range full scale (kPa)
	Transducer ranges +3.44, +74, +689.47, +3447 kPa	$+[(0.03) + (0.5 R/FS)^2]^{1/2} \%$ of full scale	
	Transducer ranges +6894, +10 342 kPa	$+[(0.02) + (0.5 R/FS)^2]^{1/2} \%$ of full scale	
	Temperature sensitivity	+0.5% of transducer full scale	
General data acquisition and processing	+0.15% of system full scale		
Air entrapment	+0.069 kPa		
Density	Calibration	+1.0% of reading (kg/m ³)	}
	Detector system Uncertainty	+2.1 kg/m ³	
	General data acquisition and processing	+0.15% of system full scale (kg/m ³)	

228

507 272

TABLE C-II (continued)

Measurement Category	Uncertainty Sources	Uncertainty Value	Expected Uncertainty Values
Density (continued)	Flow regime	Gr ^c	}
		where	
		Gr = flow regime uncertainty (kg/m ³)	
Volumetric Flow (turbine flow-meter)	Calibration instrument reading	+0.25% of transducer full scale	}
	Calibration standards	+19.56 x 10 ⁻² 1/s	
	Velocity profile	+2.9% of reading	
	Frequency-to-voltage conversion	+0.25% of transducer full scale	
	General data acquisition and processing	+0.15% of system full scale	
	Dead bands	+5% of transducer full scale	
	Flow regimes	c	

229

507 293

TABLE C-II (continued)

Measurement Category	Uncertainty Sources	Uncertainty Value	Expected Uncertainty Values
Mass Flow Rate (from volumetric flow and density data)	Combined results from individual uncertainty sources for volumetric flow and density data ^d	c	c

- a. This value is no longer valid after thermocouple dryout occurs.
- b. Value is based on observed system performance. It is more conservative than that obtained from the statistical summation of the identified engineering uncertainties.
- c. Uncertainty value is time and flow regime dependent.
- d. The general method for combining volumetric flow with density data to obtain mass flow rate and the resulting uncertainties in the data are explained in Reference C-2.

230

507
29A

TABLE C-III

TIME PERIODS WHEN FLOW REGIME UNCERTAINTIES WERE APPLIED
(TEST S-07-9)

<u>Detector Identification</u>	<u>Time During Which Flow Regime Uncertainties Were Applied (s)</u>	<u>Figure</u>
FI-1	1 to 26 50 to 75	C-23
FI-17	5 to 18	C-24
FB-45	10 to 48	C-25
GI-1C	1 to 26 50 to 75	C-31
GI-17C	5 to 18	C-34
GB-45VR	10 to 48	C-35
FI-1, GI-1C	1 to 26 50 to 75	C-37
FI-17, GI-17C	5 to 18	C-38
FB-45, GB-45VR	10 to 48	C-39

REFERENCES

- C-1. G. E. P. Box and B. M. Jenkins, *Time Series Analysis — Forecasting and Control*, San Francisco: Holden-Day, 1970.
- C-2. E. M. Feldman and S. A. Naff, *Error Analysis for 1-1/2-Loop Semiscale System Isothermal Test Data*, ANCR-1188 (May 1975).

DISTRIBUTION RECORD FOR NUREG/CR-0815
(TREE-1229)

Internal Distribution

- 1 - R. J. Beers, ID
- 2 - P. E. Litteneker, ID
- 3-5 - INEL Technical Library
- 6-10 - Authors
- 11-41 - Special Internal

External Distribution

- 42-50 - Special External
- 51-52 - Saul Levine, Director
Office of Nuclear Regulatory Research, NRC
Washington, D.C. 20555
- 53-341 - Distribution under P.2, Water Reactor Safety Research -
Systems Engineering

507 296